

A firm acc

TENDER
ited to BS EN ISO 9001 - 2000, Reg No. 2006

NP

Arcobaleno Consulting E	GROUND FLOOR VENTILATION LAYOUT	STOURBRIDGE LION MEDICAL CENTRE

Project:	VERLANE	Client:	REV REASON FOR REVISION		A1 ISSUED FOR APPROVAL	T1 ISSUED FOR TENDER	
			N				
			DR		NP	NP.	
			APP		Ω	CJ	
							_

T	A1	T1		
	A1 ISSUED FOR APPROVAL	T1 ISSUED FOR TENDER		
	NP	NP		
	CJ	IJ		
	NP CJ 28/02/13	NP CJ 22/03/13		

DTG DOOR TRANSFER GRILLE

DTG	\$	/	₽	
DOOR TRANSFER GRILLE	ATTENUATOR	VOLUME CONTROL DAMPER	EXTRACT AIR GRILLE	

14. ALL REDUNDANT MATERIALS SHALL BE REMOVED FROM SITE.

13. ALL SERVICES PASSING THROUGH DESIGNATED FIRE COMPARTMENTS, SHALL BE PROVIDED WITH APPROPRIATE FIRE PROTECTION AND ADEQUATE ACCESS. 12. THE M&E SERVICES CONTRACTOR SHALL ALLOW FOR ALL NECESSARY (TEMPORARY OR OTHERWISE) WORKS TO ACCOMMODATE THE MAIN CONTRACTORS SEQUENCING OF ALL ELEMENTS OF THE PROJECT.

11. ALL CERTIFICATES AND AS FITTED DRAWINGS SHALL BE CONTAINED WITHIN THE OPERATING AND MAINTENANCE MANUALS WHICH SHALL BE MADE AVAILABLE TO THE ENGINEER PRIOR TO HAND OVER. FAILURE TO PROVIDE APPROPRIATE CERTIFICATES AT THIS TIME MAY DELAY ACCEPTANCE AND HAND OVER OF THE PROJECT. 10. THE CONTRACTOR SHALL AT A TIME TO BE AGREED AND PRIOR TO HANDOVER INSTRUCT THE EMPLOYER'S STAFF IN THE USE AND CORRECT OPERATION OF THE INSTALLATION AND SHALL SATISFY HIMSELF THAT SUCH STAFF ARE COMPETENT TO TAKE OVER THE INSTALLATION ON COMPLETION.

(5)

(U)

000

60

×—

ALL ELECTRICAL SERVICES SHALL BE CARRIED OUT BY AN APPROVED NICEIC REGISTERED ELECTRICAL CONTRACTOR AND FULLY COMPLY WITH THE CURRENT EDITION OF THE IEE WIRING REGULATIONS, BS7671:2008, INCORPORATING ALL AMENDMENTS. MECHANICAL & ELECTRICAL SERVICES WORKS SHALL BE CARRIED OUT IN ACCORDANCE WITH THE MAIN CONTRACTORS PROGRAMME AND PHASING REQUIREMENTS.

ALL BUILDERS WORK INCLUDING, PENETRATIONS THROUGH WALLS, ROOFS, WEATHERING, UPSTANDS, ETC., ASSOCIATED WITH THE SERVICES INSTALLATION(S) INCLUDING ALL MAKING GOOD, SHALL BE CARRIED OUT BY THE CONTRACTOR. THE MECHANICAL & ELECTRICAL CONTRACTOR(S) SHALL BE RESPONSIBLE FOR ANY ACCESS/LIFTING EQUIPMENT REQUIRED TO CARRY OUT THEIR WORKS. ALL EXISTING REDUNDANT SERVICES AND EQUIF SHALL BE REMOVED WHERE POSSIBLE.

—《

-(N

4. THE MECHANICAL & ELECTRICAL CONTRACTOR(S) SHALL BE RESPONSIBLE FOR ON SITE CO—ORDINATION OF THE NEW M&E SERVICES WITH EXISTING SERVICES AND THE NEW/EXISTING BUILDING STRUCTURE. LOCATIONS OF ALL ITEMS OF EQUIPMENT SHALL BE AGREED ON SITE WITH THE ENGINEER. 3. THE DRAWING HAS BEEN PRODUCED FOR ILLUSTRATION PURPOSES ONLY. WHERE SHOWN, ALL DIMENSIONS ARE IN MILLIMETRES AND SHALL BE CHECKED ON SITE. 2. THE CONTRACTOR SHALL ASCERTAIN THE NATURE OF THE SITE, ACCESS THERETO AND ALL LOCAL CONDITIONS AND RESTRICTIONS LIKELY TO AFFECT THE EXECUTION OF THE WORKS, SINCE NO CLAIM SHALL BE CONSIDERED ON THE GROUNDS OF, LACK OF SITE KNOWLEDGE. MENT

FURNITURE LAYOUTS ARE TO CONFIRMED BY ARCHITECT B H DO NOT SCALE FROM THIS DRAWING.

NOTES:

1. ALL MECHANICAL & ELECTRICAL WORKS SHALL BE INSTALLED AND FULLY COMPLY WITH ARCOBALENO STANDARD & PROJECT SPECIFIC SPECIFICATION(S).

2013 Copyright ©

ALL

C DUCTED HEAT RECOVERY UNIT
C WALL MOUNTED EXTRACT FAN
C WALL MOUNTED EXTRACT FAN
C WALL MOUNTED EXTRACT FAN

