




V2.17 01-05-13




Elevation B




Elevation D



Elevation A



Elevation C



- |   |   |  |
|---|---|--|
| Ⓐ | Ⓐ | 1 No . 900086 . Inlet . 2 1/2" Equilibrium Drop Arm Ball Valve + 12" Copper Float  |
| Ⓑ | Ⓑ | 1 No . 900027 . Overflow . 4" Screened Overflow Assembly + Internal Elbow (Type16) |
| Ⓒ | Ⓒ | 1 No . 821201 . Warning pipe . 3/4" Screened Overflow - R30E                       |
| Ⓓ | Ⓓ | 1 No . 825072 . Outlet . 2" PVC Stub Flange Assembly                               |

In accordance with our normal policy on product development, this specification is subject to change without notice.

SCALE : n/a	DRAWN BY: ITRAK	TITLE: Cold Water Storage Tank - General Arrangement	Agile Building Services Ltd.
DW-64413-241020	DATE: 03-05-2013	SIZE: Internal 2,000 X 2,000 X 1,000, External 2,150 X 2,150 X 1,060	The Lion Medical Centre - Birmingham