

NOTES:

- 1. This drawing shall be read in conjunction with Arcobaleno Building Services Consulting Engineers Electrical Specification.
- 2. This drawing shall not be used as a working drawing. All scaled dimensions shall be verified on site.
- 3. For architectural and structural details please refer to appropriate specialist drawings
- 4. Each loop shall be left with 20% spare capacity

LEGEND:

- EMERGENCY BREAK GLASS UNIT, 1100mm AFFL UNLESS OTHERWISE STATED
- FIRE ALARM INTERFACE UNIT, AS DETAILED
- OPTICAL SMOKE DETECTOR
- OPTICAL SMOKE DETECTOR COMPLETE WITH BASE MOUNTED SOUNDER/BEACON
- HEAT DETECTOR
- HEAT DETECTOR COMPLETE WITH BASE MOUNTED SOUNDER/BEACON
- XENON BEACON UNIT, MOUNTED 2200mm AFFL
- FIRE ALARM LOOP ISOLATOR TO ALLOW FOR FUTURE MODIFICATION WORKS AND ZONE BREAKS

T1	Drawing Issue for Tender	CJ	KB	22-03-11
A1	Drawing Issue for approval	CJ	KB	01-03-11
P1	Preliminary drawing issue for approval & comment	CJ	KB	24-10-11
REV	REASON FOR REVISION	DR	APP	DATE

Client:  
**VERLANE**

Project:  
**STOURBRIDGE LION MEDICAL CENTRE**

Title:  
**PROPOSED FIRE ALARM SCHEMATIC**



**Arcobaleno | Consulting Engineers**  
Suite 3, Third Floor,  
104 - 106 Hagley Road,  
Edgbaston, Birmingham,  
West Midlands,  
B16 8LT  
TEL: 0121 455 0225  
E-Mail - info@abek.org

Project No:	ABS/12/003	Drawing No:	00(60)002	Rev:	T1
Date:	OCTOBER 2012	Scale:	@ A1	NTS	

Drawn	C JONES	Approved	K BAWA
TENDER			

