

TYPICAL CONNECTION DETAIL FOR HAND DRYERS



ALL WORKS SHALL BE CARRIED OUT IN ACCORDANCE WITH B.S.7671, LANDLORDS TERMS AND CONDITIONS AND ALL VALID LEGISLATION.

2013 Copyright ©

NOTES:

1. This drawing shall be read in conjunction with Arcobaleno Building Services Consulting Engineers Electrical Specification.
2. This drawing shall not be used as a working drawing. All scaled dimensions shall be verified on site.
3. For architectural and structural details please refer to appropriate specialist drawings
4. Furniture layouts to be confirmed by architect

LEGEND:

- White plastic single switched socket outlet, mounted 450mm affl unless otherwise stated
- White plastic twin switched socket outlet mounted 450mm affl unless otherwise stated

  MC Denotes Metal Clad version
- Switched fused connection unit, white plastic complete with neon indicator, mounted adjacent equipment it is feeding, as follows:

  WB Water Boiler power supply
  CC Comfort Cooling unit power supply
  E Examination lamp power supply
  HD Hand Drier power supply
- Switched fused connection unit (150mm above worktop) connected to low level single socket outlet (450mm AFFL), white plastic complete with neon indicator, as follows:

  FR Denotes Refrigerator power supply
  DW Denotes dishwasher power supply
- Un-switched fused connection unit, white plastic complete with neon indicator, mounted adjacent equipment it is feeding unless otherwise stated, as follows:

  AC Access Control power supply
  CCTV CCTV Camera power supply
  SC Staff Call system (2000mm AFFL)
  DTA Denotes disabled toilet alarm PS
- SP&N Switched isolator
  R denotes rating of device
- TP&N Switched isolator
  R denotes rating of device
- Single data point
- Twin data point
- Indicates item is located within ceiling void
- TV system outlet, mounted 2000mm AFFL adjacent power supply socket outlet
- Supplementary earthing bond for pipework
- F2 2 Compartment recessed floorbox containing the following outlets:

  1 No. Twin switched socket outlets
  1 No. data plate for on site punching

REV	REASON FOR REVISION	DR	APP	DATE
T1	Drawing issue for Tender	CJ	KB	22-03-1
A1	Drawing issue for approval	CJ	KB	04-03-1

Client:

VERLANE

Project:

STOURBRIDGE LION MEDICAL CENTRE

Title:

PROPOSED SECOND FLOOR SMALL POWER AND DATA LAYOUT

Arcobaleno | Consulting Engineers
Suite 3, Third Floor,
104 - 106 Hagley Road,
Edgbaston, Birmingham,
West Midlands,
B16 8LT
TEL: 0121 455 0225
E-Mail - info@abuuk.org

Project No:	Drawing No:	Rev:
ABS/12/003	02(62)003	T1
Date: FEBRUARY 2012		Scale@A0: 1:100
Drawn: C JONES	Approved: K BAJWA	

TENDER

A firm accreitted to BS EN ISO 9001 - 2000, Reg No. 2006/449