

- NOTES:
1. This drawing shall be read in conjunction with Accobreno Building Services Consulting Engineers Electrical Specification.
 2. This drawing shall not be used as a working drawing. All scaled dimensions shall be verified on site.
 3. For architectural and structural details please refer to appropriate specialist drawings.

FIRE ALARM LEGEND:


- SURFACE MOUNTED SMOKE DETECTOR
- SURFACE MOUNTED SMOKE DETECTOR CW BASE
- MOUNTED SOUNDER
- SURFACE MOUNTED SMOKE DETECTOR CW BASE
- MOUNTED SOUNDER AND BEACON
- SURFACE MOUNTED HEAT DETECTOR CW BASE
- MOUNTED SOUNDER
- SURFACE MOUNTED HEAT DETECTOR CW BASE
- MOUNTED BEACON
- SURFACE MOUNTED SOUNDER AND BEACON
- SURFACE MOUNTED EMERGENCY BREAK GLASS UNIT, MOUNTED 1100mm AFL
- SEM-RECESSED FIRE ALARM PANEL
- FIRE ALARM INPUT - OUTPUT MODULE

DISABLED TOILET ALARM LEGEND:

- DISABLED TOILET ALARM POWER SUPPLY UNIT
- MOUNTED WITHIN CEILING VOID
- DISABLED TOILET ALARM RESET BUTTON, MOUNTED WITHIN REACH OF PERSON SITTING ON TOILET - PART B BUILDING REGS
- DISABLED TOILET ALARM PULL CHORD, WITH 2 DETAILLED IN PART M BUILDING REGS
- DISABLED TOILET ALARM VISUAL/TONE UNIT MOUNTED CENTRALLY ABOVE TOILET DOOR
- DISABLED ALARM PANEL


INTRUDER/SECURITY ALARM LEGEND:

- INTRUDER ALARM SURFACE MOUNTED PASSIVE INFRARED MOTION SENSOR
- INTRUDER ALARM DOOR CONTACT
- WALL MOUNTED PANIC ATTACK BUTTON COMPLETE WITH MOUNTING AND RESET BUTTON
- WALL MOUNTED PANIC ATTACK ALARM VISUAL/TONE INDICATOR, MOUNTED ABOVE DOOR
- INTRUDER ALARM PANEL
- PANIC ATTACK ALARM PANEL
- INTRUDER ALARM ENTRY / EXIT KEY PAD, MOUNTED 1100mm AFL
- MAGNETIC DOOR LOCK
- PROXIMITY CARD OR RFID READER
- PUSH TO EXIT BUTTON
- EMERGENCY BREAK GLASS BUTTON
- CCTV MONITOR(S) LOCATION
- CCTV RECORDING EQUIPMENT
- CCTV CONTROL CONSOLE
- INTRUDER ALARM INTERNAL SOUNDER
- INTRUDER ALARM EXTERNAL SOUNDER
- COVERT FIXED POSITION CCTV CAMERA




DETAIL A


TYPICAL DISABLED TOILET ALARM LAYOUT (1:50)



FIRE ALARM LAYOUT



SECURITY LAYOUT



REV	REASON FOR REVISION	DR	APP	DATE
T1	Drawing issue for tender	CI	K9	22-08-12
A1	Drawing issue for approval	CI	K9	01-09-12
P1	Preliminary drawing issue for approval & comment	CI	K9	10-10-12

VERLANE

Project:
STOURBRIDGE LION MEDICAL CENTRE

Title:
PROPOSED SECOND FLOOR FIRE ALARM AND SECURITY SERVICES LAYOUT

Accobreno | Consulting Engineers
Suite 3, Third Floor,
104 - 106 Hagley Road,
West Midlands,
B16 8LT
TEL: 0121 455 0225
E-Mail: info@accobreno.org

Project No.	Drawing No.	Rev.
ABS12/003	02/07/03	T1
Date	Drawn	Approved
DECEMBER 2012	C. JONES	K. BAWA
	TENDER	

ALL WORKS SHALL BE CARRIED OUT IN ACCORDANCE WITH B.S 7671 LANDSCAPE TERMS AND CONDITIONS AND ALL VALID LEGISLATION.