





CONSTRUCTION

닺





ES OLDBURY

EMR OFFICES SMALL POWER AND DATA LAYOUT

Status
PRELIMINARY

Prawn CJ

Checked KB

rawing No 00(62)007

17.07.12

3 COMPARTMENT WHITE PLASTIC DADO TRUNKING
3 COMPARTMENT WHITE PLASTIC DADO
TRUNKING RISER POSITION

DISABLED TOILET ALARM TONE/VISUAL
INDICATOR UNIT MOUNTED ABOVE DOOR

DISABLED TOILET ALARM POWER SUPPLY UNIT,
MOUNTED IN CEILING VOID

DISABLED TOILET ALARM RESET BUTTON

DISABLED TOILET ALARM PULL CHORD COMPLETE
WITH 2 No. RED TRIANGULAR RED BANGLES.

45A SHOWER PULL CHORD 13A UNSWITCHED FUSED CONNECTION UNIT,
MOUNTED ADJACENT EQUIPMENT BEING SERVED:
SECURITY ALARM PANEL
FIRE ALARM PANEL
COUNTER TOP INDUCTION LOOP POWER SUPPLY
SHAVER SOCKET OUTLET 13A SWITCHED FUSED CONNECTION UNIT,
MOUNTED ADJACENT EQUIPMENT BEING SERVED:
FAN COIL UNIT
HAND DRIER
ACCESS CONTROL
EXTRACT FAN
MECHANICAL HEATING & COOLING SUPPLY SINGLE RJ45 OUTLET
TWIN RJ45 OUTLET DENOTES ELECTRICAL OUTLET MOUNTED WITHIN CEILING VOID TP&N SWITCHED ISOLATOR, R DENOTES RATING OF DEVICE 3 COMPARTMENT FLOORBOX CONTAINING 2 No. TSSO'S AND 1 No. BLANK PLATE FOR ON SITE DATA OUTLET PUNCHING

PSU

R

THIS DRAWING IS COPYRIGHT AND MAY NOT BE REPRODUCED OR MADE USE OF UNLESS EXPRESSLY AGREED BY EMCOR ENGINEERING SERVICES LIMITED NOTES

 \bigcirc

Mechanical power supplies to be added once mechanical design concepts have been agreed

For architectural and structural details please refer to appropriate specialist drawings

This drawing shall not be used as a working drawing. All scaled dimensions shall be verified on site.

2

SINGLE SWITCHED SOCKET OUTLET FOR CLEANERS, MOUNTED 450mm AFFL UNLESS OTHERWISE STATED

WHITE PLASTIC TWIN SWITCHED SOCKET OUTLET MOUNTED 450mm AFFL UNLESS OTHERWISE STATED

SWITCHED FUSED CONNECTION UNIT MOUNTED ABOVE WORKTOP CONNECTED TO LOW LEVEL SINGLE SOCKET OUTLET FOR THE FOLLOWING EQUIPMENT: