


- This drawing shall not be read as a working drawing. All scaled dimensions shall be verified on site.
- For architectural and structural details please refer to appropriate specialist drawings.
- Mechanical power supplies to be added once mechanical design concepts have been agreed.

LEGEND

- SINGLE SWITCHED SOCKET OUTLET FOR CLEANERS, MOUNTED 450mm AFTL, UNLESS OTHERWISE STATED
- WHITE PLASTIC TWIN SWITCHED SOCKET OTHERWISE STATED
- SWITCHED FUSED CONNECTION UNIT, MOUNTED ABOVE WORKTOP CONNECTED TO LOW LEVEL SINGLE SOCKET OUTLET FOR THE FOLLOWING EQUIPMENT:
 - REFRIGERATOR
 - 13A SWITCHED FUSED CONNECTION UNIT, MOUNTED ADJACENT EQUIPMENT BEING SERVED
 - HAND DRIER
 - A2 ACCESS CONTROL
 - EXTRACT FAN
 - WVW MECHANICAL HEATING & COOLING SUPPLY
 - EH ELECTRIC HEATER
 - 13A UNSWITCHED FUSED CONNECTION UNIT, MOUNTED ADJACENT EQUIPMENT BEING SERVED
 - SGP SECOND ALARM PANEL
 - DL DOWNER TOP INDUCTION LOOP POWER SUPPLY
 - WCP MECHANICAL CONTROL PANEL, POWER SUPPLY
 - SHOWER SOCKET OUTLET
 - 45A COOKER OUTLET
 - SEMI SWITCHED ISOLATOR, R DENOTES RATING OF 63A/42
 - TOTAL SWITCHED ISOLATOR, R DENOTES RATING OF 63A/42
 - SINGLE R45 OUTLET
 - TWIN R45 OUTLET
 - 3 COMPARTMENT WHITE PLASTIC DADO TRUNKING RISE/POSSIBLE
 - ROBUST TOILET ALARM AND ALARM INDICATOR UNIT, MOUNTED ABOVE DOOR
 - DISABLED TOILET ALARM POWER SUPPLY UNIT, MOUNTED IN CEILING VOID
 - DISABLED TOILET ALARM TEST BUTTON
 - DISABLED TOILET ALARM TEST BUTTON CONNECTED TO 2 % RED THERMOSTAT RED BLOCES
 - 45A SHOWER PULL OUT/RO

Rev	Description	Date	Eng
A1	ISSUED FOR APPROVAL, STATUS	7.2.13	CJ



IES OLDBURY

EMR OFFICES SMALL
POWER AND DATA LAYOUT

Drawn	Checked	Size
CJ	KB	A0

Job No	Scale	Date
C00062	1:50	07.02.13

Drawn	Rev
00/62/008	A1