



Oracle by FP&C Export

Date: 2026-02-21 10:13

Apex File: Sung Residence v207.2.apex

Additional Info File: 02 19 26 Additional Info - Sung.xlsx

Filter: Keywords = -clock, Start Date/Time = None, End Date/Time = None

31 [2026-02-21 08:56:12.140] VHDx - Failed to reach the matrix
35 [2026-02-21 08:59:15.630] Sense event 'When [Sense 1] Gate opens'
36 [2026-02-21 08:59:15.650] Macro - Start
37 [2026-02-21 08:59:15.109] Macro - End
38 [2026-02-21 08:59:38.829] Driver event 'When 'Garage West DOOR Opened' happens on 'DSC PowerSeries\Zone Open' [No Profile!]
39 [2026-02-21 08:59:38.831] Macro - Start
40 [2026-02-21 08:59:38.832] System macro 'GARAGE DOOR - West is OPEN' - Start
41 [2026-02-21 08:59:38.879] Driver Command (Clipsal C-Bus): 'Garage Recessed switched to 121 [Unknown State!].'
42 [2026-02-21 08:59:39.452] System macro 'GARAGE DOOR - West is OPEN' - End
43 [2026-02-21 08:59:39.452] Macro - End
45 [2026-02-21 09:00:00.866] Scheduled event 'Every day at 9:00 AM'
46 [2026-02-21 09:00:00.875] Macro - Start
47 [2026-02-21 09:00:00.193] IR - Port:'XP-8v','RTI RCM-12 Relay Module' Command:'RELAY 2 CLOSE [/ /]' Sustain:NO
48 [2026-02-21 09:00:02.437] Macro - End
49 [2026-02-21 09:00:22.714] Driver event 'When 'App 56, Garage West Door Toggle (Phantom) On' happens on 'Clipsal C-Bus\App 56 Group On'
50 [2026-02-21 09:00:22.715] Macro - Start
51 [2026-02-21 09:00:22.717] System macro 'GARAGE DOOR - West TOGGLE' - Start
52 [2026-02-21 09:00:22.719] Relay/Trigger - Port:'XP-8v','Garage Door West' Action:ON
53 [2026-02-21 09:00:22.730] Delay 2000ms
54 [2026-02-21 09:00:24.744] Relay/Trigger - Port:'XP-8v','Garage Door West' Action:OFF
55 [2026-02-21 09:00:24.757] System macro 'GARAGE DOOR - West TOGGLE' - End
56 [2026-02-21 09:00:24.757] Macro - End
57 [2026-02-21 09:00:34.718] Driver event 'When 'Garage West DOOR Closed' happens on 'DSC PowerSeries\Zone Closing' [No Profile!]
58 [2026-02-21 09:00:34.719] Macro - Start
59 [2026-02-21 09:00:34.721] System macro 'GARAGE DOOR - West is CLOSED' - Start
60 [2026-02-21 09:00:34.768] Driver Command (Clipsal C-Bus): 'Garage Recessed switched to Off.'
61 [2026-02-21 09:00:34.780] System macro 'GARAGE DOOR - West is CLOSED' - End
62 [2026-02-21 09:00:34.780] Macro - End
63 [2026-02-21 09:00:51.446] Driver event 'When 'Garage (Stat 2) - Operating State Change' happens on 'Venstar ColorTouch\Garage (Stat 2) Events' [No Profile!]
64 [2026-02-21 09:00:51.448] Macro - Start
65 [2026-02-21 09:00:51.473] Relay/Trigger - Port:'XP-8v','Garage Boiler Trigger' Action:ON
66 [2026-02-21 09:00:51.495] Macro - End
68 [2026-02-21 09:01:01.970] Sense event 'When [Sense 1] Gate closes'
69 [2026-02-21 09:01:01.972] Macro - Start
70 [2026-02-21 09:01:01.160] Macro - End
80 [2026-02-21 09:10:30.745] Driver event 'When 'App 56, Guest Bedroom Recessed On' happens on 'Clipsal C-Bus\App 56 Group On'
81 [2026-02-21 09:10:30.747] Macro - Start
82 [2026-02-21 09:10:30.749] Driver Command (Lutron Caseta / RA2 Select): 'Guest Bed Shelf dimmer level ramped to 100 over 2 seconds.'
83 [2026-02-21 09:10:30.750] Lutron Lower - ID 13, Set Dimmer Level to 100, with a fade rate of 00:00:02
84 [2026-02-21 09:10:30.766] Lutron Lower - ID 13, Level is 100
85 [2026-02-21 09:10:30.766] Lutron Lower - ID 13, Status On is true
86 [2026-02-21 09:10:30.977] Macro - End
92 [2026-02-21 09:15:01.391] Macro event
93 [2026-02-21 09:15:01.393] Macro - Start
94 [2026-02-21 09:15:01.400] IR - Port:'XP-8v','RTI RCM-12 Relay Module' Command:'RELAY 2 OPEN [/ /]' Sustain:NO
95 [2026-02-21 09:15:01.390] System macro 'HRV - Check MAIN FAN Should be OFF?' - Start
96 [2026-02-21 09:15:01.224] IR - Port:'XP-8v','RTI RCM-12 Relay Module' Command:'RELAY 1 OPEN [/ /]' Sustain:NO
97 [2026-02-21 09:15:02.846] System macro 'HRV - Check MAIN FAN Should be OFF?' - End
98 [2026-02-21 09:15:02.846] Macro - End
99 [2026-02-21 09:15:55.572] Driver event 'When 'App 56, Group 13 [No Map!] On' happens on 'Clipsal C-Bus\App 56 Group On'
100 [2026-02-21 09:15:55.574] Macro - Start

101 [2026-02-21 09:15:55.575] System macro 'LIGHTS - LUTRON Master Bath ALL ON' - Start
102 [2026-02-21 09:15:55.577] Driver Command (Lutron Caseta / RA2 Select): 'Master Bath Counter dimmer level ramped to 100 over 2 seconds.'
103 [2026-02-21 09:15:55.579] Lutron Upper - ID 2, Set Dimmer Level to 100, with a fade rate of 00:00:02
104 [2026-02-21 09:15:55.580] System Manager - Popup SysVarChange Callback Initated with 3361
105 [2026-02-21 09:15:55.591] Lutron Upper - ID 2, Level is 100
106 [2026-02-21 09:15:55.592] Lutron Upper - ID 2, Status On is true
107 [2026-02-21 09:15:55.919] Driver Command (Lutron Caseta / RA2 Select): 'Master Bath Mirror dimmer level ramped to 100 over 2 seconds.'
108 [2026-02-21 09:15:55.921] Lutron Upper - ID 3, Set Dimmer Level to 100, with a fade rate of 00:00:02
109 [2026-02-21 09:15:55.134] Lutron Upper - ID 3, Level is 100
110 [2026-02-21 09:15:55.135] Lutron Upper - ID 3, Status On is true
111 [2026-02-21 09:15:55.276] Driver Command (Lutron Caseta / RA2 Select): 'Master Bath Kick dimmer level ramped to 100 over 2 seconds.'
112 [2026-02-21 09:15:56.284] Lutron Upper - ID 8, Set Dimmer Level to 100, with a fade rate of 00:00:02
113 [2026-02-21 09:15:56.483] Lutron Upper - ID 8, Level is 100
114 [2026-02-21 09:15:56.484] Lutron Upper - ID 8, Status On is true
115 [2026-02-21 09:15:56.604] Driver Command (Lutron Caseta / RA2 Select): 'Master Bath Sconces dimmer level ramped to 100 over 2 seconds.'
116 [2026-02-21 09:15:56.606] Lutron Upper - ID 10, Set Dimmer Level to 100, with a fade rate of 00:00:02
117 [2026-02-21 09:15:56.810] Lutron Upper - ID 10, Level is 100
118 [2026-02-21 09:15:56.810] Lutron Upper - ID 10, Status On is true
119 [2026-02-21 09:15:56.818] System macro 'LIGHTS - LUTRON Master Bath ALL ON' - End
120 [2026-02-21 09:15:56.818] Macro - End
121 [2026-02-21 09:15:56.101] Lutron Upper - ID 8, Level is 100
122 [2026-02-21 09:15:56.101] Lutron Upper - ID 8, Status On is true
123 [2026-02-21 09:15:57.300] Lutron Upper - ID 2, Level is 100
124 [2026-02-21 09:15:57.300] Lutron Upper - ID 2, Status On is true
145 [2026-02-21 09:35:39.720] System Manager - Popup SysVarChange Callback Initated with 4927
146 [2026-02-21 09:35:39.721] System Manager - Popup SysVarChange Callback Initated with 5183
147 [2026-02-21 09:35:39.723] System Manager - Popup SysVarChange Callback Initated with 4928
148 [2026-02-21 09:35:39.724] System Manager - Popup SysVarChange Callback Initated with 5184
149 [2026-02-21 09:35:57.540] Sense event 'When [Sense 1] Gate closes'
150 [2026-02-21 09:35:57.560] Macro - Start
151 [2026-02-21 09:35:57.100] Macro - End
160 [2026-02-21 09:43:37.451] Driver event 'When 'Garage (Stat 2) - Operating State Change' happens on 'Venstar ColorTouch\Garage (Stat 2) Events' [No Profile!]
161 [2026-02-21 09:43:37.453] Macro - Start
162 [2026-02-21 09:43:37.478] Relay/Trigger - Port:'XP-8v','Garage Boiler Trigger' Action:OFF
163 [2026-02-21 09:43:37.836] Macro - End
171 [2026-02-21 09:50:55.221] Driver event 'When 'Garage (Stat 2) - Operating State Change' happens on 'Venstar ColorTouch\Garage (Stat 2) Events' [No Profile!]
172 [2026-02-21 09:50:55.224] Macro - Start
173 [2026-02-21 09:50:55.248] Relay/Trigger - Port:'XP-8v','Garage Boiler Trigger' Action:ON
174 [2026-02-21 09:50:55.270] Macro - End
182 [2026-02-21 09:57:27.183] Driver event 'When 'Garage (Stat 2) - Operating State Change' happens on 'Venstar ColorTouch\Garage (Stat 2) Events' [No Profile!]
183 [2026-02-21 09:57:27.185] Macro - Start
184 [2026-02-21 09:57:27.210] Relay/Trigger - Port:'XP-8v','Garage Boiler Trigger' Action:OFF
185 [2026-02-21 09:57:27.221] Macro - End
192 [2026-02-21 10:03:37.812] Driver event 'When 'App 56, Hobby Room Fan Toggle (Phantom) On' happens on 'Clipsal C-Bus\App 56 Group On'
193 [2026-02-21 10:03:37.814] Macro - Start
194 [2026-02-21 10:03:37.816] System macro 'HRV - Basement Bath Fan TOGGLE' - Start
195 [2026-02-21 10:03:37.840] System macro 'HRV - Basement Bath Fan ON' - Start
196 [2026-02-21 10:03:38.459] IR - Port:'XP-8v','RTI RCM-12 Relay Module' Command:'RELAY 8 CLOSE [/ /]' Sustain:NO
197 [2026-02-21 10:03:39.703] System macro 'HRV - Basement Bath Fan ON' - End
198 [2026-02-21 10:03:39.704] System macro 'HRV - Basement Bath Fan TOGGLE' - End
199 [2026-02-21 10:03:39.704] Macro - End
200 [2026-02-21 10:03:58.501] Device 'iPhone (David)' has connected
202 [2026-02-21 10:04:04.930] System Manager - Popup SysVarChange Callback Initated with 8235
203 [2026-02-21 10:04:04.990] Driver event 'Activity Ready: Media in Gym on RTiPanel (iPhone X or newer)'
204 [2026-02-21 10:04:04.101] Macro - Start
205 [2026-02-21 10:04:04.103] Change to page "Media" on device 'iPhone (David)'
206 [2026-02-21 10:04:04.114] Macro - End

207 [2026-02-21 10:04:08.114] Button Down - Device:'iPhone (David)' Transport:Ethernet TCP
208 [2026-02-21 10:04:08.117] Driver Command (System Manager): 'System Manager\[Hide]\Route Command(16849898)' [No Format!]
209 [2026-02-21 10:04:08.118] Button Down - Device:'iPhone (David)' Transport:Ethernet TCP
210 [2026-02-21 10:04:08.121] Macro - Start
211 [2026-02-21 10:04:08.123] System macro 'POWER OFF - Room (Lights)' - Start
212 [2026-02-21 10:04:08.144] Button Up
213 [2026-02-21 10:04:09.289] Driver Command (Clipsal C-Bus): 'Gym Recessed switched to Off.'
214 [2026-02-21 10:04:09.382] Driver Command (System Manager): 'Source for Gym set to Room Home.'
215 [2026-02-21 10:04:09.391] System Manager - Popup SysVarChange Callback Initated with 8235
216 [2026-02-21 10:04:09.394] System macro 'POWER OFF - Room (Lights)' - End
217 [2026-02-21 10:04:09.501] Driver Command (System Manager): 'System Manager\[Hide]\Room Off' [No Format!]
218 [2026-02-21 10:04:09.512] Macro - End
219 [2026-02-21 10:04:09.519] System Manager - Popup SysVarChange Callback Initated with 8235
220 [2026-02-21 10:04:09.524] System Manager - Popup SysVarChange Callback Initated with 8631
221 [2026-02-21 10:04:09.527] Driver event 'Video OFF in Gym'
222 [2026-02-21 10:04:09.528] Driver event 'Room OFF in Gym'
223 [2026-02-21 10:04:09.529] Driver event 'Room Off Complete in Gym on RTiPanel (iPhone X or newer)'
224 [2026-02-21 10:04:09.531] Macro - Start
225 [2026-02-21 10:04:09.548] IR - Port:'XP-8v','ECB5 #1' Command:'POWER OFF [/ /]' Sustain:NO
226 [2026-02-21 10:04:09.680] IR - Port:'XP-8v','ECB5 #3 Direct 1' Command:'POWER OFF [/ /]' Sustain:NO
227 [2026-02-21 10:04:10.612] Macro - End
228 [2026-02-21 10:04:10.688] Macro - Start
229 [2026-02-21 10:04:10.690] Driver Command (Vaux Lattis Matrix): 'Gym power set to Off.'
230 [2026-02-21 10:04:10.701] Macro - End
231 [2026-02-21 10:04:10.747] System Manager - Popup SysVarChange Callback Initated with 553
232 [2026-02-21 10:04:10.805] Macro - Start
233 [2026-02-21 10:04:10.833] Driver Command (System Manager): 'Source for Gym set to Room Home.'
234 [2026-02-21 10:04:10.866] System Manager - Popup SysVarChange Callback Initated with 8235
235 [2026-02-21 10:04:10.869] Macro - End
236 [2026-02-21 10:04:10.872] Driver event 'Activity Ready: Home in Gym on RTiPanel (iPhone X or newer)'
237 [2026-02-21 10:04:10.976] Macro - Start
238 [2026-02-21 10:04:10.978] Change to page "Room Floorplan" on device 'iPhone (David)'
239 [2026-02-21 10:04:10.989] Macro - End
240 [2026-02-21 10:04:13.623] Device 'iPhone (David)' has disconnected
241 [2026-02-21 10:04:20.100] Device 'iPhone (David)' has connected
242 [2026-02-21 10:04:21.822] Device 'iPhone (David)' has disconnected
245 [2026-02-21 10:06:10.653] System Manager - Popup SysVarChange Callback Initated with 20161