Belagavi District Drinking water Qulaity Testing Laboratory
Rural Drinking Water and Sanitation Department
PRED Building Near Nehru Nagar , Krishndevaraya circle -590010
Emial-rdwsd.wqmspbelagavi@gmail.com/ee.rws.bgm@gmail.com Ph no:- 0831-2420835/2420836
TC-12459

TEST REPORT

Costumer Name : **Aaryans Fun School**
Location of Source : **Aaryans Fun School,CTC No.484/45B,2nd Cross,opp Dr.Baliga Hospital,Sadashiva Nagar.Belagavi.**

Report date:28-05-2024
ULRNO:- TC1245924001275 F
Report Number:-341
Reference: Sample receipt Form
Sample receipt date: 27-05-2024
Sample code: BGV24MAY0341
Date of Sample collection: 27-05-2024
Analysis start date: 27-05-2024
Analysis completion date: 28-05-2024
Sample collection protocol: APHA 24th Method
Sample Particulars: Ground Water
Sample quantity:1 LITRE

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless Liquid					
1.	pH Value at 25°C	6.81	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance at 25°C,µS/cm	180	-	_	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) :2023
5.	Colour, Hazen Units	10	5	15	IS 3025 (Part-4) :2021
6.	Turbidity, NTU	2.8	1	5	IS 3025 (Part-10) : 2023
7.	Total Dissolved Solids at 180°C, mg/l	112	500	2000	IS 3025 (Part-16) : 2023
8.	Alkalinity as $CaCO_3$, mg/l	63.68	200	600	IS 3025 (Part-23) : 2023
9.	Total Hardness as $CaCO_3$, mg/l	67.38	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	15.87	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	6.74	30	100	IS 3025 (Part-46) : 2023
12.	Chloride as Cl, mg/l	23.82	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO_4, mg/l	7.83	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/l	0.13	1	1.5	APHA 24th Method
15.	Nitrate as NO_3, mg/l	3.57	45	No relaxation	APHA 24th Method
16.	Iron as Fe, mg/l	0.08	1	No relaxation	IS 3025 (Part-53) : 2003

Reviewed by:
Junior Analyst (V S HANNIKERI)

Authorized Signatory:
Technical Manager(U M MULLA)

RDWSD/WQMSP/TeR/01

Note:

1) **The above results relate only to the sample tested.**
2) **The report shall not be reproduced except in full without the prior approval of the Quality Manager.**
3) **Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.**
4) **Samples will be discarded after 15 days from the date of report generation.**
5) **Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.**

-- -------End Of Report----------