


BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	1	8"	CAP 8" P150
2	70'-8"	8"	PIPE 8" P150 BEVELLED ENDS
3	1	8"x4"	TEE REDUCING 8" × 4" P150
4	2	8"	GUIDE FOR 8" LINE (GUIDE-8)
5	1	8"	SHOE FOR 8" LINE (SHOE-8)

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

WATER (COOLING AND PROCESS)

NOTES:


1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. REMOVE BURRS FROM ALL CUT ENDS

TEST PRESS.	INSULATION	PAINT
-	NONE	-
PWHT	NDE	FLUID
-	-	CWR

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
8"-P150-CWR-2002	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-CWR-2002	1 OF 4	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	39'-1 11/16"	8"	PIPE 8" P150 BEVELLED ENDS
2	1	8"x4"	TEE REDUCING 8" × 4" P150
3	1	8"	ANCHOR FOR 8" LINE (ANCHOR-8)
4	1	8"	GUIDE FOR 8" LINE (GUIDE-8)

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. CHECK ORIENTATION BEFORE WELDING

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

WATER (COOLING AND PROCESS)


TEST PRESS.	INSULATION	PAINT
-	NONE	-

PWHT	NDE	FLUID
-	-	CWR

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
8"-P150-CWR-2002	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-CWR-2002	2 OF 4	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	32'-7 1/16"	8"	PIPE 8" P150 BEVELLED ENDS
2	1	8"x4"	TEE REDUCING 8" × 4" P150
3	1	8"	SHOE FOR 8" LINE (SHOE-8)
4	1	8"	GUIDE FOR 8" LINE (GUIDE-8)

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

WATER (COOLING AND PROCESS)

NOTES:


1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. CHECK ORIENTATION BEFORE WELDING
4. REMOVE BURRS FROM ALL CUT ENDS

TEST PRESS.	INSULATION	PAINT
-	NONE	-
PWHT	NDE	FLUID
-	-	CWR

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
8"-P150-CWR-2002	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-CWR-2002	3 OF 4	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	1	8"	CAP 8" P150
2	8'-11 5/16"	8"	PIPE 8" P150 BEVELLED ENDS
3	3	8"x3/4"	TEE REDUCING 8" × 3/4" P150
4	3	3/4"	FLANGE WELD-NECK 3/4" P150 RAISED FACE
5	6	3/4"	GASKET 3/4" P150 COMPRESSED SHEET
6	3	3/4"	VALVE, BALL, FLOATING 3/4" P150
7	6	3/4"	STUD SET 4 × 0.5" × 4-1/4" WITH 2 NUTS, FOR 3/4" P150
8	3	3/4"	FLANGE BLIND 3/4" P150 RAISED FACE

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. CHECK ORIENTATION BEFORE WELDING
4. HYDROTEST BEFORE PAINTING

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

WATER (COOLING AND PROCESS)

TEST PRESS.	INSULATION	PAINT
-	NONE	-

PWHT	NDE	FLUID
-	-	CWR

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
8"-P150-CWR-2002	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-CWR-2002	4 OF 4	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS