

BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	3	1"	FLANGE WELD-NECK 1" P300 RAISED FACE
2	4	1"	GASKET 1" P300 COMPRESSED SHEET
3	2	1"	VALVE, BALL, FLOATING 1" P300
4	4	1"	STUD SET 4 × 0.5" × 4" WITH 2 NUTS, FOR 1" P300
5	33'-1 3/16"	1"	PIPE 1" P300 BEVELLED ENDS
6	2	1"	ELBOW 90° R = 5/3 OD 1" P300
7	1	1"	FLANGE BLIND 1" P300 RAISED FACE
8	1	1"	HANGER FOR 1" LINE (HANGER-1x59.8)

NOTES:
1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. REMOVE BURRS FROM ALL CUT ENDS
4. FLANGE BOLT HOLES STRADDLE CENTRELINES

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

LOW-PRESSURE STEAM

TEST PRESS.	INSULATION	PAINT
-	YES	-
PWHT	NDE	FLUID
-	-	HS

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
1"-P300-HS-5038	S300	300 PSIG	-

DRAWING NO.	SHEET	REV
ISO-HS-5038	1 OF 1	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS