

BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	3	2"	FLANGE WELD-NECK 2" P300 RAISED FACE
2	4	2"	GASKET 2" P300 COMPRESSED SHEET
3	2	2"	VALVE, GATE, WEDGE, OS&Y 2" P300
4	4	2"	STUD SET 4 × 0.625" × 4-1/4" WITH 2 NUTS, FOR 2" P300
5	54'-5 1/4"	2"	PIPE 2" P300 BEVELLED ENDS
6	5	2"	ELBOW 90° R = 5/3 OD 2" P300
7	1	2"	HANGER FOR 2" LINE (HANGER-2x87.0)
8	1	2"	HANGER FOR 2" LINE (HANGER-2x77.0)
9	1	2"	TRUNNION FOR 2" LINE (TRUNNION-2x29.0)

NOTES:
1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. HYDROTEST BEFORE PAINTING
4. CHECK ORIENTATION BEFORE WELDING

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

LOW-PRESSURE STEAM

TEST PRESS.	INSULATION	PAINT
-	YES	-

PWHT	NDE	FLUID
-	-	LS

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
2"-P300-LS-3007	S300	300 PSIG	-

DRAWING NO.	SHEET	REV
ISO-LS-3007	1 OF 1	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS