


BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	1	3"	CAP 3" P150
2	23'-2"	3"	PIPE 3" P150 BEVELLED ENDS
3	2	3"x2"	TEE REDUCING 3" × 2" P150
4	1	3"	SHOE FOR 3" LINE (SHOE-3)
5	1	3"	GUIDE FOR 3" LINE (GUIDE-3)

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

STEAM CONDENSATE

NOTES:


1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. HYDROTEST BEFORE PAINTING
4. CHECK ORIENTATION BEFORE WELDING

TEST PRESS.	INSULATION	PAINT
-	YES	-
PWHT	NDE	FLUID
-	-	SC

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-SC-2004	C150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-SC-2004	1 OF 6	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	30'-0"	3"	PIPE 3" P150 BEVELLED ENDS
2	3	3"	SHOE FOR 3" LINE (SHOE-3)

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD

TEST PRESS.	INSULATION	PAINT
-	YES	-

PWHT	NDE	FLUID
-	-	SC

COMPANY

SMARTWELD


TITLE

STEAM CONDENSATE

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-SC-2004	C150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-SC-2004	2 OF 6	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	40'-0"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"	GUIDE FOR 3" LINE (GUIDE-3)
3	2	3"	SHOE FOR 3" LINE (SHOE-3)
4	1	3"	ANCHOR FOR 3" LINE (ANCHOR-3)

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

NOTES:
1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD

TEST PRESS.	INSULATION	PAINT
-	YES	-
PWHT	NDE	FLUID
-	-	SC

COMPANY

SMARTWELD


TITLE

STEAM CONDENSATE

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-SC-2004	C150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-SC-2004	3 OF 6	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	30'-0"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"	GUIDE FOR 3" LINE (GUIDE-3)
3	2	3"	SHOE FOR 3" LINE (SHOE-3)

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

STEAM CONDENSATE

NOTES:


1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD

TEST PRESS.	INSULATION	PAINT
-	YES	-
PWHT	NDE	FLUID
-	-	SC

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-SC-2004	C150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-SC-2004	4 OF 6	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	30'-4"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"x3/4"	TEE REDUCING 3" × 3/4" P150
3	1	3/4"	FLANGE WELD-NECK 3/4" P150 RAISED FACE
4	2	3/4"	GASKET 3/4" P150 COMPRESSED SHEET
5	1	3/4"	VALVE, BALL, FLOATING 3/4" P150
6	2	3/4"	STUD SET 4 × 0.5" × 4-1/4" WITH 2 NUTS, FOR 3/4" P150
7	1	3/4"	FLANGE BLIND 3/4" P150 RAISED FACE
8	2	3"	SHOE FOR 3" LINE (SHOE-3)
9	1	3"	GUIDE FOR 3" LINE (GUIDE-3)

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. PAINT PER PROJECT SPECIFICATION

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE


STEAM CONDENSATE

TEST PRESS.	INSULATION	PAINT
-	YES	-
PWHT	NDE	FLUID
-	-	SC

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-SC-2004	C150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-SC-2004	5 OF 6	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	1	3"	CAP 3" P150
2	2'-5"	3"	PIPE 3" P150 BEVELLED ENDS
3	2	3"x3/4"	TEE REDUCING 3" × 3/4" P150
4	2	3/4"	FLANGE WELD-NECK 3/4" P150 RAISED FACE
5	4	3/4"	GASKET 3/4" P150 COMPRESSED SHEET
6	2	3/4"	VALVE, BALL, FLOATING 3/4" P150
7	4	3/4"	STUD SET 4 × 0.5" × 4-1/4" WITH 2 NUTS, FOR 3/4" P150
8	2	3/4"	FLANGE BLIND 3/4" P150 RAISED FACE

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

NOTES:
1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD

TEST PRESS.	INSULATION	PAINT
-	YES	-
PWHT	NDE	FLUID
-	-	SC

COMPANY
SMARTWELD

TITLE
STEAM CONDENSATE

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-SC-2004	C150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-SC-2004	6 OF 6	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS