


BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	1	3"	CAP 3" P150
2	13'-7"	3"	PIPE 3" P150 BEVELLED ENDS
3	1	3"x1"	TEE REDUCING 3" × 1" P150
4	1	3"	SHOE FOR 3" LINE (SHOE-3)

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

NOTES:
1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD

TEST PRESS.	INSULATION	PAINT
-	NONE	-
PWHT	NDE	FLUID
-	-	W

COMPANY

SMARTWELD


TITLE

WATER (COOLING AND PROCESS)

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-W-2008	1 OF 10	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	19'-7"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"x1"	TEE REDUCING 3" × 1" P150
3	1	3"	GUIDE FOR 3" LINE (GUIDE-3)
4	1	3"	SHOE FOR 3" LINE (SHOE-3)

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. CHECK ORIENTATION BEFORE WELDING

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

WATER (COOLING AND PROCESS)


TEST PRESS.	INSULATION	PAINT
-	NONE	-

PWHT	NDE	FLUID
-	-	W

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-W-2008	2 OF 10	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	19'-7"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"x1"	TEE REDUCING 3" × 1" P150
3	2	3"	SHOE FOR 3" LINE (SHOE-3)

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

NOTES:
1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD

TEST PRESS. -	INSULATION **NONE**	PAINT -	
PWHT -	NDE -	FLUID **W**	


COMPANY
SMARTWELD

TITLE
WATER (COOLING AND PROCESS)

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	**W150**	**150 PSIG**	**-**

DRAWING NO.	SHEET	REV
ISO-W-2008	**3 OF 10**	**0**

DATE	DRAWN	CHECKED	SCALE
2026-11-01	**-**	**-**	**NTS**



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	19'-7"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"x1"	TEE REDUCING 3" × 1" P150
3	1	3"	GUIDE FOR 3" LINE (GUIDE-3)
4	1	3"	SHOE FOR 3" LINE (SHOE-3)

NOTES:
1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD

TEST PRESS.	INSULATION	PAINT
-	NONE	-

PWHT	NDE	FLUID
-	-	W

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD


TITLE

WATER (COOLING AND PROCESS)

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-W-2008	4 OF 10	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	25'-9 3/4"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"x1"	TEE REDUCING 3" × 1" P150
3	1	3"x3/4"	TEE REDUCING 3" × 3/4" P150
4	1	3"	ANCHOR FOR 3" LINE (ANCHOR-3)
5	1	3"	SHOE FOR 3" LINE (SHOE-3)
6	1	3"	GUIDE FOR 3" LINE (GUIDE-3)

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. HYDROTEST BEFORE PAINTING
4. FLANGE BOLT HOLES STRADDLE CENTRELINES

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE


WATER (COOLING AND PROCESS)

TEST PRESS.	INSULATION	PAINT
-	NONE	-
PWHT	NDE	FLUID
-	-	W

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-W-2008	5 OF 10	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	23'-10 1/2"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"x1"	TEE REDUCING 3" × 1" P150
3	1	3"x3/4"	TEE REDUCING 3" × 3/4" P150
4	2	3"	SHOE FOR 3" LINE (SHOE-3)

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

WATER (COOLING AND PROCESS)


TEST PRESS.	INSULATION	PAINT
-	NONE	-

PWHT	NDE	FLUID
-	-	W

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-W-2008	6 OF 10	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	16'-7 3/4"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"x1"	TEE REDUCING 3" × 1" P150
3	2	3"x3/4"	TEE REDUCING 3" × 3/4" P150
4	1	3"	SHOE FOR 3" LINE (SHOE-3)
5	1	3"	GUIDE FOR 3" LINE (GUIDE-3)

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE


WATER (COOLING AND PROCESS)

TEST PRESS.	INSULATION	PAINT
-	NONE	-
PWHT	NDE	FLUID
-	-	W

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-W-2008	7 OF 10	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	6'-0"	3"	PIPE 3" P150 BEVELLED ENDS
2	3	3"x3/4"	TEE REDUCING 3" × 3/4" P150
3	1	3/4"	FLANGE WELD-NECK 3/4" P150 RAISED FACE
4	2	3/4"	GASKET 3/4" P150 COMPRESSED SHEET
5	1	3/4"	VALVE, BALL, FLOATING 3/4" P150
6	2	3/4"	STUD SET 4 × 0.5" × 4-1/4" WITH 2 NUTS, FOR 3/4" P150
7	1	3/4"	FLANGE BLIND 3/4" P150 RAISED FACE
8	1	3"	SHOE FOR 3" LINE (SHOE-3)

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. REMOVE BURRS FROM ALL CUT ENDS

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

WATER (COOLING AND PROCESS)


TEST PRESS.	INSULATION	PAINT
-	NONE	-

PWHT	NDE	FLUID
-	-	W

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-W-2008	8 OF 10	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	2'-2"	3"	PIPE 3" P150 BEVELLED ENDS
2	1	3"x1"	TEE REDUCING 3" × 1" P150
3	1	3"x3/4"	TEE REDUCING 3" × 3/4" P150
4	1	3/4"	FLANGE WELD-NECK 3/4" P150 RAISED FACE
5	2	3/4"	GASKET 3/4" P150 COMPRESSED SHEET
6	1	3/4"	VALVE, BALL, FLOATING 3/4" P150
7	2	3/4"	STUD SET 4 × 0.5" × 4-1/4" WITH 2 NUTS, FOR 3/4" P150
8	1	3/4"	FLANGE BLIND 3/4" P150 RAISED FACE

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. HYDROTEST BEFORE PAINTING

TEST PRESS.	INSULATION	PAINT
-	NONE	-
PWHT	NDE	FLUID
-	-	W

COMPANY

SMARTWELD


TITLE

WATER (COOLING AND PROCESS)

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-W-2008	9 OF 10	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS



BILL OF MATERIALS

PT	QTY	NPS	DESCRIPTION
1	1	3"	CAP 3" P150
2	3'-3"	3"	PIPE 3" P150 BEVELLED ENDS
3	3	3"x3/4"	TEE REDUCING 3" × 3/4" P150
4	1	3/4"	FLANGE WELD-NECK 3/4" P150 RAISED FACE
5	2	3/4"	GASKET 3/4" P150 COMPRESSED SHEET
6	1	3/4"	VALVE, BALL, FLOATING 3/4" P150
7	2	3/4"	STUD SET 4 × 0.5" × 4-1/4" WITH 2 NUTS, FOR 3/4" P150
8	1	3/4"	FLANGE BLIND 3/4" P150 RAISED FACE

NOTES:

1. ALL DIMENSIONS IN FEET AND INCHES UNLESS NOTED
2. BEVEL ENDS FOR BUTT WELD
3. FLANGE BOLT HOLES STRADDLE CENTRELINES

REV	DATE	DESCRIPTION	BY
0	2026-11-01	ISSUED FOR CONSTRUCTION	-

COMPANY

SMARTWELD

TITLE

WATER (COOLING AND PROCESS)

TEST PRESS.	INSULATION	PAINT
-	NONE	-

PWHT	NDE	FLUID
-	-	W

LINE NO.	PIPING CLASS	DESIGN PRESS.	DESIGN TEMP.
3"-P150-W-2008	W150	150 PSIG	-

DRAWING NO.	SHEET	REV
ISO-W-2008	10 OF 10	0

DATE	DRAWN	CHECKED	SCALE
2026-11-01	-	-	NTS