

FACILITY CONDITION SURVEY

INSTRUCTIONS: Those assigned to conduct this survey should do so along with the users of the facility who are responsible for maintenance. They should take the following actions: Safely examine the entire property, including each building, to determine the current condition. Determine if an established maintenance program and the required safety inspections are being carried out according to an established schedule. Identify any areas of concern, especially safety hazards. Check that the brothers know how to carry out the upcoming maintenance tasks safely and have access to the equipment they need in order to do so safely. Ensure that they are able to complete a *Job Hazard Analysis* (DC-83) or *Congregation Job Hazard Analysis* (DC-85) properly for each potentially hazardous task. Provide a clear description of any problems in the "Follow-up Points" section of this survey, indicating who is responsible for promptly correcting the problem. Discuss the results of this survey and the follow-up points with the facility oversight, and leave a copy with them. Those assigned to conduct the survey should also complete the *Facility Life-Cycle Analysis* (DC-97) workbook and send both of these completed items to the Local Design/Construction Department (LDC).

In the case of a Kingdom Hall, the brother assigned to conduct this survey should follow the above steps with all available elders. Therefore, he will invite all available elders to accompany him while he examines the property and to discuss the results of the survey.

PROPERTY DESCRIPTION

Address:	262-264 Cameron Street, Ashburton		
Primary use:	Kingdom Hall	WHQ number:	AUS0515
Evaluated by:	Kyle Tarry	Survey date:	16/02/2024

FACILITY

- | | |
|---|--|
| 1. Briefly describe the number and size of buildings and describe the property being maintained. Are facility drawings and schematics up-to-date? If not, please explain. | 1 Building and grounds. Total Lot size 1011m ² . Building 235m ² |
| 2. Are there any aspects of the facility that are maintenance intensive? If so, please describe. | No |
| 3. What is the <i>overall</i> condition of the site and facilities? | Good |
| 4. Are the facilities and property being effectively utilized for the intended theocratic purpose? | Yes |

MAINTENANCE PROGRAM

- | | |
|---|--|
| 5. Have all follow-up points from the previous survey been completed? If not, please explain. | No. Due to Covid. |
| 6. Are preventive maintenance tasks and safety inspections being done as scheduled by a maintenance program? Are the congregations keeping up with tasks for maintenance-intensive areas? If not, please explain. | Yes. However newly appointed Maintenance Coordinator is still learning the role. |
| 7. Are efforts being made to use and train local volunteers to support the program? | Work in progress |
| 8. Is additional maintenance instruction or training needed to ensure they can complete the work safely? If so, what is recommended? | Yes. MTV recommended in future |

GENERAL OBSERVATIONS

- | | |
|--|---|
| 9. Has available facility oversight reviewed this survey, and are they in agreement with its findings? If not, please explain. | Yes |
| 10. Has a record been kept locally of replacements (partial or full) of any facility elements since the last survey, and have these replacements been reported and noted on the DC-97? | No. Reminder to keep History Cards up to date |

OTHER

- | | |
|---|-----|
| 11. Are current property-usage permits on file? (Certificate of Occupancy/Classification) If not, the LDC Department will care for obtaining these. | N/A |
| 12. Are annual reporting documents current and lodged with local authorities? | Yes |

SAFETY CHECKLIST

If there is a deficiency in any of the items listed below, do not check the box. List the specific issue as a follow-up point along with a recommended solution and the person responsible for follow-up. If the item is not applicable, simply check the box to indicate that it has been reviewed. Actively look for ways to reduce the risk of fire.

Fire Safety

- ☒ Are fire extinguishers located at main exits and all other places required by law, and are they tagged with annual proof of service or inspection?
- ☒ Are fire-hose or sprinkler systems in good working condition?
- ☒ Are fire-detection and alarm systems, where fitted, fully functional and up-to-date with building use modifications?
- ☒ Do dwelling-unit kitchens have fire detectors? Has grease and dirt been cleaned from ovens, hoods, ducts, and filters?
- ☒ Has the emergency lighting been tested and found to be working with an appropriate discharge time? Are batteries, where used for these systems, not over five years old?
- ☒ Are all exits free of obstructions, and are they marked with compliant signs?
- ☒ Do exit doors always operate easily?
- ☒ Is the storage of flammable paints or liquids eliminated or kept to a minimum, and are they stored in their original containers? Non-flammable water-based paints and cleaning supplies and non-aerosol containers are recommended wherever possible.
- ☒ Are electrical closets and mechanical rooms free of all combustible materials, including gas-powered tools or equipment? Are any areas where combustible materials are stored, including the attic, fitted with fire detection (where required)?
- ☒ Are heating flues properly isolated from combustible materials and regularly serviced by qualified personnel?
- ☒ Have all gas and electrical installations and appliances been inspected by a licensed inspector at the appropriate interval (wherever legally required) and found to be safe?
- ☒ Is a valid Certificate of Occupancy and/or Place of Public Assembly permit (if required) posted? Has an evacuation plan been put into place and displayed?

Slip/Trip and Fall Prevention

- ☒ Do stairs and ramps have surfaces that are anti-slip even when wet? If handrails are provided, are they securely fastened?
- ☒ Are glass doors, sidelights, and full-length windows shatterproof or of safety glass material?
- ☒ Are mops and "wet floor" signs on hand for spills or water brought in by footwear or for use when bathrooms and other hard floor surfaces are being cleaned?
- ☒ Are entry-floor mats in good condition, without curled-up edges, and fixed in a position that will keep them from sliding around?
- ☒ Are outside walking areas (such as car parks and footpaths) in good condition and free of holes or trip hazards?
- ☒ Are uneven surfaces (such as steps near doors or footpaths) marked with contrasting colours or another method to warn pedestrians of the danger of falling?
- ☒ Is the exterior lighting adequate in all walking areas, including carparks?
- ☒ Are supplies and proper equipment on hand to keep walkways and parking areas free of ice and snow?

General Loss Prevention

- ☐ Are *Congregation Job Hazard Analysis* (DC-85) forms being used and are they filled out correctly?
- ☐ Is the equipment needed for upcoming tasks available, such as good access equipment, fall protection, safety glasses, hardhats, and gloves?
- ☒ Are cleaning compounds and other hazardous chemicals safely stored out of reach of young children?
- ☒ Are the entire grounds free of holes, wires, or other hazards that could cause injury, even to uninvited visitors after dark?
- ☒ Are roofs, roof drains, and gutters in good repair and cleaned regularly so they function properly, with no signs of leaks?
- ☒ Are basements, interior surfaces of exterior walls, ceilings, bathrooms, and other areas where moisture could accumulate and cause damage free of any signs of moisture problems?
- ☒ Has an annual termite inspection been performed? (This is not necessary if there are no structural wood components.)
- ☒ Have carbon monoxide and radon alarms been checked, and do they function properly (if required in the building or dwelling unit)?
- ☒ Is a first-aid kit present on-site (where required), with all supplies in place and not expired?

FOLLOW-UP POINTS

Please list any issues along with the solution. Check the appropriate box to specify who will follow on each point. Add lines as needed.

Item	Issue	Recommended solution	✓User	✓LDC
1	Front wrought iron fence rusting & peeling	Treat rust & repaint (C-4)	✓	
2	Moisture ingress asphalt carpark	Continue to seal cracks in carpark (C-7)	✓	
3	Rough aluminium edge on front door	Smooth edge (B-5)	✓	
4	Earth spike uncovered	Fit earth protection tube	✓	
5	Gutter fascia paint peeling	Repaint (B-3)	✓	
6	Lichen on roof	Spray lichen (B-3)	✓	
7	Unpainted patches in kitchen and door frame	Fill holes and repaint (B-2, B-5)	✓	
8	Corrugated iron fence & block wall patchy with unpainted areas	Repaint (C-4)	✓	
9	Patch of wall paper in auditorium entrance damaged	Repair (B-2)	✓	
10	Door to mens bathroom closes too fast	Adjust door closer (B-5)	✓	
11			✓	
12				
13				
14				
15				