



District Level Water Testing Laboratory, Ranchi
VISWA Campus, Near Jodapool, Kanke ,
Ranchi- 834006, Jharkhand, India
Email:dlwtl.ranchi@gmail.com



TC-13614

Test Report

Report No:	Ref no.- 09	Issue Date : 24/07/2025
Issued To: (Name & Address of Customer)	The Principal, Sanatan Vidya Niketan, Sanatan Road, Jamuary, Kanke, Ranchi, Jharkhand. Sample no.01- Boring Water	Order Ref. No.: ULR No.: TC1361425000000125F
Date of Start Analysis :	22/07/2025	Sampling: Not done by laboratory Sample Received Date: 22/07/2025
Date of Completion Analysis :	24/07/2025	Environmental Condition of laboratory Temperature: 25.9°C Humidity: 52%

Sl. No.	Parameter	Unit	Result	Method Reference	Specification as per BIS – 10500:2012 (Second Revision) (Reaffirmed 2023)	
					Acceptable Limit	Permissible Limit (In Absence of Alternate source)
1	pH at 25 °C	-	6.93	IS 3025 (Part 11):2022,	6.5 – 8.5	No relaxation
2	Turbidity	NTU	-	IS 3025 (part 10):2023	1	5
3	Total Dissolved Solids at 180 °C	mg/L	108	IS 3025 (Part 16):2023, (Total Dissolved Solids Dried at 180 °C)	500	2000
4	Hardness as CaCO ₃	mg/L	84	IS 3025 (Part 21):2019, (EDTA Titration method)	200	600
5	Alkalinity as CaCO ₃	mg/L	116	IS 3025 (Part 23):2023, (Titration method)	200	600
6	Calcium as Ca ⁺	mg/L	19.20	IS 3025 (Part 40):2023, (EDTA Titration method)	75	200
7	Magnesium as Mg ⁺²	mg/L	8.75	IS 3025 (Part 46):2023	30	100
8	Chloride as Cl ⁻	mg/L	11.99	IS 3025 (Part 32):2019, (Argentometric method)	250	1000
9	Colour	Hazen Unit	5	IS 3025 (Part 4):2021, (Visual Comparison method)	5	15
10	Odour	-	Agreeable	IS 3025 (Part5): 2018	Agreeable	Agreeable
11	Taste	-	Agreeable	IS 3025 (Part 7): 2017 (Taste Threshold)	Agreeable	Agreeable

Notes: -

- ♦ The results listed refer only to the tested sample and applicable parameters.
- ♦ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ♦ This report cannot be reproduced, except when in full, without the written permission of the Lab In-charge
- ♦ All disputes are subjected to the Ranchi Jurisdiction.

Reviewed by:-

Archana Khalkho

-End of the Report-

Page 1 of 2

Krishna Kumar
(Krishna Kumar)

Chemist
Technical Manager
DLWTL, Ranchi



District Level Water Testing Laboratory, Ranchi
VISWA Campus, Near Jodapool, Kanke ,
Ranchi- 834006, Jharkhand, India
Email:dlwtl.ranchi@gmail.com

Test Report

Report No:	Ref no.- 09	Issue Date : 24/07/2025
Issued To: (Name & Address of Customer)	The Principal, Sanatan Vidya Niketan, Sanatan Road, Jamuary, Kanke, Ranchi, Jharkhand. Sample no.01- Boring Water	
Date of Start Analysis :	22/07/2025	Sampling: Not done by laboratory Sample Received Date: 22/07/2025
Date of Completion Analysis :	24/07/2025	Environmental Condition of laboratory Temperature: 25.9°C Humidity: 52%

Sl. No.	Parameter	Unit	Result	Method Reference	Specification as per BIS – 10500:2012 (Second Revision) Amendment – June 2015	
					Acceptable Limit	Permissible Limit (In Absence of Alternate source)
01.	Fluoride	mg/L	0.5	FTK	1.0	1.5
02.	Iron	mg/L	0.0	FTK	1.0	No relaxation
03.	Total Coliform	-	Absent	H ₂ S Vial	Absent	

Notes: -

- ♦ The results listed refer only to the tested sample and applicable parameters.
- ♦ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ♦ This report cannot be reproduced, except when in full, without the written permission of the Lab In-charge
- ♦ All disputes are subjected to the Ranchi Jurisdiction.

Reviewed by:-

Archana Khalkho

Krishna Kumar

(Krishna Kumar)

Chemist

Technical Manager

DLWTL, Ranchi