



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

TEST REPORT

IEC 60950-1:2005+AMD1:2009+AMD2:2013 - Information technology equipment - Safety - Part 1: General requirements

Report No. : WLR25/ETI/211/01

Sample No. : WS25/ETI/211/01

Client Name : GST Datacom Technology LLC

Address : Al Jaddaf, Dubai, UAE

Testing Laboratory : Wimpey Laboratories LLC

Address : Al Quoz Ind. Area-01, Dubai, UAE.

Test Item Description : Floor Standing Cabinet

Manufacturer : Datacom

Brand / Trade Mark : Datacom

Model/Type Ref. / Batch No. : NC SERIES / DC-NCXXX

Tested Model : DC-NC42U

Country of Origin : China

Test Standard / Method : IEC 60950-1:2005+AMD1:2009+AMD2:2013

Report Date : 30/09/2025

Test Item Received : 10/09/2025

Date of Test : 10/09/2025 - 25/09/2025

Tested By : JA

Summary of Testing : The below test parameter complies with the specification of IEC 60950-1:2005+AMD1:2009+AMD2:2013.



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

RESULTS

Test Environmental Conditions

Temperature (°C) : 23 ±2 °C

Relative Humidity (%) : 55 ±5%

Clause	Requirement - Test	Result - Remark	Verdict
1.7	Markings and instructions		P
1.7.1	Power rating and identification markings		P
1.7.1.1	Power rating markings	"220-240 V, 50/60 Hz"	P
	Multiple mains supply connections	Only one core provided	P
	Rated voltage(s) or voltage range(s) (V)		N/A
	Symbol for nature of supply, for d.c. only		N/A
	Rated frequency or rated frequency range (Hz)		N/A
	Rated current (mA or A)		N/A
	Rated power		N/A
1.7.1.2	Identification markings	DATACOM	P
	Manufacturer's name or trade-mark or identification mark		N/A
	Model identification or type reference	DC-NC4281G1P2B	P
	Symbol for Class II equipment only		N/A
	Other markings and symbols		N/A
1.7.1.3	Use of graphical symbols		N/A
1.7.2	Safety instructions and marking		N/A
	Equipment for restricted access locations		N/A
2	Protection from hazards		P
2.1	Protection from electric shock and energy hazards	Fans behind grille, inaccessible	P
2.2.1	General requirements		P
2.2.2	Voltages under normal conditions (V)	220-240 V AC for fans	P



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

2.2.3	Voltages under fault conditions (V)		N/A
2.2.4	Connection of SELV circuits to other circuits	No SELV circuits present	N/A
2.3	TNV circuits		N/A
2.4	Limited current circuits		N/A
2.5	Limited power sources		N/A
2.6	Provisions for earthing and bonding		N/A
2.6.1	Protective earthing	Metal chassis, earthing possible but not marked	N/A
2.6.5.6	Corrosion resistance	Powder coating, no rust observed	P
2.6.5.7	Screws for protective bonding	Not identified	N/A
2.7	Overcurrent and earth fault protection in primary circuits		N/A
2.7.1	Basic requirements	No circuits	N/A
2.7.4	Number and location of protective devices		N/A
2.8	Safety interlocks		N/A
2.8.1	General principles	Lockable door	P
2.8.2	Protection requirements	Not applicable	N/A
2.8.5	Moving parts	Only door, safe operation	P
2.8.7	Switches, relays and their related circuits		N/A
2.8.4.7	Electric strength test	No circuits	N/A
2.9	Electrical insulation		N/A
2.9.1	Properties of insulating materials	No insulation parts	N/A
2.9.2	Humidity conditioning	Not applicable	N/A
	Relative humidity (%), temperature (°C)		N/A
2.9.3	Grade of insulation	Not applicable	N/A
2.9.4	Separation from hazardous voltages	Fan grille provides separation	P



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

2.10	Clearances, creepage distances and distances through insulation		N/A
2.10.1	Determination of working voltage		N/A
2.10.2	Determination of working voltage		N/A
2.10.3	Clearances		N/A
2.10.4	Creepage distances		N/A
2.10.5	Solid insulation		N/A
3	Wiring, connections and supply		N/A
3.1.1	Current rating and overcurrent protection	Not present	N/A
3.1.2	Protection against mechanical damage	Cabinet protects cables	P
3.1.3	Securing of internal wiring	No wiring provided	N/A
3.1.4	Insulation of conductors		N/A
3.2.1.1	Connection to an a.c. mains supply	Non-detachable cord with plug	P
3.3	Wiring terminals for connection of external conductors		N/A
3.3.1	Wiring terminals	Not provided	N/A
3.3.2	Connection of non-detachable power supply cords	Yes, fixed cord	P
3.4	Disconnection from the mains supply		N/A
3.4.1	General requirement	By unplugging cord	P
3.4.2	Disconnect devices		N/A
3.4.3	Permanently connected equipment		N/A
3.5	Interconnection of equipment		N/A
3.5.1	General requirements		N/A
3.5.2	Types of interconnection circuits		N/A
3.5.3	ELV circuits as interconnection circuits	Not present	N/A
3.5.4	Data ports for additional equipment	Not provided	N/A
4	PHYSICAL REQUIREMENTS		N/A



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

4.1	Stability	Cabinet stable on casters	P
4.2	Mechanical strength		N/A
4.2.2	Steady force test,		
4.3	Design and construction		P
4.3.1	Edges and corners	Rounded, safe	P
4.3.4	Securing of parts	Fixed panels & shelves secure	P
4.3.5	Connection by plugs and sockets	Not applicable	N/A
4.4	Protection against hazardous moving parts	Fans Guarded	P
5.1	Touch current and protective conductor current		N/A
5.1.1	Equipment is constructed in such way touch current nor protective conductor current which likely to create electric shock	No electrical parts	N/A
5.2	Electric strength		N/A
5.3	Abnormal operating and fault conditions	No circuits	N/A
5.3.1	Protection against overload and abnormal operation	Not applicable	N/A

Possible Test Case Verdicts:

- test case does not apply to the test object : N/A
- test case does not conduct to the test object : N/C
- test object does meet the requirement : P (Pass)
- test object does not meet the requirement : F (Fail)

Remarks: Nil

Signed for and on behalf of Wimpey Laboratories L.L.C

Sajeesh Varkey
Laboratory Manager - E & E

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.





مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

Photograph of Test Object and Marking





مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

Annexure

As declared by the manufacturer, all brands and products listed below originate from the same production facility and conform to identical functional requirements, components, and materials. These products are manufactured using the same processes and standards as the tested model. Therefore, the listed products are considered equivalent to the tested product and have not been separately tested.

S.No	Product Description	Manufacturer	Trade Mark / Brand	Model number	Country of Origin
1	18U FREE STANDING CABINET	GST DATACOM	DATACOM	DC-NC1868G1S1B	China
2	22U FREE STANDING CABINET	GST DATACOM	DATACOM	DC-NC2268G1P2B DC-NC2288G1S1B DC-NC2288G1P2B DC-NC2281G1P2B	China
3	27U FREE STANDING CABINET	GST DATACOM	DATACOM	DC-NC2768G1P2B DC-NC2768P2P2B DC-NC2788G1P2B DC-NC2788P2P2B DC-NC2781G1P2B DC-NC2781P2P2B	China
4	42U FREE STANDING CABINET	GST DATACOM	DATACOM	DC-NC4268G1P2B DC-NC4288G1P2B DC-NC4288P2P2B DC-NC4281G1P2B DC-NC4281P2P2B DC-NC4282G1P2B DC-NC4282P2P2B	China
5	47U FREE STANDING CABINET	GST DATACOM	DATACOM	DC-NC4788G1P2B DC-NC4788P2P2B DC-NC4781G1P2B DC-NC4781P2P2B	China

-End of Text-