



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

TEST REPORT

IEC 60950-1:2005+AMD1:2009+AMD2:2013 - Information technology equipment - Safety - Part 1: General requirements

Report No. : WLR25/ETI/211/02

Sample No. : WS25/ETI/211/02

Client Name : GST Datacom Technology LLC

Address : Al Jaddaf, Dubai, UAE

Testing Laboratory : Wimpey Laboratories LLC

Address : Al Quoz Ind. Area-01, Dubai, UAE.

Test Item Description : Wall Mount Single Section Cabinet

Manufacturer : Datacom

Brand / Trade Mark : Datacom

Model/Type Ref. / Batch No. : WC AND RK SERIES / DC-RK / DC-WC / 020015202CH

Tested Model : 12U

Country of Origin : 'China

Test Standard / Method : IEC 60950-1:2005+AMD1:2009+AMD2:2013

Report Date : 25/09/2025

Test Item Received : 10/09/2025

Date of Test : 10/09/2025 - 25/09/2025

Tested By : JA

Summary of Testing : The below test parameter complies with the specification of IEC 60950-1:2005+AMD1:2009+AMD2:2013.



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

RESULTS

Test Environmental Conditions

Temperature (°C) : 23 ±2 °C

Relative Humidity (%) : 55 ±5%

Clause	Requirement - Test	Result - Remark	Verdict
1.7	Markings and instructions		
1.7.1	Power rating and identification markings	"220–240 V, 50/60 Hz" for fan unit	P
1.7.1.1	Power rating markings	Only one supply cord present	P
	Multiple mains supply connections		N/A
	Rated voltage(s) or voltage range(s) (V)		N/A
	Symbol for nature of supply, for d.c. only	Not required (AC supply only)	P
	Rated frequency or rated frequency range (Hz)		N/A
	Rated current (mA or A)		N/A
	Rated power		N/A
1.7.1.2	Identification markings		P
	Manufacturer's name or trade-mark or identification mark	"DATACOM" marked	P
	Model identification or type reference	DC-RK-12WS-4B	P
	Symbol for Class II equipment only	Not Class II (earthed metal)	N/A
	Other markings and symbols	CE/standard safety marks not visible	N/A
1.7.1.3	Use of graphical symbols	No additional safety symbols seen	N/A
1.7.2	Safety instructions and marking	MANUAL	P
	General		P
	Language(s)	English	P
	Equipment for restricted access locations		P
2	Protection from hazards		P
2.1	Protection from electric shock and energy hazards	Fans behind grille, inaccessible	P
2.2.1	General requirements	Live parts not accessible	P



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

2.2.2	Voltages under normal conditions (V)	Fans rated for 220–240 V	P
2.2.3	Voltages under fault conditions (V)		N/A
2.2.4	Connection of SELV circuits to other circuits	No SELV present	N/A
2.3	TNV circuits		N/A
2.4	Limited current circuits		N/A
2.5	Limited power sources		N/A
2.6	Provisions for earthing and bonding		N/A
2.6.1	Protective earthing	Cabinet metal, cord with earth pin provided	P
2.6.5.6	Corrosion resistance	Powder coating, no rust observed	P
2.6.5.7	Screws for protective bonding	Not identified	N/A
2.7	Overcurrent and earth fault protection in primary circuits		N/A
2.7.1	Basic requirements	No circuits	N/A
2.7.4	Number and location of protective devices		N/A
2.8	Safety interlocks		N/A
2.8.1	General principles	Lockable door	P
2.8.2	Protection requirements	Not applicable	N/A
2.8.5	Moving parts	Only door, safe operation	P
2.8.7	Switches, relays and their related circuits		N/A
2.8.4.7	Electric strength test	No circuits	N/A
2.9	Electrical insulation		N/A
2.9.1	Properties of insulating materials	No insulation parts	N/A
2.9.2	Humidity conditioning	Not applicable	N/A
	Relative humidity (%), temperature (°C)		N/A
2.9.3	Grade of insulation	Not applicable	N/A
2.9.4	Separation from hazardous voltages	Fan grille provides separation	P



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

2.10	Clearances, creepage distances and distances through insulation		N/A
2.10.1	Determination of working voltage	220–240 V AC	P
2.10.2	Determination of working voltage	220–240 V AC	P
2.10.3	Clearances		N/A
2.10.4	Creepage distances		N/A
2.10.5	Solid insulation		N/A
3	Wiring, connections and supply		N/A
3.1.1	Current rating and overcurrent protection	Not present	N/A
3.1.2	Protection against mechanical damage	Cabinet protects cables	P
3.1.3	Securing of internal wiring	Cord tied, fan wiring fixed	P
3.1.4	Insulation of conductors	Standard mains cord	P
3.2.1.1	Connection to an a.c. mains supply	Cord with plug	P
3.3	Wiring terminals for connection of external conductors		N/A
3.3.1	Wiring terminals	Not provided	N/A
3.3.2	Connection of non-detachable power supply cords	Present	P
3.4	Disconnection from the mains supply		N/A
3.4.1	General requirement	By plug removal	P
3.4.2	Disconnect devices		N/A
3.4.3	Permanently connected equipment		N/A
3.5	Interconnection of equipment		N/A
3.5.1	General requirements		N/A
3.5.2	Types of interconnection circuits		N/A
3.5.3	ELV circuits as interconnection circuits	Not present	N/A
3.5.4	Data ports for additional equipment	Not provided	N/A
4	PHYSICAL REQUIREMENTS		N/A
4.1	Stability	Small cabinet, stable	P
4.2	Mechanical strength		N/A



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

4.2.2	Steady force test,		
4.3	Design and construction		P
4.3.1	Edges and corners	Rounded, safe	P
4.3.4	Securing of parts	Panels and door fixed	P
4.3.5	Connection by plugs and sockets	Not applicable	N/A
4.4	Protection against hazardous moving parts	None accessible	P
5.1	Touch current and protective conductor current		N/A
5.1.1	Equipment is constructed in such way touch current nor protective conductor current which likely to create electric shock	No electrical parts	N/A
5.2	Electric strength		N/A
5.3	Abnormal operating and fault conditions	No circuits	N/A
5.3.1	Protection against overload and abnormal operation	Not applicable	N/A

Possible Test Case Verdicts:

- test case does not apply to the test object : N/A
- test case does not conduct to the test object : N/C
- test object does meet the requirement : P (Pass)
- test object does not meet the requirement : F (Fail)

Remarks: Nil

Signed for and on behalf of Wimpey Laboratories L.L.C



Sajeesh Varkey
Laboratory Manager - E & E


Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

Photograph of Test Object and Marking





مختبرات ويمبي ش.ذ.م.م.
WIMPEY LABORATORIES L.L.C.

Annexure

As declared by the manufacturer, all brands and products listed below originate from the same production facility and conform to identical functional requirements, components, and materials. These products are manufactured using the same processes and standards as the tested model. Therefore, the listed products are considered equivalent to the tested product and have not been separately tested.

S.No	Product Description	Manufacturer	Trade Mark / Brand	Model number	Country of Origin
1	WALL MOUNT SINGLE SECTION CABINET	GST DATACOM	DATACOM	DC-RK-06-WS-1B DC-RK-06WS-4B DC-WC06US68B DC-RK-09WS-4B DC-RK-12WS-1B DC-RK-12WS-4B DC-RK-15WS-4B DC-WC15US68B DC-WC16US68B DC-WC18US68B DC-RK-21-WS-4B	China
2	WALL MOUNT DOUBLE SECTION CABINET	GST DATACOM	DATACOM	DC-RK-09-WD-4B DC-RK-12-WD-4B DC-RK-15-WD-4B DC-RK-21-WD-4B	China

-End of text-