

KSEB Renewable Energy Feasibility Report

Generated report · 2000 transformers across 1 districts. Balance % = (Balance Available ÷ 90% DTR Capacity) × 100.

District Summary

District	Transformers	Balance (kW)	Very High	High	Medium	Low	Very Low	Unknown
ERNAKULAM	2000	165,127.8	1059	395	233	98	215	0
TOTAL	2000	165,127.8	1059	395	233	98	215	0

ERNAKULAM — 2000 transformers

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Alangad [5737]	AADAYAKKADA	81.0	17.0	56.0	8.0	9.9	Very Low
ERNAKULAM	Alangad [5737]	ALANGAD KAVU	81.0	3.0	77.3	0.7	0.9	Very Low
ERNAKULAM	Alangad [5737]	ALANGAD MASJID	20.0	0.0	8.0	12.0	60.0	High
ERNAKULAM	Alangad [5737]	ANGADIKADAVU	81.0	3.0	35.0	43.0	53.1	High
ERNAKULAM	Alangad [5737]	AYURVEDAM	81.0	6.6	31.6	42.8	52.8	High
ERNAKULAM	Alangad [5737]	BIVERAGES	20.0	5.0	0.0	15.0	75.0	Very High
ERNAKULAM	Alangad [5737]	BLOCK ROAD	20.0	0.0	19.0	1.0	5.0	Very Low
ERNAKULAM	Alangad [5737]	CHEMBORA	81.0	0.0	18.0	63.0	77.8	Very High
ERNAKULAM	Alangad [5737]	CHENGOTHKUNNE	81.0	3.0	43.7	34.3	42.3	Medium
ERNAKULAM	Alangad [5737]	CHERAPPADAM	81.0	16.0	50.0	15.0	18.5	Low
ERNAKULAM	Alangad [5737]	CHIRAYAM KADAVU	81.0	8.0	49.8	23.2	28.6	Medium
ERNAKULAM	Alangad [5737]	CHIRAYAM NORTH	81.0	20.0	51.3	9.7	12.0	Low
ERNAKULAM	Alangad [5737]	CHIRAYAM RATION KADA	81.0	3.0	77.9	0.1	0.1	Very Low
ERNAKULAM	Alangad [5737]	COLONYPADY	81.0	14.0	64.4	2.6	3.2	Very Low
ERNAKULAM	Alangad [5737]	EDAKKATHODE	81.0	30.0	44.0	7.0	8.6	Very Low
ERNAKULAM	Alangad [5737]	GOLDEN EYE	81.0	0.0	31.0	50.0	61.7	High
ERNAKULAM	Alangad [5737]	GOPIKA SOUTH	81.0	6.3	35.0	39.7	49.0	Medium
ERNAKULAM	Alangad [5737]	IRRIGATION	129.0	8.3	46.0	74.7	57.9	High
ERNAKULAM	Alangad [5737]	K K JUNCTION	129.0	6.0	40.0	83.0	64.3	High
ERNAKULAM	Alangad [5737]	KALLARAKKAL	81.0	3.0	27.5	50.5	62.3	High
ERNAKULAM	Alangad [5737]	KALLUPALAM	81.0	22.1	37.0	21.9	27.1	Medium
ERNAKULAM	Alangad [5737]	KALLUPALAM ANGANVADY	81.0	19.0	36.2	25.8	31.8	Medium
ERNAKULAM	Alangad [5737]	KARINGAMTHURUTH	129.0	9.0	118.3	1.7	1.3	Very Low
ERNAKULAM	Alangad [5737]	KARUMALLOOR EAST	20.0	0.0	8.2	11.8	59.2	High
ERNAKULAM	Alangad [5737]	KEERAMPILLY	129.0	17.0	108.7	3.3	2.5	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Alangad [5737]	KOCHERIKA CHURCH	81.0	5.0	8.0	68.0	84.0	Very High
ERNAKULAM	Alangad [5737]	KOCHERIKKA	81.0	9.0	37.5	34.5	42.7	Medium
ERNAKULAM	Alangad [5737]	KODUVAZHANGA	81.0	11.0	31.8	38.2	47.1	Medium
ERNAKULAM	Alangad [5737]	KOGOORPILLY BANK	81.0	10.0	71.0	0.0	0.0	Very Low
ERNAKULAM	Alangad [5737]	KONGORPILLY	202.0	32.0	86.8	83.2	41.2	Medium
ERNAKULAM	Alangad [5737]	KONGORPILLY SCHOOL	81.0	19.0	61.8	0.2	0.3	Very Low
ERNAKULAM	Alangad [5737]	KONGORPPILLY SOUTH	81.0	14.0	35.4	31.6	39.0	Medium
ERNAKULAM	Alangad [5737]	KONGORPPILLY ST GEORGE KAPPELA	81.0	3.0	57.0	21.0	25.9	Medium
ERNAKULAM	Alangad [5737]	KOTTAPPILLYKUNNU	81.0	0.0	50.9	30.1	37.1	Medium
ERNAKULAM	Alangad [5737]	KOTTAPPURAM VAYANASALA	81.0	0.0	37.1	43.9	54.2	High
ERNAKULAM	Alangad [5737]	KOTTAPPURAM-1	202.0	5.0	46.0	151.0	74.8	High
ERNAKULAM	Alangad [5737]	KRISHNA PURAM TEMPLE	81.0	0.0	80.8	0.2	0.2	Very Low
ERNAKULAM	Alangad [5737]	KURIPARAMBU	20.0	0.0	19.0	1.0	5.0	Very Low
ERNAKULAM	Alangad [5737]	KUTTIKULANGARA TEMPLE	81.0	10.0	30.0	41.0	50.6	High
ERNAKULAM	Alangad [5737]	MADAMBI	81.0	15.0	55.3	10.7	13.2	Low
ERNAKULAM	Alangad [5737]	MALOTH	81.0	9.0	56.4	15.7	19.3	Low
ERNAKULAM	Alangad [5737]	MALOTH ANGANVADY	81.0	0.0	18.0	63.0	77.8	Very High
ERNAKULAM	Alangad [5737]	MALOTH CHURCH	81.0	14.0	66.0	1.0	1.2	Very Low
ERNAKULAM	Alangad [5737]	MALOTH SAW MILL	81.0	8.0	39.3	33.7	41.6	Medium
ERNAKULAM	Alangad [5737]	MALOTH SOUTH	20.0	3.0	15.5	1.5	7.5	Very Low
ERNAKULAM	Alangad [5737]	MARAYI SCHOOL	81.0	12.0	51.0	18.0	22.2	Low
ERNAKULAM	Alangad [5737]	MASJID NEERICODE	81.0	8.0	71.3	1.7	2.1	Very Low
ERNAKULAM	Alangad [5737]	MEPPADAM	81.0	15.0	20.0	46.0	56.8	High
ERNAKULAM	Alangad [5737]	METHANAM	129.0	45.0	79.2	4.8	3.7	Very Low
ERNAKULAM	Alangad [5737]	MMT-AUTOMATION	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Alangad [5737]	NAIRKULAM	81.0	11.0	69.4	0.6	0.7	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Alangad [5737]	NANDHIPARAMBU	81.0	3.0	17.5	60.5	74.7	High
ERNAKULAM	Alangad [5737]	NEERICODE BRIDGE	81.0	3.0	11.0	67.0	82.7	Very High
ERNAKULAM	Alangad [5737]	NEERICODE CHURCH	81.0	0.0	79.0	2.0	2.4	Very Low
ERNAKULAM	Alangad [5737]	NEERICODE PANCHAYATH	81.0	8.0	37.4	35.6	43.9	Medium
ERNAKULAM	Alangad [5737]	NEERICODE TEMPLE	81.0	11.0	49.0	21.0	25.9	Medium
ERNAKULAM	Alangad [5737]	NETTOOR MILL	81.0	8.0	20.0	53.0	65.4	High
ERNAKULAM	Alangad [5737]	PALLATHNADU	81.0	5.0	20.0	56.0	69.1	High
ERNAKULAM	Alangad [5737]	PALM VILLAGE	255.0	0.0	37.0	218.0	85.5	Very High
ERNAKULAM	Alangad [5737]	PARAYANTHURUTHU	129.0	46.0	82.0	1.0	0.8	Very Low
ERNAKULAM	Alangad [5737]	PAZHAMPILLY JUNCTION	81.0	4.0	76.2	0.8	1.0	Very Low
ERNAKULAM	Alangad [5737]	PAZHAMPILLY KAPPELA	81.0	5.0	32.0	44.0	54.3	High
ERNAKULAM	Alangad [5737]	PAZHAMTHODE	81.0	0.0	86.7	0.0	0.0	Very Low
ERNAKULAM	Alangad [5737]	PEEDIKAPADI TRANSFORMER	129.0	0.0	128.0	1.0	0.8	Very Low
ERNAKULAM	Alangad [5737]	PETTAPALAM	81.0	16.0	29.0	36.0	44.4	Medium
ERNAKULAM	Alangad [5737]	PHC KARINGAMTHURUTH	81.0	8.0	59.3	13.7	16.9	Low
ERNAKULAM	Alangad [5737]	PLAKKATTAMPILLY BRIDGE	81.0	6.0	37.6	37.4	46.2	Medium
ERNAKULAM	Alangad [5737]	PRIYADARSHINI COLONY	81.0	2.0	32.3	46.7	57.7	High
ERNAKULAM	Alangad [5737]	PUTHIYA ROAD	81.0	12.0	67.2	1.8	2.2	Very Low
ERNAKULAM	Alangad [5737]	SHA INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Alangad [5737]	SN NEERICODE	129.0	20.0	107.0	2.0	1.6	Very Low
ERNAKULAM	Alangad [5737]	SN WEST	81.0	3.0	76.9	1.1	1.4	Very Low
ERNAKULAM	Alangad [5737]	VISHWADEEPTHI	81.0	0.0	28.6	52.4	64.7	High
ERNAKULAM	Alangad [5737]	WARRIOMROAD	81.0	5.0	40.0	36.0	44.4	Medium
ERNAKULAM	Aluva North [5568]	ADVAITHASHRAMAM	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Aluva North [5568]	AISWARYANAGAR	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	AMBALAPADY	81.0	17.0	44.3	19.7	24.3	Low
ERNAKULAM	Aluva North [5568]	AMBATTUKAVU - NH	202.0	25.0	23.0	154.0	76.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva North [5568]	AMBATTUKAVU EAST	81.0	16.0	64.4	0.6	0.7	Very Low
ERNAKULAM	Aluva North [5568]	AMITY LANDMARK- INDOOR FLAT	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	AMITY SAROVAR INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	AMITY VISTA- INDOOR-FLAT	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	ANAKADAN	202.0	25.0	117.0	60.0	29.7	Medium
ERNAKULAM	Aluva North [5568]	ANGANWADI PULLALIKKARA	81.0	8.0	32.0	41.0	50.6	High
ERNAKULAM	Aluva North [5568]	ANNAPOORNA	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	ARYABHANGY HONDA	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Aluva North [5568]	ASHIYANA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	ASSET GREEN FORD - INDOOR	324.0	0.0	45.0	279.0	86.1	Very High
ERNAKULAM	Aluva North [5568]	ASSET SWAN-INDOOR-FLAT	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	AURIOUM BUILDING	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	AXIS-UTI BANK	81.0	0.0	47.0	34.0	42.0	Medium
ERNAKULAM	Aluva North [5568]	AYYANKARY	81.0	16.0	65.0	0.0	0.0	Very Low
ERNAKULAM	Aluva North [5568]	BANK ROAD	202.0	10.0	100.3	91.7	45.4	Medium
ERNAKULAM	Aluva North [5568]	BBS - CRYSTAL	255.0	0.0	19.0	236.0	92.5	Very High
ERNAKULAM	Aluva North [5568]	BRIDGE	202.0	0.0	35.0	167.0	82.7	Very High
ERNAKULAM	Aluva North [5568]	BULLET	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	BUS STAND	81.0	7.4	72.7	0.9	1.1	Very Low
ERNAKULAM	Aluva North [5568]	CARD BANK	255.0	0.0	20.0	235.0	92.2	Very High
ERNAKULAM	Aluva North [5568]	CHALAPPADAM	81.0	17.3	48.4	15.3	18.8	Low
ERNAKULAM	Aluva North [5568]	CHANDRIKA KUNJUNNIKARA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	CHEERAKADA	202.0	8.0	148.0	46.0	22.8	Low
ERNAKULAM	Aluva North [5568]	CHERUBS SKY VILLA-INDOOR	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	CHICKING	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	CHIRA	81.0	9.0	72.0	0.0	0.0	Very Low
ERNAKULAM	Aluva North [5568]	CHIRA PHC	129.0	11.0	117.4	0.6	0.4	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva North [5568]	CHIRA PHC NO 2	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Aluva North [5568]	CHOICE	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Aluva North [5568]	CIMAR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	CITY CASTLE- INDOOR-FLAT	202.0	0.0	30.0	172.0	85.1	Very High
ERNAKULAM	Aluva North [5568]	CITY TOWER	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	CIVIL STATION	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	CONFIDENT SYMPHONY	510.0	0.0	0.0	510.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	CSS	801.0	0.0	229.8	571.2	71.3	High
ERNAKULAM	Aluva North [5568]	DD GLOBAL VILLAGE-INDOORFLAT	405.0	0.0	75.0	330.0	81.5	Very High
ERNAKULAM	Aluva North [5568]	DDIC	129.0	0.0	40.0	89.0	69.0	High
ERNAKULAM	Aluva North [5568]	DELSTAR ARCADE INDOOR	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	DOMINOS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	DZIRE HABITAT -FLAT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	EDAMULA	81.0	23.7	57.3	0.0	0.0	Very Low
ERNAKULAM	Aluva North [5568]	ELANJIKA	81.0	0.0	30.0	51.0	63.0	High
ERNAKULAM	Aluva North [5568]	FBOA ROAD	81.0	0.0	38.2	42.8	52.8	High
ERNAKULAM	Aluva North [5568]	FEDERAL APARTMENTS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	FEDERAL BANK NH	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	FEDERAL GARDENS-INDOOR	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	FIRE STATION	81.0	0.0	76.0	5.0	6.2	Very Low
ERNAKULAM	Aluva North [5568]	FIT - PUBLIC	129.0	3.0	93.4	32.6	25.2	Medium
ERNAKULAM	Aluva North [5568]	FRIENDS LANE	129.0	0.0	129.0	0.0	0.0	Very Low
ERNAKULAM	Aluva North [5568]	FURNACE	255.0	8.0	141.6	105.4	41.3	Medium
ERNAKULAM	Aluva North [5568]	GARAGE-PUBLIC	81.0	5.0	75.8	0.2	0.2	Very Low
ERNAKULAM	Aluva North [5568]	GENERALATE	202.0	8.0	136.7	57.3	28.4	Medium
ERNAKULAM	Aluva North [5568]	GREAT WATERS-INDOOR FLAT	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	HDFC BANK	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva North [5568]	HERO MEGA MOTORS	81.0	0.0	30.0	51.0	63.0	High
ERNAKULAM	Aluva North [5568]	HIGH ROAD	129.0	0.0	76.0	53.0	41.1	Medium
ERNAKULAM	Aluva North [5568]	HIGHWAY GARAGE	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Aluva North [5568]	HYCOUNT PIPES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	JANAM - DHANLAXMI BANK	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	JEWEL HOMES - INDOOR - FLAT	162.0	0.0	0.0	162.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	JOY ICE CREAM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KALATHIL BUILDING-MORE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KALLANS	81.0	0.0	28.0	53.0	65.4	High
ERNAKULAM	Aluva North [5568]	KALLUNGAPARAMBU	129.0	5.0	5.0	119.0	92.2	Very High
ERNAKULAM	Aluva North [5568]	KANAMPURAM	129.0	30.0	98.3	0.7	0.5	Very Low
ERNAKULAM	Aluva North [5568]	KARIPPAI	51.0	0.0	0.0	51.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KAROTHUKUZH I HOSPITAL	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KAROTHUKUZH I JUNCTION	202.0	9.0	144.7	48.3	23.9	Low
ERNAKULAM	Aluva North [5568]	KATTIKKUZHI	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Aluva North [5568]	KATTIKKUZHI - KRA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KATTILPARAMBIL	81.0	5.0	44.0	32.0	39.5	Medium
ERNAKULAM	Aluva North [5568]	KAVIKULANGARA TEMPLE	129.0	8.0	46.0	75.0	58.1	High
ERNAKULAM	Aluva North [5568]	KHADER POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KKM COMPLEX - HANA	81.0	0.0	65.0	16.0	19.8	Low
ERNAKULAM	Aluva North [5568]	KMK HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KMRL-A	364.0	0.0	0.0	364.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KMRL-B	364.0	0.0	0.0	364.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KOMBARA JUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KOTONAM KADAVU	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Aluva North [5568]	KRISHNAN KOVIL	202.0	13.0	97.7	91.3	45.2	Medium
ERNAKULAM	Aluva North [5568]	KUNJUNNIKARA JUMA MASJID	129.0	20.0	75.3	33.7	26.1	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva North [5568]	KUNJUNNIKARA KAPOORI	81.0	14.0	53.0	14.0	17.2	Low
ERNAKULAM	Aluva North [5568]	KUNJUNNIKARA PATHAYAPURA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	KUNJUNNIKKARA MARANGATTU	129.0	5.0	117.0	7.0	5.4	Very Low
ERNAKULAM	Aluva North [5568]	KUNNATHERY MOSQUE	81.0	16.0	62.0	3.0	3.7	Very Low
ERNAKULAM	Aluva North [5568]	KUNNATHERY NO 1-PRAVASI	81.0	3.0	77.5	0.5	0.6	Very Low
ERNAKULAM	Aluva North [5568]	KUNNATHERY NO 2-SHAJAHAN	129.0	3.0	48.3	77.7	60.2	High
ERNAKULAM	Aluva North [5568]	KUNNUMPURAM NO 2 AUDITORIUM	81.0	22.0	56.7	2.3	2.8	Very Low
ERNAKULAM	Aluva North [5568]	KUNNUMPURAM NO I	129.0	29.0	50.3	49.7	38.5	Medium
ERNAKULAM	Aluva North [5568]	LG SERVICE CENTER	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Aluva North [5568]	LORD KRISHNA	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MADATHAZHAM	81.0	22.0	26.0	33.0	40.7	Medium
ERNAKULAM	Aluva North [5568]	MADAVAPURAM	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Aluva North [5568]	MALIAKAL PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MANADATH COMPANYPADY	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Aluva North [5568]	MANADATH HOMES-INDOOR FLAT	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MANTHARAKKAL	81.0	0.0	81.0	0.1	0.1	Very Low
ERNAKULAM	Aluva North [5568]	MANTHRAKKAL CANAL	81.0	17.0	63.6	0.4	0.5	Very Low
ERNAKULAM	Aluva North [5568]	MAP NEST	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MARIYIL	81.0	7.0	74.0	0.0	0.0	Very Low
ERNAKULAM	Aluva North [5568]	MASJID	81.0	0.0	25.0	56.0	69.1	High
ERNAKULAM	Aluva North [5568]	MB HEIGHTS FLAT 1	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MB HEIGHTS FLAT 2	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MES MANTRAKKAL	129.0	48.2	74.0	6.8	5.3	Very Low
ERNAKULAM	Aluva North [5568]	METRO HEIGHTS FLAT	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MEZKKAR	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MKS	81.0	15.0	64.8	1.2	1.5	Very Low
ERNAKULAM	Aluva North [5568]	MUHAYUDEEN	81.0	0.0	3.2	77.8	96.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva North [5568]	MUKKATH BUILDING	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MUNCIPAL BUILDING	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MUNCIPAL PARK	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MUTHALAKUZH	129.0	10.0	0.0	119.0	92.2	Very High
ERNAKULAM	Aluva North [5568]	MUTHIRAPADAM	202.0	3.0	198.2	0.8	0.4	Very Low
ERNAKULAM	Aluva North [5568]	MUTHIRAPADAM ANGEL ROAD	81.0	5.0	3.0	73.0	90.1	Very High
ERNAKULAM	Aluva North [5568]	MUTTOM	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	MUTTOM HARIJAN COLONY	81.0	0.0	17.0	64.0	79.0	Very High
ERNAKULAM	Aluva North [5568]	NAD	81.0	15.0	32.0	34.0	42.0	Medium
ERNAKULAM	Aluva North [5568]	NAVARANG BUILDING INDOOR	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	NAZARETH CHURCH	81.0	5.0	75.9	0.1	0.1	Very Low
ERNAKULAM	Aluva North [5568]	NAZARETH CLUB	81.0	0.0	79.0	2.0	2.5	Very Low
ERNAKULAM	Aluva North [5568]	NEW MARKET NCC	81.0	0.0	50.0	31.0	38.3	Medium
ERNAKULAM	Aluva North [5568]	NIRMALA SCHOOL	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Aluva North [5568]	NOCHIMA	255.0	80.0	173.0	2.0	0.8	Very Low
ERNAKULAM	Aluva North [5568]	ONROAD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	PALACE	202.0	3.0	35.6	163.4	80.9	Very High
ERNAKULAM	Aluva North [5568]	PALACE VIEW-INDOOR FLAT	162.0	0.0	0.0	162.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	PALAM LANDS BUILDING - INDOOR	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	PALLIKAVALA	129.0	13.0	115.6	0.4	0.3	Very Low
ERNAKULAM	Aluva North [5568]	PANCHAYATHU LIBRARY	81.0	0.0	16.0	65.0	80.2	Very High
ERNAKULAM	Aluva North [5568]	PANKAJAM	202.0	10.0	36.0	156.0	77.2	Very High
ERNAKULAM	Aluva North [5568]	PARK	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	PATTADUPADAM	81.0	10.0	13.0	58.0	71.6	High
ERNAKULAM	Aluva North [5568]	PATTERIPURAM	129.0	3.0	125.1	0.9	0.7	Very Low
ERNAKULAM	Aluva North [5568]	PERIYAR BLOSSOM-INDOOR FLAT	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	PERIYAR BRIDGE	129.0	3.0	67.0	59.0	45.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva North [5568]	PERIYAR CASTLE	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	PERIYAR HERMITAGE-FLAT	405.0	0.0	25.0	380.0	93.8	Very High
ERNAKULAM	Aluva North [5568]	PERIYAR HERMITAGE-VILLA	202.0	0.0	76.3	125.7	62.2	High
ERNAKULAM	Aluva North [5568]	PERIYAR HOTEL	81.0	0.0	69.3	11.7	14.4	Low
ERNAKULAM	Aluva North [5568]	PERIYAR PALACE -INDOOR FLAT	129.0	0.0	11.0	118.0	91.5	Very High
ERNAKULAM	Aluva North [5568]	PMK WEIGH BRIDGE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	POLYMERS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	POTTACHIRA	129.0	44.6	84.0	0.4	0.3	Very Low
ERNAKULAM	Aluva North [5568]	PULINCHODE	202.0	10.0	157.5	34.5	17.1	Low
ERNAKULAM	Aluva North [5568]	RAHMANIYA	129.0	18.0	93.0	18.0	14.0	Low
ERNAKULAM	Aluva North [5568]	RELIANCE	129.0	0.0	15.0	114.0	88.4	Very High
ERNAKULAM	Aluva North [5568]	RIVERWAY PLAZA INDOOR	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	ROYAL PLAZA -INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	S N PURAM	129.0	38.0	90.6	0.4	0.3	Very Low
ERNAKULAM	Aluva North [5568]	SANTHI LOTUS - 1 INDOOR	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	SIGNAL PULINCHODU	81.0	4.0	16.0	61.0	75.3	Very High
ERNAKULAM	Aluva North [5568]	SILVER CREST-INDOOR FLAT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	SOORYA CANAL	81.0	0.0	42.0	39.0	48.1	Medium
ERNAKULAM	Aluva North [5568]	SOUTHERN STEEL PLANT	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Aluva North [5568]	SPENCERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	SPM APARTMENT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	SPRING DALE	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	SPW	81.0	3.0	77.0	1.0	1.2	Very Low
ERNAKULAM	Aluva North [5568]	SRI KRISHNA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	ST XAVIERS COLLEGE	81.0	60.0	8.0	13.0	16.0	Low
ERNAKULAM	Aluva North [5568]	STEEL LAND	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	SUNNYS HOTEL- INDOOR	255.0	0.0	30.0	225.0	88.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva North [5568]	SURYA LANE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	TAMARIND RAJADHANI FLAT	510.0	0.0	0.0	510.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	TASS ROAD	81.0	0.0	14.9	66.0	81.5	Very High
ERNAKULAM	Aluva North [5568]	TONY FERNANDEZ	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	TOWN LIMITED ROAD	129.0	11.0	78.3	39.7	30.8	Medium
ERNAKULAM	Aluva North [5568]	TYREX	129.0	8.0	76.8	44.2	34.3	Medium
ERNAKULAM	Aluva North [5568]	ULIYANNOOR KADAVU-PULINCHODU	81.0	5.0	29.0	47.0	58.0	High
ERNAKULAM	Aluva North [5568]	ULIYANNOOR MADRASA	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Aluva North [5568]	ULIYANNOOR MANA	129.0	3.0	125.6	0.4	0.3	Very Low
ERNAKULAM	Aluva North [5568]	ULIYANNOOR MASJID	129.0	13.0	115.3	0.7	0.6	Very Low
ERNAKULAM	Aluva North [5568]	ULIYANNOOR NSS JN	51.0	0.0	5.0	46.0	90.2	Very High
ERNAKULAM	Aluva North [5568]	ULIYANNOOR SOCIETY	129.0	2.0	126.8	0.2	0.1	Very Low
ERNAKULAM	Aluva North [5568]	ULIYANNOOR ST REETHA	81.0	21.0	59.0	1.0	1.2	Very Low
ERNAKULAM	Aluva North [5568]	ULIYANNOOR TEMPLE	129.0	11.0	117.7	0.3	0.2	Very Low
ERNAKULAM	Aluva North [5568]	UNI MIDTOWN-INDOOR-FLAT	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	URBAN BANK	81.0	0.0	14.0	67.0	82.7	Very High
ERNAKULAM	Aluva North [5568]	VIDAKUZHA	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Aluva North [5568]	VIDAKUZHA CLUB	81.0	0.0	78.4	2.6	3.2	Very Low
ERNAKULAM	Aluva North [5568]	VISHAL MART	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	YASORAM-FLAT INDOOR	162.0	0.0	0.0	162.0	100.0	Very High
ERNAKULAM	Aluva North [5568]	ZEENU	81.0	38.0	43.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	ABAD AQUABREEZE	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ABAD AQUARIES	405.0	50.0	25.0	330.0	81.5	Very High
ERNAKULAM	Aluva Town [5567]	ABAD VILLAS	255.0	0.0	100.6	154.4	60.6	High
ERNAKULAM	Aluva Town [5567]	ABSON CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ADIVARAM	81.0	10.0	51.9	19.1	23.6	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva Town [5567]	ADIVARAM PUMP	129.0	14.0	74.5	40.5	31.4	Medium
ERNAKULAM	Aluva Town [5567]	AJANTHA	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Aluva Town [5567]	AJL VILLAS	255.0	0.0	119.7	135.3	53.1	High
ERNAKULAM	Aluva Town [5567]	ALPHA MULTIPLAST	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	AMBALACHIRA	81.0	11.0	18.0	52.0	64.2	High
ERNAKULAM	Aluva Town [5567]	AMCO PHARMA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	AMITY INFENIA	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ANAMALA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ANDICOMPANY CANAL	81.0	16.0	60.0	5.0	6.2	Very Low
ERNAKULAM	Aluva Town [5567]	ARJUNA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ARJUNA NATURAL EXTRACTS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ASOKA	129.0	8.0	46.0	75.0	58.1	High
ERNAKULAM	Aluva Town [5567]	ASSET SILVER STREAK	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ASSISI	81.0	13.0	67.3	0.7	0.9	Very Low
ERNAKULAM	Aluva Town [5567]	AYUSH	81.0	14.0	27.0	40.0	49.4	Medium
ERNAKULAM	Aluva Town [5567]	BADANI ASHRAM	81.0	3.0	77.0	1.0	1.2	Very Low
ERNAKULAM	Aluva Town [5567]	BADANI GODOWN	81.0	3.0	74.0	4.0	4.9	Very Low
ERNAKULAM	Aluva Town [5567]	BAGAVATHY TEMPLE	81.0	16.0	63.8	1.2	1.5	Very Low
ERNAKULAM	Aluva Town [5567]	BAZAR	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	BEEBA REGALIA	162.0	0.0	0.0	162.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	BENGLAMKUDI	129.0	18.0	75.3	35.7	27.7	Medium
ERNAKULAM	Aluva Town [5567]	BHARAT MATHA	81.0	0.0	79.1	1.9	2.4	Very Low
ERNAKULAM	Aluva Town [5567]	BOBAN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	BUILD OWN DEVELOPERS	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Aluva Town [5567]	CARMEL	202.0	10.0	79.8	112.2	55.6	High
ERNAKULAM	Aluva Town [5567]	CARMEL CANAL	81.0	3.0	42.0	36.0	44.4	Medium
ERNAKULAM	Aluva Town [5567]	CASINO	129.0	5.0	83.7	40.3	31.3	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva Town [5567]	CASINO THEATRE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	CATHOLIC CENTER	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	CHAKANKULANGARA	81.0	22.0	56.0	3.0	3.7	Very Low
ERNAKULAM	Aluva Town [5567]	CHEMBAKASSERY KADAVU	129.0	8.0	73.3	47.7	37.0	Medium
ERNAKULAM	Aluva Town [5567]	CHOONDY	202.0	28.0	173.4	0.6	0.3	Very Low
ERNAKULAM	Aluva Town [5567]	CHOWARA FERRY	129.0	13.0	89.9	26.1	20.2	Low
ERNAKULAM	Aluva Town [5567]	CHUNAGAMVELI	202.0	18.0	144.6	39.4	19.5	Low
ERNAKULAM	Aluva Town [5567]	CHUNAGAMVELI CHURCH	81.0	14.0	37.0	30.0	37.0	Medium
ERNAKULAM	Aluva Town [5567]	CHUNAGAMVELI MADAM	81.0	10.0	55.0	16.0	19.8	Low
ERNAKULAM	Aluva Town [5567]	CHUNANGAMVELI AUDITORIUM	81.0	0.0	17.0	64.0	79.0	Very High
ERNAKULAM	Aluva Town [5567]	CHUNANGUMVELI TOWER	81.0	8.0	41.3	31.7	39.1	Medium
ERNAKULAM	Aluva Town [5567]	CINTEX	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	CINTEX POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	COCHIN BANK	81.0	0.0	37.0	44.0	54.3	High
ERNAKULAM	Aluva Town [5567]	COLONYPADY	81.0	10.0	13.0	58.0	71.6	High
ERNAKULAM	Aluva Town [5567]	COLONYPADY CHURCH	81.0	28.0	50.0	3.0	3.7	Very Low
ERNAKULAM	Aluva Town [5567]	CSI COMPLEX	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	D2R INTERIORS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	DEEP COLONY	129.0	3.0	36.0	90.0	69.8	High
ERNAKULAM	Aluva Town [5567]	DEEPAM	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	DONBOSCO	81.0	5.0	43.0	33.0	40.7	Medium
ERNAKULAM	Aluva Town [5567]	DONBOSCO PRIEST HOME	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Aluva Town [5567]	DYNAMIC -2	81.0	0.0	4.0	77.0	95.1	Very High
ERNAKULAM	Aluva Town [5567]	DYNAMIC 1	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	DYSP	129.0	8.0	120.1	0.9	0.7	Very Low
ERNAKULAM	Aluva Town [5567]	EDAYAPPURAM NO 2	81.0	0.0	79.0	2.0	2.5	Very Low
ERNAKULAM	Aluva Town [5567]	EDAYAPPURAM NO1	202.0	12.0	100.3	89.7	44.4	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva Town [5567]	EDAYAPPURAM TEMPLE	202.0	44.0	150.7	7.3	3.6	Very Low
ERNAKULAM	Aluva Town [5567]	EDAYAPURAM HEALTH CENTER	81.0	19.0	47.8	14.2	17.5	Low
ERNAKULAM	Aluva Town [5567]	EDAYAPURAM MASJID	81.0	10.0	70.9	0.1	0.1	Very Low
ERNAKULAM	Aluva Town [5567]	ELIZABETH PARK	129.0	6.0	47.0	76.0	58.9	High
ERNAKULAM	Aluva Town [5567]	ERAKKATH	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Aluva Town [5567]	ESSART FOOD	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ETTEKKAR	81.0	0.0	58.3	22.7	28.0	Medium
ERNAKULAM	Aluva Town [5567]	EXAM CENTRE	81.0	5.0	76.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	FATHIMAS	81.0	0.0	81.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	FERN VALLEY	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	FERRIC	202.0	13.0	38.0	151.0	74.8	High
ERNAKULAM	Aluva Town [5567]	GANDHINAGAR	129.0	8.0	120.6	0.4	0.3	Very Low
ERNAKULAM	Aluva Town [5567]	GAS GODOWN	81.0	0.0	98.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	GOVT HOSPITAL COVID	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	GOVT HOSPITAL OLD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	GRAND-MARK	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	GREEN PARK	129.0	3.0	27.0	99.0	76.7	Very High
ERNAKULAM	Aluva Town [5567]	GREEN WORMS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	GTN TEXTILES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	HAROON PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	HORMIS EVENT CENTER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	HOTEL VKJ	129.0	0.0	10.0	119.0	92.2	Very High
ERNAKULAM	Aluva Town [5567]	HYCOUNT	81.0	3.0	0.0	78.0	96.3	Very High
ERNAKULAM	Aluva Town [5567]	I BELL	129.0	0.0	128.9	0.1	0.1	Very Low
ERNAKULAM	Aluva Town [5567]	IMA TRUNK EXCHANGE	202.0	0.0	41.0	161.0	79.7	Very High
ERNAKULAM	Aluva Town [5567]	INDIAN POURAN	81.0	0.0	43.0	38.0	46.9	Medium
ERNAKULAM	Aluva Town [5567]	IRRIGATION	202.0	3.0	86.0	113.0	55.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva Town [5567]	J J POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	JOMOUNT SCHOOL	81.0	5.0	26.0	50.0	61.7	High
ERNAKULAM	Aluva Town [5567]	KADEEJA TOWERS	162.0	0.0	10.0	152.0	93.8	Very High
ERNAKULAM	Aluva Town [5567]	KAIRALI STEELS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	KAIRALY NAGAR	129.0	0.0	80.0	49.0	38.0	Medium
ERNAKULAM	Aluva Town [5567]	KALLUNGAL LANE	81.0	4.0	76.5	0.5	0.7	Very Low
ERNAKULAM	Aluva Town [5567]	KANAKA	129.0	0.0	33.0	96.0	74.4	High
ERNAKULAM	Aluva Town [5567]	KAP	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	KARIYAKKARILLAM	129.0	8.0	104.8	16.2	12.6	Low
ERNAKULAM	Aluva Town [5567]	KAVIL PLASTIC	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Aluva Town [5567]	KAVITHA	129.0	8.0	66.0	55.0	42.6	Medium
ERNAKULAM	Aluva Town [5567]	KEERAMKUNNU	129.0	13.0	91.0	25.0	19.4	Low
ERNAKULAM	Aluva Town [5567]	KODAVATH	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	KODIKUTHUMALA 1	202.0	47.0	154.3	0.7	0.3	Very Low
ERNAKULAM	Aluva Town [5567]	KODIKUTHUMALA-2	129.0	0.0	129.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	KOMPARA	129.0	3.0	56.0	70.0	54.2	High
ERNAKULAM	Aluva Town [5567]	KOOTTANCHERI	129.0	38.0	80.6	10.4	8.1	Very Low
ERNAKULAM	Aluva Town [5567]	KORALIKKAVU	81.0	11.0	70.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	KOTTEKKAD	81.0	3.0	27.0	51.0	63.0	High
ERNAKULAM	Aluva Town [5567]	KP ALIYAR ARCADES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	KRISHIBAVAN	81.0	0.0	22.0	59.0	72.8	High
ERNAKULAM	Aluva Town [5567]	KULAKKADU COLONY	81.0	3.0	11.0	67.0	82.7	Very High
ERNAKULAM	Aluva Town [5567]	KUNNUMPURAM	81.0	11.0	69.8	0.2	0.2	Very Low
ERNAKULAM	Aluva Town [5567]	KWA QUARTERS	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Aluva Town [5567]	L AND T TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	L F SEMINARY	81.0	0.0	50.0	31.0	38.3	Medium
ERNAKULAM	Aluva Town [5567]	LEMON GRASS KST	324.0	0.0	0.0	324.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva Town [5567]	LIC	81.0	0.0	79.2	1.8	2.2	Very Low
ERNAKULAM	Aluva Town [5567]	LIVLONG	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	MADAPPILLYTHAZHAM	81.0	3.0	67.5	10.5	12.9	Low
ERNAKULAM	Aluva Town [5567]	MAHARANI	129.0	0.0	92.2	36.8	28.5	Medium
ERNAKULAM	Aluva Town [5567]	MAHILA SAMAJAM	129.0	5.0	123.8	0.2	0.2	Very Low
ERNAKULAM	Aluva Town [5567]	MAHILALAYAM	129.0	6.0	123.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	MAHILALAYAM PUBLIC SCHOOL	81.0	0.0	25.0	56.0	69.1	High
ERNAKULAM	Aluva Town [5567]	MALAYAKADU	81.0	23.0	46.0	12.0	14.8	Low
ERNAKULAM	Aluva Town [5567]	MANAKKAPADY CHIRA	81.0	3.0	36.0	42.0	51.9	High
ERNAKULAM	Aluva Town [5567]	MANAKKAPPADY	129.0	10.0	88.0	31.0	24.0	Low
ERNAKULAM	Aluva Town [5567]	MANAKKAPPADY CANAL	129.0	12.0	87.0	30.0	23.3	Low
ERNAKULAM	Aluva Town [5567]	MANAKKATHAZHAM	129.0	21.0	101.3	6.7	5.2	Very Low
ERNAKULAM	Aluva Town [5567]	MANAKKATHAZHAM CANAL	81.0	0.0	80.0	1.0	1.2	Very Low
ERNAKULAM	Aluva Town [5567]	MANDRAMPILLY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	MANTHIAPPARA	202.0	57.0	109.5	35.5	17.6	Low
ERNAKULAM	Aluva Town [5567]	MARWAR	129.0	37.0	82.3	9.7	7.5	Very Low
ERNAKULAM	Aluva Town [5567]	MASCO PLAST	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	MATHA	405.0	0.0	10.0	395.0	97.5	Very High
ERNAKULAM	Aluva Town [5567]	MEKKARAM KUNNU	81.0	21.0	57.0	3.0	3.7	Very Low
ERNAKULAM	Aluva Town [5567]	MEZHUKKATTIL 1	202.0	0.0	5.0	197.0	97.5	Very High
ERNAKULAM	Aluva Town [5567]	MEZHUKKATTIL 2	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	MICROWAVE	202.0	10.0	111.3	80.7	39.9	Medium
ERNAKULAM	Aluva Town [5567]	MINI	202.0	0.0	39.0	163.0	80.7	Very High
ERNAKULAM	Aluva Town [5567]	MONASTERY	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	MOOKKAMKURINJI	81.0	18.0	34.3	28.7	35.4	Medium
ERNAKULAM	Aluva Town [5567]	MOOLANS	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Aluva Town [5567]	MRS	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva Town [5567]	MUNICIPALITY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	MUTHIRAKKAD	129.0	16.0	20.0	93.0	72.1	High
ERNAKULAM	Aluva Town [5567]	NATURE KAVALA	81.0	11.0	23.0	47.0	58.0	High
ERNAKULAM	Aluva Town [5567]	NAZERATH MADAM	81.0	19.0	61.3	0.7	0.9	Very Low
ERNAKULAM	Aluva Town [5567]	NEELATHOPE	81.0	4.0	77.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	NEELATHOPE KINAR	81.0	14.0	64.8	2.2	2.7	Very Low
ERNAKULAM	Aluva Town [5567]	NEST VILLAS	648.0	0.0	28.0	620.0	95.7	Very High
ERNAKULAM	Aluva Town [5567]	NGO QUARTERS	81.0	0.0	46.0	35.0	43.2	Medium
ERNAKULAM	Aluva Town [5567]	NIRMALA CONVENT	81.0	5.0	35.9	40.1	49.5	Medium
ERNAKULAM	Aluva Town [5567]	OCHERYVALAVU	129.0	47.0	50.4	31.6	24.5	Low
ERNAKULAM	Aluva Town [5567]	ORBIC	81.0	12.0	13.0	56.0	69.1	High
ERNAKULAM	Aluva Town [5567]	ORCHID HOMES	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	PADAM	129.0	8.0	100.8	20.2	15.7	Low
ERNAKULAM	Aluva Town [5567]	PALLIKKUNNU	129.0	9.0	119.5	0.5	0.4	Very Low
ERNAKULAM	Aluva Town [5567]	PANJICOMPANY	81.0	13.0	32.9	35.1	43.4	Medium
ERNAKULAM	Aluva Town [5567]	PANTHAKKADA 1	202.0	0.0	23.0	179.0	88.6	Very High
ERNAKULAM	Aluva Town [5567]	PANTHAKKADA 2	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	PAREKKATTIL	81.0	13.0	67.3	0.7	0.9	Very Low
ERNAKULAM	Aluva Town [5567]	PEARL TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	PERIYAR BEVERAGE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	PERIYAR RESIDENCY	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	PERIYAR WINDS	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	PERIYARMUGHAM	81.0	6.0	24.0	51.0	63.0	High
ERNAKULAM	Aluva Town [5567]	PHARMACEUTICAL COLLAGE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	PHED	129.0	16.0	40.0	73.0	56.6	High
ERNAKULAM	Aluva Town [5567]	PIPELINE	81.0	14.0	38.7	28.3	34.9	Medium
ERNAKULAM	Aluva Town [5567]	PLATINOPUS	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva Town [5567]	PLAZA	81.0	0.0	59.0	22.0	27.2	Medium
ERNAKULAM	Aluva Town [5567]	POLICE STATION	129.0	3.0	43.5	82.5	63.9	High
ERNAKULAM	Aluva Town [5567]	PORTUINCULA	202.0	5.0	149.4	47.6	23.5	Low
ERNAKULAM	Aluva Town [5567]	POWER HOUSE	202.0	13.0	86.0	103.0	51.0	High
ERNAKULAM	Aluva Town [5567]	PRANAMAM	81.0	0.0	55.5	25.5	31.4	Medium
ERNAKULAM	Aluva Town [5567]	PRIYADARSINI	129.0	39.0	80.0	10.0	7.7	Very Low
ERNAKULAM	Aluva Town [5567]	RAILWAY STATION 2	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Aluva Town [5567]	RAILWAY STATION NO 1	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	RANGASAYEES	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Aluva Town [5567]	RATIONKADA KAVALA	81.0	3.0	21.0	57.0	70.4	High
ERNAKULAM	Aluva Town [5567]	RELIANCE JIO	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ROYAL CASTLE	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	S D CONVENT	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	S D GENERALATE	81.0	0.0	31.0	50.0	61.7	High
ERNAKULAM	Aluva Town [5567]	S N GIRI	81.0	0.0	36.0	45.0	55.6	High
ERNAKULAM	Aluva Town [5567]	S N LIBRARY	81.0	3.0	13.0	65.0	80.2	Very High
ERNAKULAM	Aluva Town [5567]	S N PURAM	129.0	11.0	44.5	73.5	57.0	High
ERNAKULAM	Aluva Town [5567]	SAFE SYSTEM	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	SAHALA POLYMER	81.0	11.0	68.0	2.0	2.5	Very Low
ERNAKULAM	Aluva Town [5567]	SANTHIDAM	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Aluva Town [5567]	SHARAFIYA POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	SIA PLASTICS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	SINAI VILLAS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	SIRAJ NAGAR	129.0	11.0	48.5	69.5	53.9	High
ERNAKULAM	Aluva Town [5567]	SIVAGIRI	81.0	7.0	73.3	0.7	0.9	Very Low
ERNAKULAM	Aluva Town [5567]	SKYLINE	324.0	0.0	25.0	299.0	92.3	Very High
ERNAKULAM	Aluva Town [5567]	SKYRE HOMES	324.0	0.0	5.0	319.0	98.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva Town [5567]	SN PACKAGE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	SNEHALAYAM	81.0	0.0	80.0	1.0	1.2	Very Low
ERNAKULAM	Aluva Town [5567]	SOCIAL	81.0	0.0	81.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	SOCIETYPADY NO 1	202.0	8.0	83.0	111.0	54.9	High
ERNAKULAM	Aluva Town [5567]	SOCIETYPADY NO2 TOWER	81.0	12.0	29.0	40.0	49.4	Medium
ERNAKULAM	Aluva Town [5567]	SOS NO-1	81.0	13.0	68.0	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	SOS NO-2	81.0	8.0	23.0	50.0	61.7	High
ERNAKULAM	Aluva Town [5567]	SOUMYA PLASTIC	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	SOUTH HILL	81.0	0.0	47.0	34.0	42.0	Medium
ERNAKULAM	Aluva Town [5567]	SOUTH HILL VILLAS	81.0	7.7	73.3	0.0	0.0	Very Low
ERNAKULAM	Aluva Town [5567]	SRUTHI	129.0	0.0	36.4	92.7	71.8	High
ERNAKULAM	Aluva Town [5567]	ST FRANCIS CONVENT	81.0	0.0	24.8	56.2	69.4	High
ERNAKULAM	Aluva Town [5567]	ST MARYS	801.0	14.0	76.0	711.0	88.8	Very High
ERNAKULAM	Aluva Town [5567]	STAR VILLAGE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	SURYA TOWER	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	TALENT	81.0	8.0	38.0	35.0	43.2	Medium
ERNAKULAM	Aluva Town [5567]	THOPPIL APSARA MANOR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	THORAPPU	129.0	20.0	27.2	81.8	63.4	High
ERNAKULAM	Aluva Town [5567]	THOTTUMUGHAM	255.0	30.0	194.7	30.3	11.9	Low
ERNAKULAM	Aluva Town [5567]	THURUTHIYIL LANE	81.0	35.0	44.0	2.0	2.5	Very Low
ERNAKULAM	Aluva Town [5567]	TOWN HALL	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	UNI HOMES RIVER HEIGHTS	324.0	0.0	10.0	314.0	96.9	Very High
ERNAKULAM	Aluva Town [5567]	UNIVERSAL TIMBER	81.0	10.0	54.0	17.0	21.0	Low
ERNAKULAM	Aluva Town [5567]	UNNIMADOM	81.0	35.0	44.7	1.3	1.6	Very Low
ERNAKULAM	Aluva Town [5567]	URUMBATH	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	VAYAMPURA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	VELTON	202.0	13.0	32.3	156.7	77.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva Town [5567]	VETINARY	129.0	10.0	117.0	2.0	1.6	Very Low
ERNAKULAM	Aluva Town [5567]	VIMAL JYOTI	81.0	0.0	56.8	24.2	29.9	Medium
ERNAKULAM	Aluva Town [5567]	WATER AUTHORITY	81.0	0.0	29.0	52.0	64.2	High
ERNAKULAM	Aluva Town [5567]	YASH SQUARE	202.0	0.0	25.0	177.0	87.6	Very High
ERNAKULAM	Aluva Town [5567]	YMCA -2	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Aluva Town [5567]	YMCA-1	129.0	0.0	28.5	100.5	77.9	Very High
ERNAKULAM	Aluva Town [5567]	YUVADEEPTHI	81.0	5.0	24.0	52.0	64.2	High
ERNAKULAM	Aluva Town [5567]	ZAH1 RUBBERS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva Town [5567]	ZEENATH	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	ABY ECO GARDEN	162.0	0.0	25.0	137.0	84.6	Very High
ERNAKULAM	Aluva West [5569]	ADUVATHURUTH	202.0	0.0	27.2	174.8	86.5	Very High
ERNAKULAM	Aluva West [5569]	ADUVATHURUTH 4CENT	81.0	3.0	16.0	62.0	76.5	Very High
ERNAKULAM	Aluva West [5569]	ADUVATHURUTH BUS STAND	129.0	27.0	78.3	23.7	18.4	Low
ERNAKULAM	Aluva West [5569]	AKASALA	202.0	0.0	3.0	199.0	98.5	Very High
ERNAKULAM	Aluva West [5569]	AKKATU LANE	81.0	5.0	61.2	14.8	18.2	Low
ERNAKULAM	Aluva West [5569]	ALTHARA	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Aluva West [5569]	AMBADY GREEN MEADOWS	202.0	0.0	22.1	179.9	89.1	Very High
ERNAKULAM	Aluva West [5569]	AMPLE MALIKA ELOOKARA	324.0	0.0	15.0	309.0	95.4	Very High
ERNAKULAM	Aluva West [5569]	ANTISON	81.0	0.0	64.0	17.0	21.0	Low
ERNAKULAM	Aluva West [5569]	APPLE TOWERS	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	AQUACITY DUAL CORE	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	AQUACITY MAGIC LILLY	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	AQUACITY MOON WATER	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	AQUACITY PALM BAY VILLA	202.0	0.0	13.0	189.0	93.6	Very High
ERNAKULAM	Aluva West [5569]	AQUACITY TETRACORE-22	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	AQUACITY TRICORE-22	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	ARAVINDAN	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva West [5569]	AREEPADAM	129.0	21.0	61.0	47.0	36.4	Medium
ERNAKULAM	Aluva West [5569]	ASSET BAY	129.0	0.0	20.0	109.0	84.5	Very High
ERNAKULAM	Aluva West [5569]	ATTIPUZHA	81.0	8.0	41.3	31.7	39.1	Medium
ERNAKULAM	Aluva West [5569]	AUTO BAHN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	AUTUMN WOODS VILLAS MAMBRA	255.0	0.0	13.5	241.5	94.7	Very High
ERNAKULAM	Aluva West [5569]	BBC	129.0	5.0	52.0	72.0	55.8	High
ERNAKULAM	Aluva West [5569]	BBC CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	BBC PIPES	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	BISCUIT	129.0	8.0	120.9	0.1	0.1	Very Low
ERNAKULAM	Aluva West [5569]	BLUE BERRY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	CARMEL GIRI	81.0	0.0	12.0	69.0	85.2	Very High
ERNAKULAM	Aluva West [5569]	CENTURY	81.0	16.0	27.1	37.9	46.8	Medium
ERNAKULAM	Aluva West [5569]	CHACKO HOMES	129.0	0.0	20.0	109.0	84.5	Very High
ERNAKULAM	Aluva West [5569]	CHAMAPARAMB	202.0	21.0	118.4	62.6	31.0	Medium
ERNAKULAM	Aluva West [5569]	CHATTUKULAM	81.0	3.0	76.7	1.3	1.6	Very Low
ERNAKULAM	Aluva West [5569]	CHEMBIKKAD	129.0	10.0	69.3	49.7	38.5	Medium
ERNAKULAM	Aluva West [5569]	CHENGAMATHA	129.0	3.0	124.5	1.5	1.1	Very Low
ERNAKULAM	Aluva West [5569]	CHERTHANAD	129.0	3.0	29.5	96.5	74.8	High
ERNAKULAM	Aluva West [5569]	CHIRANGARA TEMPLE	81.0	11.0	70.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	CMRL	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	CONFIDENT OBERON ALANGAD	510.0	0.0	0.0	510.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	CONVENT ROAD	81.0	15.0	64.0	2.0	2.5	Very Low
ERNAKULAM	Aluva West [5569]	CRESCENT FURNITURE KANIPADY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	CRIME BRANCH	801.0	16.0	133.2	651.8	81.4	Very High
ERNAKULAM	Aluva West [5569]	CROSSBAR JUNCTION	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Aluva West [5569]	DREAM FLOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	DZIRE SYMPHONY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva West [5569]	E KADUNGALLOOR CANAL BUNT	81.0	2.0	78.9	0.1	0.1	Very Low
ERNAKULAM	Aluva West [5569]	EAST KADUNGALLOOR	81.0	0.0	81.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	ELOOKARA FERRY	129.0	15.0	106.3	7.7	6.0	Very Low
ERNAKULAM	Aluva West [5569]	ELOOKARA MAZJID JUNCTION	129.0	23.0	106.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	ELOOKARA PUMP HOUSE	202.0	0.0	60.0	142.0	70.3	High
ERNAKULAM	Aluva West [5569]	ELOOKKARA SPICES	129.0	60.0	0.0	69.0	53.5	High
ERNAKULAM	Aluva West [5569]	EMPIR HEIGHTS	202.0	10.0	0.0	192.0	95.0	Very High
ERNAKULAM	Aluva West [5569]	EXCHANGE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	FEDERAL GREEN MARIAPADY	648.0	0.0	30.0	618.0	95.4	Very High
ERNAKULAM	Aluva West [5569]	FEDERAL-ELOOKARA NO-1	324.0	5.0	0.0	319.0	98.5	Very High
ERNAKULAM	Aluva West [5569]	FEDERAL-ELOOKARA NO-2	324.0	15.0	0.0	309.0	95.4	Very High
ERNAKULAM	Aluva West [5569]	FISHERIES	81.0	2.0	79.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	FISHERIES AQUA VENTURE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	GCDA AYURVEDA	81.0	0.0	81.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	GCDA HOLLY GHOST	81.0	0.0	80.9	0.1	0.1	Very Low
ERNAKULAM	Aluva West [5569]	GCDA WOMENS COLLEGE	81.0	3.0	75.6	2.4	3.0	Very Low
ERNAKULAM	Aluva West [5569]	GOOD PEOPLE FLAT	129.0	5.0	78.5	45.5	35.3	Medium
ERNAKULAM	Aluva West [5569]	GREEN LEAVES FLAT	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	HACIENDA VAYALAKAD	810.0	0.0	0.0	810.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	HAG ARCHADE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	HILLWAYLANE	81.0	20.0	43.0	18.0	22.2	Low
ERNAKULAM	Aluva West [5569]	HOUSING BOARD	129.0	3.0	8.0	118.0	91.5	Very High
ERNAKULAM	Aluva West [5569]	JACOBITE	129.0	5.0	123.8	0.2	0.1	Very Low
ERNAKULAM	Aluva West [5569]	JAI HIND	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Aluva West [5569]	JAYANTHI WORKSHOP	81.0	11.0	69.8	0.2	0.2	Very Low
ERNAKULAM	Aluva West [5569]	JEGAN CHACKO GODOWN	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	JYOTHI NIVAS SCHOOL	129.0	0.0	40.0	89.0	69.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva West [5569]	KACHERIKADAVU	81.0	10.0	39.0	32.0	39.5	Medium
ERNAKULAM	Aluva West [5569]	KADEPILLY	81.0	6.0	58.8	16.2	20.0	Low
ERNAKULAM	Aluva West [5569]	KADEPPILLY THOPPIL	129.0	24.0	89.3	15.7	12.2	Low
ERNAKULAM	Aluva West [5569]	KADOPADAM	129.0	8.0	119.0	2.0	1.6	Very Low
ERNAKULAM	Aluva West [5569]	KADUNGALLOOR TEMPLE	202.0	17.0	153.4	31.6	15.6	Low
ERNAKULAM	Aluva West [5569]	KADUNGALLOOR TIMBER	202.0	3.0	112.0	87.0	43.1	Medium
ERNAKULAM	Aluva West [5569]	KALYANI MANDIRAM	81.0	3.0	37.5	40.5	50.0	Medium
ERNAKULAM	Aluva West [5569]	KANIPADY	129.0	16.0	57.1	55.9	43.3	Medium
ERNAKULAM	Aluva West [5569]	KANIYAMKUNNU THAIKAVU	81.0	0.0	81.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	KANIYANKUNNU	202.0	16.0	98.2	87.8	43.5	Medium
ERNAKULAM	Aluva West [5569]	KARUKUNNU	81.0	0.0	80.2	0.8	1.0	Very Low
ERNAKULAM	Aluva West [5569]	KAVALA CASTLE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	KAVERI	81.0	5.0	20.0	56.0	69.1	High
ERNAKULAM	Aluva West [5569]	KEERAPILLY	81.0	0.0	29.0	52.0	64.2	High
ERNAKULAM	Aluva West [5569]	KILIKAR	81.0	17.0	62.5	1.5	1.8	Very Low
ERNAKULAM	Aluva West [5569]	KINDER JOY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	KORAPPALLAM	81.0	15.0	35.0	31.0	38.3	Medium
ERNAKULAM	Aluva West [5569]	KUNDELI	81.0	15.0	64.3	1.7	2.1	Very Low
ERNAKULAM	Aluva West [5569]	KUNNELPALLY	81.0	11.0	45.0	25.0	30.9	Medium
ERNAKULAM	Aluva West [5569]	L P SCHOOL	129.0	0.0	127.9	1.1	0.9	Very Low
ERNAKULAM	Aluva West [5569]	LAVENDER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	LIVIT HARMONY	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	MADATHIL LANE	81.0	0.0	80.0	1.0	1.2	Very Low
ERNAKULAM	Aluva West [5569]	MADHURYA	510.0	0.0	5.0	505.0	99.0	Very High
ERNAKULAM	Aluva West [5569]	MALIKAMPEEDIKA	202.0	22.0	98.4	81.6	40.4	Medium
ERNAKULAM	Aluva West [5569]	MALIKAMPEEDIKA CHIRANGARA ROAD	81.0	19.0	61.6	0.4	0.4	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva West [5569]	MAMBRA	129.0	14.0	114.8	0.2	0.1	Very Low
ERNAKULAM	Aluva West [5569]	MANADATH	810.0	0.0	0.0	810.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	MANAKKALETHETTA	81.0	5.0	18.0	58.0	71.6	High
ERNAKULAM	Aluva West [5569]	MANALANE	81.0	4.6	70.3	6.1	7.5	Very Low
ERNAKULAM	Aluva West [5569]	MANAPPURAM	81.0	7.0	49.0	25.0	30.9	Medium
ERNAKULAM	Aluva West [5569]	MANELIPADI	129.0	23.0	95.0	11.0	8.5	Very Low
ERNAKULAM	Aluva West [5569]	MANGALAPUZHA	81.0	0.0	81.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	MANJOORAN RIVERINE VILLAS	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	MARIYAPPADY CURVE	81.0	29.0	51.5	0.5	0.6	Very Low
ERNAKULAM	Aluva West [5569]	MATHER GREEN RANCH	81.0	20.0	0.0	61.0	75.3	Very High
ERNAKULAM	Aluva West [5569]	MATTOOPADY	129.0	15.0	49.0	65.0	50.4	High
ERNAKULAM	Aluva West [5569]	MAYURA PERIYAR VIEW	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	MCBS	129.0	9.0	61.3	58.7	45.5	Medium
ERNAKULAM	Aluva West [5569]	MELAM MASALA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	MELODY APPARTMENTS	255.0	0.0	0.0	255.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	MENACHERI	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	MILLUPADI	129.0	32.0	97.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	MOOLEPEEDIKA	81.0	8.0	73.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	MT LINK ROAD	202.0	41.0	151.9	9.1	4.5	Very Low
ERNAKULAM	Aluva West [5569]	MULLAKKAL-CHERIYATH	81.0	31.3	27.0	22.7	28.0	Medium
ERNAKULAM	Aluva West [5569]	MULLEPPILLY	129.0	13.0	96.3	19.7	15.2	Low
ERNAKULAM	Aluva West [5569]	MV BRIDGE	202.0	0.0	37.8	164.2	81.3	Very High
ERNAKULAM	Aluva West [5569]	MY HOMES	81.0	0.0	38.0	43.0	53.1	High
ERNAKULAM	Aluva West [5569]	NATIONAL GRANITE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	ONE AND EYE ONLY KANIPADY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	OVA-JALEEL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	OXONIYA	510.0	0.0	30.0	480.0	94.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva West [5569]	PARANA	129.0	18.0	102.7	8.3	6.5	Very Low
ERNAKULAM	Aluva West [5569]	PARAVOOR JN	202.0	10.0	172.1	19.9	9.8	Very Low
ERNAKULAM	Aluva West [5569]	PARUVAKKAD	81.0	10.0	34.3	36.7	45.3	Medium
ERNAKULAM	Aluva West [5569]	PERIKAPALAM	129.0	5.0	123.0	1.0	0.8	Very Low
ERNAKULAM	Aluva West [5569]	PERIKAPALAM CANAL	129.0	0.0	128.5	0.5	0.4	Very Low
ERNAKULAM	Aluva West [5569]	PERIYAR BANKS	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	PERIYAR SCAPE	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	PERIYAR VIEW CHERIYATH	202.0	0.0	10.0	192.0	95.0	Very High
ERNAKULAM	Aluva West [5569]	PETRONET	51.0	0.0	0.0	51.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	POPULAR	81.0	0.0	17.8	63.2	78.0	Very High
ERNAKULAM	Aluva West [5569]	POPULAR TATA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	POSITIVE ASSOCIATES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	PRATHIBHA APARTMENT	81.0	3.4	35.0	42.6	52.5	High
ERNAKULAM	Aluva West [5569]	RAJASREE SCHOOL	81.0	8.0	51.0	22.0	27.2	Medium
ERNAKULAM	Aluva West [5569]	RASHEEDA ROYAL VILLA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	RATION SHOP	129.0	0.0	128.7	0.3	0.2	Very Low
ERNAKULAM	Aluva West [5569]	RB IMPERIAL	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	RELIANCE MALIKAMPEEDIKA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	RM HOMES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	ROYAL NEST	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	SANTHI LANE	81.0	16.0	34.0	31.0	38.3	Medium
ERNAKULAM	Aluva West [5569]	SAPHIRE	129.0	0.0	5.0	124.0	96.1	Very High
ERNAKULAM	Aluva West [5569]	SASTHRI LANE	81.0	0.0	81.0	0.0	0.0	Very Low
ERNAKULAM	Aluva West [5569]	SEMINARYPADI	129.0	30.0	96.3	2.7	2.1	Very Low
ERNAKULAM	Aluva West [5569]	SETTLEMENT	202.0	19.0	86.3	96.7	47.9	Medium
ERNAKULAM	Aluva West [5569]	SIDHIVINAYAKA	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	SIMILIYA	81.0	24.0	56.0	1.0	1.2	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva West [5569]	SN PRESS ARJUNA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	SN PRESS NH	81.0	3.0	52.0	26.0	32.1	Medium
ERNAKULAM	Aluva West [5569]	SN PRESS SURYA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	SNDP	129.0	14.0	57.3	57.7	44.7	Medium
ERNAKULAM	Aluva West [5569]	SNEHANAGAR	129.0	0.0	84.5	44.5	34.5	Medium
ERNAKULAM	Aluva West [5569]	SOCIETY ROAD	81.0	19.0	33.9	28.1	34.7	Medium
ERNAKULAM	Aluva West [5569]	SODA COMPANY	81.0	18.0	61.9	1.1	1.4	Very Low
ERNAKULAM	Aluva West [5569]	SUDEERGOPI	81.0	15.0	35.0	31.0	38.3	Medium
ERNAKULAM	Aluva West [5569]	SUMMER NEST APPARTMENT	202.0	0.0	20.0	182.0	90.1	Very High
ERNAKULAM	Aluva West [5569]	TERRAFIRM MAMBRA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	THADIKKAKADAVU IRRIGATION	202.0	0.0	6.0	196.0	97.0	Very High
ERNAKULAM	Aluva West [5569]	THADIKKAKKADAVU	202.0	0.0	60.0	142.0	70.3	High
ERNAKULAM	Aluva West [5569]	THADIKKAKKADAVU MADRASSA	81.0	0.0	40.0	41.0	50.6	High
ERNAKULAM	Aluva West [5569]	THADIKKAKKADAVU MASJID	81.0	17.0	63.6	0.4	0.5	Very Low
ERNAKULAM	Aluva West [5569]	THADIRIKKAL	81.0	0.0	74.4	6.6	8.1	Very Low
ERNAKULAM	Aluva West [5569]	THIRUVALLORE	129.0	10.0	98.9	20.1	15.6	Low
ERNAKULAM	Aluva West [5569]	THOTTAKKATTUKARA	801.0	0.0	150.4	650.6	81.2	Very High
ERNAKULAM	Aluva West [5569]	THOTTAKKATTUKARA JUMAH MASJID	81.0	0.0	79.9	1.1	1.4	Very Low
ERNAKULAM	Aluva West [5569]	TRI AMITY	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	TRUMB MARVEL	81.0	0.0	80.0	1.0	1.3	Very Low
ERNAKULAM	Aluva West [5569]	TULSI BLU RAIN	324.0	0.0	25.2	298.8	92.2	Very High
ERNAKULAM	Aluva West [5569]	UC COLLEGE	202.0	0.0	62.6	139.4	69.0	High
ERNAKULAM	Aluva West [5569]	V H COLANY	81.0	6.0	62.0	13.0	16.0	Low
ERNAKULAM	Aluva West [5569]	VALIYARA U C	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Aluva West [5569]	VALLYAPPAN PADY	81.0	3.0	73.7	4.3	5.3	Very Low
ERNAKULAM	Aluva West [5569]	VAYALAKKAD	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Aluva West [5569]	VAYALODAM	129.0	26.0	88.0	15.0	11.6	Low
ERNAKULAM	Aluva West [5569]	VELAMPARAMBU	129.0	5.0	62.0	62.0	48.1	Medium
ERNAKULAM	Aluva West [5569]	VESCOOPS	81.0	0.0	50.0	31.0	38.3	Medium
ERNAKULAM	Aluva West [5569]	VETTUVELI	81.0	15.0	51.0	15.0	18.5	Low
ERNAKULAM	Aluva West [5569]	VIDYABHAVAN	81.0	4.0	62.4	14.6	18.0	Low
ERNAKULAM	Aluva West [5569]	VRINDAVAN	81.0	5.0	74.5	1.6	1.9	Very Low
ERNAKULAM	Aluva West [5569]	WELFARE TRUST	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Amballoor [5552]	AIRTEL	129.0	0.0	43.0	86.0	66.7	High
ERNAKULAM	Amballoor [5552]	AKKAPPANAM	81.0	6.0	55.3	19.7	24.3	Low
ERNAKULAM	Amballoor [5552]	AMBEDKAR COLONY	81.0	32.0	36.0	13.0	16.0	Low
ERNAKULAM	Amballoor [5552]	ARAYANKAVU	129.0	10.0	70.0	49.0	38.0	Medium
ERNAKULAM	Amballoor [5552]	BHARATHI	81.0	3.0	24.7	53.3	65.8	High
ERNAKULAM	Amballoor [5552]	BLOCK	81.0	0.0	29.0	52.0	64.2	High
ERNAKULAM	Amballoor [5552]	BSNL	81.0	11.0	68.3	1.7	2.1	Very Low
ERNAKULAM	Amballoor [5552]	CHALAKKAPARA	81.0	11.0	44.0	26.0	32.1	Medium
ERNAKULAM	Amballoor [5552]	CHITTETHUKATTI	129.0	30.3	77.0	21.7	16.8	Low
ERNAKULAM	Amballoor [5552]	EDAVATTOM	81.0	15.0	39.0	27.0	33.3	Medium
ERNAKULAM	Amballoor [5552]	GAMA	81.0	3.0	26.0	52.0	64.2	High
ERNAKULAM	Amballoor [5552]	IDEA	81.0	14.0	35.0	32.0	39.5	Medium
ERNAKULAM	Amballoor [5552]	INDUSTRIAL ESTATE	81.0	11.0	19.4	50.6	62.5	High
ERNAKULAM	Amballoor [5552]	KAITHRI	81.0	13.0	51.0	17.0	21.0	Low
ERNAKULAM	Amballoor [5552]	KAMILARI	81.0	0.0	19.0	62.0	76.5	Very High
ERNAKULAM	Amballoor [5552]	KANJIRAMATTOM CENTRE	129.0	0.0	42.1	86.9	67.3	High
ERNAKULAM	Amballoor [5552]	KOOTTEKKAVU	129.0	16.0	106.3	6.7	5.2	Very Low
ERNAKULAM	Amballoor [5552]	KOTTAPURAM	81.0	17.0	38.3	25.7	31.7	Medium
ERNAKULAM	Amballoor [5552]	KULAYETTIKKARA	81.0	5.0	13.0	63.0	77.8	Very High
ERNAKULAM	Amballoor [5552]	KUNNAMKULAM PSS	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Amballoor [5552]	MALEPALLY	81.0	3.0	58.0	20.0	24.7	Low
ERNAKULAM	Amballoor [5552]	MAMPUZHA	81.0	3.0	28.7	49.3	60.9	High
ERNAKULAM	Amballoor [5552]	MANAKATHAZHAM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Amballoor [5552]	MANIKANAMPARAMBIL	81.0	0.0	80.0	1.0	1.2	Very Low
ERNAKULAM	Amballoor [5552]	MANNARVELI	81.0	9.0	43.0	29.0	35.8	Medium
ERNAKULAM	Amballoor [5552]	MANTHURUTH	81.0	0.0	55.0	26.0	32.1	Medium
ERNAKULAM	Amballoor [5552]	MARITHAZHAM	81.0	8.0	14.0	59.0	72.8	High
ERNAKULAM	Amballoor [5552]	MELOTH	81.0	0.0	62.0	19.0	23.5	Low
ERNAKULAM	Amballoor [5552]	MILMA	129.0	0.0	131.8	0.0	0.0	Very Low
ERNAKULAM	Amballoor [5552]	MITHRA PURAM	81.0	28.0	32.9	20.1	24.8	Low
ERNAKULAM	Amballoor [5552]	MOSQUE	129.0	12.0	67.8	49.2	38.1	Medium
ERNAKULAM	Amballoor [5552]	NAZEER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Amballoor [5552]	NEDUVELIKKUNNU	81.0	6.0	36.3	38.7	47.8	Medium
ERNAKULAM	Amballoor [5552]	NEERPARA	81.0	8.0	18.0	55.0	67.9	High
ERNAKULAM	Amballoor [5552]	OLD PANCHAYATH	129.0	3.0	124.3	1.7	1.3	Very Low
ERNAKULAM	Amballoor [5552]	OLIPURAM	81.0	4.0	11.0	66.0	81.5	Very High
ERNAKULAM	Amballoor [5552]	PADATHUKAVU	81.0	8.0	67.3	5.7	7.0	Very Low
ERNAKULAM	Amballoor [5552]	PADEES PALAM	81.0	23.0	10.0	48.0	59.3	High
ERNAKULAM	Amballoor [5552]	PALLIYANTHADAM	81.0	3.0	43.3	34.7	42.8	Medium
ERNAKULAM	Amballoor [5552]	PANAR PALAM	129.0	23.0	71.0	35.0	27.1	Medium
ERNAKULAM	Amballoor [5552]	PANDIYALIL	81.0	22.0	49.0	10.0	12.3	Low
ERNAKULAM	Amballoor [5552]	PARAKKAVELI	81.0	0.0	38.5	42.5	52.4	High
ERNAKULAM	Amballoor [5552]	PARAPURATH	81.0	19.0	44.6	17.4	21.5	Low
ERNAKULAM	Amballoor [5552]	PATHADY	81.0	0.0	57.3	23.7	29.3	Medium
ERNAKULAM	Amballoor [5552]	PATHIKKAL	81.0	10.0	38.0	33.0	40.7	Medium
ERNAKULAM	Amballoor [5552]	PATTAPADY	129.0	21.0	67.0	41.0	31.8	Medium
ERNAKULAM	Amballoor [5552]	PAVI INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Amballoor [5552]	PERUMPILLY CHURCH	129.0	13.0	81.0	35.0	27.1	Medium
ERNAKULAM	Amballoor [5552]	PERUMPILLY NADA	129.0	19.0	83.0	27.0	20.9	Low
ERNAKULAM	Amballoor [5552]	POYYATTITHAZHAM	81.0	0.0	27.0	54.0	66.7	High
ERNAKULAM	Amballoor [5552]	PUTHIYA PANCHAYATH	81.0	11.0	67.3	2.7	3.3	Very Low
ERNAKULAM	Amballoor [5552]	RAILWAY STATION	129.0	0.0	128.9	0.1	0.1	Very Low
ERNAKULAM	Amballoor [5552]	RELIANCE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Amballoor [5552]	RUPESH	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Amballoor [5552]	S N D P EAST	81.0	3.0	56.0	22.0	27.2	Medium
ERNAKULAM	Amballoor [5552]	SAKTHIKAVU	81.0	16.0	62.5	2.5	3.1	Very Low
ERNAKULAM	Amballoor [5552]	SASTHA	81.0	3.0	23.0	55.0	67.9	High
ERNAKULAM	Amballoor [5552]	SHASTHAMKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Amballoor [5552]	SNDP	129.0	5.0	65.0	59.0	45.7	Medium
ERNAKULAM	Amballoor [5552]	SOUTH INDIAN BANK	81.0	5.0	22.0	54.0	66.7	High
ERNAKULAM	Amballoor [5552]	ST GEORGE	81.0	3.0	50.3	27.7	34.2	Medium
ERNAKULAM	Amballoor [5552]	SUBEESH	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Amballoor [5552]	THONDILANGADI	129.0	8.0	42.8	78.2	60.6	High
ERNAKULAM	Amballoor [5552]	THOTTARA CHURCH	81.0	8.0	22.0	51.0	63.0	High
ERNAKULAM	Amballoor [5552]	UZHUTHWAMANA	129.0	19.0	76.0	34.0	26.4	Medium
ERNAKULAM	Amballoor [5552]	VELIPALAM	81.0	11.0	50.0	20.0	24.7	Low
ERNAKULAM	Amballoor [5552]	VELLUTHAMKUNNU	81.0	0.0	41.0	40.0	49.4	Medium
ERNAKULAM	Amballoor [5552]	VILLAGE GARDEN	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Amballoor [5552]	VINEETH	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Amballoor [5552]	WITFIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Amballoor [5552]	ZRAMKUZHI	81.0	25.0	26.0	30.0	37.0	Medium
ERNAKULAM	Angamaly [5579]	ADAM PUBLIC SCHOOL	81.0	27.3	44.0	9.7	12.0	Low
ERNAKULAM	Angamaly [5579]	AG-ICE PLANT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	AGRO TREET	60.0	0.0	0.0	60.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Angamaly [5579]	AIRPORT ROAD	81.0	8.0	3.0	70.0	86.4	Very High
ERNAKULAM	Angamaly [5579]	AKAY RUBBER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	AL AMEEN	81.0	0.0	60.0	21.0	25.9	Medium
ERNAKULAM	Angamaly [5579]	ALAPPATT SQUARE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ALIBABA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ALL PURPOSE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ALPHA-INDUSTIRES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ALUVAROAD	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ANGADIKADAV	202.0	11.0	35.6	155.4	76.9	Very High
ERNAKULAM	Angamaly [5579]	ANGADIKADAVU KAPELLA	81.0	8.0	59.0	14.0	17.3	Low
ERNAKULAM	Angamaly [5579]	ANNAS BAKERY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ANNIE	81.0	8.0	22.3	50.7	62.6	High
ERNAKULAM	Angamaly [5579]	ANTU	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	APPACHAN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	APPLE BREAD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ARUNODHAYAM	129.0	0.0	15.0	114.0	88.4	Very High
ERNAKULAM	Angamaly [5579]	ASSOCIATED RUBBER	81.0	80.0	0.0	1.0	1.2	Very Low
ERNAKULAM	Angamaly [5579]	ASWATHY HEAT TECH	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ATHAPPILLYKAVALA RAPDRP	81.0	16.0	55.2	9.8	12.1	Low
ERNAKULAM	Angamaly [5579]	B COLONY CABLE	81.0	0.0	34.0	47.0	58.0	High
ERNAKULAM	Angamaly [5579]	BAMBOO	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Angamaly [5579]	BASANT	129.0	3.0	125.4	0.6	0.5	Very Low
ERNAKULAM	Angamaly [5579]	BEST VINYL	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	BEXLEY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	BHADRA APPARTMENT	202.0	0.0	23.0	179.0	88.6	Very High
ERNAKULAM	Angamaly [5579]	BHAVANA NAGAR CABLE	81.0	0.0	80.3	0.7	0.9	Very Low
ERNAKULAM	Angamaly [5579]	BINDU SASIKUMAR	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Angamaly [5579]	BINOY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	BISMI	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	BLIND	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	BLUE BELL	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	BLUE STAR	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	BOVANS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	CANCORE COLONY	81.0	4.0	76.8	0.2	0.3	Very Low
ERNAKULAM	Angamaly [5579]	CAR WASH	81.0	0.0	32.5	48.5	59.8	High
ERNAKULAM	Angamaly [5579]	CASA SERENA	129.0	0.0	10.0	119.0	92.2	Very High
ERNAKULAM	Angamaly [5579]	CENTRAL BANK	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Angamaly [5579]	CHACOLA COLONY	81.0	0.0	42.0	39.0	48.1	Medium
ERNAKULAM	Angamaly [5579]	CHAKKARAPARAMB	81.0	3.0	76.7	1.3	1.7	Very Low
ERNAKULAM	Angamaly [5579]	CHANDY KAVALA	129.0	5.2	123.8	0.0	0.0	Very Low
ERNAKULAM	Angamaly [5579]	CHENGAI	81.0	0.0	43.0	38.0	46.9	Medium
ERNAKULAM	Angamaly [5579]	CHIC KING	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	CITY TOWER	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Angamaly [5579]	CLASSIC CONCRETE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	COLOUR PLUS	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	CONCERT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	CONCORD	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	COSMO PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	CVR	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Angamaly [5579]	CVR NEW	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	DAMODAR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	DECCAN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	DEEPTHI GRAMAM	81.0	3.0	76.9	1.1	1.4	Very Low
ERNAKULAM	Angamaly [5579]	DELTA CENTRE	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Angamaly [5579]	DELUX CARTONS	129.0	3.0	8.3	117.7	91.2	Very High
ERNAKULAM	Angamaly [5579]	DOCTORS DIAMOND HILL	129.0	0.0	5.0	124.0	96.1	Very High
ERNAKULAM	Angamaly [5579]	DON BOSCO	81.0	3.0	55.0	23.0	28.4	Medium
ERNAKULAM	Angamaly [5579]	DONBOSCO SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	DOUBLE PALAM	81.0	15.0	65.5	0.6	0.7	Very Low
ERNAKULAM	Angamaly [5579]	DUROLAC	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	E V CHARGING STATION	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	EAST CHURCH	129.0	5.0	122.6	1.4	1.1	Very Low
ERNAKULAM	Angamaly [5579]	EDACHERIL CORNER	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	EDACHERY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	EDAPPARA	129.0	2.0	83.0	44.0	34.1	Medium
ERNAKULAM	Angamaly [5579]	EDEN NAGAR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ELCION	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ELITE	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	EME EXPORTS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	EMJAY TOWER	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ESI	202.0	0.0	113.8	88.2	43.7	Medium
ERNAKULAM	Angamaly [5579]	EURO PAINTS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	EV TRANSFORMER	405.0	8.0	88.0	309.0	76.3	Very High
ERNAKULAM	Angamaly [5579]	EVER GREEN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	EXOTIC FOOD	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	FASHION PLY WOODS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	FASSIO	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	FEDARAL CITY APPARTMENTS	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	FEDERAL BANK ANGADIKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	FEDERAL BANK KARAYAMPARAMBU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Angamaly [5579]	FEDERAL CITY	405.0	0.0	0.0	405.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	FOOD CORPERATION	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GANGOTRI	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GAS GODOWN	129.0	13.0	41.0	75.0	58.1	High
ERNAKULAM	Angamaly [5579]	GAY LOARD	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GLOBAL COMMUNICATIONS	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GOBAL-INDUSTRIES	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GOLDEN PLAZA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GOOD LUCK	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GOOD LUCK-II	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GOODLUCK-INKEL	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GOVT HOSPITAL RAPDRP	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Angamaly [5579]	GRAND LT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	GREEN GRADEN	129.0	10.0	105.5	13.4	10.4	Low
ERNAKULAM	Angamaly [5579]	HAFCO-INDUSTRIES	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	HEMALATHA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	HEMAN	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	HI-TECH	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	HILLS PARK	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	HINDUSTAN POWER LINK	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	HOME SCIENCE	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Angamaly [5579]	I O VARGHESE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ICE FACTORY PAVIZHAPONG	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	ICON	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	IIP	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	INDUS	81.0	0.0	29.7	51.3	63.3	High
ERNAKULAM	Angamaly [5579]	INKEL TOWER	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Angamaly [5579]	INKEL TOWER NO-II	1,012.0	0.0	10.0	1,002.0	99.0	Very High
ERNAKULAM	Angamaly [5579]	INSIGHT	81.0	0.0	36.2	44.8	55.4	High
ERNAKULAM	Angamaly [5579]	JACOB ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	JAWAHAR NAGAR	81.0	3.0	40.5	37.5	46.3	Medium
ERNAKULAM	Angamaly [5579]	JOB PRESS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	JOSCO PLASTICS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	JOSCO-2	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	JOSEPH PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	JOSPURAM	81.0	23.0	43.9	14.1	17.4	Low
ERNAKULAM	Angamaly [5579]	K P BABU	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KACHAPILLY ENGINEERING	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KACHAPPILLY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KADAVU	81.0	13.0	8.0	60.0	74.1	High
ERNAKULAM	Angamaly [5579]	KAIRALI CHEMICALS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KALLIYATH LT-I	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KALLUPALAM RAPDRP	81.0	5.0	41.0	35.0	43.2	Medium
ERNAKULAM	Angamaly [5579]	KARAYAMPARAMBU	129.0	11.0	117.6	0.4	0.3	Very Low
ERNAKULAM	Angamaly [5579]	KARIPPAPADAM	81.0	5.0	76.0	0.0	0.0	Very Low
ERNAKULAM	Angamaly [5579]	KARSHAKAN KAVALA	81.0	0.0	80.6	0.4	0.4	Very Low
ERNAKULAM	Angamaly [5579]	KATHIR ANNEX	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KAVARAPARAMBU NO-1	202.0	33.0	162.3	6.7	3.3	Very Low
ERNAKULAM	Angamaly [5579]	KAVARAPARAMBU NO-II	129.0	3.0	85.4	40.6	31.4	Medium
ERNAKULAM	Angamaly [5579]	KAYATTAMKUZHY	129.0	13.0	32.3	83.7	64.9	High
ERNAKULAM	Angamaly [5579]	KAYYALAPADY	81.0	0.0	62.2	18.8	23.2	Low
ERNAKULAM	Angamaly [5579]	KFC	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KIDANGOOR NO-2	81.0	2.0	79.0	0.0	0.0	Very Low
ERNAKULAM	Angamaly [5579]	KIDANGOOR NO1	129.0	8.0	120.8	0.2	0.2	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Angamaly [5579]	KIDANGOOR SOUTH	81.0	3.0	24.0	54.0	66.7	High
ERNAKULAM	Angamaly [5579]	KOCHURANI CUSTOMER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KOLENCHERY TOWER	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KOLUVANS	81.0	30.0	50.1	0.9	1.1	Very Low
ERNAKULAM	Angamaly [5579]	KONSEAL PIPES	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KOORANS	81.0	10.0	0.0	71.0	87.7	Very High
ERNAKULAM	Angamaly [5579]	KOTHAKULANGARA N H	129.0	5.0	58.4	65.6	50.8	High
ERNAKULAM	Angamaly [5579]	KOTHAKULANGARA TEMPLE	202.0	6.0	139.3	56.7	28.1	Medium
ERNAKULAM	Angamaly [5579]	KOYIKKAKUDIYIL	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Angamaly [5579]	KSEB SECTION	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Angamaly [5579]	KSRTC	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Angamaly [5579]	KULAPPURAKAVU	81.0	11.0	54.0	16.0	19.8	Low
ERNAKULAM	Kallookad [5593]	ALUMKAMARY	129.0	8.0	50.0	71.0	55.0	High
ERNAKULAM	Kallookad [5593]	ANNA COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	APPU GRANITES	81.0	3.0	18.7	59.3	73.3	High
ERNAKULAM	Kallookad [5593]	AYAVANA AYURVEDAM	81.0	0.0	12.0	69.0	85.2	Very High
ERNAKULAM	Kallookad [5593]	AYAVANA TOWN	81.0	26.0	46.5	8.5	10.5	Low
ERNAKULAM	Kallookad [5593]	BETHLEHEM SCHOOL	81.0	0.0	42.0	39.0	48.1	Medium
ERNAKULAM	Kallookad [5593]	CHAAL	51.0	5.0	16.0	30.0	58.8	High
ERNAKULAM	Kallookad [5593]	CHARLIES THAZHUVANKUNNU	81.0	0.0	17.5	63.5	78.4	Very High
ERNAKULAM	Kallookad [5593]	CHATTUPARA	129.0	0.0	5.0	124.0	96.1	Very High
ERNAKULAM	Kallookad [5593]	CHELAKKAKADAVU	81.0	0.0	18.5	62.5	77.2	Very High
ERNAKULAM	Kallookad [5593]	CHEMBINTHOTTY	81.0	3.0	16.0	62.0	76.5	Very High
ERNAKULAM	Kallookad [5593]	EAST KALLOOR	81.0	10.0	16.0	55.0	67.9	High
ERNAKULAM	Kallookad [5593]	EAST KALLOOR TOWER	81.0	0.0	4.0	77.0	95.1	Very High
ERNAKULAM	Kallookad [5593]	EDAPPAZHAM	81.0	0.0	22.0	59.0	72.8	High
ERNAKULAM	Kallookad [5593]	ENANALLOOR SHAPPU	81.0	0.0	21.0	60.0	74.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kallookad [5593]	IICM CAMPUS SNDP AYAVANA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	JEKSON	81.0	11.0	46.3	23.7	29.3	Medium
ERNAKULAM	Kallookad [5593]	JESUS TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	KADUKKANCHIRA	129.0	45.8	22.0	61.2	47.4	Medium
ERNAKULAM	Kallookad [5593]	KALLOOR AIRTEL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	KALLOOR KANAM	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kallookad [5593]	KALLOOR KOCHUKUDY	81.0	15.0	31.5	34.5	42.6	Medium
ERNAKULAM	Kallookad [5593]	KALLOOR RAW WATER	81.0	0.0	17.0	64.0	79.0	Very High
ERNAKULAM	Kallookad [5593]	KALLOOR XNGE	81.0	0.0	25.0	56.0	69.1	High
ERNAKULAM	Kallookad [5593]	KALLOORKAD CANAL	81.0	8.0	13.0	60.0	74.1	High
ERNAKULAM	Kallookad [5593]	KALLOORKAD POLICE STATION	81.0	0.0	37.0	44.0	54.3	High
ERNAKULAM	Kallookad [5593]	KALLOORKAD TOWN	129.0	3.0	30.0	96.0	74.4	High
ERNAKULAM	Kallookad [5593]	KALLOORKADU XNGE	81.0	3.0	0.0	78.0	96.3	Very High
ERNAKULAM	Kallookad [5593]	KANIYANKUDY	81.0	3.0	37.0	41.0	50.6	High
ERNAKULAM	Kallookad [5593]	KARIMATTAM CHAPPEL	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Kallookad [5593]	KARIMATTAM SCHOOL	81.0	0.0	50.0	31.0	38.3	Medium
ERNAKULAM	Kallookad [5593]	KARIMATTOM MUDAKKALIL	81.0	0.0	37.0	44.0	54.3	High
ERNAKULAM	Kallookad [5593]	KAVAKAD	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	KAVAKAD TOWER	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Kallookad [5593]	KAVUMPADY	81.0	6.0	56.7	18.3	22.5	Low
ERNAKULAM	Kallookad [5593]	KOOCHAN	81.0	5.0	45.0	31.0	38.3	Medium
ERNAKULAM	Kallookad [5593]	KULANGATTUPARA	51.0	0.0	5.0	46.0	90.2	Very High
ERNAKULAM	Kallookad [5593]	KULANGATTUPARA TIN TIN	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	KULANGATTUPRA KAVALA	81.0	10.0	5.0	66.0	81.5	Very High
ERNAKULAM	Kallookad [5593]	KUMMAYAPURA	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Kallookad [5593]	KUZHIMBITHAZHAM	81.0	0.0	20.4	60.6	74.8	High
ERNAKULAM	Kallookad [5593]	MAHILAMAARKKAVU	81.0	0.0	61.0	20.0	24.7	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kallookad [5593]	MALANIRAPPU	81.0	15.0	21.0	45.0	55.6	High
ERNAKULAM	Kallookad [5593]	MANACKAPADY	129.0	3.0	47.0	79.0	61.2	High
ERNAKULAM	Kallookad [5593]	MANACKAPADY CREEP	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	MANALIPEEDIKA	81.0	5.0	5.0	71.0	87.7	Very High
ERNAKULAM	Kallookad [5593]	MANAPUZHA	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Kallookad [5593]	MANIYANTHRAM GRAPHITE	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Kallookad [5593]	MANIYANTHRAM MUDI	20.0	0.0	0.0	20.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	MANIYANTHRAM SCHOOL	81.0	8.0	13.0	60.0	74.1	High
ERNAKULAM	Kallookad [5593]	MANIYANTHRAM SHAP	81.0	0.0	2.0	79.0	97.5	Very High
ERNAKULAM	Kallookad [5593]	MANJALLOOR	81.0	5.0	26.0	50.0	61.7	High
ERNAKULAM	Kallookad [5593]	MARUTHUR	81.0	5.0	44.0	32.0	39.5	Medium
ERNAKULAM	Kallookad [5593]	MOOPARUPADY	81.0	0.0	35.0	46.0	56.8	High
ERNAKULAM	Kallookad [5593]	MULLAPUZHACHAL	81.0	2.0	29.6	49.4	61.0	High
ERNAKULAM	Kallookad [5593]	MUNJANATTUPEEDIKA	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Kallookad [5593]	NAGAPUZHA	129.0	0.0	62.0	67.0	51.9	High
ERNAKULAM	Kallookad [5593]	NAGARAJA TEMPLE PERAMANGALAM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	NEERAMPUZHA	129.0	3.0	23.0	103.0	79.8	Very High
ERNAKULAM	Kallookad [5593]	NP ASSOCIATES MANAPUZHA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	NP PLYWOOD MANAPUZHA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	PACHACKATHAZHAM	81.0	0.0	11.0	70.0	86.4	Very High
ERNAKULAM	Kallookad [5593]	PAMPOORANPARA	20.0	0.0	0.0	20.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	PATHAKUTHY	129.0	5.0	52.7	71.3	55.2	High
ERNAKULAM	Kallookad [5593]	PERAMANGALAM MANAYATHUMAR Y	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	PERAMANGALAM TEMPLE	129.0	0.0	5.0	124.0	96.1	Very High
ERNAKULAM	Kallookad [5593]	PERIYAR LATEX	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	PERUKKU	81.0	0.0	11.0	70.0	86.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kallookad [5593]	PERUMANKANADAM	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kallookad [5593]	RANDAR RAJEEV COLONY	81.0	5.0	34.0	42.0	51.9	High
ERNAKULAM	Kallookad [5593]	RANDAR SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kallookad [5593]	SANTHUKADU TEMPLE	81.0	0.0	31.0	50.0	61.7	High
ERNAKULAM	Kallookad [5593]	SNDP AYAVANA	81.0	3.0	20.0	58.0	71.6	High
ERNAKULAM	Kallookad [5593]	STMICHAELS SCHOOL	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Kallookad [5593]	TANK KAVALA	81.0	23.0	13.0	45.0	55.6	High
ERNAKULAM	Kallookad [5593]	THAIMATTOM	81.0	5.0	29.0	47.0	58.0	High
ERNAKULAM	Kallookad [5593]	THAIMATTOM TOWER	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Kallookad [5593]	THAZHUVAMKUNNU CANAL	81.0	0.0	49.4	31.6	39.0	Medium
ERNAKULAM	Kallookad [5593]	THAZHUVANKUNNU	81.0	10.0	20.0	51.0	62.9	High
ERNAKULAM	Kallookad [5593]	THONIKUZH	81.0	3.0	23.0	55.0	67.9	High
ERNAKULAM	Kallookad [5593]	THOTTAMCHERY	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kallookad [5593]	THOTTANCHERY MILMA	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Kallookad [5593]	VADACODE	81.0	3.0	28.0	50.0	61.7	High
ERNAKULAM	Kallookad [5593]	VALARITHANDU	81.0	3.0	13.0	65.0	80.2	Very High
ERNAKULAM	Kallookad [5593]	VAZHUYANCHIRA	81.0	0.0	25.0	56.0	69.1	High
ERNAKULAM	Kallookad [5593]	VELLARAMKALLU	81.0	0.0	9.0	72.0	88.9	Very High
ERNAKULAM	Kallookad [5593]	VEMPILLY HOSPITAL	81.0	0.0	25.0	56.0	69.1	High
ERNAKULAM	Koothattukulam [5598]	ALACKAPADY	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Koothattukulam [5598]	ALAPURAM	129.0	3.0	29.0	97.0	75.2	Very High
ERNAKULAM	Koothattukulam [5598]	ALAPURAM-II	81.0	8.0	21.0	52.0	64.2	High
ERNAKULAM	Koothattukulam [5598]	AMAS GOLD	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Koothattukulam [5598]	AMBALAMKUNNU	81.0	5.0	27.0	49.0	60.5	High
ERNAKULAM	Koothattukulam [5598]	AMBATTUKANDAM	81.0	10.0	27.6	43.4	53.6	High
ERNAKULAM	Koothattukulam [5598]	ARICKAPILLY	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Koothattukulam [5598]	ARICKAPPILLY CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Koothattukulam [5598]	AROOR	81.0	0.0	64.8	16.2	20.0	Low
ERNAKULAM	Koothattukulam [5598]	AROOR CRUSHER	81.0	0.0	6.0	75.0	92.6	Very High
ERNAKULAM	Koothattukulam [5598]	ASWATHY	81.0	0.0	9.0	72.0	88.9	Very High
ERNAKULAM	Koothattukulam [5598]	ATTIPEEDIKA	81.0	0.0	18.3	62.7	77.4	Very High
ERNAKULAM	Koothattukulam [5598]	BAPPUJI SCHOOL	81.0	0.0	34.2	46.8	57.8	High
ERNAKULAM	Koothattukulam [5598]	BULL MARKET	202.0	35.0	51.9	115.2	57.0	High
ERNAKULAM	Koothattukulam [5598]	CHAKKALAPARA TOWER	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Koothattukulam [5598]	CHAMBAMALA	81.0	8.0	9.0	64.0	79.0	Very High
ERNAKULAM	Koothattukulam [5598]	CHELAPPARA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	CHELAPUZHA	81.0	0.0	21.0	60.0	74.1	High
ERNAKULAM	Koothattukulam [5598]	CHELLACKAPADY	81.0	6.0	23.8	51.2	63.2	High
ERNAKULAM	Koothattukulam [5598]	CHENAPPARAMBU	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	CHORAKKUZHY CHURCH	129.0	0.0	42.0	87.0	67.4	High
ERNAKULAM	Koothattukulam [5598]	CHORAKKUZHY SAW MILL	81.0	0.0	25.0	56.0	69.1	High
ERNAKULAM	Koothattukulam [5598]	CHORAKUZH I DRINKING WATER	81.0	5.0	6.0	70.0	86.4	Very High
ERNAKULAM	Koothattukulam [5598]	CHORAKUZH Y BRIDGE	81.0	0.0	44.0	37.0	45.7	Medium
ERNAKULAM	Koothattukulam [5598]	CHORAKUZH Y POPULAR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	COLLEGE OF NURSING	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Koothattukulam [5598]	CSI COMMERCIAL BUILDING	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	DARSANA	81.0	0.0	21.0	60.0	74.1	High
ERNAKULAM	Koothattukulam [5598]	DEVAMATHA TOWER	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Koothattukulam [5598]	EDASSERITHAZHAM	81.0	0.0	29.0	52.0	64.2	High
ERNAKULAM	Koothattukulam [5598]	EDAYAR PALLIPPADY	202.0	5.0	56.9	140.1	69.4	High
ERNAKULAM	Koothattukulam [5598]	EDAYAR PUNNAMATTOM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	EDAYAR WEST	129.0	6.0	14.0	109.0	84.5	Very High
ERNAKULAM	Koothattukulam [5598]	ELANJI	202.0	0.0	71.0	131.0	64.8	High
ERNAKULAM	Koothattukulam [5598]	ELANJI BUS STAND	81.0	0.0	34.1	46.9	57.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Koothattukulam [5598]	ELANJI IDEA TOWER	81.0	0.0	8.5	72.5	89.5	Very High
ERNAKULAM	Koothattukulam [5598]	ELANJI PALLIPADY	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Koothattukulam [5598]	ERUMAKKULAM	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Koothattukulam [5598]	GOGREEN POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	GOVT HOSPITAL	202.0	0.0	13.0	189.0	93.6	Very High
ERNAKULAM	Koothattukulam [5598]	H S ROAD	202.0	0.0	57.5	144.5	71.5	High
ERNAKULAM	Koothattukulam [5598]	HARIDWAR EV	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	HI-CARE	129.0	0.0	34.0	95.0	73.6	High
ERNAKULAM	Koothattukulam [5598]	HILLS DALE	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	ILLIKUNNU NO-1	81.0	0.0	6.0	75.0	92.6	Very High
ERNAKULAM	Koothattukulam [5598]	ILLIKUNNU NO-2	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Koothattukulam [5598]	IOCL UPPUKANDOM	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Koothattukulam [5598]	JAYANTHI ROAD	81.0	0.0	38.9	42.1	52.0	High
ERNAKULAM	Koothattukulam [5598]	JOHN ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	JOSEGIRI	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Koothattukulam [5598]	JUPITER	81.0	0.0	26.0	55.0	67.9	High
ERNAKULAM	Koothattukulam [5598]	K K ROAD	81.0	8.0	37.0	36.0	44.4	Medium
ERNAKULAM	Koothattukulam [5598]	KADAMBANATTUTHAZHAM	81.0	5.0	29.0	47.0	58.0	High
ERNAKULAM	Koothattukulam [5598]	KADAVELIL	81.0	0.0	36.0	45.0	55.6	High
ERNAKULAM	Koothattukulam [5598]	KALANIMATTAM	129.0	5.0	36.3	87.7	68.0	High
ERNAKULAM	Koothattukulam [5598]	KALANIMATTOM PUMP HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	KALPAKA	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Koothattukulam [5598]	KANIYALIPADY	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Koothattukulam [5598]	KAPPIPPILLY	81.0	5.0	0.0	76.0	93.8	Very High
ERNAKULAM	Koothattukulam [5598]	KARAMALA	81.0	10.0	35.0	36.0	44.4	Medium
ERNAKULAM	Koothattukulam [5598]	KARIMPANA	129.0	5.0	27.0	97.0	75.2	Very High
ERNAKULAM	Koothattukulam [5598]	KARUKUNNU	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Koothattukulam [5598]	KATTOOPADAM CHIRA	81.0	0.0	77.0	4.0	4.9	Very Low
ERNAKULAM	Koothattukulam [5598]	KAVUMBHAGAM	81.0	0.0	22.0	59.0	72.8	High
ERNAKULAM	Koothattukulam [5598]	KEERTHY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	KIZHAKOMBU TEMPLE	81.0	5.0	5.0	71.0	87.7	Very High
ERNAKULAM	Koothattukulam [5598]	KORANGOLITHADATHIL TOWER	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	KOTHOLIPPADY	81.0	5.0	31.0	45.0	55.6	High
ERNAKULAM	Koothattukulam [5598]	KOZHIPALLI WAITING SHED JN	81.0	0.0	19.4	61.6	76.1	Very High
ERNAKULAM	Koothattukulam [5598]	KOZHIPPILLY KAVU	81.0	0.0	33.4	47.6	58.7	High
ERNAKULAM	Koothattukulam [5598]	KULAMKANDAM	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Koothattukulam [5598]	KUNNUMCHIRA	81.0	6.0	52.3	22.7	28.0	Medium
ERNAKULAM	Koothattukulam [5598]	KUZHALANATTU	162.0	0.0	0.0	162.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	KUZHICKATTUKUNNU NEW	81.0	5.0	43.0	33.0	40.7	Medium
ERNAKULAM	Koothattukulam [5598]	MADUKKA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	MANGALATHUTHAZHAM	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Koothattukulam [5598]	MANGALATHUTHAZHAM ANGANVADY	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Koothattukulam [5598]	MANGATTAMBALAM DRINKING WATER	81.0	0.0	21.0	60.0	74.1	High
ERNAKULAM	Koothattukulam [5598]	MANGATTU AMBALAM	129.0	5.0	15.0	109.0	84.5	Very High
ERNAKULAM	Koothattukulam [5598]	MANIKANDAN BRIDGE	81.0	5.0	8.0	68.0	84.0	Very High
ERNAKULAM	Koothattukulam [5598]	MANJADY	81.0	0.0	21.0	60.0	74.1	High
ERNAKULAM	Koothattukulam [5598]	MANNARAKUNNU	81.0	0.0	9.0	72.0	88.9	Very High
ERNAKULAM	Koothattukulam [5598]	MANNATHOOR JUNCTION	81.0	0.0	11.0	70.0	86.4	Very High
ERNAKULAM	Koothattukulam [5598]	MARANGOLI	81.0	0.0	16.0	65.0	80.2	Very High
ERNAKULAM	Koothattukulam [5598]	MARIKA	81.0	0.0	33.0	48.0	59.3	High
ERNAKULAM	Koothattukulam [5598]	MARUTHI JN	81.0	0.0	32.5	48.5	59.9	High
ERNAKULAM	Koothattukulam [5598]	MAVINCHUVADU	81.0	0.0	16.0	65.0	80.2	Very High
ERNAKULAM	Koothattukulam [5598]	MEENKUNNAM	81.0	2.0	37.2	41.8	51.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Koothattukulam [5598]	MILLUMPADY	81.0	0.0	51.0	30.0	37.0	Medium
ERNAKULAM	Koothattukulam [5598]	MM RUBBERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	MOONGAMKUNNU	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Koothattukulam [5598]	MOONGAMKUNNU JUNCTION	81.0	0.0	25.4	55.6	68.6	High
ERNAKULAM	Koothattukulam [5598]	MUNDACKAPPILLY	129.0	8.0	34.0	87.0	67.4	High
ERNAKULAM	Koothattukulam [5598]	MUNDUNADA	81.0	3.0	17.0	61.0	75.3	Very High
ERNAKULAM	Koothattukulam [5598]	MUTHOLAPURAM CHURCH	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Koothattukulam [5598]	MUTHOLAPURAM JN	129.0	0.0	8.0	121.0	93.8	Very High
ERNAKULAM	Koothattukulam [5598]	MUTHOLAPURAM TEMPLE	81.0	4.0	3.0	74.0	91.4	Very High
ERNAKULAM	Koothattukulam [5598]	MVIP OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	MYLADUMPARA	81.0	5.0	53.0	23.0	28.4	Medium
ERNAKULAM	Koothattukulam [5598]	MYTHRI	81.0	0.0	6.4	74.6	92.0	Very High
ERNAKULAM	Koothattukulam [5598]	NADUKKARA	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Koothattukulam [5598]	NELLOORUPARA	81.0	5.0	8.0	68.0	84.0	Very High
ERNAKULAM	Koothattukulam [5598]	NORTH PALAKUZHA	81.0	5.0	39.0	37.0	45.7	Medium
ERNAKULAM	Koothattukulam [5598]	NSS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	OLIYAPPURAM OLIYAKULAM	81.0	1.6	89.1	0.0	0.0	Very Low
ERNAKULAM	Koothattukulam [5598]	OLIYAPPURAM SAW MILL	129.0	3.0	31.2	94.8	73.4	High
ERNAKULAM	Koothattukulam [5598]	OLIYAPPURAM TOWN	81.0	0.0	26.9	54.1	66.8	High
ERNAKULAM	Koothattukulam [5598]	OLIYAPURAM TOWER	81.0	13.0	19.0	49.0	60.5	High
ERNAKULAM	Koothattukulam [5598]	ONAMKUNNUKAVU	81.0	0.0	9.0	72.0	88.9	Very High
ERNAKULAM	Koothattukulam [5598]	OZHON DEEMED	129.0	10.0	16.0	103.0	79.8	Very High
ERNAKULAM	Koothattukulam [5598]	PAITTAKKULAM	81.0	3.0	77.8	0.2	0.3	Very Low
ERNAKULAM	Koothattukulam [5598]	PAITTAKULAM GRANITES	129.0	0.0	95.0	34.0	26.4	Medium
ERNAKULAM	Koothattukulam [5598]	PAITTAKULAM MARBLES	129.0	0.0	60.0	69.0	53.5	High
ERNAKULAM	Koothattukulam [5598]	PALAKKUZHA	129.0	0.0	40.0	89.0	69.0	High
ERNAKULAM	Koothattukulam [5598]	PALAKUZHA CSI	81.0	5.0	65.4	10.6	13.0	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Koothattukulam [5598]	PALAKUZHA SAWMILL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	PANDARAMPADY	81.0	0.0	18.0	63.0	77.8	Very High
ERNAKULAM	Koothattukulam [5598]	PANNAPPURAM MALA	81.0	0.0	43.0	38.0	46.9	Medium
ERNAKULAM	Koothattukulam [5598]	PARISUDHAM OIL MILL	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	PARUDEESA	81.0	0.0	23.1	57.9	71.5	High
ERNAKULAM	Koothattukulam [5598]	PERUMKUTTY	81.0	0.0	29.0	52.0	64.2	High
ERNAKULAM	Koothattukulam [5598]	PERUMKUTTY SAW MILL	51.0	0.0	0.0	51.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	PHOTOFLASH	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	POLICE STATION	81.0	0.0	14.0	67.0	82.7	Very High
ERNAKULAM	Koothattukulam [5598]	POOVAKKULAM	81.0	0.0	18.3	62.7	77.4	Very High
ERNAKULAM	Koothattukulam [5598]	POOVAKULAM SCHOOL	81.0	0.0	30.4	50.6	62.4	High
ERNAKULAM	Koothattukulam [5598]	PULICKAMALI	81.0	0.0	16.0	65.0	80.2	Very High
ERNAKULAM	Koothattukulam [5598]	PUNNAMATTOM	81.0	0.0	30.0	51.0	63.0	High
ERNAKULAM	Koothattukulam [5598]	PUNNAMCODE	81.0	0.0	14.0	67.0	82.7	Very High
ERNAKULAM	Koothattukulam [5598]	PUNNATHANAM	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	RAMAPURAM ROAD	129.0	0.0	53.0	76.0	58.9	High
ERNAKULAM	Koothattukulam [5598]	RANDILAVUNKAL	81.0	3.0	38.0	40.0	49.4	Medium
ERNAKULAM	Koothattukulam [5598]	RELAINCE TRENDS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	ROYAL EV CHARGING STATION	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	ROYAL HARDWARES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	RPS JOSEGIRI	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Koothattukulam [5598]	S S ROAD	81.0	6.0	42.0	33.0	40.7	Medium
ERNAKULAM	Koothattukulam [5598]	SAI SERVICE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	SANTHULA HOSPITAL	81.0	0.0	75.0	6.0	7.4	Very Low
ERNAKULAM	Koothattukulam [5598]	SAVOI	202.0	0.0	9.5	192.5	95.3	Very High
ERNAKULAM	Koothattukulam [5598]	SDOT	202.0	5.0	44.8	152.2	75.3	Very High
ERNAKULAM	Koothattukulam [5598]	SOUTH MARIKA	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Koothattukulam [5598]	SREEDHAREEYAM	81.0	0.0	27.5	53.5	66.0	High
ERNAKULAM	Koothattukulam [5598]	SREEDHAREEYAM MANA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	SREEDHAREEYAM VILLA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	ST JOHNS HS	81.0	0.0	42.8	38.2	47.2	Medium
ERNAKULAM	Koothattukulam [5598]	T B KUNNU	81.0	0.0	17.0	64.0	79.0	Very High
ERNAKULAM	Koothattukulam [5598]	TATA TOWER	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Koothattukulam [5598]	THATTEKATTUMALA	81.0	0.0	24.2	56.8	70.1	High
ERNAKULAM	Koothattukulam [5598]	THEKKANALCHIRA	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Koothattukulam [5598]	TJ COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	UPPUKANDAM	81.0	5.0	42.0	34.0	42.0	Medium
ERNAKULAM	Koothattukulam [5598]	URUKUZH Y	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Koothattukulam [5598]	VADAKARA	129.0	15.0	42.0	72.0	55.8	High
ERNAKULAM	Koothattukulam [5598]	VALAPPU	129.0	0.0	43.5	85.5	66.3	High
ERNAKULAM	Koothattukulam [5598]	VALAPPU AQUADATE	81.0	0.0	19.5	61.5	75.9	Very High
ERNAKULAM	Koothattukulam [5598]	VALAPPU BRICK	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	VALAPPU GAS GODOWN	81.0	5.0	21.0	55.0	67.9	High
ERNAKULAM	Koothattukulam [5598]	VALAPPU SODA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	VALIYAKANDAM PALLITHAZHAM	81.0	0.0	26.0	55.0	67.9	High
ERNAKULAM	Koothattukulam [5598]	VALIYAKULANGARA MINI TOWER	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	VELACHERITHAZHAM	129.0	0.0	55.8	73.2	56.8	High
ERNAKULAM	Koothattukulam [5598]	VILANGAPARA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Koothattukulam [5598]	YOHANNAN PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	46 ACRE	81.0	0.0	24.0	57.0	70.4	High
ERNAKULAM	Kothamangalam-II [5601]	90 CENT	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	ADIVAD	81.0	8.0	52.0	21.0	25.9	Medium
ERNAKULAM	Kothamangalam-II [5601]	ADIVARAM	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Kothamangalam-II [5601]	AGRICULTUREL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kothamangalam-II [5601]	ALACKAL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	ALAPPATTU	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	ALLUNGAL-100 KVA	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Kothamangalam-II [5601]	AMBALAPARAMBU	81.0	15.0	47.0	19.0	23.5	Low
ERNAKULAM	Kothamangalam-II [5601]	ANAKAL	81.0	7.0	31.0	43.0	53.1	High
ERNAKULAM	Kothamangalam-II [5601]	APPACKKAPADY	81.0	8.0	23.0	50.0	61.7	High
ERNAKULAM	Kothamangalam-II [5601]	AR TOWER	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	ARABIAN AUTO	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	ARAMANAPADY	129.0	12.0	85.0	32.0	24.8	Low
ERNAKULAM	Kothamangalam-II [5601]	AVOLICHAL	81.0	0.0	48.0	33.0	40.7	Medium
ERNAKULAM	Kothamangalam-II [5601]	AVOLICHAL-INDUS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	AXIS BANK	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	AYYANKAVU	81.0	8.0	73.0	0.0	0.0	Very Low
ERNAKULAM	Kothamangalam-II [5601]	BAVAS PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	BLUE MOON	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	BOSEWEL	81.0	5.0	25.0	51.0	63.0	High
ERNAKULAM	Kothamangalam-II [5601]	BOYS TOWN	81.0	10.0	52.1	18.9	23.3	Low
ERNAKULAM	Kothamangalam-II [5601]	BPCL CHARGING STATION AYYANKAV	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	CAPITAL PLASSA	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Kothamangalam-II [5601]	CENTRAL TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	CHAKKIYAM	129.0	5.0	78.0	46.0	35.6	Medium
ERNAKULAM	Kothamangalam-II [5601]	CHARUPARA	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Kothamangalam-II [5601]	CHEBANKUZH Y CHAPPEL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	CHEEKOTTUMALI	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Kothamangalam-II [5601]	CHEMBANKUZH Y	81.0	5.0	0.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	CHEMMANAM COLONY	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kothamangalam-II [5601]	CHINNAMMA SCARIA ROAD	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	CHIRAPADY	81.0	0.0	24.4	56.6	69.8	High
ERNAKULAM	Kothamangalam-II [5601]	CHULLIKANDOM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	CHURCH VIEW	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	CLAY OVEN EV CHARGING	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	COLLEGE ROAD	81.0	0.0	32.0	49.0	60.5	High
ERNAKULAM	Kothamangalam-II [5601]	DAILY BREAD	81.0	0.0	27.7	53.3	65.8	High
ERNAKULAM	Kothamangalam-II [5601]	DANIEL SIR	81.0	0.0	26.8	54.2	66.9	High
ERNAKULAM	Kothamangalam-II [5601]	DEVIYAR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	DISCOPPADY	81.0	0.0	7.8	73.2	90.4	Very High
ERNAKULAM	Kothamangalam-II [5601]	DOUBLE CROSS	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	DTPC	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	EASTERN TEA	81.0	0.0	28.0	53.0	65.4	High
ERNAKULAM	Kothamangalam-II [5601]	ELAVUMPARAMB	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Kothamangalam-II [5601]	EMBASSERY KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	EMJ TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	ENIYEKKAHV	81.0	0.0	12.0	69.0	85.2	Very High
ERNAKULAM	Kothamangalam-II [5601]	ENTE NAADU	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	ERAPPINKAL	81.0	3.0	5.0	73.0	90.1	Very High
ERNAKULAM	Kothamangalam-II [5601]	FRESHES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	GREENMOUNT	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	GREENVALLEY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	HDFC BANK	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	HIGH RANGE JN	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	ILANKAVE	81.0	3.0	40.0	38.0	46.9	Medium
ERNAKULAM	Kothamangalam-II [5601]	ILLAM NEYYE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	IMPERIAL	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kothamangalam-II [5601]	INCHAPATHAL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	INCHIPPARA	81.0	0.0	22.0	59.0	72.8	High
ERNAKULAM	Kothamangalam-II [5601]	INCHOOOR	81.0	13.0	20.0	48.0	59.3	High
ERNAKULAM	Kothamangalam-II [5601]	JBM SCHOOL	81.0	10.0	21.0	50.0	61.7	High
ERNAKULAM	Kothamangalam-II [5601]	JEEVA WATER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	JJ FOODS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	KAIRALI NAGER	81.0	0.0	43.1	37.9	46.8	Medium
ERNAKULAM	Kothamangalam-II [5601]	KAITHAMATTAM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	KALACHANDHA	81.0	0.0	26.3	54.7	67.5	High
ERNAKULAM	Kothamangalam-II [5601]	KANJIRAMPARA	129.0	3.0	7.0	119.0	92.2	Very High
ERNAKULAM	Kothamangalam-II [5601]	KANNADIKODU	81.0	3.5	25.0	52.5	64.8	High
ERNAKULAM	Kothamangalam-II [5601]	KARAKOMBIL	129.0	0.0	80.0	49.0	38.0	Medium
ERNAKULAM	Kothamangalam-II [5601]	KARIMARUTHUM CHAL	81.0	0.0	12.0	69.0	85.2	Very High
ERNAKULAM	Kothamangalam-II [5601]	KARIPUZHAKADAVU	81.0	5.0	45.3	30.7	37.9	Medium
ERNAKULAM	Kothamangalam-II [5601]	KATTATTUKULAM	81.0	0.0	9.0	72.0	88.9	Very High
ERNAKULAM	Kothamangalam-II [5601]	KATTUCHIRA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	KAVALANGADU	81.0	8.0	56.3	16.7	20.6	Low
ERNAKULAM	Kothamangalam-II [5601]	KEEZHTHANDU	81.0	0.0	12.0	69.0	85.2	Very High
ERNAKULAM	Kothamangalam-II [5601]	KERA FED	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	KOLLIKADU	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	KOMENDAPADY	81.0	3.0	15.4	62.6	77.3	Very High
ERNAKULAM	Kothamangalam-II [5601]	KOTHAMANGALAM AUTO FUELS EV	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	KOTHAMANGALAM CLUB	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	KOTTAKANDATHIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	KOZHIPILLY PARK	129.0	5.0	5.0	119.0	92.2	Very High
ERNAKULAM	Kothamangalam-II [5601]	KOZHIPILLY BYPASS	81.0	5.0	29.0	47.0	58.0	High
ERNAKULAM	Kothamangalam-II [5601]	KOZHIPILLY MOBILE TOWER	81.0	10.0	42.8	28.2	34.8	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kothamangalam-II [5601]	KOZHIPPILLY PTKD	81.0	10.0	5.0	66.0	81.5	Very High
ERNAKULAM	Kothamangalam-II [5601]	KOZHIPPILY EXCHANGE	81.0	0.0	54.0	27.0	33.3	Medium
ERNAKULAM	Kothamangalam-II [5601]	KSRTC	202.0	80.0	38.9	83.1	41.1	Medium
ERNAKULAM	Kothamangalam-II [5601]	KUMBALATHUMURY	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	KURISUPARA	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	KUROOR BRIDGE	129.0	0.0	15.0	114.0	88.4	Very High
ERNAKULAM	Kothamangalam-II [5601]	KURUMKULAM	81.0	5.0	41.0	35.0	43.2	Medium
ERNAKULAM	Kothamangalam-II [5601]	KUTHUKUZH Y	81.0	5.0	21.0	55.0	67.9	High
ERNAKULAM	Kothamangalam-II [5601]	KUTHUKUZH Y PALLI	81.0	3.0	29.0	49.0	60.5	High
ERNAKULAM	Kothamangalam-II [5601]	KUTHUKUZH Y SOCIETY	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Kothamangalam-II [5601]	KUTHUKUZY LPS	81.0	11.0	63.0	7.0	8.6	Very Low
ERNAKULAM	Kothamangalam-II [5601]	LATHEEN PALLY	81.0	10.0	71.0	0.0	0.0	Very Low
ERNAKULAM	Kothamangalam-II [5601]	LILLY WHITE	81.0	0.0	64.0	17.0	21.0	Low
ERNAKULAM	Kothamangalam-II [5601]	MADIYOOR	129.0	0.0	11.0	118.0	91.5	Very High
ERNAKULAM	Kothamangalam-II [5601]	MAHIMA	129.0	5.0	43.5	80.5	62.4	High
ERNAKULAM	Kothamangalam-II [5601]	MAHIMA JUICE	81.0	13.2	16.0	51.8	64.0	High
ERNAKULAM	Kothamangalam-II [5601]	MAIKKATHANDU	81.0	5.0	21.0	55.0	67.9	High
ERNAKULAM	Kothamangalam-II [5601]	MALAYINKEEZH	202.0	0.0	75.0	127.0	62.9	High
ERNAKULAM	Kothamangalam-II [5601]	MANGATTU	81.0	5.0	72.5	3.5	4.3	Very Low
ERNAKULAM	Kothamangalam-II [5601]	MARACHERY	81.0	5.0	20.0	56.0	69.1	High
ERNAKULAM	Kothamangalam-II [5601]	MARAMANGALAM	81.0	10.0	30.0	41.0	50.6	High
ERNAKULAM	Kothamangalam-II [5601]	MATHA	202.0	3.0	5.0	194.0	96.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	MATHA THEATRE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	MATHANGAKURIZ	81.0	3.2	20.0	57.8	71.4	High
ERNAKULAM	Kothamangalam-II [5601]	MENTHANDU	81.0	0.0	16.0	65.0	80.2	Very High
ERNAKULAM	Kothamangalam-II [5601]	MINI CIVIL STATION	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	MULOTTUCHIRA	129.0	16.0	6.0	107.0	82.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kothamangalam-II [5601]	MUNDACKAL	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	MUNIPPARA	81.0	3.0	20.0	58.0	71.6	High
ERNAKULAM	Kothamangalam-II [5601]	MUNIPPARA TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	NAMBOORIKOUP	81.0	15.0	16.0	50.0	61.7	High
ERNAKULAM	Kothamangalam-II [5601]	NAVODAYA	81.0	0.0	50.0	31.0	38.3	Medium
ERNAKULAM	Kothamangalam-II [5601]	NEENDAPARA	81.0	0.0	7.0	74.0	91.4	Very High
ERNAKULAM	Kothamangalam-II [5601]	NELLIMATTAM EXCHANGE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	NELLIMATTOM	202.0	10.0	48.0	144.0	71.3	High
ERNAKULAM	Kothamangalam-II [5601]	NERIAMANGALAM COLONY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	NERIAMANGALAM FARM	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	NERIAMANGALM EXCHANG	129.0	0.0	11.0	118.0	91.5	Very High
ERNAKULAM	Kothamangalam-II [5601]	NERIAMANGALM TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Kothamangalam-II [5601]	NERIMANGALAM TOWN	129.0	0.0	3.0	126.0	97.7	Very High
ERNAKULAM	Kothamangalam-II [5601]	NICE ROAD	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Kothamangalam-II [5601]	OJES AUTOMOBILES	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	OONNUKAL	129.0	5.0	21.0	103.0	79.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	OONNUKAL EXCHANGE	81.0	5.0	40.7	35.3	43.5	Medium
ERNAKULAM	Kothamangalam-II [5601]	OONNUKAL PALLI	81.0	5.0	17.0	59.0	72.8	High
ERNAKULAM	Kothamangalam-II [5601]	PADAYATTIL EV	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	PADINJAREMURY	81.0	0.0	33.0	48.0	59.3	High
ERNAKULAM	Kothamangalam-II [5601]	PAITTAKKULAM	81.0	0.0	25.0	56.0	69.1	High
ERNAKULAM	Kothamangalam-II [5601]	PAITTAKKULAM EV	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	PALAM	81.0	0.0	78.3	2.7	3.3	Very Low
ERNAKULAM	Kothamangalam-II [5601]	PARAMBATHUPADY	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	PARASALAPPADY	81.0	14.0	65.0	2.0	2.4	Very Low
ERNAKULAM	Kothamangalam-II [5601]	PARASSALAPADY HEALTH CENTRE	81.0	5.0	11.0	65.0	80.2	Very High
ERNAKULAM	Kothamangalam-II [5601]	PARAYITHOTTAM	129.0	11.2	18.0	99.8	77.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kothamangalam-II [5601]	PAREEKANNI	81.0	8.5	40.8	31.7	39.2	Medium
ERNAKULAM	Kothamangalam-II [5601]	PATTAYATHUPARA	81.0	5.0	10.0	66.0	81.5	Very High
ERNAKULAM	Kothamangalam-II [5601]	PERAKUTHU	81.0	5.0	0.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	PHED	405.0	0.0	7.5	397.5	98.1	Very High
ERNAKULAM	Kothamangalam-II [5601]	POLICE STATION	129.0	0.0	5.0	124.0	96.1	Very High
ERNAKULAM	Kothamangalam-II [5601]	POONOLIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	POPPET	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	POTHUKUZHYY	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Kothamangalam-II [5601]	POTHUPARA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	POTHUPARA RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	PUKKUNNEL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	PULICKAL	81.0	5.0	0.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	PULICKAL SQUARE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	PULIKKAYAM	129.0	0.0	10.0	119.0	92.2	Very High
ERNAKULAM	Kothamangalam-II [5601]	PUTHENKURIZ	129.0	0.0	76.2	52.8	40.9	Medium
ERNAKULAM	Kothamangalam-II [5601]	RAMALLOOR	129.0	0.0	50.8	78.2	60.6	High
ERNAKULAM	Kothamangalam-II [5601]	RAMALLOORE KAPPELA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	RELIANCE FRESH	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	RELIANT CREDITS	129.0	0.0	50.0	79.0	61.2	High
ERNAKULAM	Kothamangalam-II [5601]	SAMSKARA	81.0	0.0	26.9	54.1	66.8	High
ERNAKULAM	Kothamangalam-II [5601]	SANGEERTHANA	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	SHAPPUMPADY	81.0	0.0	29.0	52.0	64.2	High
ERNAKULAM	Kothamangalam-II [5601]	SNEHALAYAM	81.0	5.0	29.0	47.0	58.0	High
ERNAKULAM	Kothamangalam-II [5601]	SPICES	81.0	0.0	27.0	54.0	66.7	High
ERNAKULAM	Kothamangalam-II [5601]	ST GEORGE COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	ST GEORGE SCHOOL	81.0	0.0	35.0	46.0	56.8	High
ERNAKULAM	Kothamangalam-II [5601]	SUDHEEMS	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kothamangalam-II [5601]	THADATHIKAVALA	81.0	26.3	49.0	5.7	7.0	Very Low
ERNAKULAM	Kothamangalam-II [5601]	THADIKKULAM	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	THALAKODE MOSQUE	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Kothamangalam-II [5601]	THALAKODU	81.0	0.0	14.0	67.0	82.7	Very High
ERNAKULAM	Kothamangalam-II [5601]	THANKALAM BYE PASS	81.0	0.0	43.0	38.0	46.9	Medium
ERNAKULAM	Kothamangalam-II [5601]	THEKKEKKUNNEL	81.0	5.0	26.0	50.0	61.7	High
ERNAKULAM	Kothamangalam-II [5601]	THEKKILAKATT	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	THEKKINI	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Kothamangalam-II [5601]	THENKODE MOSQUE	81.0	0.0	47.0	34.0	42.0	Medium
ERNAKULAM	Kothamangalam-II [5601]	THENKODU	81.0	0.0	21.0	60.0	74.1	High
ERNAKULAM	Kothamangalam-II [5601]	THONDUMPADY	81.0	13.0	31.0	37.0	45.7	Medium
ERNAKULAM	Kothamangalam-II [5601]	TRIBAL COLONY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	UDUPPI	81.0	10.0	31.4	39.6	48.8	Medium
ERNAKULAM	Kothamangalam-II [5601]	UNPA RUBBERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	UPPUKULAM	129.0	0.0	35.0	94.0	72.9	High
ERNAKULAM	Kothamangalam-II [5601]	VALACHIRA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	VALIYAKAVU	81.0	5.0	23.0	53.0	65.4	High
ERNAKULAM	Kothamangalam-II [5601]	VALIYAPARA	202.0	5.0	56.5	140.5	69.5	High
ERNAKULAM	Kothamangalam-II [5601]	VANDHANA	81.0	0.0	20.5	60.5	74.7	High
ERNAKULAM	Kothamangalam-II [5601]	VANITHA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	VAYANASALAPADI	81.0	0.0	47.4	33.6	41.5	Medium
ERNAKULAM	Kothamangalam-II [5601]	VELLAMAKUTH BRIDGE	81.0	0.0	6.0	75.0	92.6	Very High
ERNAKULAM	Kothamangalam-II [5601]	VELLAMAKUTHU	129.0	0.0	23.0	106.0	82.2	Very High
ERNAKULAM	Kothamangalam-II [5601]	VELLAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	VENGOLI	81.0	5.0	27.0	49.0	60.5	High
ERNAKULAM	Kothamangalam-II [5601]	VETTINARY HOSPITAL	81.0	0.0	61.2	19.8	24.4	Low
ERNAKULAM	Kothamangalam-II [5601]	VIKAS BHAVAN	81.0	15.0	38.0	28.0	34.6	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Kothamangalam-II [5601]	VILLANCHIRA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	VILLANCHIRA KAMBILINE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	VILLANCHIRA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	W M RESORT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Kothamangalam-II [5601]	WOOD DEPOT	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Kothamangalam-II [5601]	ZACH RUBBERS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	5TH MILE	81.0	11.0	63.0	7.0	8.6	Very Low
ERNAKULAM	Manjalloor [5752]	ACHAKOTTIMALA	81.0	0.0	21.0	60.0	74.1	High
ERNAKULAM	Manjalloor [5752]	ACHANKAVALA	129.0	33.0	87.0	9.0	7.0	Very Low
ERNAKULAM	Manjalloor [5752]	ANICADU TOWER	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Manjalloor [5752]	ARACKAPEEDIKA	81.0	0.0	11.0	70.0	86.4	Very High
ERNAKULAM	Manjalloor [5752]	ARAKUZHA PALLITHAZHAM	81.0	3.0	8.0	70.0	86.4	Very High
ERNAKULAM	Manjalloor [5752]	ARIKUZHA CHURCH	81.0	10.0	47.0	24.0	29.6	Medium
ERNAKULAM	Manjalloor [5752]	ARIKUZHA-1 MOOZHAKAVU	81.0	8.0	37.0	36.0	44.4	Medium
ERNAKULAM	Manjalloor [5752]	ARIKUZHA-2 THRIKKA	81.0	0.0	33.0	48.0	59.3	High
ERNAKULAM	Manjalloor [5752]	AVOLY SOCIETYPADY	81.0	5.0	27.0	49.0	60.5	High
ERNAKULAM	Manjalloor [5752]	AVOLY TEMPLE	129.0	0.0	61.0	68.0	52.7	High
ERNAKULAM	Manjalloor [5752]	BALABHAVAN	81.0	5.0	76.0	0.0	0.0	Very Low
ERNAKULAM	Manjalloor [5752]	BONE MILL	81.0	3.0	19.3	58.7	72.5	High
ERNAKULAM	Manjalloor [5752]	CAPACITOR BANK	81.0	0.0	24.0	57.0	70.4	High
ERNAKULAM	Manjalloor [5752]	CARMEL CHURCH	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Manjalloor [5752]	CARMEL PUBLIC SCHOOL	81.0	10.0	43.0	28.0	34.6	Medium
ERNAKULAM	Manjalloor [5752]	CARMEL TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	CENTRAL FORT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	CHAKKARAS SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	CHANTHIAM	81.0	0.0	31.0	50.0	61.7	High
ERNAKULAM	Manjalloor [5752]	CHENGARA	81.0	5.0	51.5	24.5	30.2	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Manjalloor [5752]	CHIRAKKARA	129.0	0.0	44.3	84.7	65.7	High
ERNAKULAM	Manjalloor [5752]	EASTERN	129.0	10.0	46.0	73.0	56.6	High
ERNAKULAM	Manjalloor [5752]	FAVAZ SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	GANDHINAGAR	81.0	0.0	21.0	60.0	74.1	High
ERNAKULAM	Manjalloor [5752]	HIGHWAY OMNI	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Manjalloor [5752]	INDUS EDAKKATTUKAYATTOM	81.0	11.0	30.4	39.6	48.9	Medium
ERNAKULAM	Manjalloor [5752]	INDUS TOWER VAZHAKULAM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	J B JUNCTION	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Manjalloor [5752]	JAWAN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	JOSCO	129.0	5.0	28.0	96.0	74.4	High
ERNAKULAM	Manjalloor [5752]	JOYAL PLAST	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Manjalloor [5752]	KADALIKKAD	81.0	0.0	56.0	25.0	30.9	Medium
ERNAKULAM	Manjalloor [5752]	KADALIKKAD MADAM	81.0	0.0	6.0	75.0	92.6	Very High
ERNAKULAM	Manjalloor [5752]	KADATHITHAZHAM	81.0	18.0	46.0	17.0	21.0	Low
ERNAKULAM	Manjalloor [5752]	KALAYAKKAD	81.0	0.0	80.2	0.8	1.0	Very Low
ERNAKULAM	Manjalloor [5752]	KALAYAKKAD CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	KANNAMPUZHA BRIDGE	81.0	5.0	52.0	24.0	29.6	Medium
ERNAKULAM	Manjalloor [5752]	KAPPU	202.0	15.0	97.5	89.5	44.3	Medium
ERNAKULAM	Manjalloor [5752]	KAVANA AMBI	129.0	8.0	41.0	80.0	62.0	High
ERNAKULAM	Manjalloor [5752]	KAVANA CREEP	129.0	0.0	36.0	93.0	72.1	High
ERNAKULAM	Manjalloor [5752]	KAVANA KADAVU	405.0	5.0	54.0	346.0	85.4	Very High
ERNAKULAM	Manjalloor [5752]	KAVANA SHAP	81.0	0.0	79.0	2.0	2.4	Very Low
ERNAKULAM	Manjalloor [5752]	KAVANA-1 SNDP	81.0	20.0	57.0	4.0	4.9	Very Low
ERNAKULAM	Manjalloor [5752]	KAVANA-2 SCHOOL	121.0	0.0	15.0	106.0	87.6	Very High
ERNAKULAM	Manjalloor [5752]	KEVALLIKADAVU	81.0	0.0	19.0	62.0	76.5	Very High
ERNAKULAM	Manjalloor [5752]	KIRAN	81.0	0.0	50.7	30.3	37.4	Medium
ERNAKULAM	Manjalloor [5752]	KISHORE THEKKUMMALA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Manjalloor [5752]	KOCHANGADI	129.0	10.0	42.0	77.0	59.7	High
ERNAKULAM	Manjalloor [5752]	KOCHANGADI 4 POLE	81.0	7.0	73.8	0.2	0.3	Very Low
ERNAKULAM	Manjalloor [5752]	KOCHUMUTTAM MARPHY	202.0	0.0	5.0	197.0	97.5	Very High
ERNAKULAM	Manjalloor [5752]	KOLCHIRA	81.0	0.0	35.0	46.0	56.8	High
ERNAKULAM	Manjalloor [5752]	KOTTAMCHERY	81.0	0.0	79.7	1.3	1.6	Very Low
ERNAKULAM	Manjalloor [5752]	LAVENDER	81.0	5.0	40.0	36.0	44.4	Medium
ERNAKULAM	Manjalloor [5752]	M H TIMBERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	MADAKKATHANAM	81.0	0.0	28.0	53.0	65.4	High
ERNAKULAM	Manjalloor [5752]	MADAKKATHANAM KWA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	MALIKAPEEDIKA	129.0	0.0	14.0	115.0	89.1	Very High
ERNAKULAM	Manjalloor [5752]	MANCO	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	MANIYANTHRAM H C	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Manjalloor [5752]	MARACA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	MARIA PARK	129.0	0.0	15.0	114.0	88.4	Very High
ERNAKULAM	Manjalloor [5752]	MARICON	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	MATCH FACTORY	129.0	0.0	10.0	119.0	92.2	Very High
ERNAKULAM	Manjalloor [5752]	MATTUPARA-1 MYLACOMBU	81.0	27.0	51.0	3.0	3.7	Very Low
ERNAKULAM	Manjalloor [5752]	MATTUPARA-2 TOWER	129.0	0.0	29.0	100.0	77.5	Very High
ERNAKULAM	Manjalloor [5752]	MEMADANGU	81.0	5.0	24.0	52.0	64.2	High
ERNAKULAM	Manjalloor [5752]	MULLAPADY	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Manjalloor [5752]	MUPRAKKADU	81.0	0.0	6.0	75.0	92.6	Very High
ERNAKULAM	Manjalloor [5752]	MYTHRY RUBBERS	81.0	3.0	57.3	20.7	25.5	Medium
ERNAKULAM	Manjalloor [5752]	NADUKKARA	81.0	0.0	47.0	34.0	42.0	Medium
ERNAKULAM	Manjalloor [5752]	NEW CARE SURGICALS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	PALAKKATTUTHAZHAM	81.0	15.0	63.0	3.0	3.7	Very Low
ERNAKULAM	Manjalloor [5752]	PALLATHUPARAMBU	81.0	8.0	60.0	13.0	16.0	Low
ERNAKULAM	Manjalloor [5752]	PALLICKAMADATHAZHAM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Manjalloor [5752]	PALLIKKUNNU	81.0	8.0	48.0	25.0	30.9	Medium
ERNAKULAM	Manjalloor [5752]	PANAYAKKUNNU	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Manjalloor [5752]	PANDAPILLY BSNL EXCHANGE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	PANDAPILLY HOSPITAL	81.0	5.0	73.0	3.0	3.7	Very Low
ERNAKULAM	Manjalloor [5752]	PANDAPILLY SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	PANDAPPILLY KWA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	PANDAPPILLY MARKET	81.0	5.0	5.0	71.0	87.7	Very High
ERNAKULAM	Manjalloor [5752]	PANDAPPILLY TOWER	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Manjalloor [5752]	PARAKKADAVU	129.0	0.0	20.0	109.0	84.5	Very High
ERNAKULAM	Manjalloor [5752]	PAREEKAPEEDIKA	81.0	5.0	34.0	42.0	51.9	High
ERNAKULAM	Manjalloor [5752]	PINEAPPLECITY EV CHARGER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	PIRALIMATTOM KWA PUMP HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	PIRALIMATTOM RAW WATER	129.0	23.0	28.6	77.4	60.0	High
ERNAKULAM	Manjalloor [5752]	PIRALIMATTOM TREATMENT PLANT	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	PLATHOTAM	81.0	3.0	3.0	75.0	92.6	Very High
ERNAKULAM	Manjalloor [5752]	POTHUMTHAM	81.0	5.0	39.0	37.0	45.7	Medium
ERNAKULAM	Manjalloor [5752]	PREMIER EDAKKATTUKAYATTOM	81.0	6.6	74.4	0.0	0.0	Very Low
ERNAKULAM	Manjalloor [5752]	PULIMOOTTIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	R F MOTORS KAPPU	81.0	3.0	37.0	41.0	50.6	High
ERNAKULAM	Manjalloor [5752]	REHABILITATION CENTRE	81.0	0.0	31.0	50.0	61.7	High
ERNAKULAM	Manjalloor [5752]	RIVER TERRACE RESORT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	S M PLYWOOD	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	S T JOSEPH SAWMILL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	SANTHINAGAR	81.0	3.0	33.0	45.0	55.6	High
ERNAKULAM	Manjalloor [5752]	ST LITTLE TERESAS SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	ST PIOUS SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	SUPER TECH	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Manjalloor [5752]	THALACHIRA	81.0	3.0	3.0	75.0	92.6	Very High
ERNAKULAM	Manjalloor [5752]	THARANIKAVALA	81.0	3.3	55.3	22.4	27.6	Medium
ERNAKULAM	Manjalloor [5752]	THEKKUMMALA	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Manjalloor [5752]	THOTTAKARA	129.0	0.0	33.0	96.0	74.4	High
ERNAKULAM	Manjalloor [5752]	THOTTAKARA CHURCH	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Manjalloor [5752]	UMAMAHASWARI	81.0	0.0	18.0	63.0	77.8	Very High
ERNAKULAM	Manjalloor [5752]	UNION SAW MILL	129.0	3.0	45.5	80.5	62.4	High
ERNAKULAM	Manjalloor [5752]	UNNIS	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Manjalloor [5752]	VADACODE	81.0	0.0	48.0	33.0	40.7	Medium
ERNAKULAM	Manjalloor [5752]	VADAKKEMURITHAZHAM	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Manjalloor [5752]	VALLIKKADA	81.0	8.0	8.0	65.0	80.2	Very High
ERNAKULAM	Manjalloor [5752]	VATTAKUDI KADAVU	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	VAZHAKULAM BUS STAND	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Manjalloor [5752]	VAZHAKULAM TOWN	129.0	0.0	18.6	110.4	85.6	Very High
ERNAKULAM	Manjalloor [5752]	VELANKADAVU	81.0	0.0	26.0	55.0	67.9	High
ERNAKULAM	Manjalloor [5752]	VENGACHUVADU	81.0	10.0	60.0	11.0	13.6	Low
ERNAKULAM	Manjalloor [5752]	VENGACHUVADU PINEAPPLE COMPANY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	VFCK	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Manjalloor [5752]	VISCO	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Pothanikad [5592]	4TH BLOCK	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Pothanikad [5592]	8TH MILE	81.0	0.0	25.0	56.0	69.1	High
ERNAKULAM	Pothanikad [5592]	90 CENT COLONEY	81.0	0.0	9.8	71.2	87.9	Very High
ERNAKULAM	Pothanikad [5592]	ABBAS	81.0	6.0	11.0	64.0	79.0	Very High
ERNAKULAM	Pothanikad [5592]	ADHITHYA AGENCIES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	ADIVAD CANAL	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Pothanikad [5592]	ADIVAD SCHOOL	81.0	10.0	71.0	0.0	0.0	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Pothanikad [5592]	ADIVAD SOUTH	81.0	0.0	30.0	51.0	63.0	High
ERNAKULAM	Pothanikad [5592]	ADIVADU	202.0	0.0	45.9	156.1	77.3	Very High
ERNAKULAM	Pothanikad [5592]	AKATHOOTTUPADY	81.0	10.0	43.0	28.0	34.6	Medium
ERNAKULAM	Pothanikad [5592]	ANATHUKUZHI	129.0	0.0	3.0	126.0	97.7	Very High
ERNAKULAM	Pothanikad [5592]	ANJALPETTY	81.0	5.0	60.0	16.0	19.8	Low
ERNAKULAM	Pothanikad [5592]	AR PLYWOOD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	ASSOCIATE AGRIGATES	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	AVER 3	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Pothanikad [5592]	AYANKARA	129.0	0.0	38.1	90.8	70.4	High
ERNAKULAM	Pothanikad [5592]	BHARATI	81.0	0.0	16.5	64.5	79.6	Very High
ERNAKULAM	Pothanikad [5592]	BISMI	129.0	10.0	18.0	101.0	78.3	Very High
ERNAKULAM	Pothanikad [5592]	CHACKALACKAN	51.0	0.0	0.0	51.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	CHAKIRI	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	CHATHAMATTAM FOREST	81.0	0.0	20.3	60.7	74.9	High
ERNAKULAM	Pothanikad [5592]	CHATHAMATTOM EXCHANGE	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Pothanikad [5592]	CHELAKKAKADAVU	81.0	0.0	26.0	55.0	67.9	High
ERNAKULAM	Pothanikad [5592]	CHERULI	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Pothanikad [5592]	DINU	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	DOUBLE PARA	81.0	0.0	14.0	67.0	82.7	Very High
ERNAKULAM	Pothanikad [5592]	EASTERN	202.0	25.0	54.0	123.0	60.9	High
ERNAKULAM	Pothanikad [5592]	EDAPPANAPADY	81.0	19.0	57.6	4.4	5.4	Very Low
ERNAKULAM	Pothanikad [5592]	ERAMBRA	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Pothanikad [5592]	ERAMBRA CANAL	81.0	4.0	26.5	50.5	62.3	High
ERNAKULAM	Pothanikad [5592]	FIFA	129.0	0.0	30.0	99.0	76.7	Very High
ERNAKULAM	Pothanikad [5592]	FIFA PLYWOOD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	FINE PLYWOOD PIDAVOOR	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	ICE CREAM MAVUDY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Pothanikad [5592]	IDEAL MANIKINAR	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Pothanikad [5592]	IDUKKI READY MIX	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	III RD WARD	81.0	10.0	0.0	71.0	87.7	Very High
ERNAKULAM	Pothanikad [5592]	ILLICHODU	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Pothanikad [5592]	INCHAKRANTHY	81.0	0.0	51.0	30.0	37.0	Medium
ERNAKULAM	Pothanikad [5592]	INCHOOOR AMBALAMPADY	81.0	13.0	35.0	33.0	40.7	Medium
ERNAKULAM	Pothanikad [5592]	INCHOOOR PIPE	129.0	0.0	5.0	124.0	96.1	Very High
ERNAKULAM	Pothanikad [5592]	IRSHADIYA	129.0	5.0	69.2	54.8	42.5	Medium
ERNAKULAM	Pothanikad [5592]	KADAOOR IDEA	81.0	5.0	28.0	48.0	59.3	High
ERNAKULAM	Pothanikad [5592]	KADAVOOR	129.0	21.0	28.0	80.0	62.0	High
ERNAKULAM	Pothanikad [5592]	KADAVOOR BSNL	81.0	0.0	14.8	66.2	81.7	Very High
ERNAKULAM	Pothanikad [5592]	KAIRALI PLYWOOD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	KAKATTOOR	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Pothanikad [5592]	KALAMPOOR	129.0	5.0	42.2	81.8	63.4	High
ERNAKULAM	Pothanikad [5592]	KALAMPOOR KAVU	81.0	3.0	28.0	50.0	61.7	High
ERNAKULAM	Pothanikad [5592]	KALAMPOORCHURCH	81.0	0.0	37.6	43.4	53.6	High
ERNAKULAM	Pothanikad [5592]	KALLELIL KUNNU	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Pothanikad [5592]	KANDOTHUPADY	81.0	15.0	56.0	10.0	12.3	Low
ERNAKULAM	Pothanikad [5592]	KANNARATHOTTY	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Pothanikad [5592]	KARINGATTUMALIL	81.0	0.0	50.0	31.0	38.3	Medium
ERNAKULAM	Pothanikad [5592]	KOLLANPADY	81.0	8.0	9.0	64.0	79.0	Very High
ERNAKULAM	Pothanikad [5592]	KONNAKKATTU MALA	81.0	5.0	61.0	15.0	18.5	Low
ERNAKULAM	Pothanikad [5592]	KONTHAN PARA	81.0	0.0	12.3	68.7	84.8	Very High
ERNAKULAM	Pothanikad [5592]	KOOTTAMVELY	129.0	6.0	13.3	109.7	85.0	Very High
ERNAKULAM	Pothanikad [5592]	KOOVALLOR	81.0	17.2	28.0	35.8	44.1	Medium
ERNAKULAM	Pothanikad [5592]	KOZHIPPILLY	81.0	3.0	11.0	67.0	82.7	Very High
ERNAKULAM	Pothanikad [5592]	KUDAMUNDA	81.0	3.0	33.0	45.0	55.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Pothanikad [5592]	KUDILI COLONY	81.0	0.0	11.0	70.0	86.4	Very High
ERNAKULAM	Pothanikad [5592]	KULAPPURAM CHURCH	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Pothanikad [5592]	KULAPURAM	129.0	10.0	47.8	71.2	55.2	High
ERNAKULAM	Pothanikad [5592]	KULAPURAM KAPELA	81.0	3.0	5.0	73.0	90.1	Very High
ERNAKULAM	Pothanikad [5592]	KUMMAMKOTTIL	81.0	13.0	37.3	30.7	37.9	Medium
ERNAKULAM	Pothanikad [5592]	KUNNEKUDIYIL PLYWOOD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	KURUPPUKANDOM	81.0	5.0	26.0	50.0	61.7	High
ERNAKULAM	Pothanikad [5592]	LAS CIGAL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	M AND S WOOD	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	M S M	129.0	0.0	14.0	115.0	89.1	Very High
ERNAKULAM	Pothanikad [5592]	MADAPARAMBIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	MADATHOTHUPARA	81.0	8.0	55.8	17.2	21.2	Low
ERNAKULAM	Pothanikad [5592]	MADIYOOR	81.0	4.2	9.0	67.8	83.7	Very High
ERNAKULAM	Pothanikad [5592]	MADIYOOR M-SAND	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Pothanikad [5592]	MADOM PADY	129.0	3.0	34.0	92.0	71.3	High
ERNAKULAM	Pothanikad [5592]	MAHARAJ	81.0	0.0	20.3	60.7	74.9	High
ERNAKULAM	Pothanikad [5592]	MANALODY	81.0	0.0	19.0	62.0	76.5	Very High
ERNAKULAM	Pothanikad [5592]	MANIKINAR	81.0	8.1	3.0	69.9	86.3	Very High
ERNAKULAM	Pothanikad [5592]	MAVUDI	129.0	10.0	20.0	99.0	76.7	Very High
ERNAKULAM	Pothanikad [5592]	MAVUDI CANAL	81.0	3.0	0.0	78.0	96.3	Very High
ERNAKULAM	Pothanikad [5592]	MAVUDI PALAM	81.0	4.9	63.2	12.9	15.9	Low
ERNAKULAM	Pothanikad [5592]	MAVUDI SCHOOL	81.0	5.0	7.0	69.0	85.2	Very High
ERNAKULAM	Pothanikad [5592]	MENMA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	MENMA-2	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	METHRANKOOPPU	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	MINAR	81.0	5.0	15.0	61.0	75.3	Very High
ERNAKULAM	Pothanikad [5592]	MOOZHICKAMYALIL	81.0	19.0	50.0	12.0	14.8	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Pothanikad [5592]	MOOZHITHODU	129.0	0.0	13.0	116.0	89.9	Very High
ERNAKULAM	Pothanikad [5592]	MS PLYWOOD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	MUKKANNI	129.0	0.0	18.0	111.0	86.0	Very High
ERNAKULAM	Pothanikad [5592]	MUKKANNI HOLLOW BRIKS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	MULLANKUTHI	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Pothanikad [5592]	MYLOOR	81.0	14.0	65.8	1.2	1.5	Very Low
ERNAKULAM	Pothanikad [5592]	MYLOORTHADOM	81.0	0.0	11.0	70.0	86.4	Very High
ERNAKULAM	Pothanikad [5592]	NAJEEB CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	NATHUKANNI	81.0	6.0	8.0	67.0	82.7	Very High
ERNAKULAM	Pothanikad [5592]	NEUCLEUS PLY	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	NJARAKKADU	81.0	5.0	14.9	61.1	75.4	Very High
ERNAKULAM	Pothanikad [5592]	NORTH PUNNAMATTAM	81.0	0.0	9.0	72.0	88.9	Very High
ERNAKULAM	Pothanikad [5592]	OLICKATHAZHAM	81.0	10.0	5.0	66.0	81.5	Very High
ERNAKULAM	Pothanikad [5592]	OSCAR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	PADAM	81.0	5.0	21.0	55.0	67.9	High
ERNAKULAM	Pothanikad [5592]	PADIKKAMATTOM	81.0	0.0	30.0	51.0	63.0	High
ERNAKULAM	Pothanikad [5592]	PAIMATTOM	129.0	5.0	30.0	94.0	72.9	High
ERNAKULAM	Pothanikad [5592]	PAIMATTOM PLYWOOD	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	PAINGOTTOOE SERVICE STATION	81.0	0.0	52.8	28.2	34.8	Medium
ERNAKULAM	Pothanikad [5592]	PAINGOTTOOR CHURCH	81.0	10.0	39.0	32.0	39.5	Medium
ERNAKULAM	Pothanikad [5592]	PAINGOTTOOR SCHOOL	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	PAINGOTTOOR STAND	81.0	5.0	31.5	44.5	54.9	High
ERNAKULAM	Pothanikad [5592]	PAINGOTTOOR TEMPLE	81.0	0.0	32.0	49.0	60.5	High
ERNAKULAM	Pothanikad [5592]	PAIUS CREEP	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	PALAKKADAN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	PALLARIMANGALAM SAW MILL	81.0	5.0	54.0	22.0	27.2	Medium
ERNAKULAM	Pothanikad [5592]	PALLARIMANGALAM TOWN	81.0	11.0	67.3	2.7	3.3	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Pothanikad [5592]	PALLIKUNNU	81.0	20.0	61.0	0.0	0.0	Very Low
ERNAKULAM	Pothanikad [5592]	PANAMKARA	81.0	5.0	26.0	50.0	61.7	High
ERNAKULAM	Pothanikad [5592]	PANJITHAZHAM	81.0	5.0	37.0	39.0	48.1	Medium
ERNAKULAM	Pothanikad [5592]	PARAMPANCHERI	81.0	5.0	33.4	42.6	52.7	High
ERNAKULAM	Pothanikad [5592]	PARAMPANCHERI PUMP	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Pothanikad [5592]	PARAMPANCHERI STAR	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	PARATHAZHAM	81.0	3.0	10.0	68.0	84.0	Very High
ERNAKULAM	Pothanikad [5592]	PAREPADY	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Pothanikad [5592]	PB BOARDS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	PERINEER	81.0	3.0	16.4	61.6	76.0	Very High
ERNAKULAM	Pothanikad [5592]	PERIYAR	129.0	3.0	0.0	126.0	97.7	Very High
ERNAKULAM	Pothanikad [5592]	PIDAVOOR	81.0	13.8	52.3	14.9	18.4	Low
ERNAKULAM	Pothanikad [5592]	PIDAVOOR KAVUMPADY	81.0	5.0	18.0	58.0	71.6	High
ERNAKULAM	Pothanikad [5592]	PIDAVOOR PDDP	81.0	5.0	25.0	51.0	63.0	High
ERNAKULAM	Pothanikad [5592]	PITTAPPILLY	81.0	0.0	28.0	53.0	65.4	High
ERNAKULAM	Pothanikad [5592]	PMA MADIYOOR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	POTHAKULAM	81.0	13.0	14.0	54.0	66.7	High
ERNAKULAM	Pothanikad [5592]	POTHANAKAVU	81.0	4.8	35.7	40.5	50.0	Medium
ERNAKULAM	Pothanikad [5592]	POTHANICAD 4POLE	129.0	0.0	68.0	61.0	47.3	Medium
ERNAKULAM	Pothanikad [5592]	POTHANICAD KSEB	202.0	3.0	71.3	127.7	63.2	High
ERNAKULAM	Pothanikad [5592]	POTHANICADU IDEA	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Pothanikad [5592]	PRINCE PLYWOOD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	PULIKKUNNEPADY	81.0	5.0	22.0	54.0	66.7	High
ERNAKULAM	Pothanikad [5592]	PULINTHANAM FLUX	81.0	5.0	57.3	18.7	23.1	Low
ERNAKULAM	Pothanikad [5592]	PULINTHANAM PALAM	81.0	5.0	12.0	64.0	79.0	Very High
ERNAKULAM	Pothanikad [5592]	PULIYANPARA	129.0	3.0	19.0	107.0	82.9	Very High
ERNAKULAM	Pothanikad [5592]	PULPRAPEEDIKA	81.0	3.0	60.9	17.1	21.1	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Pothanikad [5592]	RELIANCE ADIVAD	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	SAKTHY	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	SHALIMAR PLY	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	SHANTHI NAGAR	81.0	20.0	51.0	10.0	12.3	Low
ERNAKULAM	Pothanikad [5592]	SHIBU GRANITE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	SIDHENPADI	129.0	8.0	73.0	48.0	37.2	Medium
ERNAKULAM	Pothanikad [5592]	SILCO	129.0	0.0	5.0	124.0	96.1	Very High
ERNAKULAM	Pothanikad [5592]	SOUTH PUNNAMATTAM	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Pothanikad [5592]	SUNNY	81.0	0.0	44.0	37.0	45.7	Medium
ERNAKULAM	Pothanikad [5592]	SURAPADY	129.0	0.0	17.0	112.0	86.8	Very High
ERNAKULAM	Pothanikad [5592]	TEACHERS COLONY	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Pothanikad [5592]	THACHALI PUMP	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	THACHLIKADAVU	129.0	0.0	28.0	101.0	78.3	Very High
ERNAKULAM	Pothanikad [5592]	THARAMUTTAM	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Pothanikad [5592]	THEKEKUNNU	81.0	0.0	66.1	14.9	18.4	Low
ERNAKULAM	Pothanikad [5592]	THRIKKEPADI	81.0	10.0	28.3	42.7	52.7	High
ERNAKULAM	Pothanikad [5592]	THRIKKEPADI TEMPLE	81.0	0.0	45.6	35.4	43.7	Medium
ERNAKULAM	Pothanikad [5592]	THRIPPALLI	81.0	0.0	14.0	67.0	82.7	Very High
ERNAKULAM	Pothanikad [5592]	ULTRA PLYWOOD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	UNILAND PLY	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	UNIQUE PARATHAZHAM	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	UNITED PLYWWOD	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	UPPUKUZHI	129.0	0.0	6.0	123.0	95.3	Very High
ERNAKULAM	Pothanikad [5592]	VAKATHIPARA KINAR	81.0	0.0	8.0	73.0	90.2	Very High
ERNAKULAM	Pothanikad [5592]	VAKKATHIPARA	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Pothanikad [5592]	VALACHIRA	81.0	5.0	12.0	64.0	79.0	Very High
ERNAKULAM	Pothanikad [5592]	VALLAKADAVU	81.0	3.0	21.0	57.0	70.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Pothanikad [5592]	VALLIKANDOM	81.0	0.0	21.0	60.0	74.1	High
ERNAKULAM	Pothanikad [5592]	VARAMBUPARA	81.0	0.0	39.2	41.8	51.6	High
ERNAKULAM	Pothanikad [5592]	VARAPETTY	202.0	12.0	53.0	137.0	67.8	High
ERNAKULAM	Pothanikad [5592]	VARAPETTY EXCHANGE	81.0	26.0	53.2	1.8	2.2	Very Low
ERNAKULAM	Pothanikad [5592]	VARAPPETTY SOCITY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Pothanikad [5592]	VATTAKUDY PEDIKA	129.0	3.0	39.0	87.0	67.4	High
ERNAKULAM	Pothanikad [5592]	VETTITHARA	81.0	5.0	24.0	52.0	64.2	High
ERNAKULAM	Pothanikad [5592]	VILAKKATH	81.0	8.0	28.0	45.0	55.6	High
ERNAKULAM	Pothanikad [5592]	VIMALJYOTHI	81.0	0.0	19.0	62.0	76.5	Very High
ERNAKULAM	Pothanikad [5592]	WESTERN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	A R PLASTIC	129.0	5.0	55.0	69.0	53.5	High
ERNAKULAM	Thodupuzha-I [5618]	A S PRINTERS	81.0	25.0	0.0	56.0	69.1	High
ERNAKULAM	Thodupuzha-I [5618]	ADAM STAR	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	AFFINITY TOWER KOTHAYIKUNNU	324.0	0.0	40.0	284.0	87.7	Very High
ERNAKULAM	Thodupuzha-I [5618]	AHALYA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	AIRTEL MADAPARAMBIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	AISWARIA RESIDENCY	81.0	17.0	36.0	28.0	34.6	Medium
ERNAKULAM	Thodupuzha-I [5618]	AISWARYA	81.0	0.0	30.5	50.5	62.4	High
ERNAKULAM	Thodupuzha-I [5618]	AJEES VALLEY VIEW APT	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ALANTA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ALPARA TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
ERNAKULAM	Thodupuzha-I [5618]	ANAKKUDU JN	129.0	10.0	33.0	86.0	66.7	High
ERNAKULAM	Thodupuzha-I [5618]	ANAKKUDU KADAVU	81.0	0.0	29.0	52.0	64.2	High
ERNAKULAM	Thodupuzha-I [5618]	ANGAMVETTY	129.0	8.0	17.0	104.0	80.6	Very High
ERNAKULAM	Thodupuzha-I [5618]	ANGAMVETTY MARVEL BED	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ANGAMVETTY-KAMPIPALAM	81.0	3.0	18.0	60.0	74.1	High
ERNAKULAM	Thodupuzha-I [5618]	ANGAMVETTY-STADIUM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-I [5618]	ARACKAPARA	81.0	8.0	37.0	36.0	44.4	Medium
ERNAKULAM	Thodupuzha-I [5618]	ARAVALLIKAVU	81.0	5.0	20.0	56.0	69.1	High
ERNAKULAM	Thodupuzha-I [5618]	ARCHANA	129.0	0.0	29.8	99.2	76.9	Very High
ERNAKULAM	Thodupuzha-I [5618]	ARCHANA HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ARIKKUZHA-PARAKKADAVU	81.0	3.0	5.0	73.0	90.1	Very High
ERNAKULAM	Thodupuzha-I [5618]	ARIKUZHA CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ARIKUZHA FARM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ARIKUZHA HS	129.0	3.0	59.5	66.5	51.6	High
ERNAKULAM	Thodupuzha-I [5618]	ASHIKA PRESS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ATHEENA ARCADE	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Thodupuzha-I [5618]	AUTO BODY	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Thodupuzha-I [5618]	AXIS BANK	81.0	0.0	23.6	57.4	70.9	High
ERNAKULAM	Thodupuzha-I [5618]	BRAHMINS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	BRAHMINS SUPERMARKET	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	BRUTEC PHARMA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	BSNL CUSTOMER CARE	202.0	0.0	10.0	192.0	95.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	BSNL EXCHANGE ROAD	81.0	0.0	47.3	33.7	41.6	Medium
ERNAKULAM	Thodupuzha-I [5618]	BSNL QUARTERS	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Thodupuzha-I [5618]	BSNL VENGALLOOR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CANARA BANK	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CARMEL	202.0	0.0	5.0	197.0	97.5	Very High
ERNAKULAM	Thodupuzha-I [5618]	CHARALIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CHATHANANIKKALPARA	129.0	0.0	18.0	111.0	86.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CHENGANATTUPALAM	81.0	10.0	30.5	40.5	50.0	High
ERNAKULAM	Thodupuzha-I [5618]	CHITTOOR CHURCH	81.0	3.0	13.0	65.0	80.2	Very High
ERNAKULAM	Thodupuzha-I [5618]	CHORAPPUZHA	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CHUMKAM ADAPPU	129.0	5.0	33.0	91.0	70.5	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-I [5618]	CHUMKAM CHURCH	81.0	5.0	29.9	46.1	57.0	High
ERNAKULAM	Thodupuzha-I [5618]	CHUMKAM-KOLLIKKADU JN	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Thodupuzha-I [5618]	CITY GATE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CITYMALL	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CIVIL STATION	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CIVILSTATION-INDOOR	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CO-OP HOSPITAL	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CO-OP SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	CRIPTAMS	81.0	35.0	20.7	25.3	31.2	Medium
ERNAKULAM	Thodupuzha-I [5618]	DAYA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	DHANWANTHARY JN	202.0	0.0	6.0	196.0	97.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	DHANWNATHARI FACTORY	129.0	0.0	25.0	104.0	80.6	Very High
ERNAKULAM	Thodupuzha-I [5618]	DIVYARAKSHALAYAM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	DREAM MALL LT	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	EAP PVT	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	EASTERN MATTRESSES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	EDAMANNIKKAL	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	EDASSERY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ENGG COLLEGE MUTTOM	129.0	0.0	100.0	29.0	22.5	Low
ERNAKULAM	Thodupuzha-I [5618]	ERUKUMPUZHA	81.0	5.0	50.0	26.0	32.1	Medium
ERNAKULAM	Thodupuzha-I [5618]	ERUKUMPUZHAPPALAM	81.0	5.0	41.0	35.0	43.2	Medium
ERNAKULAM	Thodupuzha-I [5618]	FACIO	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	FRAY ARCADE	129.0	0.0	10.0	119.0	92.2	Very High
ERNAKULAM	Thodupuzha-I [5618]	GEMINI	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	GEORGE TOWN	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	GHSS THODUPUZHA	129.0	10.0	40.0	79.0	61.2	High
ERNAKULAM	Thodupuzha-I [5618]	GURU-ITC	129.0	5.0	70.5	53.5	41.5	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-I [5618]	GURUNAGAR	81.0	5.0	14.0	62.0	76.5	Very High
ERNAKULAM	Thodupuzha-I [5618]	HDFC BANK	81.0	0.0	6.0	75.0	92.6	Very High
ERNAKULAM	Thodupuzha-I [5618]	HIGHRANGE RESIDENCY	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	HILLY ACQUA CHARGING STATION	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	HONDA	129.0	5.0	5.0	119.0	92.2	Very High
ERNAKULAM	Thodupuzha-I [5618]	HORIZON MOTORS AANAKKODU JN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	HORIZON MOTORS VENGALLOOR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	HOUSING BOARD	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Thodupuzha-I [5618]	IDBI	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	IMA THODUPUZZHA	81.0	0.0	29.0	52.0	64.2	High
ERNAKULAM	Thodupuzha-I [5618]	INDIAN BAKERY BORMA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	INDUS WORKSHOP	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	INDUSMOTORS TPZA	129.0	0.0	9.9	119.1	92.3	Very High
ERNAKULAM	Thodupuzha-I [5618]	INTEREXT	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	JAIL MUTTOM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	JAYARANI	81.0	0.0	43.0	38.0	46.9	Medium
ERNAKULAM	Thodupuzha-I [5618]	JESUS TOWER PAYNKULAM	81.0	0.0	30.0	51.0	63.0	High
ERNAKULAM	Thodupuzha-I [5618]	JOANCE LAKE VIEW	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	JOTHY SUPERBAZAR	202.0	0.0	5.0	197.0	97.5	Very High
ERNAKULAM	Thodupuzha-I [5618]	K P CHACKO AND SONS	81.0	34.0	0.0	47.0	58.0	High
ERNAKULAM	Thodupuzha-I [5618]	K S E B-II	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Thodupuzha-I [5618]	KADS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KAITHAKODU	202.0	8.0	25.0	169.0	83.7	Very High
ERNAKULAM	Thodupuzha-I [5618]	KALARIKKAL	202.0	0.0	10.0	192.0	95.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KALYAN CANDERE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KANDATHINKARA	81.0	5.0	32.0	44.0	54.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-I [5618]	KANNADIPARA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KARUNA	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Thodupuzha-I [5618]	KGEES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KKJ POLYMER ARIKKUHZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KKJ POLYMER ARIKKUZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KOCHU VEMBILLIL-PERUKONI	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Thodupuzha-I [5618]	KODATHY JUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KOKANDATHIL PLASA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KOLANI	202.0	10.0	79.5	112.5	55.7	High
ERNAKULAM	Thodupuzha-I [5618]	KOLANI TEMPLE	129.0	15.0	53.0	61.0	47.3	Medium
ERNAKULAM	Thodupuzha-I [5618]	KONATTUPLAZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KOTHAIKUNNU-BYPASS	81.0	0.0	31.3	49.7	61.4	High
ERNAKULAM	Thodupuzha-I [5618]	KOVILAMKAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KSEB	81.0	0.0	55.0	26.0	32.1	Medium
ERNAKULAM	Thodupuzha-I [5618]	KSRTC DEPO	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KSRTC JN	129.0	0.0	43.6	85.4	66.2	High
ERNAKULAM	Thodupuzha-I [5618]	KUDUKKAMATTOM	81.0	0.0	81.0	0.0	0.0	Very Low
ERNAKULAM	Thodupuzha-I [5618]	KUMARAMANGALAM PULINCHUVADU	81.0	0.0	22.0	59.0	72.8	High
ERNAKULAM	Thodupuzha-I [5618]	KUNNATHUPARA KULAM	129.0	3.0	47.8	78.2	60.6	High
ERNAKULAM	Thodupuzha-I [5618]	KUNNATHUPARA KWA	129.0	0.0	5.0	124.0	96.1	Very High
ERNAKULAM	Thodupuzha-I [5618]	KUNNATHUPARA VILLA	129.0	0.0	11.0	118.0	91.5	Very High
ERNAKULAM	Thodupuzha-I [5618]	KURUTTUKULAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	KWA MRALA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	LUNAR OLAMATTOM	81.0	5.0	36.0	40.0	49.4	Medium
ERNAKULAM	Thodupuzha-I [5618]	MADATHIPALLY	81.0	3.0	73.2	4.8	5.9	Very Low
ERNAKULAM	Thodupuzha-I [5618]	MADONA	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-I [5618]	MAHARANI MEGAMART	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MAITHANAM	405.0	5.0	43.0	357.0	88.1	Very High
ERNAKULAM	Thodupuzha-I [5618]	MANAKAD RELAINCE	81.0	5.0	34.0	42.0	51.9	High
ERNAKULAM	Thodupuzha-I [5618]	MANAKAD-IDEA	81.0	0.0	15.0	66.0	81.5	Very High
ERNAKULAM	Thodupuzha-I [5618]	MANAKADU H S	81.0	5.0	53.3	22.7	28.0	Medium
ERNAKULAM	Thodupuzha-I [5618]	MANAKKAD HATCHERY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MANAKKAD MINI	202.0	0.0	31.0	171.0	84.7	Very High
ERNAKULAM	Thodupuzha-I [5618]	MANGALAM-I	129.0	0.0	10.0	119.0	92.2	Very High
ERNAKULAM	Thodupuzha-I [5618]	MANGALAM-II	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MANNATHANCHERI	81.0	20.0	50.5	10.5	13.0	Low
ERNAKULAM	Thodupuzha-I [5618]	MARIKALUNK	129.0	0.0	20.2	108.8	84.3	Very High
ERNAKULAM	Thodupuzha-I [5618]	MARKET	81.0	0.0	23.3	57.7	71.2	High
ERNAKULAM	Thodupuzha-I [5618]	MATHA SHOPPING ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MATTUPARA	81.0	9.2	46.5	25.4	31.3	Medium
ERNAKULAM	Thodupuzha-I [5618]	METHALAPPARA KWA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MOON-INDUSTRIES	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MOURYA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MRALA	81.0	12.0	16.9	52.1	64.3	High
ERNAKULAM	Thodupuzha-I [5618]	MSHEP	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MULLAKKAL	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Thodupuzha-I [5618]	MUNDEKALLU	129.0	5.0	31.0	93.0	72.1	High
ERNAKULAM	Thodupuzha-I [5618]	MUNICIPAL OFFICE	81.0	0.0	30.0	51.0	63.0	High
ERNAKULAM	Thodupuzha-I [5618]	MUTTAM POLY	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Thodupuzha-I [5618]	MUTTAM-INDUSTRY-1	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MUTTAM-INDUSTRY-2	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MUTTAM-INDUSTRY-3	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	MVIP	129.0	0.0	20.0	109.0	84.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-I [5618]	MYLACOMBU	81.0	5.0	20.0	56.0	69.1	High
ERNAKULAM	Thodupuzha-I [5618]	MYLACOMBU TOWER	81.0	25.0	18.0	38.0	46.9	Medium
ERNAKULAM	Thodupuzha-I [5618]	NANDILATH VENGALLOOR	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	NEDUMPURATHU TOWER CHARGING ST	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	NELCOS JUNCTION	129.0	3.0	61.0	65.0	50.4	High
ERNAKULAM	Thodupuzha-I [5618]	NELLIKAVU	129.0	18.0	103.2	7.8	6.1	Very Low
ERNAKULAM	Thodupuzha-I [5618]	OLAMATTAM MINI-1	405.0	0.0	18.0	387.0	95.6	Very High
ERNAKULAM	Thodupuzha-I [5618]	OLAMATTAM MINI-2	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	OLAMATTOM MINI-3	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	OLD MONK	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	OZHATHIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PACHOORTHAND	81.0	4.0	24.0	53.0	65.4	High
ERNAKULAM	Thodupuzha-I [5618]	PALLIPEEDIKA	202.0	18.0	110.3	73.7	36.5	Medium
ERNAKULAM	Thodupuzha-I [5618]	PANCHAYATH KAVALA	81.0	8.0	14.0	59.0	72.8	High
ERNAKULAM	Thodupuzha-I [5618]	PAPPOOTY HALL	129.0	0.0	18.0	111.0	86.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PARA JN	81.0	0.0	80.8	0.2	0.2	Very Low
ERNAKULAM	Thodupuzha-I [5618]	PAULSON TYRES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PAYNKULAM	129.0	0.0	60.8	68.2	52.8	High
ERNAKULAM	Thodupuzha-I [5618]	PERIYAMPRA CHURCH	81.0	5.0	0.0	76.0	93.8	Very High
ERNAKULAM	Thodupuzha-I [5618]	PERUMATTOM	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PETERS NINE RIVER BAY	510.0	0.0	5.0	505.0	99.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PHC PPM	81.0	0.0	23.0	58.0	71.6	High
ERNAKULAM	Thodupuzha-I [5618]	PHED	202.0	5.0	48.6	148.4	73.5	High
ERNAKULAM	Thodupuzha-I [5618]	PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PONNAMTHANAM SHAP	81.0	5.0	16.0	60.0	74.1	High
ERNAKULAM	Thodupuzha-I [5618]	PRECIOUS HYUNDAI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-I [5618]	PRINCE CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PULIMOOTIL ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PULIMOOTIL JAKES	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PULIMOOTIL MALL	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PUTHIRY TOWER	255.0	0.0	5.0	250.0	98.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	PUTHUPPARIYARAM	129.0	6.0	21.5	101.5	78.7	Very High
ERNAKULAM	Thodupuzha-I [5618]	PUTHUSSERIYIL	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Thodupuzha-I [5618]	PVT BUS STAND	129.0	0.0	4.6	124.4	96.4	Very High
ERNAKULAM	Thodupuzha-I [5618]	PWD	129.0	0.0	23.0	106.0	82.2	Very High
ERNAKULAM	Thodupuzha-I [5618]	QUEENMARY SAWMILL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	RAVI	202.0	5.0	84.0	113.0	55.9	High
ERNAKULAM	Thodupuzha-I [5618]	RIVA TRANSFORMER	510.0	0.0	30.0	480.0	94.1	Very High
ERNAKULAM	Thodupuzha-I [5618]	RIVER VIEW	81.0	5.0	59.6	16.4	20.2	Low
ERNAKULAM	Thodupuzha-I [5618]	ROCK VIEW	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Thodupuzha-I [5618]	ROTARY	129.0	0.0	20.0	109.0	84.5	Very High
ERNAKULAM	Thodupuzha-I [5618]	ROY ROGER TOWER	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ROYAL GARDEN VILLA	202.0	8.0	10.0	184.0	91.1	Very High
ERNAKULAM	Thodupuzha-I [5618]	RUPESH PULIMOOTIL	129.0	0.0	9.0	120.0	93.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	SANIYA	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Thodupuzha-I [5618]	SARO PLAST	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	SICILIA TPZA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	SPUN PIPES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ST MICHAELS ARCADE THENAMKUNNU	324.0	0.0	0.0	324.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ST SEBASTIANS CHURCH	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Thodupuzha-I [5618]	SUNDARAM TOWER VENGALLOOR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	SURYA-INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-I [5618]	T C	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	TBTFR	202.0	8.0	14.0	180.0	89.1	Very High
ERNAKULAM	Thodupuzha-I [5618]	TCM	129.0	0.0	23.0	106.0	82.2	Very High
ERNAKULAM	Thodupuzha-I [5618]	TEMPLE	129.0	0.0	49.6	79.4	61.6	High
ERNAKULAM	Thodupuzha-I [5618]	THACHETTU NAGAR	202.0	0.0	116.0	86.0	42.6	Medium
ERNAKULAM	Thodupuzha-I [5618]	THANAPPANAL	129.0	18.0	70.2	40.8	31.6	Medium
ERNAKULAM	Thodupuzha-I [5618]	THENAMKUNNU CHURCH	81.0	0.0	14.7	66.3	81.9	Very High
ERNAKULAM	Thodupuzha-I [5618]	THERESA	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	VARKEYS MALL	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	VATTAPPILLIL SQUARE	81.0	0.0	19.8	61.2	75.6	Very High
ERNAKULAM	Thodupuzha-I [5618]	VELIYATHUMALIL ESTATE	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	VENGALLOOR CO AXIAL	405.0	5.0	75.8	324.2	80.1	Very High
ERNAKULAM	Thodupuzha-I [5618]	VENGALLOOR JN	202.0	11.0	99.3	91.7	45.4	Medium
ERNAKULAM	Thodupuzha-I [5618]	VENGALLOOR PALAM	81.0	0.0	37.0	44.0	54.3	High
ERNAKULAM	Thodupuzha-I [5618]	VENGALLOOR VANITHA-INDST	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Thodupuzha-I [5618]	VENGALLOOR-PALLIKKUTTY	129.0	15.2	19.3	94.5	73.3	High
ERNAKULAM	Thodupuzha-I [5618]	VENGALLOOR SBI	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	VENGATHANAM	81.0	10.0	46.0	25.0	30.9	Medium
ERNAKULAM	Thodupuzha-I [5618]	VENGATHANAM-2	81.0	0.0	20.0	61.0	75.3	Very High
ERNAKULAM	Thodupuzha-I [5618]	VIGILANCE VALLY	81.0	7.5	53.0	20.5	25.3	Medium
ERNAKULAM	Thodupuzha-I [5618]	VIJAYA POLYMER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	VIJAYA SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	VISHNU BHAVAN	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	VYUGA SHOES	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	WILD REIN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-I [5618]	ZIYARA HEIGHTS VENGALLOOR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	ABEY	81.0	0.0	61.0	20.0	24.7	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-II [5620]	ALPHONSA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	ANGEL BORMA	81.0	0.0	31.6	49.4	61.0	High
ERNAKULAM	Thodupuzha-II [5620]	ANILKUMAR	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	ARCHANA MANGATTUKAVALA	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	ARPAMATTOM	81.0	5.0	3.0	73.0	90.1	Very High
ERNAKULAM	Thodupuzha-II [5620]	ATTAKKULOM	129.0	2.0	35.0	92.0	71.3	High
ERNAKULAM	Thodupuzha-II [5620]	AYURVEDA HOSPITAL	129.0	0.0	13.0	116.0	89.9	Very High
ERNAKULAM	Thodupuzha-II [5620]	BRAHMINS FROZEN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	CHERUTHOTTINKARA	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Thodupuzha-II [5620]	CHESHTASYA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	CHOZHAMKUDY PUMP	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	CHURULI	81.0	10.0	50.5	20.5	25.3	Medium
ERNAKULAM	Thodupuzha-II [5620]	DE PAUL	202.0	0.0	64.9	137.1	67.9	High
ERNAKULAM	Thodupuzha-II [5620]	DIET	81.0	9.0	22.0	50.0	61.7	High
ERNAKULAM	Thodupuzha-II [5620]	DOLPHIN	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	EMPEES TIMBERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	EMPEES TOWER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	EXCEL ENTERPRISES	129.0	0.0	50.0	79.0	61.2	High
ERNAKULAM	Thodupuzha-II [5620]	EZHALLOOR	202.0	5.0	26.0	171.0	84.7	Very High
ERNAKULAM	Thodupuzha-II [5620]	EZHALLOOR SASTHA	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	HANNA POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	HERO	81.0	0.0	15.8	65.2	80.6	Very High
ERNAKULAM	Thodupuzha-II [5620]	HONDA CITY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	HOUSING BOARD	255.0	0.0	75.2	179.8	70.5	High
ERNAKULAM	Thodupuzha-II [5620]	HOUSING COLONY	51.0	0.0	0.0	51.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	KALLUMARI CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	KALLUMARY	81.0	11.0	29.0	41.0	50.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-II [5620]	KANJIRAMATTOM	129.0	5.0	40.0	84.0	65.1	High
ERNAKULAM	Thodupuzha-II [5620]	KANJIRAMATTOM BY PASS	81.0	0.0	30.9	50.1	61.9	High
ERNAKULAM	Thodupuzha-II [5620]	KANJIRAMPARA	81.0	3.0	26.0	52.0	64.2	High
ERNAKULAM	Thodupuzha-II [5620]	KAPPITHOTTOM KURISUPALLY	81.0	5.0	43.9	32.1	39.6	Medium
ERNAKULAM	Thodupuzha-II [5620]	KARIKULAM	81.0	0.0	7.7	73.3	90.5	Very High
ERNAKULAM	Thodupuzha-II [5620]	KAROOPPARA	81.0	0.0	30.0	51.0	63.0	High
ERNAKULAM	Thodupuzha-II [5620]	KARUKA	81.0	10.0	34.0	37.0	45.7	Medium
ERNAKULAM	Thodupuzha-II [5620]	KARUKA CANAL	81.0	8.0	21.0	52.0	64.2	High
ERNAKULAM	Thodupuzha-II [5620]	KEERIKODE COLONY	81.0	0.0	57.0	24.0	29.6	Medium
ERNAKULAM	Thodupuzha-II [5620]	KEERIYODE	81.0	19.6	26.0	35.4	43.7	Medium
ERNAKULAM	Thodupuzha-II [5620]	KKR-1	129.0	0.0	12.9	116.1	90.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	KKR-2	81.0	0.0	78.2	2.8	3.5	Very Low
ERNAKULAM	Thodupuzha-II [5620]	KONICKAMALY	81.0	5.0	52.6	23.4	28.8	Medium
ERNAKULAM	Thodupuzha-II [5620]	KOTTAPPALAM	81.0	31.0	33.8	16.2	20.0	Low
ERNAKULAM	Thodupuzha-II [5620]	KRISHNA OIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	KRISHNAPILLAI	81.0	5.0	66.7	9.3	11.5	Low
ERNAKULAM	Thodupuzha-II [5620]	KUMARAMANGALAM	202.0	0.0	20.0	182.0	90.1	Very High
ERNAKULAM	Thodupuzha-II [5620]	KUMBAMKALLU	129.0	24.6	69.0	35.4	27.4	Medium
ERNAKULAM	Thodupuzha-II [5620]	KUMBANKALLU AUTO BODY	81.0	0.0	13.0	68.0	84.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	KUMBANKALLU SCHOOL	81.0	3.3	77.0	0.7	0.8	Very Low
ERNAKULAM	Thodupuzha-II [5620]	KUNNAM	202.0	8.0	83.0	111.0	55.0	High
ERNAKULAM	Thodupuzha-II [5620]	LIC	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	MADAPARAMBIL CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	MADATHIKANDAM	81.0	8.0	30.0	43.0	53.1	High
ERNAKULAM	Thodupuzha-II [5620]	MALANKARA RAW WATER KWA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	MALIKA PEEDIKA	81.0	5.0	29.0	47.0	58.0	High
ERNAKULAM	Thodupuzha-II [5620]	MANGALATHUKADAVU	81.0	8.0	45.0	28.0	34.6	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-II [5620]	MANGATTUKAVALA	129.0	10.0	48.6	70.4	54.5	High
ERNAKULAM	Thodupuzha-II [5620]	MANGATTUKAVALA MUNICIPALCOMPLEX	202.0	0.0	0.0	202.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	MARAMKUNNU	81.0	16.0	32.4	32.6	40.2	Medium
ERNAKULAM	Thodupuzha-II [5620]	MARIYIL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	MAVINCHUVADU	202.0	13.3	73.6	115.1	57.0	High
ERNAKULAM	Thodupuzha-II [5620]	MENONPARAMBU	81.0	3.0	31.3	46.7	57.7	High
ERNAKULAM	Thodupuzha-II [5620]	MMK TYERS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	MOOPILKADAVU	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	MUTHALAKODAM 4 POLE	129.0	8.0	13.0	108.0	83.7	Very High
ERNAKULAM	Thodupuzha-II [5620]	MUTHALAKODAM CANAL	81.0	0.0	42.0	39.0	48.1	Medium
ERNAKULAM	Thodupuzha-II [5620]	MUTHALAKODAM CHURCH	202.0	0.0	40.0	162.0	80.2	Very High
ERNAKULAM	Thodupuzha-II [5620]	MUTHALAKODAM GROUND	81.0	5.0	48.2	27.8	34.3	Medium
ERNAKULAM	Thodupuzha-II [5620]	MUTHALAKODAM NURSING	81.0	0.0	65.0	16.0	19.8	Low
ERNAKULAM	Thodupuzha-II [5620]	MUTHALIYARMADAM-2	81.0	25.0	53.0	3.0	3.7	Very Low
ERNAKULAM	Thodupuzha-II [5620]	MUTHALIYARMADOM-1	129.0	31.0	89.6	8.4	6.5	Very Low
ERNAKULAM	Thodupuzha-II [5620]	MVIP CANAL TRANSFORMER	81.0	4.0	6.0	71.0	87.7	Very High
ERNAKULAM	Thodupuzha-II [5620]	MY G	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	NEDUMKALLEL PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	NELLIKUZHY	81.0	0.0	10.0	71.0	87.7	Very High
ERNAKULAM	Thodupuzha-II [5620]	NEWMAN COLLEGE	81.0	0.0	9.0	72.0	88.9	Very High
ERNAKULAM	Thodupuzha-II [5620]	NINARU MOSQUE	255.0	8.0	68.5	178.5	70.0	High
ERNAKULAM	Thodupuzha-II [5620]	NJARAKKUTTY	81.0	8.0	28.0	45.0	55.6	High
ERNAKULAM	Thodupuzha-II [5620]	NUTEC	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	OASIS	81.0	0.0	80.0	1.0	1.2	Very Low
ERNAKULAM	Thodupuzha-II [5620]	OFFICE	202.0	5.0	53.0	144.0	71.3	High
ERNAKULAM	Thodupuzha-II [5620]	ORANGEVILLA	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-II [5620]	PALAMALA	81.0	0.0	5.0	76.0	93.8	Very High
ERNAKULAM	Thodupuzha-II [5620]	PANJAMKULAM	81.0	0.0	59.9	21.1	26.1	Medium
ERNAKULAM	Thodupuzha-II [5620]	PATTAYAM KAVALA CANAL	129.0	15.0	85.0	29.0	22.5	Low
ERNAKULAM	Thodupuzha-II [5620]	PATTAYAMKAVALA	81.0	0.0	27.0	54.0	66.7	High
ERNAKULAM	Thodupuzha-II [5620]	PAZHERI	81.0	5.0	22.2	53.8	66.4	High
ERNAKULAM	Thodupuzha-II [5620]	PAZHUKKAKULAM	81.0	0.0	3.0	78.0	96.3	Very High
ERNAKULAM	Thodupuzha-II [5620]	PERUMPALLICHIRA	129.0	8.0	40.0	81.0	62.8	High
ERNAKULAM	Thodupuzha-II [5620]	PERUMPALLICHIRA AMBALAM	129.0	10.0	42.3	76.7	59.5	High
ERNAKULAM	Thodupuzha-II [5620]	PERUMPALLICHIRA CITY	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	PHC KUMARAMANGALAM	129.0	0.0	28.7	100.3	77.7	Very High
ERNAKULAM	Thodupuzha-II [5620]	PLANTATION	81.0	0.0	28.0	53.0	65.4	High
ERNAKULAM	Thodupuzha-II [5620]	POPULAR VEHICLE	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	PRATHAL FOODS	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	PUTHUCHIRA	81.0	0.0	51.0	30.0	37.0	Medium
ERNAKULAM	Thodupuzha-II [5620]	RANDUPALAM	81.0	0.0	14.0	67.0	82.7	Very High
ERNAKULAM	Thodupuzha-II [5620]	RATHAPALLI	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	SANTHOSH	202.0	5.0	49.1	147.9	73.2	High
ERNAKULAM	Thodupuzha-II [5620]	SAROJA	202.0	0.0	19.6	182.4	90.3	Very High
ERNAKULAM	Thodupuzha-II [5620]	SBI-BYPASS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	SBT MANGATTUKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	SIREX	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	SMART POINT MAVINCHUVADU	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	SREEKALA	81.0	6.0	16.0	59.0	72.8	High
ERNAKULAM	Thodupuzha-II [5620]	ST JOSEPH LP SCHOOL KALLUMARI	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	SURUMI PLASTICS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	THALUK HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	THEKKUMBHAGAM CANAL	81.0	0.0	29.5	51.5	63.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
ERNAKULAM	Thodupuzha-II [5620]	THEKKUMBHAGAM FERRY	81.0	5.0	11.5	64.5	79.7	Very High
ERNAKULAM	Thodupuzha-II [5620]	THEKKUMBHAGAM TEMPLE	81.0	10.0	18.0	53.0	65.4	High
ERNAKULAM	Thodupuzha-II [5620]	THONDIKUZHHA	81.0	13.0	52.0	16.0	19.8	Low
ERNAKULAM	Thodupuzha-II [5620]	THRIVENI	129.0	3.0	40.4	85.6	66.4	High
ERNAKULAM	Thodupuzha-II [5620]	THRIVENI SAKTHI MILLS	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	TIME HOMES	129.0	0.0	0.0	129.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	TOYO	81.0	0.0	22.0	59.0	72.8	High
ERNAKULAM	Thodupuzha-II [5620]	TREATMENT PLANT KWA MALANKARA	81.0	0.0	0.0	81.0	100.0	Very High
ERNAKULAM	Thodupuzha-II [5620]	UNDAPLAVU	81.0	13.0	47.0	21.0	25.9	Medium
ERNAKULAM	Thodupuzha-II [5620]	URIYARIKKUNNU CANAL	81.0	5.0	36.0	40.0	49.4	Medium
ERNAKULAM	Thodupuzha-II [5620]	URIYARIKUNNU	81.0	3.0	20.3	57.7	71.2	High
ERNAKULAM	Thodupuzha-II [5620]	UTHRAM	129.0	0.0	76.0	53.0	41.1	Medium
ERNAKULAM	Thodupuzha-II [5620]	VADAKKUMMURY	81.0	8.0	28.0	45.0	55.6	High
ERNAKULAM	Thodupuzha-II [5620]	VANITHA INDUSTRY	81.0	0.0	25.0	56.0	69.1	High
ERNAKULAM	Thodupuzha-II [5620]	VAYANASALA	81.0	5.0	25.5	50.5	62.4	High
ERNAKULAM	Thodupuzha-II [5620]	VIMALALAYAM JUNCTION	81.0	0.0	25.8	55.2	68.2	High
ERNAKULAM	Thodupuzha-II [5620]	WAREHOUSE	81.0	0.0	21.0	60.0	74.1	High
ERNAKULAM	Thodupuzha-II [5620]	YATHEEMKHANA	81.0	0.0	33.0	48.0	59.3	High