

KSEB Renewable Energy Feasibility Report

Generated report · 2000 transformers across 1 districts. Balance % = (Balance Available ÷ 90% DTR Capacity) × 100.

District Summary

District	Transformers	Balance (kW)	Very High	High	Medium	Low	Very Low	Unknown
IDUKKI	2000	160,511.9	1775	156	45	12	12	0
TOTAL	2000	160,511.9	1775	156	45	12	12	0

IDUKKI — 2000 transformers

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Adimali [5617]	10 MILE	129.0	10.0	19.0	100.0	77.5	Very High
IDUKKI	Adimali [5617]	1000 ACRE	81.0	0.0	24.0	57.0	70.4	High
IDUKKI	Adimali [5617]	1000 ACRE AKSHAYA	129.0	0.0	15.0	114.0	88.4	Very High
IDUKKI	Adimali [5617]	12TH MILE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	14 TH MILE	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Adimali [5617]	200 ACRE KAITHACHAL	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	3 RD MILE	20.0	0.0	2.0	18.0	90.0	Very High
IDUKKI	Adimali [5617]	4TH SET COLONY KATHIPPARA DIV	202.0	3.0	8.0	191.0	94.6	Very High
IDUKKI	Adimali [5617]	5 TH MILE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	6 TH MILE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	ADIMALY EAST	202.0	0.0	20.0	182.0	90.1	Very High
IDUKKI	Adimali [5617]	ADIMALY GRAMAPANCHAYATH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	AMBALAPADY	129.0	0.0	32.3	96.7	75.0	High
IDUKKI	Adimali [5617]	AMBALAPADY IDEA	81.0	0.0	34.8	46.2	57.0	High
IDUKKI	Adimali [5617]	ANAVIRATTY	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Adimali [5617]	ANAVIRATTY P O	81.0	5.0	3.0	73.0	90.1	Very High
IDUKKI	Adimali [5617]	ANAVIRATTY SCHOOL	81.0	5.0	5.0	71.0	87.7	Very High
IDUKKI	Adimali [5617]	APSARA	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Adimali [5617]	BHAVANAM PRIVATE	510.0	0.0	0.0	510.0	100.0	Very High
IDUKKI	Adimali [5617]	BLOCK OFFICE TOWN	129.0	0.0	21.0	108.0	83.7	Very High
IDUKKI	Adimali [5617]	CAMCO	81.0	10.0	34.0	37.0	45.7	Medium
IDUKKI	Adimali [5617]	CARMEL JYOTHI	81.0	0.0	4.0	77.0	95.1	Very High
IDUKKI	Adimali [5617]	CHATTUPARAKUDY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Adimali [5617]	CHEEYAPPARA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	CHILLITHODU	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Adimali [5617]	CHINNAPPARAKUDY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	CHOORAKETTAN KUDY	81.0	0.0	9.3	71.7	88.5	Very High
IDUKKI	Adimali [5617]	COLONY PALAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Adimali [5617]	CRUSHER CHATTUPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	DAILY FOOD	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Adimali [5617]	DEEPAM GRANITES	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	DEVIAR COLONY	81.0	0.0	17.0	64.0	79.0	Very High
IDUKKI	Adimali [5617]	DHANYA	405.0	0.0	76.0	329.0	81.2	Very High
IDUKKI	Adimali [5617]	DHANYA BAR ADIMALY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	E T C ADIMALY	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Adimali [5617]	GOV HOSPITAL ADIMALY	202.0	0.0	99.5	102.5	50.8	High
IDUKKI	Adimali [5617]	GOVT HIGH SCHOOL	202.0	11.0	11.0	180.0	89.1	Very High
IDUKKI	Adimali [5617]	HIGH RANGE PRINTERS	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Adimali [5617]	HILL PALACE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	HOSE COM CHATTUPARA	81.0	0.0	29.0	52.0	64.2	High
IDUKKI	Adimali [5617]	IB KATHIPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	IDEA TOWER CHATTUPARA	129.0	8.0	0.0	121.0	93.8	Very High
IDUKKI	Adimali [5617]	IDEA TOWER MACHIPLAVU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	IDEA TOWER MILLUMPADY	81.0	3.0	13.0	65.0	80.2	Very High
IDUKKI	Adimali [5617]	INNOVATIVE MERCHANT	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Adimali [5617]	IRUMPUPALAM	129.0	0.0	33.0	96.0	74.4	High
IDUKKI	Adimali [5617]	JANNAH HOTEL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	JATHITHOTTAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	JYOTHIS I T C	81.0	5.0	16.0	60.0	74.1	High
IDUKKI	Adimali [5617]	KAITHACHAL	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Adimali [5617]	KAMBILINE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	KANNAMALY	81.0	3.0	10.0	68.0	84.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Adimali [5617]	KARIMKULAM	81.0	0.0	78.3	2.7	3.4	Very Low
IDUKKI	Adimali [5617]	KATTAMUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	KATTAMUDY SCHOOL	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	KATTAMUDY TEMPLE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	KAVERY-DDUGJY	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Adimali [5617]	KGEES	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Adimali [5617]	KOOMPANPARA IDEA TOWER	81.0	20.0	0.0	61.0	75.3	Very High
IDUKKI	Adimali [5617]	KORANGATTY	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Adimali [5617]	KOYIKKAKUDY	81.0	20.0	61.0	0.0	0.0	Very Low
IDUKKI	Adimali [5617]	KUDUKKACITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	KULAMANKUZH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	KUNJIPETTY KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	LIC ADIMALY	129.0	0.0	25.0	104.0	80.6	Very High
IDUKKI	Adimali [5617]	M00KAMBIKA	81.0	0.0	29.0	52.0	64.2	High
IDUKKI	Adimali [5617]	MACHIPLAVU KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	MACHIPLAVU P O	129.0	0.0	7.0	122.0	94.6	Very High
IDUKKI	Adimali [5617]	MACHIPLAVU SCHOOL	129.0	5.0	6.0	118.0	91.5	Very High
IDUKKI	Adimali [5617]	MADAMPADY	81.0	0.0	52.0	29.0	35.8	Medium
IDUKKI	Adimali [5617]	MANKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	MANNAMKALA	81.0	0.0	3.3	77.7	95.9	Very High
IDUKKI	Adimali [5617]	MANNAMKALA COLLEGE	81.0	0.0	55.0	26.0	32.1	Medium
IDUKKI	Adimali [5617]	MATHA BAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	MATHA THEATRE	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Adimali [5617]	MAZHUMATTOM	129.0	3.0	10.0	116.0	89.9	Very High
IDUKKI	Adimali [5617]	MEZHUKUMCHAL	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Adimali [5617]	MILLUMPADY	81.0	0.0	41.0	40.0	49.4	Medium
IDUKKI	Adimali [5617]	MINIPADY	81.0	0.0	15.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Adimali [5617]	MORNING STAR LT	129.0	0.0	5.0	124.0	96.1	Very High
IDUKKI	Adimali [5617]	MUDIPPARA	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Adimali [5617]	MUKALEKKAR	81.0	8.0	30.4	42.6	52.5	High
IDUKKI	Adimali [5617]	MUNITHANDU	81.0	0.0	19.0	62.0	76.5	Very High
IDUKKI	Adimali [5617]	NAIKUNNU	81.0	0.0	20.0	61.0	75.3	Very High
IDUKKI	Adimali [5617]	NILE FOOD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	NORTH-1000ACRE	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Adimali [5617]	NOVARK	81.0	0.0	48.0	33.0	40.7	Medium
IDUKKI	Adimali [5617]	ODAKKACITY	129.0	0.0	18.0	111.0	86.0	Very High
IDUKKI	Adimali [5617]	OZHUKACITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	OZHUVATHADAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	OZHUVATHADOM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	PADICAPPU	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Adimali [5617]	PALCO FOODS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	PANAMKUTTY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	PARISSAKALLU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	PAZHAMBILLICHAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	PLAKKAYAM	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Adimali [5617]	POLINJAPALAM	81.0	3.0	70.8	7.2	8.9	Very Low
IDUKKI	Adimali [5617]	POLINJAPALAM PANAMKUTTY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	POTTAS	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Adimali [5617]	POWER LANDRY MACHIPALAVU	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	PRIYADHARSINI COLONY	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Adimali [5617]	PUMP KALLARKUTTY	202.0	0.0	3.0	199.0	98.5	Very High
IDUKKI	Adimali [5617]	PUTHAYATH-OPP MOSQUE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	RAMASWAMY KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	RANGE OFFICE KOOMPANPARA	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Adimali [5617]	RANGERS HOTEL	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Adimali [5617]	S N PADY	81.0	0.0	24.0	57.0	70.4	High
IDUKKI	Adimali [5617]	SBI	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Adimali [5617]	SHAPPUMPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	SOUGANDHIKA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	SOUTH KATHIPPARA	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Adimali [5617]	SUB STATION	81.0	0.0	17.0	64.0	79.0	Very High
IDUKKI	Adimali [5617]	TECHNICAL HIGH SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	TECHNICAL SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	TELEPHONE EXCHANGE	81.0	0.0	80.2	0.8	1.0	Very Low
IDUKKI	Adimali [5617]	THADIKACITY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Adimali [5617]	THAIKKAVU	81.0	3.0	16.0	62.0	76.5	Very High
IDUKKI	Adimali [5617]	THALAMALY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	THATTEKANNANKUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Adimali [5617]	THOTTIYAR	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Adimali [5617]	THUMPIPARA	81.0	3.0	0.0	78.0	96.3	Very High
IDUKKI	Adimali [5617]	TOWN MOSQUE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	TRAV LAUNGE 14TH MILE	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Adimali [5617]	TRENDS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	VALARA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Adimali [5617]	VEE TEE BAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Adimali [5617]	VISWADEEPTHI SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	90 ACRE	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Alakode-Thodupuzha [5753]	94 ACRE	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Alakode-Thodupuzha [5753]	ALAKODE BLOCK	81.0	0.0	32.0	49.0	60.5	High
IDUKKI	Alakode-Thodupuzha [5753]	ALAKODU PANCHAYATH	81.0	0.0	12.0	69.0	85.2	Very High
IDUKKI	Alakode-Thodupuzha [5753]	AMBALAKKAVALA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Alakode-Thodupuzha [5753]	ANAKKAYAM-1	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	ANAKKAYAM-2	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Alakode-Thodupuzha [5753]	ANCHIRI	81.0	5.0	3.0	73.0	90.1	Very High
IDUKKI	Alakode-Thodupuzha [5753]	AVARAN KUTTY	81.0	0.0	37.0	44.0	54.3	High
IDUKKI	Alakode-Thodupuzha [5753]	AYYANPARA	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Alakode-Thodupuzha [5753]	AZHAKATH	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Alakode-Thodupuzha [5753]	AZHAKATHU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	CHAVARA	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Alakode-Thodupuzha [5753]	CHAVARNA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Alakode-Thodupuzha [5753]	CHAVARNA INDUSTRY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	CHILAVU	81.0	0.0	23.0	58.0	71.6	High
IDUKKI	Alakode-Thodupuzha [5753]	CHILAVU MOSQUE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	DENTAL	81.0	0.0	18.0	63.0	77.8	Very High
IDUKKI	Alakode-Thodupuzha [5753]	DEVARUPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	EDAVETTY BSNL	81.0	23.0	40.0	18.0	22.2	Low
IDUKKI	Alakode-Thodupuzha [5753]	EDAVETTY CHIRA	81.0	25.0	55.0	1.0	1.2	Very Low
IDUKKI	Alakode-Thodupuzha [5753]	EDAVETTY CHIRA JUNCTION	81.0	15.0	29.0	37.0	45.7	Medium
IDUKKI	Alakode-Thodupuzha [5753]	EDAVETTY DEPO	81.0	0.0	34.3	46.7	57.7	High
IDUKKI	Alakode-Thodupuzha [5753]	EDAVETTY JARAM	81.0	18.3	24.3	38.4	47.4	Medium
IDUKKI	Alakode-Thodupuzha [5753]	EDAVETTY PANCHAYATH	81.0	2.0	33.0	46.0	56.8	High
IDUKKI	Alakode-Thodupuzha [5753]	EDAVETTY PHC	129.0	5.0	19.0	105.0	81.4	Very High
IDUKKI	Alakode-Thodupuzha [5753]	EDAVETTY PO	129.0	26.3	42.7	60.0	46.5	Medium
IDUKKI	Alakode-Thodupuzha [5753]	EDAVETTY R P S	81.0	0.0	17.3	63.7	78.6	Very High
IDUKKI	Alakode-Thodupuzha [5753]	ILAMDESOM MOSQUE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	ILAMDESOM SCHOOL	81.0	5.0	17.0	59.0	72.8	High
IDUKKI	Alakode-Thodupuzha [5753]	ILAMDESOM TOWN	81.0	0.0	6.3	74.7	92.2	Very High
IDUKKI	Alakode-Thodupuzha [5753]	INCHAKKATTU KAVALA	81.0	0.0	13.0	68.0	84.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Alakode-Thodupuzha [5753]	INCHIYANI	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Alakode-Thodupuzha [5753]	INCHIYANI TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	IRUKKUPALAM	81.0	8.0	16.0	57.0	70.4	High
IDUKKI	Alakode-Thodupuzha [5753]	JOSH DESIGN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	KACHIRAPPARA	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Alakode-Thodupuzha [5753]	KALAYANTHANI CHURCH	81.0	5.0	29.0	47.0	58.0	High
IDUKKI	Alakode-Thodupuzha [5753]	KALAYANTHANI EMMANUEL	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Alakode-Thodupuzha [5753]	KALAYANTHANI TANK	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	KALLANICKAL CHURCH	81.0	3.0	35.0	43.0	53.1	High
IDUKKI	Alakode-Thodupuzha [5753]	KALLANICKALCHARCH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	KIZHAKKE METHOTTY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	KONTHALAPALLY	81.0	3.0	18.0	60.0	74.1	High
IDUKKI	Alakode-Thodupuzha [5753]	KOOVAKKANDAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Alakode-Thodupuzha [5753]	KOTHAKUTHY	81.0	0.0	64.0	17.0	21.0	Low
IDUKKI	Alakode-Thodupuzha [5753]	KUNNEL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	KURUVAKAYAM	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Alakode-Thodupuzha [5753]	KUTTAPPAN KAVALA	81.0	5.0	6.0	70.0	86.4	Very High
IDUKKI	Alakode-Thodupuzha [5753]	LATHEEN PALLY KWA	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Alakode-Thodupuzha [5753]	MAN KOOTTAM	81.0	5.0	51.4	24.6	30.3	Medium
IDUKKI	Alakode-Thodupuzha [5753]	MANJAPRA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	MARAVETTIKAL	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Alakode-Thodupuzha [5753]	MARCO INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	MARTHOMA	81.0	0.0	30.0	51.0	63.0	High
IDUKKI	Alakode-Thodupuzha [5753]	MARTHOMA GRANITES	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	MEENMUTTY	81.0	3.0	5.0	73.0	90.1	Very High
IDUKKI	Alakode-Thodupuzha [5753]	MEENMUTTY IDEA	81.0	8.0	18.0	55.0	67.9	High
IDUKKI	Alakode-Thodupuzha [5753]	METHOTTY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Alakode-Thodupuzha [5753]	MS COLONY	129.0	53.3	15.3	60.4	46.8	Medium
IDUKKI	Alakode-Thodupuzha [5753]	MURIYATHODU	81.0	0.0	31.0	50.0	61.7	High
IDUKKI	Alakode-Thodupuzha [5753]	MUTHODU	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Alakode-Thodupuzha [5753]	NADAYAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	NALIYANY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	ONNARAMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	PALAKANDAM	81.0	0.0	21.3	59.7	73.7	High
IDUKKI	Alakode-Thodupuzha [5753]	PALAM CITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	PALAPPILLY	81.0	0.0	19.0	62.0	76.5	Very High
IDUKKI	Alakode-Thodupuzha [5753]	PANNIMATTOM INDUSTARY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	PANNIMATTOM TOWN	129.0	8.0	13.0	108.0	83.7	Very High
IDUKKI	Alakode-Thodupuzha [5753]	PATHIKKAMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	POOCHAPRA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Alakode-Thodupuzha [5753]	POOMALA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Alakode-Thodupuzha [5753]	PRIME ROSE	129.0	0.0	16.0	113.0	87.6	Very High
IDUKKI	Alakode-Thodupuzha [5753]	SARADHA KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	SASTAMPARA KWA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Alakode-Thodupuzha [5753]	SASTHAMPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	THADIPALAM	81.0	18.0	18.0	45.0	55.6	High
IDUKKI	Alakode-Thodupuzha [5753]	THAITHOTTAM	81.0	0.0	11.3	69.7	86.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	THAITHOTTAM II	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	THENMARY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	UPPUKULAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	VATTAMATTOM	81.0	3.0	10.0	68.0	84.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	VELLIYAMATTOM KWA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Alakode-Thodupuzha [5753]	VELLIYAMATTOM-RPS	81.0	5.0	19.8	56.2	69.3	High
IDUKKI	Alakode-Thodupuzha [5753]	VETTIMATTOM OIL PALM	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Anakkara [5742]	ALAKKA PALLY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	AMBALAMEDU	81.0	3.0	3.0	75.0	92.6	Very High
IDUKKI	Anakkara [5742]	ANAKKARA PANCHAYATHU	129.0	0.0	8.0	121.0	93.8	Very High
IDUKKI	Anakkara [5742]	ANAKKARA TOWN	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Anakkara [5742]	ANSARI 1	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	ANSARI 2	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	ARUVIKUZHY	81.0	3.3	0.0	77.7	95.9	Very High
IDUKKI	Anakkara [5742]	ATTA PUDUNGY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	BANGLADESH COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	CENTER KAVALA	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Anakkara [5742]	CHAKKUPALLAM TOWER	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Anakkara [5742]	CHAKKUPALLOM SCHOOL	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	CHEKUTHANMALA NO 2	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Anakkara [5742]	CHEKUTHANMALA NO 3	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	CHEKUTHANMALA NO 4 -DAM	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Anakkara [5742]	CHEKUTHANMALA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	CHEKUTHANMALA-NO 1	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	CHELLARCOVIL FIRST MILE	202.0	0.0	5.0	197.0	97.5	Very High
IDUKKI	Anakkara [5742]	CHELLERKOVIL CITY	129.0	0.0	5.0	124.0	96.1	Very High
IDUKKI	Anakkara [5742]	CHENGANSSERY PADY	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Anakkara [5742]	CHILLINGPLANT NO 1	81.0	0.0	16.0	65.0	80.2	Very High
IDUKKI	Anakkara [5742]	CHILLINGPLANT NO 2	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	CHITTAMPARA NO 2- DAM	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	CHITTAMPARA NO-1	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	CHITTAMPARA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	EETTAKANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	ELAVANAM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Anakkara [5742]	FIFTH MILE 5TH- MILE	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Anakkara [5742]	GANDHINAGAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	ILLIKKALAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	ILLITHARA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Anakkara [5742]	IMS COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	JEEVANANDAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KADASSIKADAVU	129.0	3.0	8.0	118.0	91.5	Very High
IDUKKI	Anakkara [5742]	KADASSIKADAVU TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KADUKKACITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KALARIKKAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KATTASOORYANPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KATTELPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KATTUPARAMBU MEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KEERIMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KOSAMATTOM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KUNGIRIPETTY	81.0	4.7	0.0	76.3	94.3	Very High
IDUKKI	Anakkara [5742]	KURANGU SASTHANADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	KUTTAMTHADAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	MAILADUMPARA	81.0	3.0	13.0	65.0	80.2	Very High
IDUKKI	Anakkara [5742]	MANGALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	MANGALA DEVI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	MATHAIKANDOM	129.0	10.0	3.0	116.0	89.9	Very High
IDUKKI	Anakkara [5742]	MEL VAZHAVEEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	MELE CHAKKUPALLOM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	MENONMEDU	81.0	0.0	12.0	69.0	85.2	Very High
IDUKKI	Anakkara [5742]	MEPPARA 1	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	MEPPARA-2	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Anakkara [5742]	MONTFORT	129.0	0.0	30.0	99.0	76.7	Very High
IDUKKI	Anakkara [5742]	MONTFORT SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	MOUNT VALLEY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	MUKKUDI	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	MUKKUDY TEMPLE	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	N S S SCHOOL PADY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Anakkara [5742]	NADU ANAKKARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	NEERANAKKUNNEL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	NINETH ACRE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	NJANGADA MEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	NSKP- CHAKKUPALLAM	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	OTTAKATHALAMEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	P K C	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	PAC	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Anakkara [5742]	PALIYAKUDY	81.0	0.0	4.0	77.0	95.1	Very High
IDUKKI	Anakkara [5742]	PAMPADICHAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	PAMPUPARA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Anakkara [5742]	PARACKAL	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	PEPPER HOMES	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	PERUMPALLY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	PEVARATTY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	PLAMOOTIL PADI TANK	81.0	0.0	3.8	77.2	95.3	Very High
IDUKKI	Anakkara [5742]	PLAMOOTTILPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	PNS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	POABSON	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	POLLAYIL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	PUTHUMANAMEDU	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Anakkara [5742]	ROYKADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	SANKARAN KADA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Anakkara [5742]	SANTHIGIRY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	SASTHANADA 1 NMR	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	SASTHANADA 2 BUS STAND	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	SASTHANADA 3 VEERAN	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Anakkara [5742]	SASTHANADA KOVIL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	SASTHANADA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	SEVENTH MILE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	SHAN HOTEL	81.0	0.0	37.0	44.0	54.3	High
IDUKKI	Anakkara [5742]	SIVANCOIL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	SIXTH MILE	129.0	0.0	5.0	124.0	96.1	Very High
IDUKKI	Anakkara [5742]	SIXTH MILE CHURCH	81.0	5.0	3.0	73.0	90.1	Very High
IDUKKI	Anakkara [5742]	SUBHIKSHA	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Anakkara [5742]	SULTHANKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	SULTHANKADA RGGVY NO I	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Anakkara [5742]	SULTHANKADA RGGVY NO II	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Anakkara [5742]	SULTHANKADA RGGVY NO III	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Anakkara [5742]	SULTHANKADA RGGVY NO IV	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Anakkara [5742]	T K S MEPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	TELECOM	129.0	0.0	34.0	95.0	73.6	High
IDUKKI	Anakkara [5742]	UDHAYAGIRIMEDU	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Anakkara [5742]	V K DRYERS	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Anakkara [5742]	VALIYAPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	VAZHAVEEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Anakkara [5742]	VODAPHONE	81.0	5.0	26.0	50.0	61.7	High
IDUKKI	Chithirapuram [5615]	12 ACRE	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	2 ND MILE	129.0	0.0	8.0	121.0	93.8	Very High
IDUKKI	Chithirapuram [5615]	20 ACRE	81.0	3.0	51.3	26.7	32.9	Medium
IDUKKI	Chithirapuram [5615]	40 ACRE	81.0	0.0	17.0	64.0	79.0	Very High
IDUKKI	Chithirapuram [5615]	50 TH MILE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	50TH MILE 2	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	60TH MILE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	6TH MILE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	6TH MILE 2	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	8 ACRE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	96 CITY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	96 CITY 2	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ABAD COPPERCASTLE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	AMAKANDAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	AMBALAKUNNU PABINKAYAM	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	AMBAZHACHAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	AMBUKKADA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Chithirapuram [5615]	AMUSE VISTA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ANACHAL SANKUPPADI	81.0	0.0	25.0	56.0	69.1	High
IDUKKI	Chithirapuram [5615]	ANACHAL TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ANACHAL TOWN	202.0	0.0	28.3	173.7	86.0	Very High
IDUKKI	Chithirapuram [5615]	ANAKKULAM 1	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ANAKKULAM 2	20.0	0.0	3.0	17.0	85.0	Very High
IDUKKI	Chithirapuram [5615]	ANAKKULAM 3	20.0	0.0	5.0	15.0	75.0	Very High
IDUKKI	Chithirapuram [5615]	ANAKULAM 4	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ANAKULAM 5	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ANAKULAM 6	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ANAKULAM 7	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	ARBOUR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ATTUKADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	AUDIT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	AUDIT LAUNTRY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	AVILA ASRAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Chithirapuram [5615]	BABUKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BAISONVALLY IDEA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BIJU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BIRDS VALLEY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BISONVALLEY SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BISONVALLEY TOWN	129.0	0.0	29.0	100.0	77.5	Very High
IDUKKI	Chithirapuram [5615]	BISONVALLY KAYATHARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BLACK FOREST	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BLACKBERRY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BLANKET	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BLUE HAZE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BOLIYARD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BOULEY YARD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	BROADBEAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	CAMELLIA AND ELETTARIA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	CHEKUTHANMUKKU	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	CHENGULAM	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Chithirapuram [5615]	CHIKKANAM KUDI	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	CHILLING PLANT MKDY PRIVATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	CHITHIRAPURAM	405.0	0.0	28.0	377.0	93.1	Very High
IDUKKI	Chithirapuram [5615]	CHITHIRAPURAM SOUTH	129.0	0.0	3.0	126.0	97.7	Very High
IDUKKI	Chithirapuram [5615]	CHOKKARA MUDI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	CK CKELLAPPAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	COMPANY KUDY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	COPPER CASTLE RESORT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	CRESHER	81.0	3.0	39.0	39.0	48.1	Medium
IDUKKI	Chithirapuram [5615]	CUCKMERE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	DESHIYA MOOLAKKADA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Chithirapuram [5615]	DEVIKULAM MANILA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	DEVIKULAM PUMP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	DEVIKULAM TOWN	129.0	0.0	2.0	127.0	98.4	Very High
IDUKKI	Chithirapuram [5615]	DOVE MOUNTAIN RESORT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	DREAM COCONUT VILLA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	DREAM LAND	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	EATI CITY	81.0	0.0	81.0	0.0	0.0	Very Low
IDUKKI	Chithirapuram [5615]	EATI CITY VARKKYKADA	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Chithirapuram [5615]	EATTOOR KUTTAPPAN CITY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Chithirapuram [5615]	ELEPHANT PASSAGE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ELKUNNU	81.0	5.0	3.0	73.0	90.1	Very High
IDUKKI	Chithirapuram [5615]	ERA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ESTANCIA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	GF RESORT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	GOMATHY KADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	GROTO	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	H C KUNDALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	H C LAKSHMI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	H C MUNNAR	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	HEAD WORKS	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	HILL VIEW	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	ICE QUEEN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	IDALYPARAKUDY	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Chithirapuram [5615]	IDEA TOWER MUTHUVANKUDI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	INDUS KALLAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	INTAKE OLD MUNNAR	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	IRIMBUKUTHU KADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	IRUMPUKUTHIKADA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	IRUTTUKANAM	81.0	0.0	4.0	77.0	95.1	Very High
IDUKKI	Chithirapuram [5615]	IRUTTUKANAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	JOYAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	K M SEBASTINE KARADIPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KAALLAR VALLEY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KAINAGIRI VIJAYAN KADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KAINNAGIRI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KAKKAKADA TOWER	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Chithirapuram [5615]	KALLAR	121.0	0.0	7.0	114.0	94.2	Very High
IDUKKI	Chithirapuram [5615]	KALLAR SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KALLAR TUNNEL SITE	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KAMBILINE	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Chithirapuram [5615]	KAMBINIKKUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KANDATHIHKUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KARADIPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KATTUKUDI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KAVITHAKKAD	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KCPMC	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KERALA FARM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KILAVIPPARA	81.0	0.0	5.2	75.8	93.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	KINAGIRI 2	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KITES RESORT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KOMALIKUDY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KONGINI CITY-1	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KONGINI CITY-2	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KOTTAPPARA	81.0	0.0	9.5	71.5	88.3	Very High
IDUKKI	Chithirapuram [5615]	KOVALI KURISU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KOYIKKACITTY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KOZHIALA KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KUNCHITHANNY SCHOOL	202.0	5.0	4.0	193.0	95.5	Very High
IDUKKI	Chithirapuram [5615]	KUNCHITHANNY TOWN	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Chithirapuram [5615]	KUNDALA DAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KUNJITHANNY BRIDGE	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Chithirapuram [5615]	KURANGUPARA ILLYCITY	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Chithirapuram [5615]	KURATHIKUDY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KURISADY KUNNU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KURISUPARA	129.0	0.0	3.0	126.0	97.7	Very High
IDUKKI	Chithirapuram [5615]	KURUTHY KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KURUTHY TUNNEL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KUTHUPARA	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Chithirapuram [5615]	KUTTIAR VALLEY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KUTTIYAVALLEY NO2 5 CENT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KUWIT CITY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	KV MUHAMMAD ISSAC	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	LAKE FOREST	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	LAKSHAM COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	LAKSHMI ESTATE	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	M G COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MAKAYIRAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MANGAPPARA AMBAZHACHAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MANILA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MANKULAM EXCHANGE	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Chithirapuram [5615]	MANKULAM TOWN	129.0	0.0	9.0	120.0	93.0	Very High
IDUKKI	Chithirapuram [5615]	MANSION HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MARYLAND	81.0	3.0	17.0	61.0	75.3	Very High
IDUKKI	Chithirapuram [5615]	MATTUPPETTI	121.0	0.0	0.0	121.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MEENAKSHI ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MEENCUT	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MERCY HOME	60.0	0.0	0.0	60.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MHEP SURGE SITE	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MUNIPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MUNNAR CASTLE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MUNNAR VILLA VISTA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MUNNU K VARGHEESE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MUSCON	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MUTHUVANKUDY	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Chithirapuram [5615]	MUTHUVANKUDY MOSQUE	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Chithirapuram [5615]	MUTHUVANKUDY TUNNEL SITE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	MUTTUKAD	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Chithirapuram [5615]	MUTTUKAD MAS	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	NADUPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	NAKSHATHRA KUTHU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	NELLIKKADU	81.0	0.0	78.0	3.0	3.7	Very Low
IDUKKI	Chithirapuram [5615]	NELLIPADY I	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	NELLIPADY II	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	NEW COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	NIRAVATH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	NJAVALLPPARA KUDY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	NOORAMKARA JALANIDHI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	NOORANKARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	OAK FIELD	81.0	0.0	30.0	51.0	63.0	High
IDUKKI	Chithirapuram [5615]	OAK RESORT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ONAN CITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PADMINI CHELLAPPAN	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PALLI CITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PALLIVASAL MOOLAKKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PAMBINKAYAM	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PAMBINKAYAYM CITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PARAKKADAVU	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PARAMADA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PEECHADU	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PERUMBANKUTH CHAPATHU	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PERUMBANKUTHU	20.0	0.0	5.0	15.0	75.0	Very High
IDUKKI	Chithirapuram [5615]	PES - PENSTOCK-KALLADI VALAV	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PES 111 VALVE HOUSE	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PES MEENCUT	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PES NEW POWER HOUSE	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PETER JOY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PETTIMUDI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PIPE LINE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PLAMALA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	POLICEKUTTY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	POOJA CURRY POWDER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	POST OFFICE BISONVALLEY	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	POTHAMEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	POTTENKADU	81.0	5.0	22.0	54.0	66.7	High
IDUKKI	Chithirapuram [5615]	POTTENKADU PUMP	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Chithirapuram [5615]	POWER HOUSE	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	PPK	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SAMSON ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SANTHI NAGAR	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SELIAMPARA MANGAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SENGULAM ASRAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SENGULAM DAM	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Chithirapuram [5615]	SENGULAM MANGAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SEVAL KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SILVER LEAF RESORT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SINKU KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SKY VALLEY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SOCIETY MEDU-1	121.0	0.0	11.0	110.0	90.9	Very High
IDUKKI	Chithirapuram [5615]	SOCIETY MEDU-2	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SOCIETYKUDY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SPICE MUNNAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SPICE TREE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	ST THOMAS ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	STAR EMIRATES	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	SUKUMARAN KADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	TAGORE M SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	TALL TREES	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	TATA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	TEA COMPANY	81.0	3.0	6.0	72.0	88.9	Very High
IDUKKI	Chithirapuram [5615]	TEA COUNTRY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	THALUMKANDAM KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	THALUMKANDAM TOWN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	THANNIPPARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Chithirapuram [5615]	THATTATHIMUKKU	81.0	0.0	22.8	58.2	71.8	High
IDUKKI	Chithirapuram [5615]	THIRTY THREE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	THOKKUPARA	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Chithirapuram [5615]	THOKKUPARA KRISHIBHAVAN	81.0	3.0	5.0	73.0	90.1	Very High
IDUKKI	Chithirapuram [5615]	THOKKUPARA SERVICE STATION	81.0	0.0	16.0	65.0	80.2	Very High
IDUKKI	Chithirapuram [5615]	THOKKUPARA SOUTH	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Chithirapuram [5615]	THOKKUPARA TUNEL	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	THOMACHANKADA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	TWIN FLOVER ETCT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	TWIN FLOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	UCL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	UMMAKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	UPPER KALLAR PROJECT	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	UPPER SURYANELLI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VALIYAPARA KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VALVE HOUSE	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VATTAYAR	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Chithirapuram [5615]	VAVA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VAZHAPILLY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VELIYAMPARA	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Chithirapuram [5615]	VELIYAMPARA KUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VIRINJAPARA I	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VIRINJAPARA II	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VIRINJAPARA III	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VIRINJAPARA SURGE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VIRIPARA 1	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VIRIPARA 2	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VIRIPARA DAM SITE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VIRIPARA TUNNEL SITE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	VODADPHONE THALUMKANDAM	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Chithirapuram [5615]	WHITE HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	WINDER MIRROR	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	WOLKENBERG	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	WONDER NOTE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Chithirapuram [5615]	YATHRI NIVAS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	ADAYALAKALLU	81.0	0.0	4.9	76.1	94.0	Very High
IDUKKI	Erattayar [5724]	ANCHUMUKKU	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Erattayar [5724]	ANTHOPPIKKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	CARMEL CITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	CHAKKAKANAM	81.0	0.0	15.0	66.0	81.5	Very High
IDUKKI	Erattayar [5724]	CHANTHAKKAVALA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Erattayar [5724]	CHEERAMKUNNEL PADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	CHEMPAKAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	CHENTHALAR	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Erattayar [5724]	D PAUL SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	EDINJAMALA CITY	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Erattayar [5724]	EDINJAMALA KURISSUMALA	81.0	0.0	12.0	69.0	85.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Erattayar [5724]	ERATTAYAR SERVICE STATION	51.0	0.0	11.0	40.0	78.4	Very High
IDUKKI	Erattayar [5724]	ERATTAYAR STAND	129.0	0.0	24.5	104.5	81.0	Very High
IDUKKI	Erattayar [5724]	ETTITHOPE	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Erattayar [5724]	ETTITHOPPU TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	EZHUKUMVAYAL	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Erattayar [5724]	GURU CHITHRA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	KAILAS NAGAR	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Erattayar [5724]	KALLARMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	KARADIYALLU	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Erattayar [5724]	KATTADIKAVALA	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Erattayar [5724]	KOCHUKAMASHI	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Erattayar [5724]	KOCHUKURAPPADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	KUZHICKANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	M K PADY	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Erattayar [5724]	MALoor CITY	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Erattayar [5724]	MAMBAZHAKKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Erattayar [5724]	MAMBAZHAKUNNU WATER TANK	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Erattayar [5724]	MANAMTHADOMPALAM	81.0	5.0	12.0	64.0	79.0	Very High
IDUKKI	Erattayar [5724]	MANNAKUDY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Erattayar [5724]	MANNAKUDY RATION KADA	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Erattayar [5724]	MEENPUZHA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	NALUMUKKU	81.0	5.0	6.5	69.5	85.8	Very High
IDUKKI	Erattayar [5724]	NANKKUTHOTTY JUNCTION	81.0	0.0	27.0	54.0	66.7	High
IDUKKI	Erattayar [5724]	NANKKUTHOTTY KWA	81.0	3.0	0.0	78.0	96.3	Very High
IDUKKI	Erattayar [5724]	NATHUKALLU	81.0	5.0	19.0	57.0	70.4	High
IDUKKI	Erattayar [5724]	NEELAKANDANKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	NELLIPARA IRRIGATION	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Erattayar [5724]	NELLIPPARA	129.0	3.0	8.0	118.0	91.5	Very High
IDUKKI	Erattayar [5724]	NORTH DAM	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Erattayar [5724]	NORTH KWA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	OVELIPADY	81.0	5.0	8.0	68.0	84.0	Very High
IDUKKI	Erattayar [5724]	PADMANABHAPURAM NSS	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Erattayar [5724]	PALLIKANAM SCHOOL	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Erattayar [5724]	PALLIKKANAM KWA	81.0	0.0	23.8	57.2	70.6	High
IDUKKI	Erattayar [5724]	PARAKADAVU IRRIGATION	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Erattayar [5724]	PARAKKADAVU	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Erattayar [5724]	PARAYANKAVALA	81.0	3.0	3.0	75.0	92.6	Very High
IDUKKI	Erattayar [5724]	PUNNAKKAVALA	81.0	5.0	20.0	56.0	69.1	High
IDUKKI	Erattayar [5724]	PUSHPAGIRI AIRTEL	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Erattayar [5724]	PUSHPAGIRI TOWER	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Erattayar [5724]	PUSHPAGIRI TOWN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	PUSHPAGIRI VODAFONE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	PUTHENPALAM	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Erattayar [5724]	PUVRSMOUNT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	S S JUNCTION	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Erattayar [5724]	SANTHIGRAM SCHOOL	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Erattayar [5724]	THEKKUMKANAM	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Erattayar [5724]	THOTTUMAKKAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	TUNNEL FACE	81.0	0.0	16.9	64.1	79.1	Very High
IDUKKI	Erattayar [5724]	UPPUKANDOM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	URUMBOLIPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	VALAVANATTU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Erattayar [5724]	VALIYATHOVALA	81.0	5.0	3.0	73.0	90.1	Very High
IDUKKI	Erattayar [5724]	VILAKKUMARATHU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kambilikandom [5710]	5 TH MILE	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kambilikandom [5710]	AALPARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kambilikandom [5710]	AANAPAPPANPADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	AARADIKETTU	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	BRUSILY MOUNT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	CHANDRALAYAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	CHEP-250 VALVE HOUSE	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	CHINNAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	CHINNAR HYDRO-INTAKE	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	CHINNAR NIRAPPU VIJAYAN	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kambilikandom [5710]	CHINNAR PROJECT-500 KVA	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	CHURULY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	DOUBLE KURISU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	FARU CITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	IDEA KAMBILIKANDOM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	INCHAPATHAL	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Kambilikandom [5710]	INCHATHOTTY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	IRUMALACUP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	IRUMALACUP RATIONKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	KADAMAMPADY	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kambilikandom [5710]	KAKKACITY	81.0	8.0	20.0	53.0	65.4	High
IDUKKI	Kambilikandom [5710]	KAKKACITY MOSQUE	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kambilikandom [5710]	KALLU ROAD	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kambilikandom [5710]	KAMBILIKADAM	129.0	0.0	29.0	100.0	77.5	Very High
IDUKKI	Kambilikandom [5710]	KAMBILIKANDAM CITY	81.0	3.0	25.4	52.6	65.0	High
IDUKKI	Kambilikandom [5710]	KANNADIPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	KARIMALA	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kambilikandom [5710]	KOMBODINJAL SOUTH	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kambilikandom [5710]	KONNATHADY	129.0	8.0	18.0	103.0	79.8	Very High
IDUKKI	Kambilikandom [5710]	KONNATHADY SCHOOL	81.0	0.0	15.0	66.0	81.5	Very High
IDUKKI	Kambilikandom [5710]	MANALKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	MANKADAVU	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Kambilikandom [5710]	MARAKKANAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kambilikandom [5710]	MAVINCHUVADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	MUKKUDAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	MUKKUDAM RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	MULLARIKKUDY KAILASAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	MULLARIKKUDY SNDP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	MUNİYARA	129.0	0.0	18.0	111.0	86.0	Very High
IDUKKI	Kambilikandom [5710]	MUNİYARA SCHOOL	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kambilikandom [5710]	NADUKANI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	NIRAPPELPADY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	PALLICITY	81.0	3.0	0.0	78.0	96.3	Very High
IDUKKI	Kambilikandom [5710]	PANAMKUTTY	81.0	0.0	6.4	74.6	92.0	Very High
IDUKKI	Kambilikandom [5710]	PANICKANKUDY SCHOOL	81.0	0.0	7.0	74.0	91.4	Very High
IDUKKI	Kambilikandom [5710]	PANNIAR COLONY	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	PARATHODE	129.0	0.0	12.0	117.0	90.7	Very High
IDUKKI	Kambilikandom [5710]	PARATHODE PALLY	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kambilikandom [5710]	PERINCHAMKUTTY	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kambilikandom [5710]	POOTHALY	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Kambilikandom [5710]	PULIKKALKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	PULLUKANDAM	129.0	0.0	17.0	112.0	86.8	Very High
IDUKKI	Kambilikandom [5710]	PULLUKANDAM COLLEGE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	QUEEN MARY SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kambilikandom [5710]	SELLIAMPARA MOSQUE	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kambilikandom [5710]	SELLIAMPARA TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kambilikandom [5710]	SOUTH SELLIAMPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	TEMPLE VELLATHOOVAL	81.0	0.0	18.2	62.8	77.5	Very High
IDUKKI	Kambilikandom [5710]	THELLITHODE	81.0	8.3	21.5	51.2	63.2	High
IDUKKI	Kambilikandom [5710]	THINKALKADU TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	THINKALKADU TOWN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	THOTTAPURA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kambilikandom [5710]	VELLATHOOVAL VILLAGE	202.0	0.0	2.0	200.0	99.0	Very High
IDUKKI	Kambilikandom [5710]	VIMALA CITY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kanchiyar [5746]	20 ACRE	129.0	5.0	26.0	98.0	76.0	Very High
IDUKKI	Kanchiyar [5746]	46 ACRE	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	ALAPPATTUPADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	AMBALAMEDU NO-1	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	AMBALAMEDU NO-2	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	AMBALAMEDU NO-3	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	ANCHURULI COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	CHANDRAN KAVALA	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Kanchiyar [5746]	CHANDRANCITY	129.0	0.0	5.0	124.0	96.1	Very High
IDUKKI	Kanchiyar [5746]	COMMERCE	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kanchiyar [5746]	EAST MATTUKKATA	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Kanchiyar [5746]	EKH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	EXCEL PADY	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Kanchiyar [5746]	GURUMANDIRAM KANCHIYAR	129.0	5.0	0.0	124.0	96.1	Very High
IDUKKI	Kanchiyar [5746]	HYUNDAI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	ILLICKAMMEDU NO-1	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	ILLICKAMMEDU NO-2	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kanchiyar [5746]	JAWAHAR COLONY	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	JOHNYKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KADAMAKUZHY	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KADAMAKUZHY CHAPPATH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KADAMAKUZHY POTTANKULAM-I	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KADAMAKUZHY POTTANKULAM-II	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KADAMAKUZHY THUMPASSERY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KAKKATTUKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KALLIYANATHANDU SUMITHIKADA	129.0	0.0	5.0	124.0	96.1	Very High
IDUKKI	Kanchiyar [5746]	KALLUPURAYIDATHIL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KALTHOTTY	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Kanchiyar [5746]	KAVADIKAVALA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kanchiyar [5746]	KIDANGU BHAGAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KOCHUCHENNATTUKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KODALIPARA	20.0	0.0	3.0	17.0	85.0	Very High
IDUKKI	Kanchiyar [5746]	KODALIPARA HOSTEL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KOKATTUMALA NO-1	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KOKKATTUMALA NO-2	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KOTTAMPADI	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Kanchiyar [5746]	KUNJIMALA	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Kanchiyar [5746]	KURISHUMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	KUZHAL PALAM	81.0	8.0	6.0	67.0	82.7	Very High
IDUKKI	Kanchiyar [5746]	LABBAKADA K S E B	81.0	0.0	32.0	49.0	60.5	High
IDUKKI	Kanchiyar [5746]	LABBAKKADA	129.0	0.0	14.5	114.5	88.8	Very High
IDUKKI	Kanchiyar [5746]	MANIYANGATTUPADY	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kanchiyar [5746]	MARTIN	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	MATTAPPALLI	81.0	0.0	13.0	68.0	84.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kanchiyar [5746]	MEPPARA	129.0	0.0	3.0	126.0	97.7	Very High
IDUKKI	Kanchiyar [5746]	MICROWAVE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	MOOZHIYANKAL PADY	81.0	3.0	5.0	73.0	90.1	Very High
IDUKKI	Kanchiyar [5746]	MURRIKATTUKUDI	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kanchiyar [5746]	MYTHRINAGAR	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kanchiyar [5746]	NARIYAMPARA NO-1	129.0	0.0	9.0	120.0	93.0	Very High
IDUKKI	Kanchiyar [5746]	NARIYAMPARA NO-2 TOWN	81.0	6.0	12.0	63.0	77.8	Very High
IDUKKI	Kanchiyar [5746]	OTTAMARAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	OZHUKAYILPADY	81.0	0.0	61.0	20.0	24.7	Low
IDUKKI	Kanchiyar [5746]	OZHUKAYILPADY TANKPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	PALAKADA	81.0	3.0	9.0	69.0	85.2	Very High
IDUKKI	Kanchiyar [5746]	PALLICITY KOZHIMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	PALLIKAVALA KANCHIYAR	129.0	0.0	34.3	94.7	73.4	High
IDUKKI	Kanchiyar [5746]	PAMPPADIKUZHYY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	PATHIPPADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	PERIYA ESTATE	129.0	0.0	3.0	126.0	97.7	Very High
IDUKKI	Kanchiyar [5746]	PERIYONKAVALA	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Kanchiyar [5746]	PEZHUMKANADAM MOSQUE	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Kanchiyar [5746]	PLAMOOD	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Kanchiyar [5746]	PONNIKKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	PRAKKADUMKAL-CUST-	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	PT KANAM NO-1	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	PT KANAM NO-2	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	PT KANAM NO-3	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	PUTHIYAPALAM	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kanchiyar [5746]	RAJAPURAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	RATHINAPPARA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kanchiyar [5746]	SN PADI KOZHIMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	SWARAJ	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kanchiyar [5746]	SWARNAVILASAM	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	THOOMKUZHY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	THOPPIPPALA	81.0	0.0	30.0	51.0	63.0	High
IDUKKI	Kanchiyar [5746]	THULASIPADY 7TH BLOCK	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	UDAYAPURAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	UDUMPANADU	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kanchiyar [5746]	VALLAKADAVU KANNAMUNDA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	VALLAKADAVU KARIMPANIPADY	81.0	0.0	22.0	59.0	72.8	High
IDUKKI	Kanchiyar [5746]	VALLAKADAVU MOOLEKKADA	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Kanchiyar [5746]	VALLAKADAVU NO-2	81.0	0.0	36.0	45.0	55.6	High
IDUKKI	Kanchiyar [5746]	VALLAKADAVU NO-1	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Kanchiyar [5746]	VALLEY	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	VALUMMEL HOME-CUST-	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	VALUMMELPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	VELLILAMKANDAM	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kanchiyar [5746]	VENATTUPADI	81.0	6.3	0.0	74.7	92.2	Very High
IDUKKI	Kanchiyar [5746]	VENGALOORKADA COLONY	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	VENGHALOORKADA TOWN	81.0	3.0	3.0	75.0	92.6	Very High
IDUKKI	Kanchiyar [5746]	VETOM	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Kanchiyar [5746]	VIKAS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	VTMR PLAMOODU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanchiyar [5746]	ZION	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	ALPARA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kanjikuzhy [5722]	AYYAPANPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	CHELACHUVAD PUMP	81.0	0.0	14.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kanjikuzhy [5722]	CHELACHUVAD STAND	129.0	0.0	15.3	113.7	88.1	Very High
IDUKKI	Kanjikuzhy [5722]	CHOODANCITY	81.0	0.0	12.0	69.0	85.2	Very High
IDUKKI	Kanjikuzhy [5722]	CHURULI	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Kanjikuzhy [5722]	CHURULIPATHAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	CSI CHELACHUVADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	EDAKKAD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	EETTIKKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	GOVT HOSPITAL THALLAKANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	IDEA KEERITHODU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	IDEA VENMONY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kanjikuzhy [5722]	ITI	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kanjikuzhy [5722]	KAITHAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	KANJIKUZH	129.0	0.0	49.0	80.0	62.0	High
IDUKKI	Kanjikuzhy [5722]	KANNADIKAVALA	81.0	5.0	8.0	68.0	84.0	Very High
IDUKKI	Kanjikuzhy [5722]	KARIMANAL POLICESTATION	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	KARIMANAL TOWN	202.0	0.0	5.0	197.0	97.5	Very High
IDUKKI	Kanjikuzhy [5722]	KATHIPARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kanjikuzhy [5722]	KEERITHOD TOWN	129.0	0.0	11.3	117.7	91.2	Very High
IDUKKI	Kanjikuzhy [5722]	KOCHU CHELACHUVADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	KOODATHOTTI	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kanjikuzhy [5722]	KUDAKKALLU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	KUDUKKAKANDAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	KUZHICITY	81.0	0.0	18.0	63.0	77.8	Very High
IDUKKI	Kanjikuzhy [5722]	MAKKUPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	MAKKUVALLY	81.0	0.0	3.3	77.7	95.9	Very High
IDUKKI	Kanjikuzhy [5722]	MAMMACHANKUNNU RGGVY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	MANAYATHADAM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kanjikuzhy [5722]	MAZHUVADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	MYLAPUZHA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kanjikuzhy [5722]	NAKKAYAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	PAINAPPILLI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	PAKUTHIPPALAM	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kanjikuzhy [5722]	PALLIPUNNAYAR	81.0	0.0	3.5	77.5	95.7	Very High
IDUKKI	Kanjikuzhy [5722]	PAMBLA COLONY KSEB	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	PAMBLA DAM	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	PANAMKUTTI	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	PANCHARAPALAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	PAZHAYARIKANDAM NO I	129.0	0.0	11.0	118.0	91.5	Very High
IDUKKI	Kanjikuzhy [5722]	PERIYARVALLEY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	PONNEDUTHAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	PRABHACITY	81.0	3.0	3.0	75.0	92.6	Very High
IDUKKI	Kanjikuzhy [5722]	SHALOMPADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	ST MARYS CHURCH KANJIKUZH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	THALLAKKANAM	81.0	3.0	21.0	57.0	70.4	High
IDUKKI	Kanjikuzhy [5722]	THATTEKALLU	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	THATTEKKANNY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	THEKKENTHONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	THOTTIYAR AUXILIARY	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	URULIKKAL	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	VAKACHUVADU 100 KVA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kanjikuzhy [5722]	VANCHICKAL RGGVY 1	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	VANCHICKAL RGGVY II	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	VARAKULAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	VARICKAMUTHAN	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kanjikuzhy [5722]	VATTOMPARA	129.0	0.0	6.0	123.0	95.3	Very High
IDUKKI	Kanjikuzhy [5722]	VAYASANPADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kanjikuzhy [5722]	VENMONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	AL AMEEN	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Karimannur [5621]	ALKALLU	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Karimannur [5621]	AMAYAPRA	81.0	3.0	53.6	24.4	30.1	Medium
IDUKKI	Karimannur [5621]	ANIKUZHA	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Karimannur [5621]	ANNA METALS	81.0	0.0	45.8	35.2	43.5	Medium
IDUKKI	Karimannur [5621]	ASSANKAVALA	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Karimannur [5621]	BOUNDRY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Karimannur [5621]	CHACKAMKUNNU	81.0	0.0	3.4	77.6	95.8	Very High
IDUKKI	Karimannur [5621]	CHAKKAPPANKAVALA	81.0	0.0	34.0	47.0	58.0	High
IDUKKI	Karimannur [5621]	CHALASSERY	81.0	5.0	3.0	73.0	90.1	Very High
IDUKKI	Karimannur [5621]	CHEENIKUZH CHURCH	81.0	0.0	12.0	69.0	85.2	Very High
IDUKKI	Karimannur [5621]	CHEENIKUZH HEALTH	81.0	0.0	54.0	27.0	33.3	Medium
IDUKKI	Karimannur [5621]	CHEPPUKULAM GURUMANDHIRAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Karimannur [5621]	CHEPPUKULAM KPC	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Karimannur [5621]	CHERADI	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Karimannur [5621]	CHILAVU CHURCH	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Karimannur [5621]	CHIRAKANDOM	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Karimannur [5621]	CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	EDAMARUKU	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Karimannur [5621]	EZHUMUTTOM	81.0	0.0	57.0	24.0	29.6	Medium
IDUKKI	Karimannur [5621]	FEDERAL BANK	81.0	0.0	14.5	66.5	82.1	Very High
IDUKKI	Karimannur [5621]	HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	INDUS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	IOCL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Karimannur [5621]	KACHIRAMOOZHI	81.0	3.0	5.0	73.0	90.1	Very High
IDUKKI	Karimannur [5621]	KAITHAMATTOM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Karimannur [5621]	KALLIKKAL	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Karimannur [5621]	KAMPIPPALAM	81.0	0.0	48.0	33.0	40.7	Medium
IDUKKI	Karimannur [5621]	KARIMANNOOR CHURCH	81.0	5.0	58.0	18.0	22.2	Low
IDUKKI	Karimannur [5621]	KASHA	81.0	3.0	44.0	34.0	42.0	Medium
IDUKKI	Karimannur [5621]	KILIYARA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Karimannur [5621]	KIZHAKKUMPADOM	81.0	3.0	18.0	60.0	74.1	High
IDUKKI	Karimannur [5621]	KOKKALAM	81.0	5.0	31.3	44.7	55.2	High
IDUKKI	Karimannur [5621]	KOLLAPPUZHA	129.0	5.0	43.0	81.0	62.8	High
IDUKKI	Karimannur [5621]	KOTTAKKAVALA	81.0	8.0	65.0	8.0	9.9	Very Low
IDUKKI	Karimannur [5621]	KULAPPARA	81.0	8.0	32.4	40.6	50.2	High
IDUKKI	Karimannur [5621]	KULAPPARA TOWER	81.0	5.0	8.0	68.0	84.0	Very High
IDUKKI	Karimannur [5621]	KURUKKANADU	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Karimannur [5621]	KURUMBALAMATTOM	81.0	8.3	72.0	0.7	0.9	Very Low
IDUKKI	Karimannur [5621]	KURUPPUMPADI	81.0	10.0	53.0	18.0	22.2	Low
IDUKKI	Karimannur [5621]	KURUTHIKKULAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	MALAYINCHI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	MAMAKKADA	81.0	0.0	34.0	47.0	58.0	High
IDUKKI	Karimannur [5621]	MANACKAPADOM	81.0	3.0	20.7	57.3	70.7	High
IDUKKI	Karimannur [5621]	MANCHIKKALLU TOWN	81.0	0.0	38.8	42.2	52.1	High
IDUKKI	Karimannur [5621]	MANGALAMPADOM	81.0	0.0	19.0	62.0	76.5	Very High
IDUKKI	Karimannur [5621]	MANKUZH	81.0	5.0	22.1	53.9	66.5	High
IDUKKI	Karimannur [5621]	MANNARATHARA	81.0	3.0	5.0	73.0	90.1	Very High
IDUKKI	Karimannur [5621]	MANNIKUNNEL PEEDIKA	81.0	0.0	37.0	44.0	54.3	High
IDUKKI	Karimannur [5621]	MARUTHUMPARA	81.0	0.0	27.0	54.0	66.7	High
IDUKKI	Karimannur [5621]	MISSIONKUNNU	81.0	0.0	23.0	58.0	71.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Karimannur [5621]	MOOLAKKADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	MOOLEPPEDIKA	81.0	5.0	24.5	51.5	63.6	High
IDUKKI	Karimannur [5621]	MULAPPURAM	81.0	0.0	44.9	36.1	44.6	Medium
IDUKKI	Karimannur [5621]	MUTHAPPAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	NELLIMALA	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Karimannur [5621]	NEYYASSERY	129.0	0.0	22.0	107.0	82.9	Very High
IDUKKI	Karimannur [5621]	OFFICE	81.0	0.0	33.0	48.0	59.3	High
IDUKKI	Karimannur [5621]	OLIKKAMATTOM	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Karimannur [5621]	PALLIKKAMURY	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Karimannur [5621]	PANNOOR	81.0	3.0	46.4	31.6	39.0	Medium
IDUKKI	Karimannur [5621]	PANNOOR CHURCH	81.0	0.0	42.0	39.0	48.1	Medium
IDUKKI	Karimannur [5621]	PAREKKAVALA	81.0	3.0	58.0	20.0	24.7	Low
IDUKKI	Karimannur [5621]	PAREKKAVU	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Karimannur [5621]	PARIYARAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Karimannur [5621]	PAZHAYARA	81.0	3.0	25.7	52.3	64.5	High
IDUKKI	Karimannur [5621]	PAZHOOKKARA	81.0	5.0	30.0	46.0	56.8	High
IDUKKI	Karimannur [5621]	PERINGASSERY	81.0	0.0	12.0	69.0	85.2	Very High
IDUKKI	Karimannur [5621]	POLICE STATION	202.0	0.0	30.0	172.0	85.1	Very High
IDUKKI	Karimannur [5621]	RANDUPALAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	REEGAL	129.0	9.0	16.0	104.0	80.6	Very High
IDUKKI	Karimannur [5621]	RELIANCE	81.0	0.0	6.3	74.7	92.2	Very High
IDUKKI	Karimannur [5621]	SANJOSE	81.0	0.0	40.0	41.0	50.6	High
IDUKKI	Karimannur [5621]	THABOR	81.0	11.0	20.0	50.0	61.7	High
IDUKKI	Karimannur [5621]	THATTAKUZHA	129.0	3.0	25.0	101.0	78.3	Very High
IDUKKI	Karimannur [5621]	THAZHE MOOLAKKADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	THEKKINKKOOTTAM	202.0	0.0	39.7	162.3	80.3	Very High
IDUKKI	Karimannur [5621]	UDUMBANNOOR KWA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Karimannur [5621]	UDUMBANNOOR MINI	202.0	0.0	7.7	194.3	96.2	Very High
IDUKKI	Karimannur [5621]	UDUMBANNOOR PANCHAYATH	81.0	0.0	33.0	48.0	59.3	High
IDUKKI	Karimannur [5621]	UDUMBANNOOR TEMPLE	81.0	0.0	38.5	42.5	52.5	High
IDUKKI	Karimannur [5621]	UDUMBANNOOR VILLAGE	202.0	8.0	51.2	142.8	70.7	High
IDUKKI	Karimannur [5621]	UNICHIKAVALA	81.0	10.0	51.5	19.5	24.1	Low
IDUKKI	Karimannur [5621]	UPPUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	VALIYAMAVU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Karimannur [5621]	VATTAKKAVU PALAM	81.0	0.0	41.5	39.5	48.8	Medium
IDUKKI	Karimannur [5621]	VELLAMTHANAM	81.0	5.0	3.0	73.0	90.1	Very High
IDUKKI	Karimannur [5621]	VENAPPARA FLAT	202.0	0.0	8.0	194.0	96.0	Very High
IDUKKI	Karimannur [5621]	VENNIYANI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	100 ACRE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	AGRI CO	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	AISWARYA THEATRE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	ALLIYAAR	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kattapana [5609]	ALPHONSA ICICI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	AMARAVATHY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	AMBALAKAVALA	81.0	5.0	23.6	52.4	64.7	High
IDUKKI	Kattapana [5609]	AMBALAMEDU	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	ANAKUTHY	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kattapana [5609]	ANAKUTHY CHURCH	129.0	3.0	0.0	126.0	97.7	Very High
IDUKKI	Kattapana [5609]	ANAPPADY	81.0	0.0	16.4	64.6	79.7	Very High
IDUKKI	Kattapana [5609]	ANJILIPPALAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	ANNIYARTHOLU	202.0	0.0	13.0	189.0	93.6	Very High
IDUKKI	Kattapana [5609]	APPAPPANPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	ATHICHUVAD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	BASIL TYRES	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kattapana [5609]	BLOCK PANCHAYATH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	BRG ASSOCIATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	BRIQUET	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	CAFCO	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	CAPITAL	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kattapana [5609]	CARE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	CHEMMANNOOR	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kattapana [5609]	CHEMPAKAPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	CHENNATTUMATTAM	129.0	0.0	15.0	114.0	88.4	Very High
IDUKKI	Kattapana [5609]	CHINTHARMANY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	CIRCLE JUNCTION	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kattapana [5609]	CO OPERATIVE HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	COFFEE BOARD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	COMPANYPADY	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Kattapana [5609]	DIST PANCHAYATHU KANJIPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	EDASSERY	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kattapana [5609]	EDATHVAMETTU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	ELLUPODI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	ETTICKALPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	FEDERAL BANK	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	GANAPATHIPPALAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	GANAPATHYPPALAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	GAYATHRI SILKS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	GOVT COLLEGE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	GREEN HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	HAPPY NAGAR	51.0	0.0	5.0	46.0	90.2	Very High
IDUKKI	Kattapana [5609]	HEMAKADAVU	202.0	0.0	0.0	202.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kattapana [5609]	HIGHRANGE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	HILL TOP	81.0	3.0	4.9	73.1	90.2	Very High
IDUKKI	Kattapana [5609]	IDUKIKAVALA	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Kattapana [5609]	IDUKKIKKAVALA TOWER	81.0	0.0	26.0	55.0	67.9	High
IDUKKI	Kattapana [5609]	INDUS	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kattapana [5609]	ITI	202.0	0.0	62.7	139.3	69.0	High
IDUKKI	Kattapana [5609]	JABBAEPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	K S E B JN	129.0	0.0	3.0	126.0	97.7	Very High
IDUKKI	Kattapana [5609]	KADUKKA PULIYANMALA	81.0	3.0	3.0	75.0	92.6	Very High
IDUKKI	Kattapana [5609]	KALARICKAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	KALLARACKAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	KALLUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	KALYANATHANDU	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	KANAKALIPADY	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kattapana [5609]	KANAPPALLY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	KANJIPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	KARIPPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	KATTAPPANA TOWN	202.0	0.0	56.8	145.2	71.9	High
IDUKKI	Kattapana [5609]	KAVALAKKATTUPADY	81.0	3.0	10.3	67.7	83.5	Very High
IDUKKI	Kattapana [5609]	KOCHUTHOVALA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	KONGINIPADAV	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kattapana [5609]	KSHB	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kattapana [5609]	KSRTC	81.0	0.0	25.6	55.4	68.4	High
IDUKKI	Kattapana [5609]	KULATHINMEDU	129.0	0.0	5.0	124.0	96.1	Very High
IDUKKI	Kattapana [5609]	KUNDALAMPARA RATIONKADA	81.0	3.0	16.0	62.0	76.5	Very High
IDUKKI	Kattapana [5609]	KUNJETTANKADA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	KURUSUPALLY KUNTHALAMPARA	81.0	5.0	4.5	71.5	88.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kattapana [5609]	KUZHIKANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	MAHENDRA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	MALABAR GOLD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	MARUTHANPADY	81.0	0.0	15.0	66.0	81.5	Very High
IDUKKI	Kattapana [5609]	METHRAN PARAMPIL	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kattapana [5609]	METTUKUZHYY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	MINI	202.0	0.0	17.0	185.0	91.6	Very High
IDUKKI	Kattapana [5609]	MLANKANDAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	MULAKARAMEDU	81.0	0.0	4.0	77.0	95.1	Very High
IDUKKI	Kattapana [5609]	MUNCIPALITY	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kattapana [5609]	NAVADHARSANA PULIYANMALA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kattapana [5609]	NEST	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	NEW BUSSTAND	129.0	0.0	4.5	124.5	96.5	Very High
IDUKKI	Kattapana [5609]	NIRMALACITY	81.0	0.0	12.0	69.0	85.2	Very High
IDUKKI	Kattapana [5609]	NIRMALAPURAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	O J PADY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	OVELIPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	PADUKAPURAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	PALAKKAMATAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	PALLIKAVALA	129.0	0.0	30.9	98.2	76.1	Very High
IDUKKI	Kattapana [5609]	PANJIKKATTUPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	PARAKADAVU	129.0	5.0	19.9	104.1	80.7	Very High
IDUKKI	Kattapana [5609]	PARAKKADAV- ANAKUTHY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	PARAMADA KUNTHALAMPARA	129.0	6.0	21.9	101.2	78.4	Very High
IDUKKI	Kattapana [5609]	PARAMADA NIRMALAPURAM	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kattapana [5609]	PARAMADA SUKUMARAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	PARAMADA VANCHITHANAM	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kattapana [5609]	PATHUKOODU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	PAVITHRA INDOOR 250	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kattapana [5609]	PAVITHRA INDOOR 315	255.0	0.0	0.0	255.0	100.0	Very High
IDUKKI	Kattapana [5609]	PEZHUMKAVALA	81.0	0.0	15.8	65.2	80.5	Very High
IDUKKI	Kattapana [5609]	POLICE STATION	129.0	6.0	5.0	118.0	91.5	Very High
IDUKKI	Kattapana [5609]	PONNIKKAVALA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	POORS MOUNT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	POOTHRACKADA	129.0	5.0	16.0	108.0	83.7	Very High
IDUKKI	Kattapana [5609]	POOVATHUMKAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	POPULAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	PORSUKAVALA	81.0	0.0	15.0	66.0	81.5	Very High
IDUKKI	Kattapana [5609]	PRATHEEKSHA BHAVAN	202.0	0.0	15.0	187.0	92.6	Very High
IDUKKI	Kattapana [5609]	PULIYANMALA	129.0	0.0	25.0	104.0	80.6	Very High
IDUKKI	Kattapana [5609]	RELIANCE FRESH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	RELIANCE TRENDS	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kattapana [5609]	SAGARA BYPASS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	SALES TAX	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	SANTHI NAGAR	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	SANTHOSH THEATRE	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kattapana [5609]	SBI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	SCHOOLMEDU PULIYANMALA	81.0	0.0	4.0	77.0	95.1	Very High
IDUKKI	Kattapana [5609]	SHINA COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kattapana [5609]	SLAUGHTER HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	SN JUNCTION	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kattapana [5609]	SOCIETY PADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	SOOLAPPARA	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Kattapana [5609]	ST JOHNS	202.0	0.0	0.0	202.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kattapana [5609]	STB	81.0	10.0	20.6	50.4	62.2	High
IDUKKI	Kattapana [5609]	SUVARNAGIRI	81.0	6.0	6.0	69.0	85.2	Very High
IDUKKI	Kattapana [5609]	TELECOM	129.0	0.0	33.7	95.3	73.9	High
IDUKKI	Kattapana [5609]	THURUTHEL ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	TVS MOTORS	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Kattapana [5609]	UMMAKKADA	81.0	0.0	12.8	68.2	84.2	Very High
IDUKKI	Kattapana [5609]	UPPUKANDAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kattapana [5609]	VALIYAKANDAM	81.0	0.0	72.6	8.4	10.4	Low
IDUKKI	Kattapana [5609]	VALIYAPARA	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Kattapana [5609]	VALIYAPARA PARAMADA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kattapana [5609]	VATTUKUNNELPADY	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kattapana [5609]	VELLAYAMKUDY	129.0	5.0	16.5	107.5	83.3	Very High
IDUKKI	Kattapana [5609]	VELLAYAMKUDY APE	81.0	11.0	12.0	58.0	71.6	High
IDUKKI	Kattapana [5609]	VETIKUZHAKAVALA	81.0	13.0	41.8	26.2	32.4	Medium
IDUKKI	Kattapana [5609]	VICTORIA	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kattapana [5609]	VILLAGEPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	VRINDAVANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kattapana [5609]	Y M C A	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	1 ST MILE	129.0	0.0	37.5	91.5	70.9	High
IDUKKI	Kumily [5708]	100 KVA OTTAKATHALA	81.0	0.0	25.0	56.0	69.1	High
IDUKKI	Kumily [5708]	13TH NO COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	2 ND MILE	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	2ND MILE PUMP HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	3RD MILE	81.0	3.0	0.0	78.0	96.3	Very High
IDUKKI	Kumily [5708]	4TH MILE 100 KVA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	5TH COLONY MURIKKADY	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	5TH NO COLONY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kumily [5708]	65TH MILE PALAM100KVA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	66TH HOSPITAL	129.0	0.0	3.4	125.6	97.3	Very High
IDUKKI	Kumily [5708]	66THVILLAGE PADI 100KVA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	8 ACRE	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Kumily [5708]	8TH ACRE CHENKARA RGGY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kumily [5708]	AIRTEL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	AKG PADI-100KVA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	AKG PADY NO 2	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	ALEMCHERIL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	AMALAGIRI PUTHUVEL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	AMALAMBIKA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	AMBADY	129.0	0.0	10.0	119.0	92.2	Very High
IDUKKI	Kumily [5708]	AMBDHEKKAR COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	ANAKUZHYPUMP	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Kumily [5708]	ANAVILASAM	81.0	0.0	27.0	54.0	66.7	High
IDUKKI	Kumily [5708]	ANAVILASAM VI	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kumily [5708]	ARAYNANIVAS	40.0	0.0	0.0	40.0	100.0	Very High
IDUKKI	Kumily [5708]	ATTAPALLOMOTTAKATHALA-VI	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Kumily [5708]	ATTAPPALLAM VI	81.0	4.0	3.0	74.0	91.4	Very High
IDUKKI	Kumily [5708]	BIJU PAUL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	BSNL MICRO WAVE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	CHAPPATH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	CHELMADA	81.0	5.0	8.0	68.0	84.0	Very High
IDUKKI	Kumily [5708]	CHELMADA160KVA	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	CHEMPAMKULAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	CHENKARA	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	CHITTUMALA	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kumily [5708]	CHOTTUPARA	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	CHURAKULAM	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Kumily [5708]	COFFEE ROUTES	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	DONBOSCO	51.0	0.0	5.0	46.0	90.2	Very High
IDUKKI	Kumily [5708]	DYMUKE PUTHUVEL	81.0	5.0	8.0	68.0	84.0	Very High
IDUKKI	Kumily [5708]	ELANJIMEDU	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kumily [5708]	FOREST GATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	GANAPATHIPLACKAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	GANDHI NAGAR	81.0	0.0	15.0	66.0	81.5	Very High
IDUKKI	Kumily [5708]	GANDHISILA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	GOEC	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	GRACE THEATRE	129.0	0.0	65.0	64.0	49.6	Medium
IDUKKI	Kumily [5708]	GREENPALACE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	HEALTH CENTRE PATHUMURI	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kumily [5708]	HOLIDAY HOME	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	JEEVANANDAN	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Kumily [5708]	KALLARAIKAL ANASAVAARI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KALLEPURAMEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KALLEPURAMIL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KALLUMEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KANJIRAMKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KANNIMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KINATTUKARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KIZHAKKUMADU IST MILE	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kumily [5708]	KOLLAMPATTADA	202.0	0.0	6.0	196.0	97.0	Very High
IDUKKI	Kumily [5708]	KSEB OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KSRTC	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kumily [5708]	KUMALY TOWN	405.0	0.0	55.0	350.0	86.4	Very High
IDUKKI	Kumily [5708]	KURIAN COLONY	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Kumily [5708]	KURISSUMLA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KURIYAN COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KUTHUKALSSERY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	KWA 1ST MILE	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Kumily [5708]	KWA OTTAKATHALA 1ST	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kumily [5708]	KWA OTTAKATHALA 2NDBOOSTER	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kumily [5708]	KWA OTTAKATHALA 3 RD BOOSTER	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	KWA THEKKADY	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	LABBAKANDAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	LE OYEC BIJU P MATHEW	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MADHAVANKANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MANNAKKUDY VI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MANNAKUDY	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Kumily [5708]	MARIYA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MATHENKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MELMADHVAMKAANAM100 KVA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MEPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	METAL CRESHURE	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	MOOLAKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MOTHER TERESA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MOUNT SAHYA	129.0	5.0	11.8	112.2	87.0	Very High
IDUKKI	Kumily [5708]	MULLAYAR	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	MULLAYAR AMBEDKAR COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MULLAYAR RGGGY 2	20.0	0.0	8.0	12.0	60.0	High
IDUKKI	Kumily [5708]	MULLAYAR RGGY	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kumily [5708]	MULLAYAR TOP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	MURIKKADY LPS	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kumily [5708]	MURIKKADY POOMARAM	81.0	0.0	22.0	59.0	72.8	High
IDUKKI	Kumily [5708]	MURIKKADY VI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	N M R	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	NEDUMPURAM VI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	NEDUMTHOTTY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	NIRMALAGIRI PALANICAVU 100	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	NOOLAMPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	NOOLAMPARA100A	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	ODAMEDU	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Kumily [5708]	PALANIKKAVU	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kumily [5708]	PALIYAKKUDI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PANDIKUZHYY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PATHUMURI NO2	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PATHUMURY	81.0	0.0	25.9	55.1	68.1	High
IDUKKI	Kumily [5708]	PATHUMURY PUMPHOUSE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PATTAYAMEDU IDEA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PERIYAR COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PERIYAR HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PERIYAR HOUSE	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Kumily [5708]	PERIYAR MEDOWS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PERIYAVALLAVU	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kumily [5708]	PMCS 65TH MILE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PUMBHOUSE 2ND MILE	81.0	0.0	20.0	61.0	75.3	Very High
IDUKKI	Kumily [5708]	PUTHUKKADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	PUTHUSSEERYKADA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kumily [5708]	PWD	129.0	0.0	10.8	118.2	91.6	Very High
IDUKKI	Kumily [5708]	RELIANCE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kumily [5708]	ROSAPPUKANDAM	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Kumily [5708]	ROSAPPUKANDAM 160 KVA	129.0	0.0	3.0	126.0	97.7	Very High
IDUKKI	Kumily [5708]	ROUNDGIRI	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Kumily [5708]	SAHYAJYOTHI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	SANKARAGIRI	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Kumily [5708]	SI PALANIKKAVU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	SILVERCREST	202.0	0.0	14.0	188.0	93.1	Very High
IDUKKI	Kumily [5708]	SN100	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	SOP LT CINNAMON	129.0	0.0	65.0	64.0	49.6	Medium
IDUKKI	Kumily [5708]	SPRING VALLEY VI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	ST THOMAS MOUNT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	SWAPNAJUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	TEKKADY GATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	THARTHIRAJ	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	THEPPAKULAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	TIGER RORE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	TREATMENT PLANT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	TREETOP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	TRIBEL COLONY	81.0	0.0	7.0	74.0	91.4	Very High
IDUKKI	Kumily [5708]	V I 1ST MILE	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Kumily [5708]	VALIYAKANDADM	81.0	3.0	33.0	45.0	55.6	High
IDUKKI	Kumily [5708]	VALLIYAMTHADAM	81.0	0.0	30.0	51.0	63.0	High
IDUKKI	Kumily [5708]	VELLARAMKUNNU	129.0	0.0	21.0	108.0	83.7	Very High
IDUKKI	Kumily [5708]	VI ATTAPALLAM	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Kumily [5708]	VI-VALIYAKANDAM	81.0	0.0	14.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Kumily [5708]	VILLEGEPADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	WASTE PLANT MURIKKADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Kumily [5708]	WATERSUPPLYPATHUMURI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	CHANDHANA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	CHATTAMUNNAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	CHEMPATTY DDUGJY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	CHERUVADU	129.0	0.0	20.0	109.0	84.5	Very High
IDUKKI	Marayoor [5616]	CHILANTHIYAR RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Marayoor [5616]	CHINNAVARA 1	81.0	0.0	3.5	77.5	95.7	Very High
IDUKKI	Marayoor [5616]	CHINNAVARA II	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	COFFEE STORE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	DINDUCOMBU	129.0	0.0	10.0	119.0	92.2	Very High
IDUKKI	Marayoor [5616]	DREAM VALLY RESORT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	ECHAMPETTYKUDY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	EDAKKADAVU RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Marayoor [5616]	G N PURAM	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Marayoor [5616]	INDIRA COLONY II TSP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	INDIRA COLONY NO 1 TSP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	JALANIDHI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	JUMAMASJIDH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	KAMMALAMKUDY DDUGJY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	KANTHALLOOR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	KARAYOOR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	KARSANAD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	KEEZHANTHOOR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	KOTTAKAMBOOR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	KOVILKADAVU	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Marayoor [5616]	KOVILOOR	129.0	0.0	5.0	124.0	96.1	Very High
IDUKKI	Marayoor [5616]	KUDILARKUDI RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Marayoor [5616]	KULACHIVAYAL	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Marayoor [5616]	KULACHIVAYAL CHEENI	81.0	0.0	36.0	45.0	55.6	High
IDUKKI	Marayoor [5616]	KUNDAKAD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	KUTHUKALKUDY DDUGJY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	LAKKAMKUDY DDUGJY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	MAMMAL RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Marayoor [5616]	MARAYOOR GRAMAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	MARAYOOR II	81.0	0.0	40.0	41.0	50.6	High
IDUKKI	Marayoor [5616]	MARAYOOR III	81.0	0.0	3.4	77.6	95.8	Very High
IDUKKI	Marayoor [5616]	MARAYOOR NO 1	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Marayoor [5616]	MASIVAYAL	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Marayoor [5616]	MELADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	MELEVALSAPETTY TSP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	MISSIONVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	NACHIVAYAL	81.0	0.0	4.3	76.7	94.7	Very High
IDUKKI	Marayoor [5616]	NAKKUPETTY DDUGJY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	NELLIPPETTY TSP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	OORKKADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PALLANADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PAMPANPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PARADIPALLOM RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Marayoor [5616]	PAZHATHOTTAM	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Marayoor [5616]	PERADIPALLOM NO 2	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PERIYAKUDY DDUGJY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PERUMALA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Marayoor [5616]	PETROL PUMB	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PIOUSNAGAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PONGAMPALLY RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Marayoor [5616]	PULICKARAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PURAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PUTHOOR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	PUTHUVETTU TSP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	SANDAL OIL FACTORY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	SUBSTATION	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Marayoor [5616]	SWAMIYARALLAKUDI RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Marayoor [5616]	THEERTHAMALAKUDY RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Marayoor [5616]	ULLAVAYALKUDY TSP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Marayoor [5616]	VALSAPETTY RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Marayoor [5616]	VATTAVADA	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Marayoor [5616]	VENGAPPARA TSP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	12TH MILE	129.0	5.0	54.8	69.2	53.6	High
IDUKKI	Moolamattom [5619]	12TH MILE KWA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	7TH MILE TEMPLE	81.0	5.0	21.5	54.5	67.3	High
IDUKKI	Moolamattom [5619]	ADOORMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	ADOORMALA CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	ALANICKAL ESTATE	81.0	0.0	41.0	40.0	49.4	Medium
IDUKKI	Moolamattom [5619]	ANAKAYAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Moolamattom [5619]	ANGEL	81.0	3.0	15.8	62.2	76.8	Very High
IDUKKI	Moolamattom [5619]	ANOOR KUMBAMKANAM	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Moolamattom [5619]	ARAKULAM PUTHENPALLI	81.0	21.0	58.7	1.3	1.6	Very Low
IDUKKI	Moolamattom [5619]	ASCO ARAKULAM	129.0	5.0	35.0	89.0	69.0	High
IDUKKI	Moolamattom [5619]	ASHOKA MOBILE TOWER	81.0	0.0	46.0	35.0	43.2	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Moolamattom [5619]	ASRAMAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	AUDIT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	AUDIT JUNCTION	81.0	0.0	27.0	54.0	66.7	High
IDUKKI	Moolamattom [5619]	BUBBLER	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Moolamattom [5619]	BUS STAND MUTTOM	81.0	0.0	48.5	32.5	40.1	Medium
IDUKKI	Moolamattom [5619]	BVC	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Moolamattom [5619]	BVMC	129.0	0.0	28.0	101.0	78.3	Very High
IDUKKI	Moolamattom [5619]	CHAKKIKAVU CHURCH	81.0	0.0	7.0	74.0	91.4	Very High
IDUKKI	Moolamattom [5619]	CHALLAVAYAL JUNCTION	81.0	0.0	41.0	40.0	49.4	Medium
IDUKKI	Moolamattom [5619]	CHAMAKALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	CHERADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	CHERADY TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	DAM TOP KULAMAVU	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Moolamattom [5619]	EDADU	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Moolamattom [5619]	EDAPPALY MUTTOM	81.0	0.0	34.0	47.0	58.0	High
IDUKKI	Moolamattom [5619]	ELAPPILLY	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Moolamattom [5619]	ELAVEEZHAPOOMCHIRA	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Moolamattom [5619]	ELlichari-1	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Moolamattom [5619]	ELLUMPURAM	81.0	4.0	6.0	71.0	87.7	Very High
IDUKKI	Moolamattom [5619]	GREEN BERG	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	GVT HOSPITAL MUTTOM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Moolamattom [5619]	ILLICHARI VANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	INDUSTRIAL KACOMBU	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Moolamattom [5619]	INTAKE GATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	JALANDAR	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Moolamattom [5619]	JYOTHI BHAVAN ASHOKA	81.0	0.0	27.0	54.0	66.7	High
IDUKKI	Moolamattom [5619]	KACOMBU	81.0	0.0	24.0	57.0	70.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Moolamattom [5619]	KAIPPA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Moolamattom [5619]	KANJAR PUMB	129.0	0.0	11.0	118.0	91.5	Very High
IDUKKI	Moolamattom [5619]	KANJAR TOWN	129.0	0.0	20.0	109.0	84.5	Very High
IDUKKI	Moolamattom [5619]	KANJAR-INDUSTRIAL	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Moolamattom [5619]	KANNIKKAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KARIPPILANGAD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KARUNA SAW MILL MUTTOM	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Moolamattom [5619]	KAVALAM CITY	81.0	8.0	26.0	47.0	58.0	High
IDUKKI	Moolamattom [5619]	KINFRA-100KVA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KINFRA-160KVA NO-1	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KINFRA-160KVA NO-2	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KINFRA-250KVA	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KOLAPRA	81.0	0.0	19.0	62.0	76.5	Very High
IDUKKI	Moolamattom [5619]	KOLAPRA BRIDGE	81.0	0.0	18.8	62.2	76.8	Very High
IDUKKI	Moolamattom [5619]	KOOVAPALLY EAST	81.0	0.0	7.0	74.0	91.4	Very High
IDUKKI	Moolamattom [5619]	KOOVAPALLY KWA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KOOVAPPILLY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KOTTAYAMMUNNI	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Moolamattom [5619]	KOZHIPALLY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KRISHNA SAW MILL	81.0	0.0	29.7	51.3	63.3	High
IDUKKI	Moolamattom [5619]	KSEB COLNY MLTM	405.0	0.0	12.0	393.0	97.0	Very High
IDUKKI	Moolamattom [5619]	KUDAYATHOOR	81.0	5.0	18.0	58.0	71.6	High
IDUKKI	Moolamattom [5619]	KUDAYATHOOR MOSQUE	81.0	0.0	35.0	46.0	56.8	High
IDUKKI	Moolamattom [5619]	KUDAYATHOOR PHC	81.0	5.0	30.0	46.0	56.8	High
IDUKKI	Moolamattom [5619]	KULAMAVU BUND	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KULAMAVU CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KULAMAVU EAST	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Moolamattom [5619]	KULAMAVU PUMP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	KURUTHIKULAM	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Moolamattom [5619]	MALANKARA PALACE	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Moolamattom [5619]	MANAPPADY	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Moolamattom [5619]	MATHAPARA PUMP	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Moolamattom [5619]	MATHAPPARA	81.0	0.0	17.7	63.3	78.2	Very High
IDUKKI	Moolamattom [5619]	MATTATHIPARA KWA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	MOBIL TOWER 7TH MILE	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Moolamattom [5619]	MOOLAMATTOM CHURCH	81.0	0.0	66.9	14.1	17.4	Low
IDUKKI	Moolamattom [5619]	MOONNUMKAVAYAL	81.0	10.0	12.0	59.0	72.8	High
IDUKKI	Moolamattom [5619]	MOONNUMKAVAYAL PUMP	81.0	0.0	28.0	53.0	65.4	High
IDUKKI	Moolamattom [5619]	MORKKAD	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	MUTHIYAMALA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Moolamattom [5619]	MUTHIYURUNDAYAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	MUTTAM TOWN	121.0	0.0	6.0	115.0	95.0	Very High
IDUKKI	Moolamattom [5619]	MUTTOM BSNL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	MUTTOM RELAINCE TOWER	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Moolamattom [5619]	MYLADY	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Moolamattom [5619]	NADUKANI	81.0	0.0	15.0	66.0	81.5	Very High
IDUKKI	Moolamattom [5619]	NAVODAYA KLMU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	NJARALAMPUZHA	81.0	0.0	18.0	63.0	77.8	Very High
IDUKKI	Moolamattom [5619]	NJARALAMPUZHA KWA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	NJARALAMPUZHA MOBIL TOWER	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Moolamattom [5619]	OFFICE-I	129.0	0.0	42.0	87.0	67.5	High
IDUKKI	Moolamattom [5619]	OORAKUNNU	81.0	0.0	48.0	33.0	40.7	Medium
IDUKKI	Moolamattom [5619]	OZHUKAYIL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	PANCHAYATH MLTM	81.0	0.0	29.0	52.0	64.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Moolamattom [5619]	PANCHAYATHUPADI MUTTOM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	PANDAPLAVU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	PANDIYANMAVU	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Moolamattom [5619]	PATHIPPALLY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	PAZHAYAMATTAM	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Moolamattom [5619]	POOMCHIRA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Moolamattom [5619]	POOTHUMATTOM	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Moolamattom [5619]	POTHUMATTOM OZHANKAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	PULLOONNUPARA	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Moolamattom [5619]	PUTHED TOWN	81.0	0.0	7.0	74.0	91.4	Very High
IDUKKI	Moolamattom [5619]	PUTHEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	RANIGIRI	81.0	5.0	31.5	44.5	55.0	High
IDUKKI	Moolamattom [5619]	S N D P MUTTOM	81.0	5.0	24.0	52.0	64.2	High
IDUKKI	Moolamattom [5619]	SANKARAPALLY SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	SANKARAPALLY VILLA	129.0	0.0	24.0	105.0	81.4	Very High
IDUKKI	Moolamattom [5619]	SANKARAPPILLY CHURCH	81.0	0.0	21.0	60.0	74.1	High
IDUKKI	Moolamattom [5619]	SANKARAPPILLY NO-I	81.0	0.0	79.5	1.5	1.9	Very Low
IDUKKI	Moolamattom [5619]	SARAMKUTHI	81.0	5.0	37.0	39.0	48.1	Medium
IDUKKI	Moolamattom [5619]	ST JOSEPH COLLEGE	81.0	0.0	45.0	36.0	44.4	Medium
IDUKKI	Moolamattom [5619]	ST MARYS SAW MILL	81.0	0.0	11.3	69.7	86.0	Very High
IDUKKI	Moolamattom [5619]	TEMPLE NADUKANI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Moolamattom [5619]	THOTTUMKARA	81.0	0.0	24.0	57.0	70.4	High
IDUKKI	Moolamattom [5619]	VADAKKEPPUZHA-3	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Moolamattom [5619]	VADAKKEPPUZHA2	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Moolamattom [5619]	VADAKKEPUZHA1	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Moolamattom [5619]	VADAKKUMMEDU	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Moolamattom [5619]	VALLIPARA	81.0	0.0	26.0	55.0	67.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Moolamattom [5619]	VENGITTA	81.0	5.0	25.0	51.0	63.0	High
IDUKKI	Moolamattom [5619]	VICHATTUKAVALA	81.0	0.0	15.4	65.6	80.9	Very High
IDUKKI	Moolamattom [5619]	VINAYAKA	81.0	0.0	48.0	33.0	40.7	Medium
IDUKKI	Murikkassery [5711]	16 KANDAM TOWN	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Murikkassery [5711]	17-COMPANY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	ANTOPURAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	ANTOPURAM RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Murikkassery [5711]	BATHEL ANGANAWADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	BETHEL	129.0	5.0	19.0	105.0	81.4	Very High
IDUKKI	Murikkassery [5711]	CHALICITY	81.0	0.0	4.0	77.0	95.1	Very High
IDUKKI	Murikkassery [5711]	CHAMPAKAPARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	CHAMPAKAPARA SNDP	81.0	3.0	0.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	CHANDANAKAVALA	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Murikkassery [5711]	CHARALANGANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	CHEMPAKAPARA MILMA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	CHINNAR	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	DAIVAMMEDU AMALA	129.0	0.0	3.0	126.0	97.7	Very High
IDUKKI	Murikkassery [5711]	DAIVAMMEDU CRESHUR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	DAIVAMMEDU KWA	51.0	0.0	5.0	46.0	90.1	Very High
IDUKKI	Murikkassery [5711]	DAIVAMMEDU MILMA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	ELEGENT VENEERS PADAMUGHAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	GOURYCITY	129.0	0.0	3.0	126.0	97.7	Very High
IDUKKI	Murikkassery [5711]	JAVANCITY	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Murikkassery [5711]	KALLIPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	KALLIPPARA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	KANAKAKUNNU M G	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	KANAKAKUNNU S I	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Murikkassery [5711]	KARIKKAVALA KATTAKALAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	KARIKKAVALA TOWN	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Murikkassery [5711]	KARIKKINMEDU	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Murikkassery [5711]	KILIYARKANDAM	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Murikkassery [5711]	KOCHUKARIMPAN	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Murikkassery [5711]	KOCHUKARIMPAN CSI KUNNE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	KONNACKAMALI	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Murikkassery [5711]	MAARIGIRI	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	MADAPRA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	MADAPRA BRIQUETTES	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	MANATHARA	129.0	0.0	16.0	113.0	87.6	Very High
IDUKKI	Murikkassery [5711]	MANNATHARA COLONY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	MELE CHINNAR	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Murikkassery [5711]	MOONGAPARA	81.0	0.0	23.0	58.0	71.6	High
IDUKKI	Murikkassery [5711]	MURICKASSERY ALPHONSA	129.0	0.0	27.4	101.6	78.8	Very High
IDUKKI	Murikkassery [5711]	MURICKASSERY BSNL	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Murikkassery [5711]	MURICKASSERY COMMUNITY HALL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	MURICKASSERY PLUS 2	129.0	0.0	13.0	116.0	89.9	Very High
IDUKKI	Murikkassery [5711]	MURIKKASSERY STADIUM	81.0	0.0	11.4	69.6	85.9	Very High
IDUKKI	Murikkassery [5711]	NALUTHOONU	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	NERCHAPARA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Murikkassery [5711]	NEW MOUNT RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Murikkassery [5711]	NEWMOUNT	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Murikkassery [5711]	PADAMUGHAM	81.0	5.0	28.0	48.0	59.3	High
IDUKKI	Murikkassery [5711]	PADAMUGHAM DEPAUL	81.0	0.0	14.0	67.0	82.7	Very High
IDUKKI	Murikkassery [5711]	PADAMUGHAM KUMARANPADY	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Murikkassery [5711]	PARAMADA	81.0	5.0	6.0	70.0	86.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Murikkassery [5711]	PARAYANKUZH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	PERINCHANKUTTY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	PERUMTHOTTY	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Murikkassery [5711]	PERUMTHOTTY TOWER	81.0	0.0	9.9	71.1	87.8	Very High
IDUKKI	Murikkassery [5711]	POOMAMKANDAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	PRAKASH	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Murikkassery [5711]	PRAKASH BSNL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	RAJAMUDY	81.0	5.0	3.0	73.0	90.1	Very High
IDUKKI	Murikkassery [5711]	RAJAMUDY TOWN	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Murikkassery [5711]	RAJAPURAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	RAJAPURAM TOWER	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Murikkassery [5711]	SCHOOL CITY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	SENAPATHY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	THAZHE 16 KANDAM S N	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Murikkassery [5711]	THEKINTHANDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	THIRD BLOCK	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Murikkassery [5711]	THOPRAMKUDY MADAMKAVALA	81.0	3.0	0.0	78.0	96.3	Very High
IDUKKI	Murikkassery [5711]	THOPRAMKUDY MADAMKAVALA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	THOPRAMKUDY SBI TR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	THOPRAMKUDY TOWN	129.0	0.0	17.0	112.0	86.8	Very High
IDUKKI	Murikkassery [5711]	THOPRANKUDY BUS STAND	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	THOTTIKADA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Murikkassery [5711]	UDAYAGIRI CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Murikkassery [5711]	UDAYAGIRY	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Murikkassery [5711]	UPPUTHODU AYUVEDA	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Murikkassery [5711]	UPPUTHODU RATIONKADA	81.0	0.0	24.0	57.0	70.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Murikkassery [5711]	VATHIHKUDI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	10 TH ACRE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	10 VALAVU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	14 KUTTY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	8 MUKU	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	ADIYARPURAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	ALADY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	AMBEDKAR COLONY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	AMBILI AMMANKANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	AMMENCHERIPPADY	81.0	3.0	22.0	56.0	69.1	High
IDUKKI	Nedumkandam [5610]	ANGANVADY	51.0	0.0	2.9	48.1	94.3	Very High
IDUKKI	Nedumkandam [5610]	ANS PADY	81.0	5.0	33.0	43.0	53.1	High
IDUKKI	Nedumkandam [5610]	ASHOKAVANAM KOCHAMMA ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	ASSARIKANDAM	81.0	4.2	56.0	20.8	25.6	Medium
IDUKKI	Nedumkandam [5610]	ATTIPADI	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Nedumkandam [5610]	ATTUPARA	81.0	5.0	3.0	73.0	90.1	Very High
IDUKKI	Nedumkandam [5610]	B-ED	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Nedumkandam [5610]	BEDIMETTU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	BEDIMETTU AMBALAM	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	BEDIMETTU TOWER	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	CARDAMOM RESEARCH STN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	CENTRE POINT	129.0	0.0	9.9	119.1	92.3	Very High
IDUKKI	Nedumkandam [5610]	CHAKKAKANAM MILMA	129.0	0.0	6.0	123.0	95.3	Very High
IDUKKI	Nedumkandam [5610]	CHAKKAKANAM NURSING COLLEGE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	CHAKKAKANAM-NO2	81.0	0.0	72.0	9.0	11.1	Low
IDUKKI	Nedumkandam [5610]	CHANDANAPARA	81.0	0.0	14.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Nedumkandam [5610]	CHARALMEDU	81.0	0.0	12.0	69.0	85.2	Very High
IDUKKI	Nedumkandam [5610]	CHEENIPPARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	CHEMBAKAKUZHI	129.0	5.0	71.5	52.5	40.7	Medium
IDUKKI	Nedumkandam [5610]	CHEMBAKAKUZHI RESORT	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	CHEMBALAM	81.0	5.0	11.0	65.0	80.2	Very High
IDUKKI	Nedumkandam [5610]	CITY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	CIVIL STATION	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	COFFEE MILL	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Nedumkandam [5610]	D F O	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Nedumkandam [5610]	ETTUMUKKU AMBALAPPADI	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	GANDHINAGAR	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	IHRD	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Nedumkandam [5610]	INDIRANAGAR	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	JEEVAMATHA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	JESUS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KAILASAM	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KAILASAPARA DAM	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KAILASAPPRA	81.0	15.0	0.0	66.0	81.5	Very High
IDUKKI	Nedumkandam [5610]	KAILASAPURI KARADIVALAVU	20.0	0.0	8.0	12.0	60.0	High
IDUKKI	Nedumkandam [5610]	KALAKKADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KALKOONTHAL	129.0	0.0	14.5	114.5	88.7	Very High
IDUKKI	Nedumkandam [5610]	KALLAR	81.0	0.0	14.8	66.2	81.8	Very High
IDUKKI	Nedumkandam [5610]	KALLAR DAM	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KAMAKSHIVILASAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KAMBALA-VALPPARA-NO1	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KARADIALA JOY ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KARIMKADU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Nedumkandam [5610]	KARITHODU	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KARUNA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KATTAKKALA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KATTIKKAYAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KAUNTHY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	KIZHAKKE KAVALA	202.0	12.0	67.8	122.2	60.5	High
IDUKKI	Nedumkandam [5610]	KJ ESTATE THOOVAL	20.0	0.0	3.0	17.0	85.0	Very High
IDUKKI	Nedumkandam [5610]	KOOTHATTUKULAM PADY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KUNNUKUZHI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	KURISUPARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	LIC	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Nedumkandam [5610]	LUXON MOTORS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	MANJAPARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	MANJAPETTY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	MANJAPPETTY CHINGAMTHARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	MANJAPPETTY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	MAVADI 40 ACRE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	MAVADY	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Nedumkandam [5610]	MAVADY PALLICITY	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Nedumkandam [5610]	MAVADY-KUNNUMMALI	81.0	3.0	0.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	MAVINCHUVADU	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	MEDICAL TRUST	81.0	0.0	79.0	2.0	2.5	Very Low
IDUKKI	Nedumkandam [5610]	MEGHA PLANTATION	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	MEKALLAR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	NEDUMKANDAM CENTRAL	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	NEDUMKANDAM STADIUM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	NEDUMKANDAM WEST	405.0	0.0	66.0	339.0	83.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Nedumkandam [5610]	ODAKKUMUKKU	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	OTTAKKADA	20.0	0.0	8.0	12.0	60.0	High
IDUKKI	Nedumkandam [5610]	P-AND-T TELICOM	81.0	3.0	0.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	PACHADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	PACHIPADY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	PAMPADUMPARA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	PAMPADUMPARA-ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	PAMPAMDUMPARA	129.0	0.0	11.0	118.0	91.5	Very High
IDUKKI	Nedumkandam [5610]	PARACKALPADY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	PARIVARTHANAMEDU	81.0	6.0	42.0	33.0	40.7	Medium
IDUKKI	Nedumkandam [5610]	PATHINANCHIL PADY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	PATHINIPARA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	PGF	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	PJ TOWER KALKOONTHAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	PONNAMALA-KOLLAMKUDI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	POOVATHANIPADY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	POPSON	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	PRAKANDOM	81.0	0.0	29.0	52.0	64.2	High
IDUKKI	Nedumkandam [5610]	PUTHUKADU	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Nedumkandam [5610]	PUTHUMANA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	SAMSKARANAPLANT	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	SAWMILL	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Nedumkandam [5610]	SDA SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	SUB STATION	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	SUPRANKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	SURESHPADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	TALUK HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Nedumkandam [5610]	THANKACHAN KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	THANKAVILASAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	THANNIMOODU	129.0	0.0	3.0	126.0	97.7	Very High
IDUKKI	Nedumkandam [5610]	THANNIMOODU NO-2	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	THAZHAKANDAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	THOOVAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	THOTTUVAKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	TRENDS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	UMMAKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	UNANI METTU	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	UNITED AGRO	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	UPPUKANDAM	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	VALLIKADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	VALLIKKAD KUTTAI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	VALPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	VANANGAMUDI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	VATHALLOORPADY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	VATTAKUZH-Y-JOHN-Y	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	VATTAPARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Nedumkandam [5610]	VYAVASAYAPARK	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Nedumkandam [5610]	WRITER KANDOM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	10 MILE STORE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	10TH MILE	129.0	0.0	13.0	116.0	89.9	Very High
IDUKKI	Painavu [5623]	7TH MILE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	8TH BLOCK	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Painavu [5623]	8TH MILE	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Painavu [5623]	9TH MILE	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Painavu [5623]	ACHANKANAM	81.0	0.0	4.7	76.3	94.2	Very High
IDUKKI	Painavu [5623]	ALINCHUVADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	AMALAGIRI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	AMALJYOTHI	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Painavu [5623]	AMBALAMEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	ANAKOMBAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	ANERT EVCS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	ASOKA	129.0	50.0	29.0	50.0	38.8	Medium
IDUKKI	Painavu [5623]	ATHIKKALPADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	BADAM KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	BHOOMIYANKULAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Painavu [5623]	CHANAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	CHEMPAKAPARA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Painavu [5623]	CHEMPAKAPARA ANGANVADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	CHERUTHONI LAB	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	CHERUTHONY DAM	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Painavu [5623]	CHERUTHONY PAPENS	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Painavu [5623]	CHERUTHONY POLICE STATION	129.0	0.0	4.0	125.0	96.9	Very High
IDUKKI	Painavu [5623]	CHERUTHONY THEATRE	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Painavu [5623]	CHETANIKADA	81.0	3.0	0.0	78.0	96.3	Very High
IDUKKI	Painavu [5623]	CHETTIMATTEL	81.0	3.0	21.0	57.0	70.4	High
IDUKKI	Painavu [5623]	COLLECTORATE	129.0	0.0	59.0	70.0	54.3	High
IDUKKI	Painavu [5623]	COLONY KSEB	405.0	0.0	13.0	392.0	96.8	Very High
IDUKKI	Painavu [5623]	COLONY SIVAN	405.0	0.0	8.0	397.0	98.0	Very High
IDUKKI	Painavu [5623]	DISTRICT HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	DOUBLE CUTTING	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Painavu [5623]	DPC KUYILIMALA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Painavu [5623]	EETTIKAVALA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Painavu [5623]	ENGG COLLEGE STAFF QUARTERS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	GANDHI NAGAR MUSLIM PALLY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	IDUKKI DAM	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Painavu [5623]	IDUKKI DAM BOTTOM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	IDUKKI NEW MAN SCHOOL	81.0	3.0	16.0	62.0	76.5	Very High
IDUKKI	Painavu [5623]	INTELLIGENCE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	IRUKOOTTY	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Painavu [5623]	KALYANATHANDU	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Painavu [5623]	KALYANATHANDU VIEW POINT	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Painavu [5623]	KAMAKSHY	81.0	3.0	11.0	67.0	82.7	Very High
IDUKKI	Painavu [5623]	KAMAKSHY HOSPITAL	81.0	0.0	20.4	60.6	74.8	High
IDUKKI	Painavu [5623]	KAMAKSHY IDEA TOWER	81.0	0.0	15.0	66.0	81.5	Very High
IDUKKI	Painavu [5623]	KARGIL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KARIKINTHOLAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KARIMBAN EXCHANGE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KARIMBAN TOWN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KARIMBANCITY VAZHAVARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KARIMBANKANAM IDEA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KATADIKAVALA	81.0	0.0	18.0	63.0	77.8	Very High
IDUKKI	Painavu [5623]	KESAMUNI	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Painavu [5623]	KOKKARAKULAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KOOTTAKALLU	81.0	0.0	10.5	70.5	87.0	Very High
IDUKKI	Painavu [5623]	KOUVANTHI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KURISHINKAL KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KURISSUPARA THANKAMANI	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Painavu [5623]	KUTHIRAKALLU	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Painavu [5623]	KUTTANKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KUTTAPPANCITY KARIMBAN	129.0	0.0	2.0	127.0	98.4	Very High
IDUKKI	Painavu [5623]	KV SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	KV STAFF QUARTERS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MACHAN KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MADATHINKADAVU	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Painavu [5623]	MANGALAMKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MANIPPARA	81.0	0.0	31.0	50.0	61.7	High
IDUKKI	Painavu [5623]	MANIYARANKUDY KATTAKALAM	81.0	0.0	7.0	74.0	91.4	Very High
IDUKKI	Painavu [5623]	MANIYARANKUDY MOSQUE	81.0	0.0	12.3	68.7	84.8	Very High
IDUKKI	Painavu [5623]	MAPPILAKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MARIAPURAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MARIYAPURAM	129.0	0.0	6.0	123.0	95.3	Very High
IDUKKI	Painavu [5623]	MATHAI PADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MATTAPPILLIKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MAYOORA	81.0	8.0	3.0	70.0	86.4	Very High
IDUKKI	Painavu [5623]	MEDICAL COLLEGE	405.0	0.0	0.0	405.0	100.0	Very High
IDUKKI	Painavu [5623]	MICROWAVE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MILLUMPADY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Painavu [5623]	MRS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MULAKUVALLY ATHICKAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	MULLAKUVALLY CHURCH	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Painavu [5623]	MURALI NEELIVAYAL	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Painavu [5623]	NARAKAKANAM CHURCH	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Painavu [5623]	NARAKAKANAM MINI DAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	NEELIVAYAL	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Painavu [5623]	NELLIPUZHAKAVALA	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Painavu [5623]	NELLIPUZHAKAVALA KUNNATHU PADY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Painavu [5623]	NJVALCHUVADU	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Painavu [5623]	PAINAVU EXCHANGE	202.0	0.0	15.0	187.0	92.6	Very High
IDUKKI	Painavu [5623]	PALITHAZHAM	81.0	8.0	17.9	55.1	68.0	High
IDUKKI	Painavu [5623]	PALLIKKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	PANDIPPARA	129.0	3.0	21.0	105.0	81.4	Very High
IDUKKI	Painavu [5623]	PANDIPPARA INDUS TOWER	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Painavu [5623]	PARAPPANANGADY VAZHAVARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Painavu [5623]	PAREMAVU	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Painavu [5623]	PARUTHIKUNNELPADY VAZHAVARA	81.0	3.0	8.0	70.0	86.4	Very High
IDUKKI	Painavu [5623]	POORNIMA	202.0	0.0	3.0	199.0	98.5	Very High
IDUKKI	Painavu [5623]	RELIANCE VELLAKAYAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	SCHOOL CITY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	THADIYAMPADU	129.0	10.0	13.0	106.0	82.2	Very High
IDUKKI	Painavu [5623]	THAKARAPALLIMEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	THANDANPALAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	THANIKANDOM GIRIJYOTHI	81.0	3.0	8.0	70.0	86.4	Very High
IDUKKI	Painavu [5623]	THANIKANDOM M G	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	THANKAMANY BUS STAND	81.0	5.0	8.0	68.0	84.0	Very High
IDUKKI	Painavu [5623]	THANKAMANY PARAMADA	202.0	8.0	17.0	177.0	87.6	Very High
IDUKKI	Painavu [5623]	THANKAMANY TEMPLE	129.0	0.0	20.0	109.0	84.5	Very High
IDUKKI	Painavu [5623]	TREATMENT PLANT KWA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	UNNI CITY	81.0	5.0	6.0	70.0	86.4	Very High
IDUKKI	Painavu [5623]	VATTAMEDU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	VAZHAVARA	129.0	0.0	16.0	113.0	87.6	Very High
IDUKKI	Painavu [5623]	VAZHAVARA KOUNTHY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Painavu [5623]	VAZHAVARA TOWER	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Painavu [5623]	VELLAKAYAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Painavu [5623]	VELLAPARA	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Painavu [5623]	VIMALAGIRI	129.0	0.0	22.0	107.0	82.9	Very High
IDUKKI	Peruvanthanam [5720]	35 TH MILE	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Peruvanthanam [5720]	36TH MILE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	AMALA PLASTICS	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	AMALAGIRI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	ANACHARI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	AZHANGADU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	BOYCE ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	CHAMAPARA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Peruvanthanam [5720]	CHENNA PARA FACTORY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	CHERUVALLIKULAM KURISHADY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	CHERUVALLIKULAM RATION KADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	CHUZHUPPU BUNGLOW	81.0	0.0	24.0	57.0	70.4	High
IDUKKI	Peruvanthanam [5720]	CHUZHUPPU CHURCH	81.0	0.0	2.0	79.0	97.5	Very High
IDUKKI	Peruvanthanam [5720]	HIGHRANGE CRUSHER NO-I	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	HIGHRANGE CRUSHER NO-II	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KADAMANKULAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KALLUKEERI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KANAMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KANAYANKAVAYAL	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Peruvanthanam [5720]	KANGANIPALAM	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Peruvanthanam [5720]	KANNATTUKAVALA KOMBUKUTHY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KAPPALUVENGA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KODIKUTHI BUNGLOW	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Peruvanthanam [5720]	KOINADU ARUTHOTTIYIL	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOINADU CHURCH	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOINADU KANAYANKAL	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOINADU KUZHIPALAYIL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOINADU MARADIYIL	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOINADU NO 7 KOLLIKOLAVIL	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOINADU NO MATHILUMKAL	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOMBUKUTHY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOMBUKUTHY CENTER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOMPANPARA	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOMPANPARA CHORAKKALI	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOMPANPARA IHDP COLONY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KOOTTAMAVU	81.0	0.0	23.0	58.0	71.6	High
IDUKKI	Peruvanthanam [5720]	KUPPAKAYAM TOP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	KURUTHIKALAM	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MADAMBA ADIPIPE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MADAMBA BUS STAND	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MADAMBA CHURCH	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MADAMBA PAYWARD	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MADAMBA RESORT	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MADAMBHA BABU HOUSE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MADANTHARA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Peruvanthanam [5720]	MANIKAL FACTORY	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MANJAKALLORAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MANORAMA KANAYANKAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MARUTHUMMOODU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MATTOM	51.0	0.0	0.0	51.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Peruvanthanam [5720]	MELORAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	MISTY HILL	129.0	40.0	0.0	89.0	69.0	High
IDUKKI	Peruvanthanam [5720]	MULAMKUNNU	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Peruvanthanam [5720]	MULLAMKUNNU ANGANAWADI	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Peruvanthanam [5720]	MURINJA PUZHA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Peruvanthanam [5720]	NAAMAH	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	NALLATHANNI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	NEDIYORAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	ORKADAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PALAKUZHI	20.0	6.0	11.0	3.0	15.0	Low
IDUKKI	Peruvanthanam [5720]	PALAKUZHI RESORT	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PALOORKAVU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PALOORKAVU BSNL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PARUDEESA PLANTATIONS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PATTIKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PERUVANTHANAM BSNL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PERUVANTHANAM NO 2 POST OFFICE	81.0	0.0	26.0	55.0	67.9	High
IDUKKI	Peruvanthanam [5720]	PERUVANTHANAM TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PILLAKKADA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	POOVANCHI	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	POTTAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PULLUPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	PURAKKAYAM	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	RELIANCE PERUVANTHANAM	81.0	10.0	2.0	69.0	85.2	Very High
IDUKKI	Peruvanthanam [5720]	ST ANTONYS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	SURENDRAN HOUSE	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Peruvanthanam [5720]	THAZHVARAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	THEKKEMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	THEKKEMALA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	VAKAMALA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	VALLEY END	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	VALLIYAMKAVU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Peruvanthanam [5720]	VELLANI SAMSKARIKANILAYAM	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Purappuzha [5743]	AARATHI	129.0	0.0	23.0	106.0	82.2	Very High
IDUKKI	Purappuzha [5743]	AATHIRA PLYWOOD	129.0	0.0	5.0	124.0	96.1	Very High
IDUKKI	Purappuzha [5743]	ADORNS MILL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	ADUTHATTU	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Purappuzha [5743]	ALPHONSA-INDUSTRY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	AMARAMKAVU	81.0	5.0	26.0	50.0	61.7	High
IDUKKI	Purappuzha [5743]	AMBALAPPADY	129.0	0.0	27.9	101.0	78.3	Very High
IDUKKI	Purappuzha [5743]	ANCHAPRA	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Purappuzha [5743]	AREEKKAL	81.0	0.0	43.0	38.0	46.9	Medium
IDUKKI	Purappuzha [5743]	AZHAKUMPARA	129.0	0.0	21.0	108.0	83.7	Very High
IDUKKI	Purappuzha [5743]	AZHIKANNI	81.0	5.0	17.0	59.0	72.8	High
IDUKKI	Purappuzha [5743]	BAPPUJI	81.0	8.0	40.0	33.0	40.7	Medium
IDUKKI	Purappuzha [5743]	BSNL EXCHANGE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	BUILTECH KARIMKUNNAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	CEDAR HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	CHELAPPARA	129.0	0.0	31.0	98.0	76.0	Very High
IDUKKI	Purappuzha [5743]	CHENAPARAMBU	81.0	8.0	29.0	44.0	54.3	High
IDUKKI	Purappuzha [5743]	CHETTIPARAMBIL	81.0	10.0	19.0	52.0	64.2	High
IDUKKI	Purappuzha [5743]	EDAYADI	81.0	0.0	21.0	60.0	74.1	High
IDUKKI	Purappuzha [5743]	ERAVIPPARA	81.0	0.0	14.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Purappuzha [5743]	ERUTTUTHODU CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Purappuzha [5743]	IMA VILLA NADUKANDAM	202.0	0.0	5.0	197.0	97.5	Very High
IDUKKI	Purappuzha [5743]	IRUTTUTHODU	81.0	5.0	43.8	32.2	39.8	Medium
IDUKKI	Purappuzha [5743]	JOYAL CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	KAARATHANAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	KADARAKKUZHY	81.0	0.0	29.0	52.0	64.2	High
IDUKKI	Purappuzha [5743]	KAIPPILLY	81.0	0.0	10.0	71.0	87.7	Very High
IDUKKI	Purappuzha [5743]	KANNADIKANDAM	81.0	0.0	47.2	33.8	41.7	Medium
IDUKKI	Purappuzha [5743]	KANNAMPARA	81.0	6.0	34.0	41.0	50.6	High
IDUKKI	Purappuzha [5743]	KARIMKUNNAM H S	129.0	5.0	8.0	116.0	89.9	Very High
IDUKKI	Purappuzha [5743]	KARIMKUNNAM IDEA	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Purappuzha [5743]	KARIMKUNNAM MADOM	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Purappuzha [5743]	KARIMKUNNAM PHC	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Purappuzha [5743]	KARIMKUNNAM THEVARANI ROAD	81.0	0.0	35.8	45.2	55.8	High
IDUKKI	Purappuzha [5743]	KATTOLY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	KODIKUTHI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	KOLADI	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Purappuzha [5743]	KOOPPUKAVALA	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Purappuzha [5743]	KUMMACHIRA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Purappuzha [5743]	KUNINJI TEMPLE	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Purappuzha [5743]	KUZHIMATTOM	81.0	0.0	56.0	25.0	30.9	Medium
IDUKKI	Purappuzha [5743]	MALANADU	81.0	3.0	32.0	46.0	56.8	High
IDUKKI	Purappuzha [5743]	MANJAKADAMBU	81.0	5.0	57.0	19.0	23.5	Low
IDUKKI	Purappuzha [5743]	MARIKA	81.0	5.0	38.0	38.0	46.9	Medium
IDUKKI	Purappuzha [5743]	MARVAL BED	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	MARY MATHA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	MATTATHIPPARA	81.0	0.0	10.0	71.0	87.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Purappuzha [5743]	MATTATHIPPARA KOOTTIYANIKKAL	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Purappuzha [5743]	MATTATHIPPARA NIRAPPU	81.0	0.0	14.3	66.7	82.3	Very High
IDUKKI	Purappuzha [5743]	MELEPURAPPUZHA	81.0	8.0	26.0	47.0	58.0	High
IDUKKI	Purappuzha [5743]	MOORIPARA	81.0	3.0	10.0	68.0	84.0	Very High
IDUKKI	Purappuzha [5743]	MULLAKKARIYIL HATCHERY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	MUNDANMALA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Purappuzha [5743]	MUTTUCHIRA	81.0	3.0	27.8	50.2	62.0	High
IDUKKI	Purappuzha [5743]	MUTTUTHATTI	81.0	3.0	28.0	50.0	61.7	High
IDUKKI	Purappuzha [5743]	NADUKANDAM	129.0	0.0	84.2	44.8	34.8	Medium
IDUKKI	Purappuzha [5743]	NAIR COLONY	81.0	5.0	44.5	31.5	38.9	Medium
IDUKKI	Purappuzha [5743]	NEDIYASALA CHURCH	81.0	0.0	24.2	56.8	70.1	High
IDUKKI	Purappuzha [5743]	NEDIYASALA MILL	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Purappuzha [5743]	NEELOOR	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Purappuzha [5743]	NELLAPARA KWA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	NELLAPPARA	81.0	3.0	11.0	67.0	82.7	Very High
IDUKKI	Purappuzha [5743]	OTTALLOOR	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Purappuzha [5743]	PANACKACHAL	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Purappuzha [5743]	PAULTRY FARM	129.0	0.0	18.0	111.0	86.0	Very High
IDUKKI	Purappuzha [5743]	PERIYAMBRA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	PLANTATION	81.0	5.0	8.0	68.0	84.0	Very High
IDUKKI	Purappuzha [5743]	PLANTATION LAKSHAM VEEDU	81.0	3.0	6.0	72.0	88.9	Very High
IDUKKI	Purappuzha [5743]	PONNAMTHANAM CHURCH	81.0	0.0	25.0	56.0	69.1	High
IDUKKI	Purappuzha [5743]	POOTHAKAVU	81.0	0.0	16.5	64.5	79.7	Very High
IDUKKI	Purappuzha [5743]	PULINCHUVADU	81.0	0.0	29.0	52.0	64.2	High
IDUKKI	Purappuzha [5743]	PUNJIRI KAVALA	129.0	0.0	29.0	100.0	77.5	Very High
IDUKKI	Purappuzha [5743]	PURAPPUZHA HS	129.0	0.0	11.0	118.0	91.5	Very High
IDUKKI	Purappuzha [5743]	PURAPPUZHA KRISHIBHAVAN	81.0	3.0	0.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Purappuzha [5743]	PURAPPUZHA MADAM	81.0	0.0	16.0	65.0	80.2	Very High
IDUKKI	Purappuzha [5743]	PURAPPUZHA TEMPLE	129.0	6.0	12.0	111.0	86.0	Very High
IDUKKI	Purappuzha [5743]	PURAPPUZHA THS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	PUTHENPALLY	202.0	0.0	27.5	174.5	86.4	Very High
IDUKKI	Purappuzha [5743]	PUTHENPALLY KWA	81.0	0.0	13.5	67.5	83.4	Very High
IDUKKI	Purappuzha [5743]	SALI-INDUSTRIES	129.0	0.0	42.0	87.0	67.4	High
IDUKKI	Purappuzha [5743]	SANTHIGIRI	129.0	0.0	25.0	104.0	80.6	Very High
IDUKKI	Purappuzha [5743]	TERESA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	THARAVATTOM	81.0	8.0	12.0	61.0	75.3	Very High
IDUKKI	Purappuzha [5743]	THATTARATHATTA	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Purappuzha [5743]	THONIKKUHIMALA	81.0	5.0	21.0	55.0	67.9	High
IDUKKI	Purappuzha [5743]	THOYIPRA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	TV RELAY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Purappuzha [5743]	VADAKKUMURY	81.0	0.0	19.0	62.0	76.5	Very High
IDUKKI	Purappuzha [5743]	VADAKKUMURY KWA	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Purappuzha [5743]	VALLIKKETTU	81.0	0.0	34.0	47.0	58.0	High
IDUKKI	Purappuzha [5743]	VAZHAPPILLY	81.0	0.0	9.3	71.7	88.5	Very High
IDUKKI	Purappuzha [5743]	VAZHITHALA 4 POLE	129.0	0.0	39.3	89.7	69.5	High
IDUKKI	Purappuzha [5743]	VAZHITHALA MERCY	129.0	0.0	34.0	95.0	73.6	High
IDUKKI	Purappuzha [5743]	VAZHITHALA PARA	81.0	0.0	20.0	61.0	75.3	Very High
IDUKKI	Purappuzha [5743]	VAZHITHALA SBT	81.0	8.0	19.5	53.5	66.1	High
IDUKKI	Purappuzha [5743]	VELLOMNEEKKIPARA	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Rajakkad [5730]	300 ACRE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	ADIVARAM - II	129.0	0.0	0.0	129.0	100.0	Very High
IDUKKI	Rajakkad [5730]	ADIVARAM-1	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Rajakkad [5730]	AMBALAKKAVALA	81.0	6.0	3.0	72.0	88.9	Very High
IDUKKI	Rajakkad [5730]	AMRUTHA DRYER	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Rajakkad [5730]	ANAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	ARAKKAKAVALA	81.0	5.0	0.0	76.0	93.8	Very High
IDUKKI	Rajakkad [5730]	ARIVILAMCHAL	121.0	6.0	11.3	103.7	85.7	Very High
IDUKKI	Rajakkad [5730]	ATHMAVUCITY	81.0	6.0	3.0	72.0	88.9	Very High
IDUKKI	Rajakkad [5730]	AUXILIARY DTR KUTHUNKAL SS	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	BSNL	81.0	0.0	38.0	43.0	53.1	High
IDUKKI	Rajakkad [5730]	CHAMBAKKARA	202.0	0.0	0.0	202.0	100.0	Very High
IDUKKI	Rajakkad [5730]	CHAPPATHU	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	CHELACHUVADU	81.0	0.0	13.0	68.0	84.0	Very High
IDUKKI	Rajakkad [5730]	CHERUPURAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	CKC -2	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	CKC-1	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	CRUSHUR	51.0	0.0	3.0	48.0	94.1	Very High
IDUKKI	Rajakkad [5730]	DAM TOP	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	EBANEZAR	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Rajakkad [5730]	ELAVUMCHUVADU	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Rajakkad [5730]	ELLAKKAL	81.0	0.0	23.0	58.0	71.6	High
IDUKKI	Rajakkad [5730]	ETTAKANAM	81.0	0.0	23.0	58.0	71.6	High
IDUKKI	Rajakkad [5730]	EZHARA ACRE	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Rajakkad [5730]	IDAKKATTUKUDY	20.0	0.0	0.0	20.0	100.0	Very High
IDUKKI	Rajakkad [5730]	ILLIPPALAM	51.0	0.0	0.0	51.0	100.0	Very High
IDUKKI	Rajakkad [5730]	JOBIN MATHEW ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	JOSEGIRI	81.0	0.0	16.4	64.6	79.7	Very High
IDUKKI	Rajakkad [5730]	KACHAPPALLI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	KACHIRAPALAM	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Rajakkad [5730]	KALLIMALY	81.0	8.0	5.0	68.0	84.0	Very High
IDUKKI	Rajakkad [5730]	KANAKAPPUZHA	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Rajakkad [5730]	KANTHIPPARA -KMR	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	KAPPIKKADU	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Rajakkad [5730]	KARIMALA ILLY CITY	81.0	0.0	9.0	72.0	88.9	Very High
IDUKKI	Rajakkad [5730]	KOCHUMULLAKKANAM	81.0	0.0	31.0	50.0	61.7	High
IDUKKI	Rajakkad [5730]	KOONA ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	KPK DRYER EDAMATTAM	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	KURANGUPARA	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	KUTHUNGAL	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Rajakkad [5730]	MAMMATTIKKANAM	129.0	0.0	9.0	120.0	93.0	Very High
IDUKKI	Rajakkad [5730]	MANGATHOTTY TOWN	81.0	0.0	11.0	70.0	86.4	Very High
IDUKKI	Rajakkad [5730]	MANGATHOTTY VILLAGE	81.0	0.0	25.0	56.0	69.1	High
IDUKKI	Rajakkad [5730]	MANJAPPILLY CITY	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Rajakkad [5730]	MAVARCITY	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Rajakkad [5730]	MOOLAMKUZHI	81.0	0.0	6.0	75.0	92.6	Very High
IDUKKI	Rajakkad [5730]	MUKKUDIL - I	81.0	0.0	17.7	63.3	78.1	Very High
IDUKKI	Rajakkad [5730]	MUKKUDIL - II	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Rajakkad [5730]	MUKUNDAN	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	N R CITY	202.0	0.0	27.0	175.0	86.6	Very High
IDUKKI	Rajakkad [5730]	NADUMATTAM	81.0	0.0	38.0	43.0	53.1	High
IDUKKI	Rajakkad [5730]	NJERIPPALAM	81.0	3.0	18.8	59.2	73.1	High
IDUKKI	Rajakkad [5730]	ORAPOOZHICKAL	129.0	0.0	30.0	99.0	76.7	Very High
IDUKKI	Rajakkad [5730]	OTTATHY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	PACHOLIPPADY	81.0	0.0	3.0	78.0	96.3	Very High
IDUKKI	Rajakkad [5730]	PALA ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	PANACHIKUZHI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	PANNIYARKUTTY	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	PARAKADAVU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
IDUKKI	Rajakkad [5730]	PARAPPANAGADI	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	PAZHAYAVIDUTHY	81.0	3.0	22.0	56.0	69.1	High
IDUKKI	Rajakkad [5730]	PAZHAYAVIDUTHY VILLAGE	81.0	0.0	8.0	73.0	90.1	Very High
IDUKKI	Rajakkad [5730]	PG	81.0	0.0	0.0	81.0	100.0	Very High
IDUKKI	Rajakkad [5730]	POLICE STATION	81.0	3.0	21.0	57.0	70.4	High
IDUKKI	Rajakkad [5730]	POOPACITY	81.0	0.0	11.5	69.5	85.8	Very High
IDUKKI	Rajakkad [5730]	POSTOFFICE PADY	81.0	0.0	5.0	76.0	93.8	Very High
IDUKKI	Rajakkad [5730]	POTHUPARA-1	81.0	0.0	0.0	81.0	100.0	Very High