

KSEB Renewable Energy Feasibility Report

Generated report · 2000 transformers across 1 districts. Balance % = (Balance Available ÷ 90% DTR Capacity) × 100.

District Summary

District	Transformers	Balance (kW)	Very High	High	Medium	Low	Very Low	Unknown
KANNUR	2000	150,935.5	1152	436	225	67	120	0
TOTAL	2000	150,935.5	1152	436	225	67	120	0

KANNUR — 2000 transformers

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Alakkode [6648]	1 ALAKODE MILMA	129.0	8.0	97.3	23.7	18.4	Low
KANNUR	Alakkode [6648]	1ANALIPPARA	81.0	0.0	19.0	62.0	76.5	Very High
KANNUR	Alakkode [6648]	1ARANGAM SS	129.0	0.0	49.8	79.2	61.4	High
KANNUR	Alakkode [6648]	1CHAPPARAMALA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Alakkode [6648]	1CHERUPARA TOWN	81.0	12.0	3.0	66.0	81.5	Very High
KANNUR	Alakkode [6648]	1HOSPITAL ALAKODE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	1KANNADIPARA	81.0	8.0	38.0	35.0	43.2	Medium
KANNUR	Alakkode [6648]	1KARUVANCHAL	129.0	0.0	3.0	126.0	97.7	Very High
KANNUR	Alakkode [6648]	1KODOPPALLY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	1KOTTAYADU KAVALA	129.0	6.0	84.0	39.0	30.2	Medium
KANNUR	Alakkode [6648]	1KUTTIPPUZHA BRIDGE	51.0	0.0	6.0	45.0	88.2	Very High
KANNUR	Alakkode [6648]	1NELLIPARA	81.0	0.0	28.5	52.5	64.8	High
KANNUR	Alakkode [6648]	1OOLIMADA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Alakkode [6648]	1PATHAYAKUNDU	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Alakkode [6648]	1PULIYILAMKUNDU	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Alakkode [6648]	1THERTHALLY PHC	81.0	0.0	33.3	47.7	58.9	High
KANNUR	Alakkode [6648]	1VELLADU CHURCH	129.0	0.0	22.0	107.0	82.9	Very High
KANNUR	Alakkode [6648]	2ALAKODE JALANIDHI	81.0	5.0	8.0	68.0	84.0	Very High
KANNUR	Alakkode [6648]	2CHEETHAPPARA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Alakkode [6648]	2CHUNKASTHANAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	2KANIYANCHAL	81.0	5.0	29.7	46.3	57.1	High
KANNUR	Alakkode [6648]	2KARUVANCHAL CENTRAL	129.0	0.0	14.3	114.7	88.9	Very High
KANNUR	Alakkode [6648]	2KUTTIPPUZHA RATION SHOP	81.0	3.0	30.0	48.0	59.3	High
KANNUR	Alakkode [6648]	2MANNANKUNDU	81.0	0.0	19.0	62.0	76.5	Very High
KANNUR	Alakkode [6648]	2NELLIPARA-INDS ESTATE	81.0	0.0	29.0	52.0	64.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Alakkode [6648]	2PATTAKALAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	2THAZHE MORANI	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Alakkode [6648]	2VAYATTUPARAMBA GROTO	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	3ALAKODE LINK	129.0	0.0	10.0	119.0	92.2	Very High
KANNUR	Alakkode [6648]	3CHEMBECHIMOTTA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	3KARUVANCHAL PUTHENPURA	129.0	0.0	15.0	114.0	88.4	Very High
KANNUR	Alakkode [6648]	3MANTHATTU	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Alakkode [6648]	3MOONNAMKUNNU	129.0	0.0	3.0	126.0	97.7	Very High
KANNUR	Alakkode [6648]	3NELLIKKUNNU	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Alakkode [6648]	3VAYATTUPARAMBA-IDEA	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Alakkode [6648]	4ALAKODE PUZHAYORAM	81.0	0.0	50.5	30.5	37.6	Medium
KANNUR	Alakkode [6648]	4CHERUPARA	129.0	0.0	3.0	126.0	97.7	Very High
KANNUR	Alakkode [6648]	4KARUNAPURAM	81.0	0.0	29.0	52.0	64.2	High
KANNUR	Alakkode [6648]	4MANJAKKADU	129.0	0.0	6.0	123.0	95.3	Very High
KANNUR	Alakkode [6648]	4PATHIMUNDA	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Alakkode [6648]	4THADIKKADAVU BRIDGE	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Alakkode [6648]	4THERTHALLY-IDEA	81.0	5.0	21.0	55.0	67.9	High
KANNUR	Alakkode [6648]	5ALAKODE CHURCH	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Alakkode [6648]	5CHEKKICHERI VAYAL	81.0	3.0	15.0	63.0	77.8	Very High
KANNUR	Alakkode [6648]	5KARAMARAMTHATTU KUTTIPPULLU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	5MANIKKAL	81.0	8.0	9.0	64.0	79.0	Very High
KANNUR	Alakkode [6648]	5MAVUMCHAL CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	5THERTHALLI	202.0	5.0	40.9	156.2	77.3	Very High
KANNUR	Alakkode [6648]	6CHENGAD	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Alakkode [6648]	6KARIVEDAKAM KUNDU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	7CHEEYANCHERI	81.0	0.0	15.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Alakkode [6648]	7KARAMARAM THATTU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	8CHEKUTHANKAYAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	8OTTATHAI	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Alakkode [6648]	9KARIMKAYAM	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Alakkode [6648]	ACHARKOLLY-25KVA	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Alakkode [6648]	AIRTEL KARUVANCHAL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	ALATHANVALAPPU	81.0	3.0	22.4	55.6	68.6	High
KANNUR	Alakkode [6648]	ALDUS MALL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	AMALAGIRI-63KVA	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Alakkode [6648]	ANAKKUZH	81.0	0.0	26.0	55.0	67.9	High
KANNUR	Alakkode [6648]	ARANGAM	129.0	0.0	44.5	84.5	65.5	High
KANNUR	Alakkode [6648]	ASANKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	AYURVEDA HOSPITAL PALLIPADI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	BALAPURAM	129.0	5.0	36.0	88.0	68.2	High
KANNUR	Alakkode [6648]	BEEMBUMKAD	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Alakkode [6648]	BRIDGE ALAKODE	81.0	6.0	27.4	47.6	58.8	High
KANNUR	Alakkode [6648]	CHANOKKUNDU	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Alakkode [6648]	CHEDIKKUNDU	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Alakkode [6648]	CHURCH VAYATTUPARAMBA	81.0	5.0	23.0	53.0	65.4	High
KANNUR	Alakkode [6648]	CITY MAX	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Alakkode [6648]	DARAPPANKUNNU	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Alakkode [6648]	EK TOWER	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Alakkode [6648]	ELAYADU	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Alakkode [6648]	EXCHANGE KARUVANCHAL	81.0	5.0	46.0	30.0	37.0	Medium
KANNUR	Alakkode [6648]	FARLONGARA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Alakkode [6648]	FEDERAL BANK-NR NSS SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	FILIM CITY ALAKKODE	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Alakkode [6648]	GREEN DAY OIL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	GROTO THADIKKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	HOSPITAL KARUVANCHAL	81.0	9.0	61.0	11.0	13.6	Low
KANNUR	Alakkode [6648]	IDEA VELLAD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	JMJ THIMIRI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	JOSES CLINIC-100 KVA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	KALLODY	129.0	3.0	25.7	100.3	77.7	Very High
KANNUR	Alakkode [6648]	KANHAMALA-SBI	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Alakkode [6648]	KASUMANCHODU	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Alakkode [6648]	KAVUMKUDI	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Alakkode [6648]	KM OILMILL MEENPATTY	129.0	0.0	10.0	119.0	92.2	Very High
KANNUR	Alakkode [6648]	KODOPPALLY	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Alakkode [6648]	KOOLAMBI	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Alakkode [6648]	KOTTAKADAVE	81.0	5.0	13.0	63.0	77.8	Very High
KANNUR	Alakkode [6648]	KUTTIKARI	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Alakkode [6648]	MALABAR OIL MILL THADIKKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	MANATTY	81.0	0.0	12.9	68.1	84.1	Very High
KANNUR	Alakkode [6648]	MARYGIRI	81.0	5.0	17.0	59.0	72.8	High
KANNUR	Alakkode [6648]	MAVUMCHAL JUNCTION	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Alakkode [6648]	MEENPATTY	81.0	25.0	55.0	1.0	1.2	Very Low
KANNUR	Alakkode [6648]	MELORAMTHATTU-TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	MOOLOTHUMKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Alakkode [6648]	MORANI	81.0	0.0	2.0	79.0	97.5	Very High
KANNUR	Alakkode [6648]	MOUVATHANI	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Alakkode [6648]	MUNDACHAL	129.0	0.0	46.0	83.0	64.3	High
KANNUR	Alakkode [6648]	MYLAMPETTY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	NARIYAMPARA	81.0	3.0	27.8	50.2	62.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Alakkode [6648]	NELLIPPARA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	NOOLITTAMALA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	OOTUKUZH-100KVA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	OTTAMUNDA	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Alakkode [6648]	PALLIKUNNU ARCADE	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Alakkode [6648]	PANAMKUTY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	PATHENPARA	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Alakkode [6648]	PAZHERIMAVE	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Alakkode [6648]	PMJ VAYATTUPARAMBA	81.0	9.0	61.0	11.0	13.6	Low
KANNUR	Alakkode [6648]	POTHIVECHATHATTU-63 KVA	51.0	0.0	15.0	36.0	70.6	High
KANNUR	Alakkode [6648]	POYIL	81.0	13.0	31.0	37.0	45.7	Medium
KANNUR	Alakkode [6648]	PRIESTHOME KARUVANCHAL	129.0	0.0	20.0	109.0	84.5	Very High
KANNUR	Alakkode [6648]	PUMP ALAKODE	129.0	0.0	38.0	91.0	70.5	High
KANNUR	Alakkode [6648]	PUTHENPURA ARCADE	202.0	0.0	37.2	164.8	81.6	Very High
KANNUR	Alakkode [6648]	RAFAYELLA	81.0	10.0	42.0	29.0	35.8	Medium
KANNUR	Alakkode [6648]	RAYAROM	129.0	0.0	57.0	72.0	55.8	High
KANNUR	Alakkode [6648]	RELIANCE THIMIRI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	SPORTS CITY KALLODY	202.0	0.0	20.0	182.0	90.1	Very High
KANNUR	Alakkode [6648]	ST MARYES ALAKODE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	SWARAJ KALINK	81.0	5.0	22.0	54.0	66.7	High
KANNUR	Alakkode [6648]	THADIKKADAVU	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Alakkode [6648]	THERMALA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Alakkode [6648]	THIMIRI	81.0	3.0	0.0	78.0	96.3	Very High
KANNUR	Alakkode [6648]	VATTAKKAYAM	81.0	0.0	12.0	69.0	85.2	Very High
KANNUR	Alakkode [6648]	VAYATTUPARAMBA KAVALA	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Alakkode [6648]	VELLADU M-I	129.0	5.0	9.0	115.0	89.1	Very High
KANNUR	Alakkode [6648]	VETERINARY THERTHALLY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Alakkode [6648]	YUVAPURAM	81.0	3.0	0.0	78.0	96.3	Very High
KANNUR	Azheekode [6662]	AC WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	AC WOOD-2 VP-INDUSTRIES	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Azheekode [6662]	AKLIYATH	81.0	24.0	52.0	5.0	6.2	Very Low
KANNUR	Azheekode [6662]	ALAVIL	202.0	0.0	116.3	85.7	42.4	Medium
KANNUR	Azheekode [6662]	ALAVIL AIR TEL TOWER	129.0	0.0	43.4	85.6	66.3	High
KANNUR	Azheekode [6662]	AMIS FOOD MINI INDUSTRY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	ANIVAYAL-2	81.0	0.0	24.0	57.0	70.4	High
KANNUR	Azheekode [6662]	ANJU FABRICATORS	81.0	0.0	31.9	49.1	60.6	High
KANNUR	Azheekode [6662]	ANJUKANDIPARAMBU	81.0	0.0	82.0	0.0	0.0	Very Low
KANNUR	Azheekode [6662]	APARNA	129.0	5.0	121.6	2.4	1.9	Very Low
KANNUR	Azheekode [6662]	ARAMKOTTAM	81.0	6.0	74.6	0.4	0.4	Very Low
KANNUR	Azheekode [6662]	ARAMKOTTAM TOWER	129.0	5.0	35.6	88.4	68.5	High
KANNUR	Azheekode [6662]	ARAYAKANDIPARA-11	81.0	2.0	33.7	45.3	55.9	High
KANNUR	Azheekode [6662]	ARAYAKANDYPPARA-1	81.0	8.3	65.3	7.4	9.1	Very Low
KANNUR	Azheekode [6662]	AYANI VAYAL	81.0	9.0	61.0	11.0	13.6	Low
KANNUR	Azheekode [6662]	AYATHANPARA	81.0	0.0	81.8	0.0	0.0	Very Low
KANNUR	Azheekode [6662]	AYATHANPARA-2	81.0	22.0	39.0	20.0	24.7	Low
KANNUR	Azheekode [6662]	AZHIKKAL BUS STAND	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Azheekode [6662]	AZHIKKAL BUS STAND-2	81.0	3.0	9.0	69.0	85.2	Very High
KANNUR	Azheekode [6662]	BANU BOARDS	81.0	10.0	36.0	35.0	43.2	Medium
KANNUR	Azheekode [6662]	BHARATH PLYWOOD	129.0	0.0	4.0	125.0	96.9	Very High
KANNUR	Azheekode [6662]	BISMILLA	81.0	0.0	42.9	38.1	47.0	Medium
KANNUR	Azheekode [6662]	BOATPALAM	129.0	13.0	81.3	34.7	26.9	Medium
KANNUR	Azheekode [6662]	C P TIMBER	129.0	0.0	16.0	113.0	87.6	Very High
KANNUR	Azheekode [6662]	CEEYAN PLY WOODUNIVARSAL	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Azheekode [6662]	CEEYAN SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Azheekode [6662]	CERA BOARD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	CHAKIRI	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Azheekode [6662]	CHAKKARAPPARA	129.0	7.0	121.5	0.5	0.4	Very Low
KANNUR	Azheekode [6662]	CHAKKIPEDIKA	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Azheekode [6662]	CHAL BEACH	81.0	3.0	31.0	47.0	58.0	High
KANNUR	Azheekode [6662]	CHEMMERASSERIPPARA	129.0	0.0	127.8	1.2	0.9	Very Low
KANNUR	Azheekode [6662]	CHURCH	81.0	3.3	55.0	22.7	28.0	Medium
KANNUR	Azheekode [6662]	CROWN BOARD ESENC	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	ELAMKARU TEMPLE ROAD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	ESI	81.0	0.0	34.0	47.0	58.0	High
KANNUR	Azheekode [6662]	FORSAMSODA	81.0	0.0	80.9	0.1	0.1	Very Low
KANNUR	Azheekode [6662]	GOPALAM PEEDIKA KACHERIPARA-II	81.0	6.0	75.0	0.0	0.0	Very Low
KANNUR	Azheekode [6662]	GRAMEENAVAYANASALA	81.0	0.0	36.7	44.3	54.6	High
KANNUR	Azheekode [6662]	GRANITE	129.0	0.0	27.3	101.7	78.8	Very High
KANNUR	Azheekode [6662]	GREENS ALLIANZE	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Azheekode [6662]	HASHMI LIBRARY	81.0	10.0	28.0	43.0	53.1	High
KANNUR	Azheekode [6662]	HEALTH CENTRE	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Azheekode [6662]	HEALTH CENTRE-2	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	HERO BOADS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	HILL TOP	81.0	0.0	81.0	0.0	0.0	Very Low
KANNUR	Azheekode [6662]	HINDUSTHAN	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	HORISON BOARD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	IOCL VANKULATHVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	JAMAYATH SCHOOL	81.0	3.0	27.0	51.0	63.0	High
KANNUR	Azheekode [6662]	JANAKEYYAM ROAD	81.0	13.0	20.3	47.7	58.9	High
KANNUR	Azheekode [6662]	JANATHA WOOD	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Azheekode [6662]	KACHERIPPARA	81.0	0.0	61.0	20.0	24.6	Low
KANNUR	Azheekode [6662]	KAKKAMPALAM AIRTEL	81.0	3.0	9.0	69.0	85.2	Very High
KANNUR	Azheekode [6662]	KALLADATHODE	129.0	0.0	50.9	78.1	60.5	High
KANNUR	Azheekode [6662]	KALLADATHODE NAGAR	81.0	5.0	62.0	14.0	17.3	Low
KANNUR	Azheekode [6662]	KANISSAN MIKKU	81.0	13.0	56.0	12.0	14.8	Low
KANNUR	Azheekode [6662]	KAPPAKADAVU	202.0	0.0	13.0	189.0	93.6	Very High
KANNUR	Azheekode [6662]	KAPPIKUNDU	81.0	5.0	25.0	51.0	63.0	High
KANNUR	Azheekode [6662]	KOTTARATHUMPARA	129.0	13.0	50.2	65.8	51.0	High
KANNUR	Azheekode [6662]	KSK	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	KUNHIKANNAN	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Azheekode [6662]	KUNNAVU	129.0	0.0	100.3	28.7	22.2	Low
KANNUR	Azheekode [6662]	KUNNAVU SCHOOL	81.0	0.0	22.0	59.0	72.8	High
KANNUR	Azheekode [6662]	LAND MARK ALAVIL	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Azheekode [6662]	MALABAR SAWMILL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	MARINE ICE PLANT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	MARINE-ICE PLANT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	MARVA TOWER VANKULATH VAYAL-11	81.0	0.0	26.0	55.0	67.9	High
KANNUR	Azheekode [6662]	MASCOT	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Azheekode [6662]	ME WOOD-1	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	ME WOOD-11	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	MEENKUNNU SCHOOL	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Azheekode [6662]	MEENKUNNU-I	129.0	5.0	54.0	70.0	54.3	High
KANNUR	Azheekode [6662]	MEENKUNNU-II	81.0	0.0	28.0	53.0	65.4	High
KANNUR	Azheekode [6662]	MIN-INDUSTRIAL ESTATE-I	202.0	0.0	3.0	199.0	98.5	Very High
KANNUR	Azheekode [6662]	MINI INDUSTRIAL ESTATE-2 DTR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	MINI INDUSTRY-3 DTR	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Azheekode [6662]	MINI-INDUSTRIAL ESTATE-2	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	MINI-INDUSTRY-3	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	MOHINI ROAD	81.0	0.0	31.0	50.0	61.7	High
KANNUR	Azheekode [6662]	MOLOLAM TEMPLE	81.0	5.0	66.0	10.0	12.3	Low
KANNUR	Azheekode [6662]	MOONNU MUKKU	81.0	11.0	8.0	62.0	76.5	Very High
KANNUR	Azheekode [6662]	MOONNUNIRATH-2 DESA BANDHU	81.0	11.0	66.9	3.1	3.8	Very Low
KANNUR	Azheekode [6662]	MOONNUNIRATHU-1	81.0	0.0	19.6	61.4	75.8	Very High
KANNUR	Azheekode [6662]	MYLADATHADAM	129.0	0.0	87.8	41.2	31.9	Medium
KANNUR	Azheekode [6662]	NALU MUKKU	129.0	0.0	60.0	69.0	53.5	High
KANNUR	Azheekode [6662]	NANMA	81.0	0.0	19.0	62.0	76.5	Very High
KANNUR	Azheekode [6662]	NATIONAL PLYWOODS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	NEERKADAVU-1	81.0	0.0	17.3	63.7	78.6	Very High
KANNUR	Azheekode [6662]	NEERKKADAVU-II ARAYA SAMAJAM	81.0	3.0	19.0	59.0	72.8	High
KANNUR	Azheekode [6662]	NOBLE PLY	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Azheekode [6662]	NUCHITHODE	81.0	3.0	30.0	48.0	59.3	High
KANNUR	Azheekode [6662]	NUCHITHODU-2	81.0	0.0	18.0	63.0	77.8	Very High
KANNUR	Azheekode [6662]	NUCHIVAYAL	129.0	17.0	111.6	0.4	0.3	Very Low
KANNUR	Azheekode [6662]	NUTRIMIX-100KVA	81.0	10.0	71.0	0.0	0.0	Very Low
KANNUR	Azheekode [6662]	OLADATHAZHA	81.0	0.0	29.3	51.7	63.8	High
KANNUR	Azheekode [6662]	ONDEN ROAD TOWER	81.0	3.0	16.0	62.0	76.5	Very High
KANNUR	Azheekode [6662]	ONDERN ROAD	81.0	0.0	22.0	59.0	72.8	High
KANNUR	Azheekode [6662]	OTTATHENGU	129.0	8.0	35.0	86.0	66.7	High
KANNUR	Azheekode [6662]	P V WOOD MOONUMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	PALLIKUNNUMBRAM-2	81.0	0.0	26.0	55.0	67.9	High
KANNUR	Azheekode [6662]	PALLIKUNNUMBURAM VAYANASALA	81.0	0.0	18.8	62.2	76.8	Very High
KANNUR	Azheekode [6662]	PALOTTU VAYAL	81.0	10.0	12.5	58.5	72.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Azheekode [6662]	PALOTTUKAVU THERU	129.0	3.0	53.0	73.0	56.6	High
KANNUR	Azheekode [6662]	PAMBADIYAL	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Azheekode [6662]	PANDARATHUMKANDI	81.0	6.0	54.3	20.7	25.6	Medium
KANNUR	Azheekode [6662]	PANNERIMUKKU-1	81.0	24.0	51.3	5.7	7.1	Very Low
KANNUR	Azheekode [6662]	PANNERIMUKKU-PASACOMPANY	129.0	23.0	70.0	36.0	27.9	Medium
KANNUR	Azheekode [6662]	PANNIYIDUKKU	81.0	0.0	34.3	46.7	57.6	High
KANNUR	Azheekode [6662]	PCK BOARD-1	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	PCK BOARD-111	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	PCK BOARD-II	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	PERFECT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	PERIYAKOVIL	129.0	12.0	3.0	114.0	88.4	Very High
KANNUR	Azheekode [6662]	PLY ASIA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	POITHUM KADAV	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	POOTHAPARA-2	81.0	0.0	57.4	23.6	29.1	Medium
KANNUR	Azheekode [6662]	POOTHAPPARA	129.0	0.0	128.9	0.1	0.0	Very Low
KANNUR	Azheekode [6662]	PORT QUARTERS	129.0	5.0	21.3	102.7	79.6	Very High
KANNUR	Azheekode [6662]	PRESTIGE	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Azheekode [6662]	PRIME	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Azheekode [6662]	PUNNAKKAPARA-1	129.0	13.0	85.5	30.5	23.6	Low
KANNUR	Azheekode [6662]	PUNNAKKAPARA-2	129.0	24.3	90.5	14.2	11.0	Low
KANNUR	Azheekode [6662]	PUTHIYAPARAMBA	81.0	20.0	30.3	30.7	37.9	Medium
KANNUR	Azheekode [6662]	PVN	81.0	0.0	52.0	29.0	35.8	Medium
KANNUR	Azheekode [6662]	QMAX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	RAILWAY CUTTING	81.0	0.0	50.4	30.6	37.7	Medium
KANNUR	Azheekode [6662]	RAJESWARY	81.0	0.0	62.4	18.6	23.0	Low
KANNUR	Azheekode [6662]	REST WELL INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	ROXY ICE PLANT	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Azheekode [6662]	ROXY-ICE PLANT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	RUBBER ROAD	129.0	10.0	95.5	23.5	18.2	Low
KANNUR	Azheekode [6662]	SAFE PAKERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	SAGER WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	SAI MANDIR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	SALIS ICE PRODUCT	81.0	5.0	0.0	76.0	93.8	Very High
KANNUR	Azheekode [6662]	SALIS-ICE PRODUCT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	SANTHWANAM DIALYSIS CENTRE	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Azheekode [6662]	SBT ALAVIL	81.0	0.0	27.0	54.0	66.7	High
KANNUR	Azheekode [6662]	SCHOOL PARA	81.0	12.0	35.0	34.0	42.0	Medium
KANNUR	Azheekode [6662]	SHILPA ICE PLANT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	SILK	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Azheekode [6662]	SINCERE WOOD	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Azheekode [6662]	SREENARAYANA VAYANASALA	81.0	15.0	51.7	14.3	17.7	Low
KANNUR	Azheekode [6662]	ST JAMES SCHOOL	81.0	3.0	65.0	13.0	16.0	Low
KANNUR	Azheekode [6662]	SUNLIGHT	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Azheekode [6662]	SUPREME PIPE	81.0	0.0	13.0	68.0	84.0	Very High
KANNUR	Azheekode [6662]	THEKKAMMARAKANDY	129.0	12.6	79.4	37.0	28.7	Medium
KANNUR	Azheekode [6662]	THERU	81.0	0.0	42.5	38.5	47.6	Medium
KANNUR	Azheekode [6662]	THITTAS NO-1	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	THITTAS NO-2	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	THITTAS NO-3	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	TIGERMUKK	81.0	0.0	84.0	0.0	0.0	Very Low
KANNUR	Azheekode [6662]	TREND WOOD UNIVERSAL PLY WOOD	81.0	15.0	56.0	10.0	12.3	Low
KANNUR	Azheekode [6662]	UPPAI CHAAL	81.0	8.0	33.7	39.3	48.5	Medium
KANNUR	Azheekode [6662]	VAIPARAMBA	81.0	3.0	39.0	39.0	48.1	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Azheekode [6662]	VAIPARAMBA-2	81.0	0.0	21.8	59.2	73.1	High
KANNUR	Azheekode [6662]	VALIAPARAMBA	81.0	5.0	31.0	45.0	55.6	High
KANNUR	Azheekode [6662]	VALSANKADA	81.0	0.0	31.0	50.0	61.7	High
KANNUR	Azheekode [6662]	VANKULATHUVAYAL	202.0	0.0	113.9	88.1	43.6	Medium
KANNUR	Azheekode [6662]	VASULAL	129.0	5.0	76.9	47.1	36.5	Medium
KANNUR	Azheekode [6662]	VELLAKKAL	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Azheekode [6662]	VELLAKKAL NAGAR	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Azheekode [6662]	VELLUPARA	81.0	3.0	54.5	23.5	29.0	Medium
KANNUR	Azheekode [6662]	WESTERN BOARDS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	WESTERN SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Azheekode [6662]	WOOD VEENERS	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasseri [6655]	33KV SUBSTATION AUXILERY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	ABHILASH HOTEL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	ABHILASH STATION ROAD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	ADARSH ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	AIRTEL MANAL	81.0	0.0	29.5	51.5	63.6	High
KANNUR	Burnasseri [6655]	AKRAM PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	ALCHEMY BURNASSERY	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Burnasseri [6655]	ALFA ONE AQUA MARINE APARTMENT	405.0	0.0	0.0	405.0	100.0	Very High
KANNUR	Burnasseri [6655]	ALLEN SOLLY	129.0	0.0	5.0	124.0	96.1	Very High
KANNUR	Burnasseri [6655]	AMNA PARK	510.0	0.0	0.0	510.0	100.0	Very High
KANNUR	Burnasseri [6655]	ARAMKOTTAM ROAD	81.0	0.0	26.3	54.7	67.5	High
KANNUR	Burnasseri [6655]	ARAT	202.0	26.0	79.5	96.5	47.8	Medium
KANNUR	Burnasseri [6655]	ARTILARY ROAD	81.0	0.0	41.5	39.5	48.8	Medium
KANNUR	Burnasseri [6655]	ASSET HOMES APARTMENTS	510.0	0.0	0.0	510.0	100.0	Very High
KANNUR	Burnasseri [6655]	ASWATHI APARTMENTS	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Burnasseri [6655]	BALARAM MANDIR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	BALIKA SADANAM	129.0	0.0	39.0	90.0	69.8	High
KANNUR	Burnasseri [6655]	BANK ROAD PALLITHARA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	BEACH RESIDENCY	81.0	0.0	40.0	41.0	50.6	High
KANNUR	Burnasseri [6655]	BELLARD ROAD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	BILAL TOWER	81.0	0.0	7.0	74.0	91.4	Very High
KANNUR	Burnasseri [6655]	BPCL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	BRB	81.0	0.0	36.0	45.0	55.6	High
KANNUR	Burnasseri [6655]	BRIGADE CENTRE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	BURNASSERY	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Burnasseri [6655]	CANDALE APARTMENTS	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Burnasseri [6655]	CASTA TOWER	162.0	0.0	0.0	162.0	100.0	Very High
KANNUR	Burnasseri [6655]	CEE KEY GOLD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasseri [6655]	CENTRAL EXCISE	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasseri [6655]	CENTRAL MARKET	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasseri [6655]	CHAKKATTIL PEEDIKA	129.0	8.0	72.1	48.9	37.9	Medium
KANNUR	Burnasseri [6655]	CHALAD AMBALA MAIDANAM	81.0	3.0	72.0	6.0	7.4	Very Low
KANNUR	Burnasseri [6655]	CHALAD AMBALAM	202.0	13.0	94.7	94.3	46.7	Medium
KANNUR	Burnasseri [6655]	CHALAD PALLI	129.0	15.0	72.5	41.5	32.2	Medium
KANNUR	Burnasseri [6655]	CHALILKAVU	81.0	0.0	13.0	68.0	83.9	Very High
KANNUR	Burnasseri [6655]	CHANDROTH COMPLEX	81.0	0.0	7.0	74.0	91.4	Very High
KANNUR	Burnasseri [6655]	CHERUMANAL	81.0	3.0	22.0	56.0	69.1	High
KANNUR	Burnasseri [6655]	CHETTIAR KAVU	129.0	8.0	35.9	85.1	66.0	High
KANNUR	Burnasseri [6655]	CHETTIYAR KULAM	81.0	0.0	28.0	53.0	65.4	High
KANNUR	Burnasseri [6655]	CHILLIKKUNNU	81.0	15.0	34.0	32.0	39.5	Medium
KANNUR	Burnasseri [6655]	CITADEL	810.0	35.0	0.0	775.0	95.7	Very High
KANNUR	Burnasseri [6655]	CITY CENTRE-1	405.0	0.0	0.0	405.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Burnasser [6655]	CITY CENTRE-2	162.0	0.0	0.0	162.0	100.0	Very High
KANNUR	Burnasser [6655]	CLIFF DALE	81.0	0.0	14.0	67.0	82.7	Very High
KANNUR	Burnasser [6655]	COFFE HOUSE	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	CONTONMENT	81.0	0.0	34.0	47.0	58.0	High
KANNUR	Burnasser [6655]	CREMETORIUM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	DECOREM	202.0	0.0	10.0	192.0	95.0	Very High
KANNUR	Burnasser [6655]	DHANWANDHARI	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	DINESH	81.0	17.9	48.8	14.3	17.7	Low
KANNUR	Burnasser [6655]	DZYN	81.0	20.0	10.0	51.0	63.0	High
KANNUR	Burnasser [6655]	EMAD TOWER 1	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	EMAD TOWER 2	162.0	0.0	0.0	162.0	100.0	Very High
KANNUR	Burnasser [6655]	ERINHATTUVAYAL	81.0	3.0	78.0	0.0	0.0	Very Low
KANNUR	Burnasser [6655]	EVCS PADANNAPALAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	EXCELLENCY APARTMENTS	255.0	0.0	0.0	255.0	100.0	Very High
KANNUR	Burnasser [6655]	FINTECH	162.0	0.0	0.0	162.0	100.0	Very High
KANNUR	Burnasser [6655]	FORT LIGHT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	FORT ROAD	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Burnasser [6655]	GIRLS SCHOOL	81.0	0.0	80.9	0.1	0.1	Very Low
KANNUR	Burnasser [6655]	GLOBAL VILLAGE	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Burnasser [6655]	GLOBAL VILLAGE -2	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	GOLDEN HOUSE	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	GRAND MARKET	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	GRAND PLAZA-1	405.0	0.0	0.0	405.0	100.0	Very High
KANNUR	Burnasser [6655]	GRAND PLAZA-2	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Burnasser [6655]	GREENPARK	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	GUEST HOUSE	202.0	0.0	3.3	198.7	98.4	Very High
KANNUR	Burnasser [6655]	HAJI COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Burnasserì [6655]	HARI TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasserì [6655]	IBF	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasserì [6655]	ILLIKKA PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasserì [6655]	ILLIKKA PLAZA USS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasserì [6655]	IRIVERIKOVIL	81.0	0.0	64.9	16.1	19.9	Low
KANNUR	Burnasserì [6655]	JAWAN MUKKU	81.0	5.0	53.0	23.0	28.4	Medium
KANNUR	Burnasserì [6655]	JAYANTHI ROAD	81.0	0.0	60.4	20.6	25.5	Medium
KANNUR	Burnasserì [6655]	K V PALAM	81.0	0.0	19.0	62.0	76.5	Very High
KANNUR	Burnasserì [6655]	KAIIROS	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Burnasserì [6655]	KALLIKKODAN	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasserì [6655]	KALLYANI COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasserì [6655]	KANCHI SILKS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasserì [6655]	KANIYIL PALAM	81.0	3.0	65.7	12.3	15.2	Low
KANNUR	Burnasserì [6655]	KANNUR CENTRAL MALL	510.0	0.0	0.0	510.0	100.0	Very High
KANNUR	Burnasserì [6655]	KANNUR HEIGHTS 1	255.0	0.0	30.0	225.0	88.2	Very High
KANNUR	Burnasserì [6655]	KANNUR HEIGHTS 2	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasserì [6655]	KARTHIKA	81.0	0.0	48.0	33.0	40.7	Medium
KANNUR	Burnasserì [6655]	KAVITHA	81.0	0.0	28.0	53.0	65.4	High
KANNUR	Burnasserì [6655]	KINGS DENTAL CLINIC	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasserì [6655]	KOMALAM	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Burnasserì [6655]	KORAL COMPLEX	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Burnasserì [6655]	KORJAN HEIGHTS APARTMENTS	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasserì [6655]	KOTTAKKANPEEDIKA	129.0	23.0	104.2	1.8	1.4	Very Low
KANNUR	Burnasserì [6655]	KP PLAZA	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasserì [6655]	KPK	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasserì [6655]	KSEB IB	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Burnasserì [6655]	KUMAR TOWER	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Burnasser [6655]	KUNNATHUKAVU	81.0	5.0	73.0	3.0	3.7	Very Low
KANNUR	Burnasser [6655]	KUZHUKUNNU	129.0	0.0	59.4	69.6	54.0	High
KANNUR	Burnasser [6655]	KVM PLAZA	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	KWA	81.0	0.0	11.7	69.3	85.5	Very High
KANNUR	Burnasser [6655]	LABBA STREET	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	LEXUS OYSTER	162.0	0.0	6.0	156.0	96.3	Very High
KANNUR	Burnasser [6655]	LV AHAMMED HAJI	81.0	5.0	24.9	51.1	63.1	High
KANNUR	Burnasser [6655]	MADATHIL COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	MAHARANI	129.0	0.0	25.0	104.0	80.6	Very High
KANNUR	Burnasser [6655]	MALABAR RESIDENCY LT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	MALLER - PG KAMMATHU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	MAMANGAM HOTEL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	MANAL	129.0	3.0	43.2	82.8	64.2	High
KANNUR	Burnasser [6655]	MANAL MUTHAPPAN KAVU	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Burnasser [6655]	MANGO	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	MANJAPPALAM	81.0	11.0	10.4	59.6	73.5	High
KANNUR	Burnasser [6655]	MARKET	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	MASCOT BEACH RESORT	129.0	0.0	15.0	114.0	88.4	Very High
KANNUR	Burnasser [6655]	MASCOT SQUARE	202.0	0.0	40.0	162.0	80.2	Very High
KANNUR	Burnasser [6655]	MATHAMILL	81.0	5.0	38.3	37.7	46.5	Medium
KANNUR	Burnasser [6655]	MAX NURSERY	81.0	5.0	43.3	32.7	40.4	Medium
KANNUR	Burnasser [6655]	MERMAID	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Burnasser [6655]	METRENDS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	MILITARY HOSPITAL	81.0	0.0	43.0	38.0	46.9	Medium
KANNUR	Burnasser [6655]	MM RESIDENCE	81.0	0.0	35.0	46.0	56.8	High
KANNUR	Burnasser [6655]	MM SQUARE LT	162.0	0.0	0.0	162.0	100.0	Very High
KANNUR	Burnasser [6655]	MOONNAMPEEDIKA	129.0	0.0	33.5	95.5	74.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Burnasseri [6655]	MTM SCHOOL	129.0	0.0	30.9	98.1	76.0	Very High
KANNUR	Burnasseri [6655]	MULLAMKANDY	202.0	18.0	95.3	88.7	43.9	Medium
KANNUR	Burnasseri [6655]	MULLAMKANDY PALAM	129.0	5.0	28.0	96.0	74.4	High
KANNUR	Burnasseri [6655]	MUNEESWARAN KOVIL	81.0	25.0	15.0	41.0	50.6	High
KANNUR	Burnasseri [6655]	MVR	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Burnasseri [6655]	NALAM VEEDU	81.0	8.0	40.4	32.6	40.3	Medium
KANNUR	Burnasseri [6655]	NETHRA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	OASIS	81.0	3.0	15.2	62.8	77.5	Very High
KANNUR	Burnasseri [6655]	OTTATHENGU	81.0	0.0	27.0	54.0	66.7	High
KANNUR	Burnasseri [6655]	PALLIYAMOOLA	81.0	18.0	19.0	44.0	54.3	High
KANNUR	Burnasseri [6655]	PALMGROVE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	PAMBANKANDY	129.0	8.0	116.2	4.8	3.8	Very Low
KANNUR	Burnasseri [6655]	PAPPAS COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasseri [6655]	PARAKKANDY	202.0	3.0	90.5	108.5	53.7	High
KANNUR	Burnasseri [6655]	PARK AVENUE APARTMENTS	405.0	0.0	7.0	398.0	98.3	Very High
KANNUR	Burnasseri [6655]	PARK TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasseri [6655]	PAWAN PLAZA	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Burnasseri [6655]	PAYYAMBALAM	81.0	0.0	53.2	27.8	34.3	Medium
KANNUR	Burnasseri [6655]	PAYYAMBALAM PARK	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Burnasseri [6655]	PILLAYAR KOVIL	202.0	0.0	52.0	150.0	74.3	High
KANNUR	Burnasseri [6655]	PK COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	PLATINUM CENTRE	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasseri [6655]	PLAZA	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasseri [6655]	PMR COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	POPULAR STORE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasseri [6655]	POTHERY SCHOOL	81.0	23.0	37.5	20.5	25.3	Medium
KANNUR	Burnasseri [6655]	PPS TOWER	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Burnasser [6655]	PRABATH RESIDENCY	255.0	0.0	0.0	255.0	100.0	Very High
KANNUR	Burnasser [6655]	PRABHATH	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Burnasser [6655]	PRABHATH ANEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	PUBLIC LIBRARY	129.0	0.0	20.0	109.0	84.5	Very High
KANNUR	Burnasser [6655]	RABI TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	RAHNAS TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	RAILWAY COMMERCIAL COMPLEX-MFC	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	RAILWAY RCD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	RAINBOW SEA BLUES APARTMENTS	405.0	0.0	40.0	365.0	90.1	Very High
KANNUR	Burnasser [6655]	RAINBOW SEA SHELLS APARTMENTS	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Burnasser [6655]	RAINBOW SEA WIND APARTMENTS	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	RAINSCAPE VILLA	129.0	0.0	8.0	121.0	93.8	Very High
KANNUR	Burnasser [6655]	RAMAN CENTRE	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	RAYMONDS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	RED BUILDING	129.0	5.0	36.0	88.0	68.2	High
KANNUR	Burnasser [6655]	REDCROSS ROAD	129.0	3.0	41.5	84.5	65.5	High
KANNUR	Burnasser [6655]	RENITH	81.0	0.0	34.0	47.0	58.0	High
KANNUR	Burnasser [6655]	RIMS SCHOOL	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Burnasser [6655]	RIYAZ HOME	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	ROYAL HEAVEN APARTMENTS	255.0	0.0	0.0	255.0	100.0	Very High
KANNUR	Burnasser [6655]	ROYAL HEIGHTS APARTMENTS	162.0	0.0	0.0	162.0	100.0	Very High
KANNUR	Burnasser [6655]	SABARI	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Burnasser [6655]	SAFIRE	202.0	0.0	25.0	177.0	87.6	Very High
KANNUR	Burnasser [6655]	SAHAKARANA ROAD	81.0	3.0	25.3	52.7	65.1	High
KANNUR	Burnasser [6655]	SAMCO	129.0	0.0	61.2	67.8	52.5	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Burnasser [6655]	SAMEER ARCADE	129.0	0.0	15.0	114.0	88.4	Very High
KANNUR	Burnasser [6655]	SAMVEDYA	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Burnasser [6655]	SANGEETHA	81.0	0.0	28.0	53.0	65.4	High
KANNUR	Burnasser [6655]	SARGAM ROAD	81.0	0.0	12.3	68.7	84.8	Very High
KANNUR	Burnasser [6655]	SEA SCAPE APARTMENTS	255.0	0.0	0.0	255.0	100.0	Very High
KANNUR	Burnasser [6655]	SEVOY	202.0	0.0	19.8	182.2	90.2	Very High
KANNUR	Burnasser [6655]	SHENOY CENTRE	324.0	0.0	15.0	309.0	95.4	Very High
KANNUR	Burnasser [6655]	SHIVOHAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	SIVASAKTHI	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Burnasser [6655]	SKYLINE APARTMENTS	510.0	0.0	0.0	510.0	100.0	Very High
KANNUR	Burnasser [6655]	SN PARK	129.0	0.0	12.9	116.0	90.0	Very High
KANNUR	Burnasser [6655]	SOUBHAGYA SAREES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	SPRING FIELD APARTMENTS	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	SREEROSH BAY HEIGHTS APARTMENT	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Burnasser [6655]	SREEROSH EMERALD APARTMENT	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	SREEROSH MIDTOWN APARTMENTS	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Burnasser [6655]	ST ANTONYS CHURCH ONDEN ROAD	81.0	16.0	44.4	20.6	25.4	Medium
KANNUR	Burnasser [6655]	ST MICHAELS	81.0	0.0	77.4	3.6	4.4	Very Low
KANNUR	Burnasser [6655]	ST THERESAS	81.0	0.0	24.0	57.0	70.4	High
KANNUR	Burnasser [6655]	STATE BANK	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Burnasser [6655]	STP PADANNAPPALAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	SUHARA ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	SUMMER FIELD APARTMENTS	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	SUNSHINE APARTMENTS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	SUPER BAZAR	202.0	0.0	0.0	202.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Burnasser [6655]	SWASTHIKA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Burnasser [6655]	SYNDICATE	202.0	0.0	45.7	156.3	77.4	Very High
KANNUR	Burnasser [6655]	SYNDICATE BANK	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Burnasser [6655]	TAPALPETTY	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Burnasser [6655]	TAXI STAND	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	THALIKKAVU	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Burnasser [6655]	THALIKKAVU TEMPLE	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Burnasser [6655]	THALIMUKKU	81.0	0.0	47.7	33.3	41.1	Medium
KANNUR	Burnasser [6655]	THAVAKARA BUS STAND	810.0	0.0	145.0	665.0	82.1	Very High
KANNUR	Burnasser [6655]	THAVAKKARA IOC	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	THEKKAN MANAL	81.0	6.0	8.0	67.0	82.7	Very High
KANNUR	Burnasser [6655]	THILLERY	81.0	0.0	81.0	0.0	0.0	Very Low
KANNUR	Burnasser [6655]	TK VEGETABLES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	TOP LAND	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	UDUMBANTHALA OCEAN PARK	510.0	0.0	0.0	510.0	100.0	Very High
KANNUR	Burnasser [6655]	UNITY COMPLEX	202.0	5.0	24.7	172.3	85.3	Very High
KANNUR	Burnasser [6655]	V K COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Burnasser [6655]	VATTAKKANDY	81.0	0.0	18.0	63.0	77.8	Very High
KANNUR	Burnasser [6655]	VIDHI-1	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	VIDHI-2	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	VYAPARI BHAVAN	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Burnasser [6655]	VYDOORYA	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Burnasser [6655]	WATER TANK	129.0	0.0	91.7	37.3	28.9	Medium
KANNUR	Burnasser [6655]	WESTERN MANNER APARTMENTS	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Burnasser [6655]	WOODLANDS	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Burnasser [6655]	ZORAH SILKS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	AFSC BANK COMPLEX	255.0	0.0	10.0	245.0	96.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chakkarakallu [6660]	AFSC CHAKIRI NIRMANA UNIT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	ALEENA STEEL	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chakkarakallu [6660]	AMBANADU	81.0	3.0	39.0	39.0	48.1	Medium
KANNUR	Chakkarakallu [6660]	ANJARAKANDY BUS STAND	81.0	15.0	64.5	1.6	1.9	Very Low
KANNUR	Chakkarakallu [6660]	ANJARAKKANDY TAVAKKAL COMPLEX	129.0	3.0	27.0	99.0	76.7	Very High
KANNUR	Chakkarakallu [6660]	ANJRAKKANDY CANAL JINNUMMA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	APPAKADAVU	129.0	34.0	94.7	0.3	0.2	Very Low
KANNUR	Chakkarakallu [6660]	ARAYAL KEEZHU	81.0	3.0	8.0	70.0	86.4	Very High
KANNUR	Chakkarakallu [6660]	BAVODE	129.0	3.0	26.0	100.0	77.5	Very High
KANNUR	Chakkarakallu [6660]	BUNGLOWMETTA	81.0	19.0	59.4	2.6	3.3	Very Low
KANNUR	Chakkarakallu [6660]	BUS STAND CHAKKARAKAL	129.0	0.0	45.0	84.0	65.1	High
KANNUR	Chakkarakallu [6660]	CANNANOREHANDLOOM	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Chakkarakallu [6660]	CHAKKARAKAL	202.0	3.0	46.0	153.0	75.7	Very High
KANNUR	Chakkarakallu [6660]	CHAKKARAKKAL TOWN	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	CHALIL TEMPLE	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chakkarakallu [6660]	CHAMAKKALI	81.0	3.0	23.0	55.0	67.9	High
KANNUR	Chakkarakallu [6660]	CHATHOTHKULAM	81.0	15.0	46.0	20.0	24.7	Low
KANNUR	Chakkarakallu [6660]	CHEMBILODE	81.0	3.0	47.5	30.5	37.6	Medium
KANNUR	Chakkarakallu [6660]	CHERIYAVALLAPPU	81.0	8.0	72.3	0.7	0.9	Very Low
KANNUR	Chakkarakallu [6660]	CHERUKUNHI	81.0	16.0	26.0	39.0	48.1	Medium
KANNUR	Chakkarakallu [6660]	CHIRAMMALPEEDIKA	81.0	0.0	34.3	46.7	57.7	High
KANNUR	Chakkarakallu [6660]	CHOOOLA	129.0	7.0	57.7	64.3	49.8	Medium
KANNUR	Chakkarakallu [6660]	CHOOOLA MUTHAPPAN	81.0	30.0	45.0	6.0	7.4	Very Low
KANNUR	Chakkarakallu [6660]	CITY CENTRE CHAKKARAKKAL	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	CLINIC	129.0	0.0	54.0	75.0	58.1	High
KANNUR	Chakkarakallu [6660]	COMMUNITY HALL	81.0	3.0	63.0	15.0	18.5	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chakkarakallu [6660]	CROWN	129.0	0.0	42.0	87.0	67.4	High
KANNUR	Chakkarakallu [6660]	CUT AND COVER	51.0	10.0	10.0	31.0	60.8	High
KANNUR	Chakkarakallu [6660]	EKKALMOTTA	129.0	13.5	115.3	0.2	0.1	Very Low
KANNUR	Chakkarakallu [6660]	GOEC	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	GOKULAM KALYANANA MANDAPAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	IRIVERY CANAL	81.0	0.0	39.0	42.0	51.9	High
KANNUR	Chakkarakallu [6660]	JINNUMMA	81.0	9.0	72.0	0.0	0.0	Very Low
KANNUR	Chakkarakallu [6660]	K K LEISURE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	KAKKOTH STADIUM	81.0	6.3	26.3	48.4	59.8	High
KANNUR	Chakkarakallu [6660]	KALLAYI	81.0	26.0	54.6	0.4	0.5	Very Low
KANNUR	Chakkarakallu [6660]	KALLAYI HAJIMUKKU	129.0	25.0	81.4	22.6	17.5	Low
KANNUR	Chakkarakallu [6660]	KALLAYI TEMPLE	81.0	15.0	26.0	40.0	49.4	Medium
KANNUR	Chakkarakallu [6660]	KANAD	81.0	0.0	13.6	67.4	83.2	Very High
KANNUR	Chakkarakallu [6660]	KANCHIRODEETHERU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	KANNADIVELICHAM	81.0	0.0	33.3	47.7	58.9	High
KANNUR	Chakkarakallu [6660]	KARA KALLERIKKARA	81.0	3.0	8.0	70.0	86.4	Very High
KANNUR	Chakkarakallu [6660]	KARAPERAVOOR	129.0	8.0	27.0	94.0	72.9	High
KANNUR	Chakkarakallu [6660]	KATTAPEETIKA	81.0	6.0	8.0	67.0	82.7	Very High
KANNUR	Chakkarakallu [6660]	KAVINMOOLA	202.0	6.0	145.4	50.6	25.0	Medium
KANNUR	Chakkarakallu [6660]	KAVINMOOLA HIGH SCHOOL	81.0	0.0	77.5	3.5	4.3	Very Low
KANNUR	Chakkarakallu [6660]	KEERIYOD PALLI	51.0	0.0	50.0	1.0	2.0	Very Low
KANNUR	Chakkarakallu [6660]	KEEZHALLUR	81.0	0.0	33.3	47.7	58.9	High
KANNUR	Chakkarakallu [6660]	KEEZHALLUR PALLI	81.0	18.0	13.0	50.0	61.7	High
KANNUR	Chakkarakallu [6660]	KOMATHKUNNAMBRAM	129.0	9.0	118.2	1.8	1.4	Very Low
KANNUR	Chakkarakallu [6660]	KOORAPEEDIKA	81.0	10.0	54.3	16.7	20.6	Low
KANNUR	Chakkarakallu [6660]	KOVIL	81.0	5.0	50.0	26.0	32.1	Medium
KANNUR	Chakkarakallu [6660]	KULAM	81.0	0.0	79.0	2.0	2.5	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chakkarakallu [6660]	KULATHVAYAL	81.0	13.0	65.0	3.0	3.7	Very Low
KANNUR	Chakkarakallu [6660]	KUNNATHCHAL	81.0	3.0	40.3	37.7	46.5	Medium
KANNUR	Chakkarakallu [6660]	KURUKKANMETTA	81.0	0.0	65.2	15.8	19.5	Low
KANNUR	Chakkarakallu [6660]	KUTTIKKACHAL	81.0	11.0	70.0	0.0	0.0	Very Low
KANNUR	Chakkarakallu [6660]	KUTTIVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	KUZHIMBALODE CANAL	81.0	0.0	53.0	28.0	34.6	Medium
KANNUR	Chakkarakallu [6660]	KUZHIMBALODE RATION SHOP	81.0	0.0	41.0	40.0	49.4	Medium
KANNUR	Chakkarakallu [6660]	KUZHIMBALODEMOTTA	81.0	0.0	22.5	58.5	72.2	High
KANNUR	Chakkarakallu [6660]	KV ROAD	81.0	0.0	55.0	26.0	32.1	Medium
KANNUR	Chakkarakallu [6660]	MACHERY	81.0	12.3	45.8	22.9	28.3	Medium
KANNUR	Chakkarakallu [6660]	MALABAR CEMENT	81.0	18.0	25.0	38.0	46.9	Medium
KANNUR	Chakkarakallu [6660]	MALLIKKANDICHIRA	81.0	5.0	14.4	61.6	76.0	Very High
KANNUR	Chakkarakallu [6660]	MAVELI	81.0	0.0	22.0	59.0	72.8	High
KANNUR	Chakkarakallu [6660]	MCF CHEMBILODE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	MELE MACHERY	81.0	0.0	40.0	41.0	50.6	High
KANNUR	Chakkarakallu [6660]	MELE PANERICHAL	81.0	16.0	57.0	8.0	9.9	Very Low
KANNUR	Chakkarakallu [6660]	MONTECARLO	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	MOWANCHERY SCHOOL	81.0	11.0	67.8	2.2	2.7	Very Low
KANNUR	Chakkarakallu [6660]	MOWENCHERY	129.0	18.0	107.2	3.8	2.9	Very Low
KANNUR	Chakkarakallu [6660]	MURINGERI	129.0	0.0	39.0	90.0	69.8	High
KANNUR	Chakkarakallu [6660]	MUTHUKUTTY	81.0	8.0	32.3	40.7	50.2	High
KANNUR	Chakkarakallu [6660]	MUTHUKUTTY TODDYSHOP	81.0	26.3	53.3	1.4	1.7	Very Low
KANNUR	Chakkarakallu [6660]	MUTTILECHIRA	129.0	3.0	61.6	64.4	49.9	Medium
KANNUR	Chakkarakallu [6660]	MUZHAPPALA	129.0	9.0	100.6	19.4	15.0	Low
KANNUR	Chakkarakallu [6660]	MUZHAPPALARATIONSHOP	129.0	3.0	55.3	70.7	54.8	High
KANNUR	Chakkarakallu [6660]	MYLADI	129.0	5.0	42.0	82.0	63.6	High
KANNUR	Chakkarakallu [6660]	NAGAMUKKU	81.0	16.0	61.0	4.0	4.9	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chakkarakallu [6660]	NALAMPEETIKA	81.0	30.5	49.0	1.5	1.9	Very Low
KANNUR	Chakkarakallu [6660]	NALUMUKKU	81.0	8.0	55.8	17.2	21.3	Low
KANNUR	Chakkarakallu [6660]	NANDANAM METTA	81.0	5.0	19.5	56.5	69.8	High
KANNUR	Chakkarakallu [6660]	NANU PEEDIKA-IRIVERY	81.0	11.0	14.0	56.0	69.1	High
KANNUR	Chakkarakallu [6660]	NIRMAL PETROLEUM	81.0	13.0	38.0	30.0	37.0	Medium
KANNUR	Chakkarakallu [6660]	ODATHILPEEDIKA	129.0	5.0	37.0	87.0	67.4	High
KANNUR	Chakkarakallu [6660]	PALAKKEEZHU	81.0	3.0	11.0	67.0	82.7	Very High
KANNUR	Chakkarakallu [6660]	PALAYAM	81.0	13.3	44.0	23.7	29.3	Medium
KANNUR	Chakkarakallu [6660]	PALAYODE CANAL	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chakkarakallu [6660]	PALAYODE-1	129.0	0.0	37.0	92.0	71.3	High
KANNUR	Chakkarakallu [6660]	PALLIKKANDY	81.0	10.0	66.0	5.0	6.1	Very Low
KANNUR	Chakkarakallu [6660]	PALLIKKANDY PALLY	81.0	21.5	59.0	0.5	0.6	Very Low
KANNUR	Chakkarakallu [6660]	PALLIPOYIL	129.0	6.0	121.1	1.9	1.5	Very Low
KANNUR	Chakkarakallu [6660]	PANAYATHAMPARAMBA	51.0	26.0	25.0	0.0	0.0	Very Low
KANNUR	Chakkarakallu [6660]	PANERICHAL	129.0	14.0	114.0	1.0	0.8	Very Low
KANNUR	Chakkarakallu [6660]	PARAMBUKARI	81.0	3.0	30.0	48.0	59.3	High
KANNUR	Chakkarakallu [6660]	PARAPPURAM	81.0	5.0	45.3	30.7	37.9	Medium
KANNUR	Chakkarakallu [6660]	PARIYARAM JUNCTION	81.0	3.0	24.0	54.0	66.7	High
KANNUR	Chakkarakallu [6660]	POOVATHUMTHARA	81.0	6.0	74.0	1.0	1.2	Very Low
KANNUR	Chakkarakallu [6660]	PUNCHIRIMUKKU	81.0	6.0	17.0	58.0	71.6	High
KANNUR	Chakkarakallu [6660]	PURATHEKKADU	129.0	12.3	56.5	60.2	46.7	Medium
KANNUR	Chakkarakallu [6660]	PURATHEKKADU MUTHAPPAN	81.0	0.0	31.7	49.3	60.8	High
KANNUR	Chakkarakallu [6660]	PUTHUKUDYCHAL	81.0	0.0	14.0	67.0	82.7	Very High
KANNUR	Chakkarakallu [6660]	REG OFFICE	81.0	9.0	38.0	34.0	42.0	Medium
KANNUR	Chakkarakallu [6660]	SAHAKARIVELICHENNA	81.0	11.0	45.0	25.0	30.9	Medium
KANNUR	Chakkarakallu [6660]	SAHARAPLAZA	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	SAPNAMART	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chakkarakallu [6660]	SREEDHARAN PEEDIKA TRASFORMER	51.0	0.0	11.0	40.0	78.4	Very High
KANNUR	Chakkarakallu [6660]	SREESAKTHI	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chakkarakallu [6660]	SUNDER RAJ PVT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	SWAMI ROAD	81.0	8.0	62.8	10.2	12.7	Low
KANNUR	Chakkarakallu [6660]	SWEET STONE AUDITORIUM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	TAVAKKAL CHAKKARAKAL	202.0	0.0	10.0	192.0	95.0	Very High
KANNUR	Chakkarakallu [6660]	THALAKKODE	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Chakkarakallu [6660]	THALAMUNDA	129.0	3.0	60.5	65.5	50.8	High
KANNUR	Chakkarakallu [6660]	THALAMUNDA DINESH	81.0	3.0	50.4	27.6	34.0	Medium
KANNUR	Chakkarakallu [6660]	THALAMUNDA PG	81.0	6.0	29.0	46.0	56.8	High
KANNUR	Chakkarakallu [6660]	THALAVIL	129.0	17.0	50.0	62.0	48.1	Medium
KANNUR	Chakkarakallu [6660]	THATTARI PALAM	81.0	0.0	54.0	27.0	33.3	Medium
KANNUR	Chakkarakallu [6660]	THATTARI TOWN	129.0	0.0	49.0	80.0	62.0	High
KANNUR	Chakkarakallu [6660]	THAZHEKAVINMOOLA	81.0	0.0	79.0	2.0	2.5	Very Low
KANNUR	Chakkarakallu [6660]	THELUPPU	81.0	0.0	32.0	49.0	60.5	High
KANNUR	Chakkarakallu [6660]	TIP TOP	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	TOOLMAGIC	81.0	0.0	79.2	1.8	2.2	Very Low
KANNUR	Chakkarakallu [6660]	TOWN CENTER	255.0	0.0	0.0	255.0	100.0	Very High
KANNUR	Chakkarakallu [6660]	TOWN GATE	255.0	0.0	6.0	249.0	97.6	Very High
KANNUR	Chakkarakallu [6660]	UCHULIKUNNUMOTTA	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Chakkarakallu [6660]	VALAYAL	81.0	3.0	33.0	45.0	55.6	High
KANNUR	Chakkarakallu [6660]	VANDYALA SCHOOL	81.0	11.0	56.0	14.0	17.3	Low
KANNUR	Chakkarakallu [6660]	VANNAN KANDY PALLI	81.0	4.0	29.0	48.0	59.2	High
KANNUR	Chakkarakallu [6660]	VENGANA	81.0	0.0	30.0	51.0	63.0	High
KANNUR	Chakkarakallu [6660]	VENMANAL	81.0	8.0	67.8	5.2	6.4	Very Low
KANNUR	Chakkarakallu [6660]	WESTERN FOOD	81.0	3.0	26.0	52.0	64.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chalode [6661]	A T PEEDIKA	51.0	23.0	28.0	0.0	0.0	Very Low
KANNUR	Chalode [6661]	ANAKKUNI	81.0	0.0	18.0	63.0	77.8	Very High
KANNUR	Chalode [6661]	ANJAMPEEDIKA	81.0	3.0	0.0	78.0	96.3	Very High
KANNUR	Chalode [6661]	ASSOCIATED COAL	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chalode [6661]	AYIPPUZHA IDEA TOWER	129.0	13.0	88.7	27.3	21.2	Low
KANNUR	Chalode [6661]	AYIPPUZHA MARAMILL	129.0	10.0	81.4	37.6	29.1	Medium
KANNUR	Chalode [6661]	AYIPUZA JUNCTION	81.0	5.0	60.8	15.2	18.8	Low
KANNUR	Chalode [6661]	AYYATHAN	81.0	3.0	8.0	70.0	86.4	Very High
KANNUR	Chalode [6661]	BEERANGI BAZAR	81.0	0.0	12.0	69.0	85.2	Very High
KANNUR	Chalode [6661]	BENGANAPARAMBA	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Chalode [6661]	BRIGHT SHELL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	BSNL CHALODE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	BUS STAND CHALODE	81.0	0.0	25.7	55.3	68.3	High
KANNUR	Chalode [6661]	CANALPALAM	81.0	10.0	34.0	37.0	45.7	Medium
KANNUR	Chalode [6661]	CANNANORE HANDLOOM	81.0	0.0	12.4	68.6	84.7	Very High
KANNUR	Chalode [6661]	CENTRE POINT	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chalode [6661]	CHAITHANYAPURI	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chalode [6661]	CHALODE-1	129.0	0.0	33.3	95.7	74.2	High
KANNUR	Chalode [6661]	CHITHRARI	81.0	5.0	38.0	38.0	46.9	Medium
KANNUR	Chalode [6661]	CHOLA	81.0	5.0	12.0	64.0	79.0	Very High
KANNUR	Chalode [6661]	CLASSIC INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	EDAYANNUR	129.0	5.0	43.0	81.0	62.8	High
KANNUR	Chalode [6661]	EDAYANNUR SCHOOL	81.0	0.0	71.0	10.0	12.3	Low
KANNUR	Chalode [6661]	ELAMPARA	81.0	8.0	60.8	12.2	15.0	Low
KANNUR	Chalode [6661]	ELAMPARA PALLI	81.0	0.0	67.5	13.5	16.7	Low
KANNUR	Chalode [6661]	ERACHIPEEDIKA	81.0	5.0	75.5	0.5	0.6	Very Low
KANNUR	Chalode [6661]	GALAXY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chalode [6661]	HARILATHA	81.0	0.0	42.0	39.0	48.1	Medium
KANNUR	Chalode [6661]	HI LOCK	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	HOLLY WOOD	129.0	0.0	66.0	63.0	48.8	Medium
KANNUR	Chalode [6661]	HOTEL MANDARIN SKY CHALODE	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Chalode [6661]	IDEA CHITHRARI	81.0	14.0	67.0	0.0	0.0	Very Low
KANNUR	Chalode [6661]	INDIAN OIL ADANI-GAIL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	INDO DOORS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	KALAMPARA	81.0	6.0	74.1	0.9	1.2	Very Low
KANNUR	Chalode [6661]	KALAMPARA GROUND	51.0	0.0	15.0	36.0	70.6	High
KANNUR	Chalode [6661]	KALAMPARA PALLI	81.0	26.0	33.0	22.0	27.2	Medium
KANNUR	Chalode [6661]	KAMMALANKUNNU	81.0	3.0	25.7	52.3	64.6	High
KANNUR	Chalode [6661]	KANAD	81.0	5.0	57.0	19.0	23.4	Low
KANNUR	Chalode [6661]	KANHIRODE WEAVERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	KANICHERI ASRAMAM	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Chalode [6661]	KANNAN KUNNU	129.0	10.0	39.0	80.0	62.0	High
KANNUR	Chalode [6661]	KARARAMBA	81.0	3.0	17.9	60.1	74.2	High
KANNUR	Chalode [6661]	KAVUMTHAZHA	81.0	8.0	51.8	21.2	26.2	Medium
KANNUR	Chalode [6661]	KELANPEEDIKA	81.0	0.0	26.0	55.0	67.9	High
KANNUR	Chalode [6661]	KODIKKANDI COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	KODIKKANDY CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	KODIKKANDY TYRES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	KODOLIPRAM	129.0	5.0	6.0	118.0	91.5	Very High
KANNUR	Chalode [6661]	KOLAPPA	129.0	10.0	77.4	41.6	32.3	Medium
KANNUR	Chalode [6661]	KOLIPPALAM	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chalode [6661]	KOLOLAM	129.0	0.0	70.8	58.2	45.1	Medium
KANNUR	Chalode [6661]	KOMAKKARI	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Chalode [6661]	KOODALI	202.0	3.0	45.4	153.6	76.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chalode [6661]	KOODALI FZELE E OMAR SCHOOL	51.0	0.0	8.0	43.0	84.3	Very High
KANNUR	Chalode [6661]	KOODALI PHC	81.0	10.0	68.0	3.0	3.7	Very Low
KANNUR	Chalode [6661]	KOODALI POST OFFICE	81.0	5.0	21.0	55.0	67.9	High
KANNUR	Chalode [6661]	KOODALI RESIDENCE	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chalode [6661]	KOORARI	81.0	5.0	76.0	0.0	0.0	Very Low
KANNUR	Chalode [6661]	KOORARI ANGANVADI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	KORARAMBA	81.0	5.0	48.0	28.0	34.5	Medium
KANNUR	Chalode [6661]	KOTTAM MUKKU	81.0	3.0	0.0	78.0	96.3	Very High
KANNUR	Chalode [6661]	KOVOOR	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chalode [6661]	KOYASSAN KUNNU	129.0	0.0	69.0	60.0	46.5	Medium
KANNUR	Chalode [6661]	KOYYODANCHAL	81.0	10.0	50.5	20.5	25.3	Medium
KANNUR	Chalode [6661]	KSEB OFFICE CHALODE	81.0	3.0	24.0	54.0	66.6	High
KANNUR	Chalode [6661]	KUMBHAM	129.0	0.0	27.0	102.0	79.1	Very High
KANNUR	Chalode [6661]	KUMMANAM	81.0	8.0	36.9	36.1	44.6	Medium
KANNUR	Chalode [6661]	KUNHALI PALLI	81.0	24.0	56.9	0.1	0.1	Very Low
KANNUR	Chalode [6661]	KUNNOTH	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Chalode [6661]	KUTTIATTOOR PANCHAYATH	51.0	0.0	14.0	37.0	72.5	High
KANNUR	Chalode [6661]	KUTTIATTOOR SS	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Chalode [6661]	KWA QUARTERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	M R WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	MADATHERA	81.0	5.0	14.0	62.0	76.5	Very High
KANNUR	Chalode [6661]	MARK AND SMITH	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	MAVINCHOTTIL	81.0	0.0	22.0	59.0	72.8	High
KANNUR	Chalode [6661]	METRO WOOD-1	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	METRO WOOD-2	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	MIE VELLIYAMPARAMBA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	MOOLAKKARI	81.0	0.0	37.0	44.0	54.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chalode [6661]	MOOLAKKARI ESTATE PARAMBA	81.0	0.0	12.0	69.0	85.2	Very High
KANNUR	Chalode [6661]	MOOLAKKARI PANCHAYATH KINAR	81.0	9.0	61.3	10.7	13.2	Low
KANNUR	Chalode [6661]	MUNDAPARAMBA STONE CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	MUTTANNUR	129.0	16.0	72.0	41.0	31.8	Medium
KANNUR	Chalode [6661]	MUTTANNUR PALLI	81.0	3.0	29.0	49.0	60.5	High
KANNUR	Chalode [6661]	NALLANI	81.0	3.0	8.0	70.0	86.4	Very High
KANNUR	Chalode [6661]	NALUPERIYA	81.0	3.0	38.8	39.2	48.4	Medium
KANNUR	Chalode [6661]	NAYATTUPARA	81.0	0.0	28.8	52.2	64.4	High
KANNUR	Chalode [6661]	NAYATTUPARA JUNCTION	81.0	11.0	65.4	4.6	5.6	Very Low
KANNUR	Chalode [6661]	NAYIKKALI TEMPLE	81.0	5.0	9.2	66.8	82.5	Very High
KANNUR	Chalode [6661]	NEW METRO WOOD-1	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	NIDUKULAM	81.0	3.0	33.9	44.1	54.4	High
KANNUR	Chalode [6661]	NIDUKULAM SCHOOL	81.0	5.0	0.0	76.0	93.8	Very High
KANNUR	Chalode [6661]	NIDUKULAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	OTTAYIKKARA	81.0	0.0	23.0	58.0	71.6	High
KANNUR	Chalode [6661]	PADICHAL	81.0	0.0	49.3	31.7	39.1	Medium
KANNUR	Chalode [6661]	PALAD	81.0	0.0	23.0	58.0	71.6	High
KANNUR	Chalode [6661]	PALAMFED	81.0	0.0	44.0	37.0	45.7	Medium
KANNUR	Chalode [6661]	PALAMUKK	129.0	0.0	29.0	100.0	77.5	Very High
KANNUR	Chalode [6661]	PALAYODE	129.0	16.0	94.4	18.6	14.4	Low
KANNUR	Chalode [6661]	PALAYODE PRAKASH HOTEL	81.0	0.0	48.5	32.5	40.1	Medium
KANNUR	Chalode [6661]	PALLIKKARA	81.0	3.0	18.0	60.0	74.1	High
KANNUR	Chalode [6661]	PANALAD	81.0	0.0	31.0	50.0	61.7	High
KANNUR	Chalode [6661]	PATTANUR BANK	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Chalode [6661]	POOVATHOOR	81.0	0.0	14.3	66.7	82.3	Very High
KANNUR	Chalode [6661]	PULPAKKARI	81.0	3.0	17.0	61.0	75.3	Very High
KANNUR	Chalode [6661]	PUNJ LLOYD	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chalode [6661]	RELIANCE NAYATTUPARA	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chalode [6661]	RKP COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	ROYAL CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	S M WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	SAW MILL VELLUVAYAL	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Chalode [6661]	SBI CHALODE	81.0	5.0	13.0	63.0	77.8	Very High
KANNUR	Chalode [6661]	SIVA WOOD	81.0	0.0	2.0	79.0	97.5	Very High
KANNUR	Chalode [6661]	SS POLIMERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	SUBHASH NAGAR	81.0	28.0	6.3	46.7	57.7	High
KANNUR	Chalode [6661]	TATA PANAYATHAMPARAMBA	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chalode [6661]	THANAL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	THANNAKKAL NAGAR	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chalode [6661]	THATTIYODE AMBALAM	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Chalode [6661]	THAVAKKAL	81.0	5.0	18.3	57.7	71.2	High
KANNUR	Chalode [6661]	THERUR	81.0	0.0	78.7	2.3	2.8	Very Low
KANNUR	Chalode [6661]	THERUR VILLAGE OFFICE	81.0	3.0	33.3	44.7	55.2	High
KANNUR	Chalode [6661]	THULACHAKINAR	81.0	0.0	23.0	58.0	71.6	High
KANNUR	Chalode [6661]	THUMBOL	81.0	0.0	21.2	59.8	73.8	High
KANNUR	Chalode [6661]	TIMBAC	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	TKMM LOGISTICS BENGANAPARAMBA	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chalode [6661]	TOWER STOP	81.0	2.0	78.7	0.3	0.3	Very Low
KANNUR	Chalode [6661]	UNITECH	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	UTHARA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	V J INDIAN CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	VADUVANKULAM	129.0	0.0	17.5	111.5	86.4	Very High
KANNUR	Chalode [6661]	VARUVAKKUND	81.0	0.0	14.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chalode [6661]	VELLAVILL PEEDIKA	81.0	0.0	12.0	69.0	85.2	Very High
KANNUR	Chalode [6661]	VELLUVAYAL	81.0	6.0	25.2	49.8	61.5	High
KANNUR	Chalode [6661]	VESALA MUKK	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Chalode [6661]	VICTORY PLYWOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	VIJNHANA KAUMUDI	81.0	3.0	6.0	72.0	88.9	Very High
KANNUR	Chalode [6661]	VISTA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chalode [6661]	VIVEKANANDA SCHOOL	81.0	3.0	15.0	63.0	77.8	Very High
KANNUR	Chalode [6661]	ZIA FOOD ESTATE ROAD	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chapparappadavu [6745]	AATTUKULAM	81.0	10.0	29.0	42.0	51.9	High
KANNUR	Chapparappadavu [6745]	AL AMEEN WOOD	81.0	0.0	29.0	52.0	64.2	High
KANNUR	Chapparappadavu [6745]	AL MAQUAR SUNNIYA	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Chapparappadavu [6745]	ALATHATTU	81.0	3.0	0.0	78.0	96.3	Very High
KANNUR	Chapparappadavu [6745]	ALPHA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	AMMANKULAM	81.0	4.0	49.0	28.0	34.6	Medium
KANNUR	Chapparappadavu [6745]	ARAMVAYAL	81.0	0.0	3.5	77.5	95.7	Very High
KANNUR	Chapparappadavu [6745]	ASMAS WOOD	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chapparappadavu [6745]	ATHIRUKUNNU	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Chapparappadavu [6745]	AYSHA WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	BADARIYA MANGARA	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Chapparappadavu [6745]	BALESSUGIRI	81.0	8.0	26.0	47.0	58.0	High
KANNUR	Chapparappadavu [6745]	BERETTO	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	BEST WINNER	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Chapparappadavu [6745]	BHARATHI-INFRA TEL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	BRIGHT WOOD	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chapparappadavu [6745]	CH SOIL BRICKS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	CHAKIRI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	CHAMIYATTU MALA	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chapparappadavu [6745]	CHAPPARAPADAVU PANJAYATH	81.0	0.0	35.0	46.0	56.8	High
KANNUR	Chapparappadavu [6745]	CHAPPARAPADAVU WOOD	81.0	3.0	22.0	56.0	69.1	High
KANNUR	Chapparappadavu [6745]	CHEMMEEN KAVALA	81.0	0.0	8.9	72.1	89.0	Very High
KANNUR	Chapparappadavu [6745]	CHERIYATH RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	CHETTIYAN KUNNEL BONE MILL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	CHETTIYANKUNNEL OIL MILL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	CHIMMINICHOOTTA RGGVY	20.0	0.0	6.0	14.0	70.0	High
KANNUR	Chapparappadavu [6745]	CHUNDAKKUNNU	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Chapparappadavu [6745]	CLASSIC WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	COPRA TRANSFORMER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	CPDV HOSPITAL	81.0	0.0	9.8	71.2	87.9	Very High
KANNUR	Chapparappadavu [6745]	CROWN PACKERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	ECHONAGAR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	EDAKKOM	81.0	3.0	30.0	48.0	59.3	High
KANNUR	Chapparappadavu [6745]	EDAKOM BUILDERS	202.0	0.0	14.9	187.1	92.6	Very High
KANNUR	Chapparappadavu [6745]	ELEMPERAM MUTHAPPAN	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Chapparappadavu [6745]	ERUVATTY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	ERUVATTY VAYANASALA	81.0	3.0	17.0	61.0	75.3	Very High
KANNUR	Chapparappadavu [6745]	FASEELA WOOD	81.0	4.0	9.7	67.3	83.1	Very High
KANNUR	Chapparappadavu [6745]	GREEN POLA	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	INNOSPHERE	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	INOSPIRE	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	IRIVELLOOR MUTHAPPAN	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	JICA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KAKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KALLYANAPURAM	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Chapparappadavu [6745]	KANARAMVAYAL	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chapparappadavu [6745]	KANIKKATHODU	51.0	0.0	13.2	37.8	74.1	High
KANNUR	Chapparappadavu [6745]	KANNADIPARA	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chapparappadavu [6745]	KARIPPAL	81.0	8.0	9.8	63.2	78.0	Very High
KANNUR	Chapparappadavu [6745]	KINFRA C1	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KINFRA C2	202.0	0.0	33.0	169.0	83.7	Very High
KANNUR	Chapparappadavu [6745]	KINFRA F-1	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KINFRA F-2	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KINFRA F3	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KINFRA PUMP ODUVALLI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KINFRA TEXTILE CENTRE-INDOOR	405.0	0.0	0.0	405.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KINFRA-A-1	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KINFRA-D-1	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Chapparappadavu [6745]	KK STONE ARTS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KOLARTHOTTY	81.0	0.0	16.2	64.8	80.0	Very High
KANNUR	Chapparappadavu [6745]	KOOVERY	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Chapparappadavu [6745]	KOTTAKANAM	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Chapparappadavu [6745]	KOTTAKOYIL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	KVS AGRI-FARM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	LATEX	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chapparappadavu [6745]	MADAKKAD	81.0	0.0	19.6	61.4	75.8	Very High
KANNUR	Chapparappadavu [6745]	MADAMTHATTU	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Chapparappadavu [6745]	MADAMTHATTU RGGVY	20.0	0.0	9.0	11.0	55.0	High
KANNUR	Chapparappadavu [6745]	MALABAR GAS	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Chapparappadavu [6745]	MANGARA CRUSHER	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	MANGARA EAST	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chapparappadavu [6745]	MANGARA R W S S	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chapparappadavu [6745]	MAVILAMPARA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chapparappadavu [6745]	MAXWORTH	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	MY BRA LIGNERIE PVT LTD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	NADUKANI ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	NADUVIL EAST	81.0	0.0	17.3	63.7	78.6	Very High
KANNUR	Chapparappadavu [6745]	NADUVIL JTS	81.0	5.0	31.0	45.0	55.6	High
KANNUR	Chapparappadavu [6745]	NADUVIL KUNDU KANDAM	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chapparappadavu [6745]	NADUVIL P H C	81.0	5.0	69.0	7.0	8.6	Very Low
KANNUR	Chapparappadavu [6745]	NADUVIL R W S S	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Chapparappadavu [6745]	NADUVIL WEST	129.0	5.0	20.5	103.5	80.2	Very High
KANNUR	Chapparappadavu [6745]	NADUVIL-IDEA	81.0	0.0	24.0	57.0	70.4	High
KANNUR	Chapparappadavu [6745]	NAMBADIYANAM	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	NAYIKUNNU RGGVY	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	NHADAMBALAM-2	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	NJADAMBALAM FARM	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	NJANDAMBALAM RGGVY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	NSAEERA WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	ODUVALLI	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Chapparappadavu [6745]	OFFICE TRANSFORMER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	ORKAYAM	81.0	5.0	15.0	61.0	75.3	Very High
KANNUR	Chapparappadavu [6745]	OTTATHOTTY	81.0	0.0	13.0	68.0	84.0	Very High
KANNUR	Chapparappadavu [6745]	PACHANI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	PACHANI KUNDUTHADAM	81.0	0.0	14.3	66.7	82.3	Very High
KANNUR	Chapparappadavu [6745]	PADAPPENGAD ASRAMAM	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chapparappadavu [6745]	PADAPPENGAD TOWN	81.0	10.0	11.0	60.0	74.1	High
KANNUR	Chapparappadavu [6745]	PADEPPENGAD BRANCH SOMESWARY	81.0	3.0	18.0	60.0	74.1	High
KANNUR	Chapparappadavu [6745]	PADEPPENGAD LINE	81.0	5.0	10.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chapparappadavu [6745]	PADEPPENGAD-IDEA	81.0	5.0	0.0	76.0	93.8	Very High
KANNUR	Chapparappadavu [6745]	PAKANJIKKAD	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chapparappadavu [6745]	PALAYADE KOOVERI	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chapparappadavu [6745]	PALERITHATTU	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chapparappadavu [6745]	PALLITHATTU	81.0	0.0	34.0	47.0	58.0	High
KANNUR	Chapparappadavu [6745]	PARAKODE	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chapparappadavu [6745]	PCT WOOD POLIMER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	PERUMALABAD	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Chapparappadavu [6745]	PERUMALABAD JUMA MASJID	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Chapparappadavu [6745]	PERUMBADAVA PETROL PUMB	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	PERUMBADAVU	129.0	0.0	21.0	108.0	83.7	Very High
KANNUR	Chapparappadavu [6745]	PERUMPADAVA MILL	81.0	0.0	32.0	49.0	60.5	High
KANNUR	Chapparappadavu [6745]	PERUMPADAVU PETROL PUMP	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	PERUVANA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chapparappadavu [6745]	PMJ WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	POONAMKODE	81.0	0.0	29.7	51.3	63.4	High
KANNUR	Chapparappadavu [6745]	POOVATHAMKUZHI	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chapparappadavu [6745]	POTHUKUNDU	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chapparappadavu [6745]	POWER-INDIA	81.0	5.0	31.0	45.0	55.6	High
KANNUR	Chapparappadavu [6745]	RAMAPURAM	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Chapparappadavu [6745]	S R CRUSHER	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	SANTHIGIRI	81.0	0.0	24.0	57.0	70.4	High
KANNUR	Chapparappadavu [6745]	SHANTHIGIRI AYURVEDAM	81.0	5.0	10.0	66.0	81.5	Very High
KANNUR	Chapparappadavu [6745]	SHIHAB COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	SIHA FOOD KINFRA C PLOT	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	SOMESWARI	81.0	0.0	17.7	63.3	78.2	Very High
KANNUR	Chapparappadavu [6745]	SUPER STONE CRUSHER	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chapparappadavu [6745]	THALAVIL	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chapparappadavu [6745]	THALAVIL-IDEA	81.0	6.0	0.0	75.0	92.6	Very High
KANNUR	Chapparappadavu [6745]	THATTYADE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	THAVUKUNNU	81.0	0.0	14.0	67.0	82.7	Very High
KANNUR	Chapparappadavu [6745]	THAZHE EDAKOM	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Chapparappadavu [6745]	THAZHE VILAKKANNUR	81.0	5.0	19.0	57.0	70.4	High
KANNUR	Chapparappadavu [6745]	THENNAM	81.0	0.0	2.0	79.0	97.5	Very High
KANNUR	Chapparappadavu [6745]	THERANDI	81.0	5.0	26.7	49.3	60.8	High
KANNUR	Chapparappadavu [6745]	THRIVENI	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chapparappadavu [6745]	THUYIPRA	51.0	0.0	10.0	41.0	80.4	Very High
KANNUR	Chapparappadavu [6745]	UMIKKUNNU RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	UROOTTERI	81.0	10.0	9.0	62.0	76.5	Very High
KANNUR	Chapparappadavu [6745]	UTHOOR	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chapparappadavu [6745]	VELLAKKADU SCHOOL	51.0	0.0	11.0	40.0	78.4	Very High
KANNUR	Chapparappadavu [6745]	VILAKKANNUR	81.0	0.0	36.0	45.0	55.6	High
KANNUR	Chapparappadavu [6745]	VILAYARKODE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chapparappadavu [6745]	VIMALASSERI	129.0	0.0	5.0	124.0	96.1	Very High
KANNUR	Chapparappadavu [6745]	WOOD CO WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	AMALA AUDITORIUM	81.0	0.0	53.0	28.0	34.6	Medium
KANNUR	Chemperi [6721]	ARANGU	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chemperi [6721]	AREECKAMALA	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Chemperi [6721]	ARRACKAL	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Chemperi [6721]	BRIGHT PLY	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chemperi [6721]	CHAKKKALAKAVALA	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chemperi [6721]	CHALIMPARAMBA	81.0	5.0	34.0	42.0	51.9	High
KANNUR	Chemperi [6721]	CHATHAMALA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	CHEMPERI	202.0	10.0	120.0	72.0	35.6	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chemperi [6721]	CHEMPERI MARKET	81.0	0.0	42.0	39.0	48.1	Medium
KANNUR	Chemperi [6721]	CHETTADI	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Chemperi [6721]	CHULLIPALLAM	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Chemperi [6721]	CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	EDAMANA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	ERUVESSY	81.0	0.0	18.0	63.0	77.8	Very High
KANNUR	Chemperi [6721]	ERUVESSY VADAKKEMOOLA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chemperi [6721]	ETTUPARA	129.0	0.0	26.0	103.0	79.8	Very High
KANNUR	Chemperi [6721]	GARUDA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	HOLLY CROSS CONVENT	81.0	10.0	62.0	9.0	11.1	Low
KANNUR	Chemperi [6721]	IDEA TOWER CHEMPERI	129.0	0.0	8.0	121.0	93.8	Very High
KANNUR	Chemperi [6721]	KAITHALAM	81.0	5.0	16.0	60.0	74.1	High
KANNUR	Chemperi [6721]	KAKKUMTHADAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	KAMPLARI	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chemperi [6721]	KANAKAKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	KANAMALA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	KANNUR CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	KARAYATHUMCHAL TOWER	81.0	0.0	17.8	63.2	78.1	Very High
KANNUR	Chemperi [6721]	KAVARAPLAVU	81.0	0.0	13.8	67.2	83.0	Very High
KANNUR	Chemperi [6721]	KODIKKANDI CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	KOOTTAKKALAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	KOOVACHI	81.0	3.0	9.0	69.0	85.2	Very High
KANNUR	Chemperi [6721]	KOTTA	81.0	0.0	33.0	48.0	59.3	High
KANNUR	Chemperi [6721]	KOTTACHOLA	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chemperi [6721]	KOTTAKKUNNU KURISSUPALLY	81.0	3.0	0.0	78.0	96.3	Very High
KANNUR	Chemperi [6721]	KOTTAKUNNU	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Chemperi [6721]	KOTTAYAMTHATTU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chemperi [6721]	KUDIYANMALA CHURCH	81.0	0.0	29.7	51.3	63.3	High
KANNUR	Chemperi [6721]	KUDIYANMALA LOWER	129.0	0.0	34.0	95.0	73.7	High
KANNUR	Chemperi [6721]	KUDIYANMALA UPPER	202.0	0.0	28.0	174.0	86.1	Very High
KANNUR	Chemperi [6721]	KUNIYAMPUZHA	81.0	0.0	9.7	71.3	88.0	Very High
KANNUR	Chemperi [6721]	KUNIYAMPUZHA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	KWA CHEMPERI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	MAMPALLAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	MANDALAM	129.0	5.0	8.0	116.0	89.9	Very High
KANNUR	Chemperi [6721]	MANJUMALA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	MANKULAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	MANNAMKUNDU BRIDGE	81.0	0.0	47.5	33.5	41.3	Medium
KANNUR	Chemperi [6721]	MANNAMKUNDU THOTTAM	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Chemperi [6721]	MATTATHINANI	81.0	0.0	29.0	52.0	64.2	High
KANNUR	Chemperi [6721]	MIDILAKAYAM LOWER	81.0	0.0	13.0	68.0	84.0	Very High
KANNUR	Chemperi [6721]	MIDILAKAYAM UPPER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	MIDILAKKAYAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	MUTHIRENTHIKKAVALA	81.0	6.0	13.0	62.0	76.5	Very High
KANNUR	Chemperi [6721]	MUYIPRA	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Chemperi [6721]	MYKKAD	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Chemperi [6721]	NARIYAMMAVU MILL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	NARIYANMAVU	81.0	0.0	28.0	53.0	65.4	High
KANNUR	Chemperi [6721]	NELLIKUTTY	202.0	3.0	22.0	177.0	87.6	Very High
KANNUR	Chemperi [6721]	NJANNAMALA	81.0	0.0	18.0	63.0	77.7	Very High
KANNUR	Chemperi [6721]	ODAYANPLAVU	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chemperi [6721]	ORAKUNDU	81.0	9.0	33.3	38.7	47.8	Medium
KANNUR	Chemperi [6721]	PAITHAL HILL ECO TOURISM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	PAITHALMALA DTPC	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chemperi [6721]	PALLIKUNNU	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Chemperi [6721]	PAYATTUCHAL	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Chemperi [6721]	POOPARAMBA	129.0	0.0	45.0	84.0	65.1	High
KANNUR	Chemperi [6721]	POOPARAMBA TOWER	81.0	5.0	16.0	60.0	74.1	High
KANNUR	Chemperi [6721]	POTTANPLAVU TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	POTTENPLAVU LOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	POTTENPLAVU UPPER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	PULIKKURUMBA TOWN	81.0	5.0	4.7	71.3	88.0	Very High
KANNUR	Chemperi [6721]	PULIKURUMBA	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Chemperi [6721]	PULIKURUMBA TOWER	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Chemperi [6721]	PULLAMVANAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	PULLIKALLU	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Chemperi [6721]	PURANJAN	81.0	14.0	19.0	48.0	59.3	High
KANNUR	Chemperi [6721]	PURANJAN TOWER	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Chemperi [6721]	PURAYIDATHILKAVALA	81.0	5.0	18.0	58.0	71.6	High
KANNUR	Chemperi [6721]	QUALITY CRUSHER	81.0	0.0	19.8	61.2	75.6	Very High
KANNUR	Chemperi [6721]	SIVAGIRI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	SNDP KAVALA	81.0	0.0	29.0	52.0	64.2	High
KANNUR	Chemperi [6721]	SUPRIYA FIBRES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chemperi [6721]	SURABHI COMPLEX	129.0	0.0	10.0	119.0	92.2	Very High
KANNUR	Chemperi [6721]	THANAL STOP	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Chemperi [6721]	THARACHITTA	81.0	0.0	12.0	69.0	85.2	Very High
KANNUR	Chemperi [6721]	THATTUKUNNU	20.0	0.0	5.0	15.0	75.0	Very High
KANNUR	Chemperi [6721]	THATTUKUNNU JN	81.0	5.0	32.0	44.0	54.3	High
KANNUR	Chemperi [6721]	THUPPELANJI KAVALA	81.0	0.0	21.9	59.1	73.0	High
KANNUR	Chemperi [6721]	THURUMBI	81.0	5.0	0.0	76.0	93.8	Very High
KANNUR	Chemperi [6721]	VALAYAMKUNDU	81.0	3.0	13.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chemperi [6721]	VALIYAPARAMBA	81.0	0.0	44.3	36.7	45.4	Medium
KANNUR	Chemperi [6721]	VELIYANADU	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Chemperi [6721]	VETILAKKODI	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Chemperi [6721]	VIMAL JYOTHI GATE	81.0	0.0	12.5	68.5	84.6	Very High
KANNUR	Chemperi [6721]	VIMALJYOTHI STAFF QUARTERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	A K FRAMES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	AACHANATT	81.0	3.0	11.3	66.7	82.3	Very High
KANNUR	Cherukunnu [6664]	AASARIMOTTA	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Cherukunnu [6664]	ABHIVALAVU	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Cherukunnu [6664]	ADLP PALLIKKARA	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Cherukunnu [6664]	AK ENGINEERING	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	AK PLYWOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	AK SAWMILL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	AMBALAM	129.0	0.0	36.9	92.1	71.4	High
KANNUR	Cherukunnu [6664]	ANUSUDHA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	ARBA COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	AVA PETROLIUM THAVAM	129.0	0.0	9.0	120.0	93.0	Very High
KANNUR	Cherukunnu [6664]	AYIRAM THENGU	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Cherukunnu [6664]	AYYOTH	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Cherukunnu [6664]	AYYOTH COIR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	C R C	129.0	11.0	28.9	89.1	69.1	High
KANNUR	Cherukunnu [6664]	CANARA FIBRE MUTTIL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	CANOSSEAN CONVENT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	CHEKKIKKUNDU	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Cherukunnu [6664]	CHEKKIKUNDU-INDUSTRIAL ESTT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	CHEMMARA VAYAL	81.0	0.0	35.0	46.0	56.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Cherukunnu [6664]	CHERUKUNNU PANCHAYATH GROUND	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	CHETTIKULAM	81.0	0.0	11.3	69.7	86.0	Very High
KANNUR	Cherukunnu [6664]	CHINACLAY JUNCTION	81.0	3.0	49.0	29.0	35.8	Medium
KANNUR	Cherukunnu [6664]	CHIRAVAKKU	81.0	0.0	21.4	59.6	73.6	High
KANNUR	Cherukunnu [6664]	CHUNDA-I	81.0	5.0	69.5	6.5	8.0	Very Low
KANNUR	Cherukunnu [6664]	CHUNDA-II	81.0	0.0	23.3	57.7	71.2	High
KANNUR	Cherukunnu [6664]	COLONY ROAD KANNAPURAM	81.0	0.0	13.0	68.0	84.0	Very High
KANNUR	Cherukunnu [6664]	CONVENT	202.0	4.0	49.0	149.0	73.7	High
KANNUR	Cherukunnu [6664]	CONVENT ROAD	81.0	0.0	47.4	33.6	41.5	Medium
KANNUR	Cherukunnu [6664]	DALIL	51.0	0.0	5.0	46.0	90.2	Very High
KANNUR	Cherukunnu [6664]	DALIL COIR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	DESAPRIYA	81.0	8.0	58.0	15.0	18.5	Low
KANNUR	Cherukunnu [6664]	DEVI VILASAM THAVAM	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherukunnu [6664]	DUBAIPARAMBU	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Cherukunnu [6664]	EDAKKEPPURAM	129.0	0.0	44.0	85.0	65.9	High
KANNUR	Cherukunnu [6664]	EDAPPARA	81.0	5.0	0.0	76.0	93.8	Very High
KANNUR	Cherukunnu [6664]	EDATHATTA	81.0	0.0	42.4	38.6	47.6	Medium
KANNUR	Cherukunnu [6664]	FAHAD COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherukunnu [6664]	G G H S	81.0	3.0	57.3	20.7	25.6	Medium
KANNUR	Cherukunnu [6664]	GBHS	129.0	0.0	41.0	88.0	68.2	High
KANNUR	Cherukunnu [6664]	GRAMEENA VAYANASALA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherukunnu [6664]	GURUKULAM	81.0	8.0	44.0	29.0	35.8	Medium
KANNUR	Cherukunnu [6664]	HALCY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	HARISREE COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	HDFC	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	IRINAV BORDER	81.0	0.0	13.0	68.0	84.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Cherukunnu [6664]	IRINAVU GATE	81.0	0.0	48.0	33.0	40.7	Medium
KANNUR	Cherukunnu [6664]	JANAKEEYA VAYANASALA	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Cherukunnu [6664]	JBIC	81.0	3.0	3.0	75.0	92.6	Very High
KANNUR	Cherukunnu [6664]	KANNAPURAM CO EV BANK PVT OWNE	129.0	0.0	50.0	79.0	61.2	High
KANNUR	Cherukunnu [6664]	KANNAPURAM PANCHAYATH	81.0	0.0	6.1	74.9	92.5	Very High
KANNUR	Cherukunnu [6664]	KANNAPURAM RAILWAY STATION	81.0	0.0	33.0	48.0	59.3	High
KANNUR	Cherukunnu [6664]	KANNAPURAM SAW MILL	202.0	0.0	20.0	182.0	90.1	Very High
KANNUR	Cherukunnu [6664]	KARIKKATTU MUTHAPPAN	81.0	0.0	32.5	48.5	59.9	High
KANNUR	Cherukunnu [6664]	KATTAKKULAM	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Cherukunnu [6664]	KAVINISSERI VAYANASALA	81.0	0.0	9.2	71.8	88.6	Very High
KANNUR	Cherukunnu [6664]	KAVINISSERY	81.0	0.0	50.4	30.6	37.8	Medium
KANNUR	Cherukunnu [6664]	KCCPL CHINACLAY	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherukunnu [6664]	KEEZHARA	81.0	15.0	65.9	0.1	0.1	Very Low
KANNUR	Cherukunnu [6664]	KELANKOOR	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Cherukunnu [6664]	KERALA CLAY-INDUSTRY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	KEY VEE WOOD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherukunnu [6664]	KOLATHUVAYAL ODIPPURAM	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Cherukunnu [6664]	KOOLOM	81.0	0.0	25.7	55.3	68.3	High
KANNUR	Cherukunnu [6664]	KOVVAPPURAM	129.0	6.0	41.0	82.0	63.6	High
KANNUR	Cherukunnu [6664]	KUNNANAGAD	81.0	3.0	0.0	78.0	96.3	Very High
KANNUR	Cherukunnu [6664]	KURUVAKKAVU	81.0	5.0	17.2	58.8	72.5	High
KANNUR	Cherukunnu [6664]	KVR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	MAAYICHAL	81.0	0.0	6.3	74.7	92.2	Very High
KANNUR	Cherukunnu [6664]	MADHAVI COMPLX	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Cherukunnu [6664]	MALABAR	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherukunnu [6664]	MATTANKEEL	81.0	0.0	16.8	64.2	79.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Cherukunnu [6664]	MAVELI STORE KANNAPURAM	81.0	0.0	31.0	50.0	61.7	High
KANNUR	Cherukunnu [6664]	MERYL AQUA FARM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	MERYL MARINE	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherukunnu [6664]	MOTTAMMAL	81.0	6.0	46.4	28.6	35.3	Medium
KANNUR	Cherukunnu [6664]	MOYON ROAD	129.0	5.0	98.9	25.1	19.4	Low
KANNUR	Cherukunnu [6664]	MUNDAPPURAM	81.0	0.0	11.3	69.7	86.0	Very High
KANNUR	Cherukunnu [6664]	MUNDAPPURAM COIR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	MUNDAPPURAM VAYANASALA	81.0	10.0	28.0	43.0	53.1	High
KANNUR	Cherukunnu [6664]	MUNEWARA	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherukunnu [6664]	MUTTIL	81.0	0.0	8.2	72.8	89.9	Very High
KANNUR	Cherukunnu [6664]	MUTTIL ROAD	81.0	3.0	10.0	68.0	84.0	Very High
KANNUR	Cherukunnu [6664]	NALONNIL	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Cherukunnu [6664]	NEDUPURAM COLONY	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Cherukunnu [6664]	NIDHA COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	NSS	81.0	5.0	25.0	51.0	63.0	High
KANNUR	Cherukunnu [6664]	O V JUNCTION	81.0	3.0	6.0	72.0	88.9	Very High
KANNUR	Cherukunnu [6664]	ODIYILE PEEDIKA	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Cherukunnu [6664]	OTHAYAMMADAM	81.0	0.0	7.0	74.0	91.4	Very High
KANNUR	Cherukunnu [6664]	PADIYIL	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Cherukunnu [6664]	PALIYATHU VALAPPU	81.0	3.0	3.0	75.0	92.6	Very High
KANNUR	Cherukunnu [6664]	PALLICHAL JUNCTION	81.0	0.0	35.1	45.9	56.6	High
KANNUR	Cherukunnu [6664]	PALLICHAL-I	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Cherukunnu [6664]	PALLIKKARA	129.0	0.0	18.0	111.0	86.0	Very High
KANNUR	Cherukunnu [6664]	PANNERI	81.0	3.0	17.7	60.3	74.4	High
KANNUR	Cherukunnu [6664]	PANTHOTTAM	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherukunnu [6664]	PARAPPURAM	81.0	0.0	29.0	52.0	64.2	High
KANNUR	Cherukunnu [6664]	PARAPPURAM KANDI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Cherukunnu [6664]	PARAYILMUKKU	81.0	0.0	28.3	52.7	65.1	High
KANNUR	Cherukunnu [6664]	PAYANGADI BRIDGE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	PONNACHI KOVVAL	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Cherukunnu [6664]	POONKAVU	81.0	0.0	7.0	74.0	91.4	Very High
KANNUR	Cherukunnu [6664]	POTTI BAZAR	81.0	10.0	47.0	24.0	29.6	Medium
KANNUR	Cherukunnu [6664]	PRATHEEKSHA BAR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	PREMIER BOARD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	PREMIER PLYWOOD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherukunnu [6664]	PUNCHAVAYAL	81.0	0.0	12.1	68.9	85.1	Very High
KANNUR	Cherukunnu [6664]	PUNCHAVAYAL PHC	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Cherukunnu [6664]	PUTHUVAKKAL	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Cherukunnu [6664]	PUTHUVAKKAL PUMP HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	RELIANCE THAVAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	SHAFCO	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	SIDHIQUE PALLI	129.0	5.0	40.6	83.5	64.7	High
KANNUR	Cherukunnu [6664]	SOMESWARY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	SREE DEVI NARAYANA TRANSFORMER	324.0	0.0	50.0	274.0	84.6	Very High
KANNUR	Cherukunnu [6664]	STAR BOARD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherukunnu [6664]	SWADAF	81.0	0.0	45.0	36.0	44.4	Medium
KANNUR	Cherukunnu [6664]	T K BOARD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	T K PLYWOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	TATA THARA	81.0	0.0	32.9	48.1	59.4	High
KANNUR	Cherukunnu [6664]	THARA	129.0	0.0	15.0	114.0	88.4	Very High
KANNUR	Cherukunnu [6664]	THAVAM COIR	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Cherukunnu [6664]	THAVAM EAST	81.0	0.0	13.5	67.5	83.3	Very High
KANNUR	Cherukunnu [6664]	THAVAM P O	202.0	3.0	15.0	184.0	91.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Cherukunnu [6664]	THAVAM TATA	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Cherukunnu [6664]	THAVAM-INDUSTRIAL ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherukunnu [6664]	THEKKUMBAD JUNCTION	81.0	0.0	26.0	55.0	67.9	High
KANNUR	Cherukunnu [6664]	THEKKUMBAD NORTH	129.0	0.0	16.0	113.0	87.6	Very High
KANNUR	Cherukunnu [6664]	THEKKUMBAD SOUTH	129.0	10.0	24.0	95.0	73.6	High
KANNUR	Cherukunnu [6664]	VALLITHODU	81.0	6.0	48.5	26.5	32.7	Medium
KANNUR	Cherukunnu [6664]	VANIYANKARA	81.0	0.0	27.0	54.0	66.7	High
KANNUR	Cherukunnu [6664]	VELLARANGAL	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Cherukunnu [6664]	VETTAKKORUMAKAN TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Cherukunnu [6664]	YOGASALA	129.0	0.0	26.0	103.0	79.8	Very High
KANNUR	Cherukunnu [6664]	YOGASALA JUNCTION	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Cherupuzha [6816]	AK CINE PALACE	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherupuzha [6816]	AKR	81.0	0.0	30.0	51.0	63.0	High
KANNUR	Cherupuzha [6816]	AMBILIPALAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	AMPALAMPALLA	51.0	0.0	3.0	48.0	94.1	Very High
KANNUR	Cherupuzha [6816]	AYIKKAD	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Cherupuzha [6816]	BALAVADY	81.0	0.0	31.0	50.0	61.7	High
KANNUR	Cherupuzha [6816]	BHOODHANAM	81.0	0.0	14.0	67.0	82.7	Very High
KANNUR	Cherupuzha [6816]	CHAMAYAM	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Cherupuzha [6816]	CHANGATHIMUKKU	81.0	0.0	18.0	63.0	77.8	Very High
KANNUR	Cherupuzha [6816]	CHAPPARAMTHATTU	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	CHATHAMANGALAM	81.0	3.0	6.0	72.0	88.9	Very High
KANNUR	Cherupuzha [6816]	CHATTIVAYAL	81.0	3.0	5.0	73.0	90.1	Very High
KANNUR	Cherupuzha [6816]	CHERUPUZHA	202.0	0.0	10.0	192.0	95.0	Very High
KANNUR	Cherupuzha [6816]	CHERUPUZHA BSNL	81.0	3.0	36.0	42.0	51.9	High
KANNUR	Cherupuzha [6816]	CHERUPUZHA DEVELOPERS	129.0	0.0	50.0	79.0	61.2	High
KANNUR	Cherupuzha [6816]	CHERUPUZHA MINI PARK	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Cherupuzha [6816]	CHERUPUZHA TEMPLE	81.0	6.0	22.0	53.0	65.4	High
KANNUR	Cherupuzha [6816]	CHITTADI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	CHLOORAPADAVE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	CHUNDA	81.0	0.0	50.0	31.0	38.3	Medium
KANNUR	Cherupuzha [6816]	CHUNNAMUKKU	81.0	0.0	23.0	58.0	71.6	High
KANNUR	Cherupuzha [6816]	CITY SQUARE BUILDING	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	EDAVARAMBA	81.0	10.0	43.0	28.0	34.6	Medium
KANNUR	Cherupuzha [6816]	EYYAMKALLU DRINKING WATER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	EYYAMKALLU-RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	EYYANKALLU	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Cherupuzha [6816]	GOODLY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	JMUPS CHERUPUZHA	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Cherupuzha [6816]	KAKKAYAMCHAL	202.0	0.0	107.2	94.8	46.9	Medium
KANNUR	Cherupuzha [6816]	KAKKODE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KAKKODE TEMPLE	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherupuzha [6816]	KALATHIL	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherupuzha [6816]	KALLAPPATHI	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KAMMALI-1	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KAMMALI-2	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KANAMVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KARIPPAL	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KARIYAKKARA	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Cherupuzha [6816]	KOKKADAVU	129.0	0.0	24.0	105.0	81.4	Very High
KANNUR	Cherupuzha [6816]	KOLATHUVAI	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KOLLADA	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Cherupuzha [6816]	KOLLADA RGGVY	20.0	5.0	8.0	7.0	35.0	Medium
KANNUR	Cherupuzha [6816]	KOLUVALLY	81.0	5.0	97.2	0.0	0.0	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Cherupuzha [6816]	KOOBANKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KOODAPRAM	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Cherupuzha [6816]	KORALI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KORALI CRUSSURE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KOTTATHALACHI	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KOZHICHAL	202.0	0.0	7.0	195.0	96.5	Very High
KANNUR	Cherupuzha [6816]	KOZHICHAL H C	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherupuzha [6816]	KOZHICHAL TOWER	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Cherupuzha [6816]	KUNDAYAMKODE	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Cherupuzha [6816]	KUNDERI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	KURICHIYAKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	LAND MARK	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	MANJAKKAD KHADI	81.0	0.0	19.0	62.0	76.5	Very High
KANNUR	Cherupuzha [6816]	MANJAKKADE	129.0	0.0	43.0	86.0	66.7	High
KANNUR	Cherupuzha [6816]	MARAKKAR COMPLEX	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherupuzha [6816]	MARUTHUMTHATTU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	MATHA FUELS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	MEENTHULLY	81.0	0.0	14.0	67.0	82.7	Very High
KANNUR	Cherupuzha [6816]	MEENTHULLY REVENUE	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	MELUTHANI	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherupuzha [6816]	MERCHANT SQUARE	129.0	0.0	8.0	121.0	93.8	Very High
KANNUR	Cherupuzha [6816]	MOONNAMPLAVE	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Cherupuzha [6816]	MULAPRA	81.0	3.0	33.0	45.0	55.6	High
KANNUR	Cherupuzha [6816]	MUTHUVAM	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Cherupuzha [6816]	NAVAJYOTHI COLLEGE	81.0	0.0	13.0	68.0	84.0	Very High
KANNUR	Cherupuzha [6816]	OOMALA	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Cherupuzha [6816]	PADINJATH	202.0	0.0	3.0	199.0	98.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Cherupuzha [6816]	PAKANJIKKAD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	PAMPANKALLU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	PANDIKKADAVE	81.0	0.0	26.0	55.0	67.9	High
KANNUR	Cherupuzha [6816]	PAROTHUMNEER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	PATTATHUVAYAL	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherupuzha [6816]	PAVAN COMPLEX	129.0	0.0	3.0	126.0	97.7	Very High
KANNUR	Cherupuzha [6816]	PERINGALA	129.0	0.0	11.0	118.0	91.5	Very High
KANNUR	Cherupuzha [6816]	PERINGALA RWSS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	PERUMKUDAL	81.0	0.0	13.7	67.3	83.1	Very High
KANNUR	Cherupuzha [6816]	PERUMTHADAM	81.0	9.0	9.0	63.0	77.8	Very High
KANNUR	Cherupuzha [6816]	PERUVATTOM RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	PERUVETTAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	PHC PULINGOME	81.0	0.0	38.0	43.0	53.1	High
KANNUR	Cherupuzha [6816]	POKKIRI MUKKE	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Cherupuzha [6816]	PRAPOIL	81.0	6.0	25.0	50.0	61.7	High
KANNUR	Cherupuzha [6816]	PULIMAVU	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	PULINGOME	121.0	0.0	18.0	103.0	85.1	Very High
KANNUR	Cherupuzha [6816]	PULINGOME EXCHANGE	81.0	0.0	53.0	28.0	34.6	Medium
KANNUR	Cherupuzha [6816]	PULIYITTAPOIL	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Cherupuzha [6816]	RAJAGIRI	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherupuzha [6816]	SB FUELS PRAPOYIL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	SEVENS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	SOORYAGIRI	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	SREE MUTHAPPAN FILLING STATION	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	ST SEBASTIAN	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	THATTACHERRY COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Cherupuzha [6816]	THAVALAKUNDU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	THEKKENMAVE	20.0	0.0	0.0	20.0	100.0	Very High
KANNUR	Cherupuzha [6816]	THIRUMENI	129.0	0.0	28.0	101.0	78.3	Very High
KANNUR	Cherupuzha [6816]	THIRUMENI BSNL	81.0	5.0	8.0	68.0	84.0	Very High
KANNUR	Cherupuzha [6816]	THOTTIKKUNDU	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Cherupuzha [6816]	TREASURY	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Cherupuzha [6816]	UMAYAMCHAL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Cherupuzha [6816]	VANIYAMKUNNE	129.0	3.0	33.0	93.0	72.1	High
KANNUR	Cherupuzha [6816]	VAYALAI	81.0	3.0	52.5	25.5	31.5	Medium
KANNUR	Cherupuzha [6816]	VAZHAKKUNDAM	81.0	0.0	28.0	53.0	65.4	High
KANNUR	Cherupuzha [6816]	VAZHAKUNDAM PUMP	81.0	0.0	35.0	46.0	56.8	High
KANNUR	Cherupuzha [6816]	VILAKKUVETTAM	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chokli [6671]	AMBEDKAR VAYANASHALA	129.0	0.0	19.0	110.0	85.3	Very High
KANNUR	Chokli [6671]	ANDIPEEDIKA PUTHUKKUDI MUKKU	81.0	3.0	64.0	14.0	17.3	Low
KANNUR	Chokli [6671]	ANDIPEEDIKA_PNR	81.0	10.0	63.0	8.0	9.9	Very Low
KANNUR	Chokli [6671]	AZHEEKKAL	129.0	5.0	100.6	23.4	18.1	Low
KANNUR	Chokli [6671]	BOFFOCE MUKKU	129.0	0.0	36.0	93.0	72.1	High
KANNUR	Chokli [6671]	CHALIL AMBALAM	129.0	5.0	71.7	52.3	40.5	Medium
KANNUR	Chokli [6671]	CHAMAYIL MUKKU	129.0	0.0	34.0	95.0	73.6	High
KANNUR	Chokli [6671]	CHATHOTH MUKKU	129.0	0.0	53.3	75.7	58.7	High
KANNUR	Chokli [6671]	CHECK POST MAHE	129.0	0.0	22.0	107.0	82.9	Very High
KANNUR	Chokli [6671]	CHERIYATHUMUKKU	81.0	17.0	63.5	0.5	0.6	Very Low
KANNUR	Chokli [6671]	CHERUVYALMUKKU	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chokli [6671]	CHOKLY HOSPITAL	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chokli [6671]	CHOKLY TAXI STAND	129.0	0.0	18.0	111.0	86.0	Very High
KANNUR	Chokli [6671]	CHOKLY TOWN	129.0	0.0	8.0	121.0	93.8	Very High
KANNUR	Chokli [6671]	CHOOAL COMPANY	129.0	0.0	50.2	78.8	61.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chokli [6671]	CP ROAD	129.0	5.0	38.8	85.2	66.0	High
KANNUR	Chokli [6671]	DEVASSY MOTTA	81.0	0.0	37.0	44.0	54.3	High
KANNUR	Chokli [6671]	EACHI	129.0	0.0	21.0	108.0	83.7	Very High
KANNUR	Chokli [6671]	EAST PANNIANNUR	81.0	0.0	23.2	57.8	71.4	High
KANNUR	Chokli [6671]	EDANNUR	129.0	10.0	38.0	81.0	62.8	High
KANNUR	Chokli [6671]	GOV COLLEGE	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chokli [6671]	GRAMA KODATHI	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Chokli [6671]	ILLATH PEEDIKA	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Chokli [6671]	JAMEELA	81.0	8.0	45.0	28.0	34.6	Medium
KANNUR	Chokli [6671]	KADUKKABAZAR	81.0	5.0	35.0	41.0	50.6	High
KANNUR	Chokli [6671]	KALARIMUKK	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chokli [6671]	KALLAYI	202.0	0.0	54.0	148.0	73.3	High
KANNUR	Chokli [6671]	KALLILMOTTA	81.0	0.0	45.1	35.9	44.3	Medium
KANNUR	Chokli [6671]	KALLUNKOOL	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Chokli [6671]	KANJIRAM	129.0	0.0	48.0	81.0	62.8	High
KANNUR	Chokli [6671]	KAVIYUR	129.0	0.0	67.7	61.3	47.5	Medium
KANNUR	Chokli [6671]	KIDARAMKUNNU	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Chokli [6671]	KIDARAMKUNNU KWA	81.0	5.0	18.0	58.0	71.6	High
KANNUR	Chokli [6671]	KM SUPERMARKET	129.0	0.0	69.3	59.6	46.2	Medium
KANNUR	Chokli [6671]	KOMATHUKANDY	81.0	0.0	26.5	54.5	67.3	High
KANNUR	Chokli [6671]	KOOLOTH AMBALAM	81.0	0.0	46.0	35.0	43.2	Medium
KANNUR	Chokli [6671]	KOORUMBA KAVU	81.0	10.0	32.3	38.7	47.8	Medium
KANNUR	Chokli [6671]	KUNNUMMAL	129.0	0.0	50.7	78.3	60.7	High
KANNUR	Chokli [6671]	KUTTIYIL PEEDIKA	129.0	8.0	32.2	88.8	68.8	High
KANNUR	Chokli [6671]	KUZHICAL PEEDIKA	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Chokli [6671]	MAHADEVA TEMPLE	51.0	0.0	3.0	48.0	94.1	Very High
KANNUR	Chokli [6671]	MAMMIMUKKU	81.0	0.0	80.1	0.9	1.1	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chokli [6671]	MANGAD VAYAL	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Chokli [6671]	MANGOTTU KAVU	81.0	12.0	42.0	27.0	33.3	Medium
KANNUR	Chokli [6671]	MARANKANDY	129.0	5.0	39.4	84.6	65.6	High
KANNUR	Chokli [6671]	MATHIPARAMBA	81.0	0.0	33.0	48.0	59.3	High
KANNUR	Chokli [6671]	MATHIYAMBATH	129.0	0.0	10.0	119.0	92.2	Very High
KANNUR	Chokli [6671]	MAYFIELD	202.0	0.0	10.0	192.0	95.0	Very High
KANNUR	Chokli [6671]	MENAPRAM	81.0	3.0	11.0	67.0	82.7	Very High
KANNUR	Chokli [6671]	MINNATH PEEDIKA	129.0	5.0	82.8	41.1	31.9	Medium
KANNUR	Chokli [6671]	MONTHAL	81.0	3.0	23.0	55.0	67.9	High
KANNUR	Chokli [6671]	MOYARAM	81.0	0.0	32.0	49.0	60.5	High
KANNUR	Chokli [6671]	MUCHILOTTUKAVU	81.0	7.0	14.3	59.7	73.7	High
KANNUR	Chokli [6671]	MUNDAYOTT SCHOOL	81.0	0.0	29.2	51.8	64.0	High
KANNUR	Chokli [6671]	NARAYANAN PARAMBA	81.0	3.0	5.0	73.0	90.1	Very High
KANNUR	Chokli [6671]	NELLIKKA BAZAR	81.0	10.0	29.0	42.0	51.9	High
KANNUR	Chokli [6671]	NKM MALL-PVT TFR	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Chokli [6671]	OLAVILAM POST OFFICE	81.0	0.0	36.0	45.0	55.6	High
KANNUR	Chokli [6671]	OLAVILAM TOWER	81.0	15.0	18.0	48.0	59.3	High
KANNUR	Chokli [6671]	ONTHATHUM KADU	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chokli [6671]	PALLIKKUNI	81.0	0.0	19.0	62.0	76.5	Very High
KANNUR	Chokli [6671]	PALLIPPRAM	129.0	15.0	50.2	63.8	49.4	Medium
KANNUR	Chokli [6671]	PANACHIYULLA	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chokli [6671]	PANNIANNUR TOWN	81.0	0.0	19.2	61.8	76.3	Very High
KANNUR	Chokli [6671]	PANNIYANNUR MADAPPURA	81.0	0.0	13.0	68.0	84.0	Very High
KANNUR	Chokli [6671]	PARIMADAM	129.0	0.0	73.0	56.0	43.4	Medium
KANNUR	Chokli [6671]	PATHIKKAL	129.0	0.0	4.6	124.4	96.4	Very High
KANNUR	Chokli [6671]	PERINGADI	202.0	0.0	127.3	74.7	37.0	Medium
KANNUR	Chokli [6671]	PERIYANDY SCHOOL	129.0	10.0	89.2	29.8	23.1	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chokli [6671]	PERUMUNDERI	81.0	0.0	24.3	56.7	70.1	High
KANNUR	Chokli [6671]	PETTIPALAM -SERVICE STATION	129.0	15.0	69.0	45.0	34.9	Medium
KANNUR	Chokli [6671]	PETTIPALM	81.0	0.0	44.5	36.5	45.0	Medium
KANNUR	Chokli [6671]	PHED MAHI	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chokli [6671]	PUNATHILMUKKU	81.0	0.0	12.0	69.0	85.2	Very High
KANNUR	Chokli [6671]	PUTHANPALLI	81.0	16.0	64.8	0.2	0.2	Very Low
KANNUR	Chokli [6671]	PUTHIYA ROAD	81.0	0.0	58.3	22.7	28.0	Medium
KANNUR	Chokli [6671]	RC PEEDIKA	81.0	4.0	14.0	63.0	77.8	Very High
KANNUR	Chokli [6671]	SAMSKARIKANILAYAM	129.0	13.0	72.8	43.2	33.5	Medium
KANNUR	Chokli [6671]	SANTHI CLINIC	81.0	8.0	55.8	17.2	21.3	Low
KANNUR	Chokli [6671]	SETTUMUKKU	81.0	5.0	50.7	25.3	31.2	Medium
KANNUR	Chokli [6671]	SKILLTECH	81.0	0.0	40.0	41.0	50.6	High
KANNUR	Chokli [6671]	SOUTH PANNIANNUR	129.0	14.0	33.7	81.3	63.1	High
KANNUR	Chokli [6671]	THAHA	81.0	13.0	46.5	21.5	26.5	Medium
KANNUR	Chokli [6671]	THRIKANAPURAM TEMPLE	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Chokli [6671]	VALAT AMBALAM	81.0	0.0	25.9	55.1	68.0	High
KANNUR	Chokli [6671]	VAYALIL PEEDIKA	129.0	3.0	20.0	106.0	82.2	Very High
KANNUR	Chokli [6671]	VELAYUTHANMOTTA	81.0	5.0	30.4	45.6	56.2	High
KANNUR	Chokli [6671]	VELLACHERI PALLY	129.0	11.0	37.0	81.0	62.8	High
KANNUR	Chokli [6671]	VIDHYABHAVAN	81.0	0.0	14.8	66.2	81.8	Very High
KANNUR	Chokli [6671]	ZUM ZUM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	A1 COLA	129.0	0.0	58.0	71.0	55.1	High
KANNUR	Chovva [6657]	AG TOWER	162.0	0.0	10.0	152.0	93.8	Very High
KANNUR	Chovva [6657]	AIRTEL MUNDAYAD	51.0	5.0	48.3	0.0	0.0	Very Low
KANNUR	Chovva [6657]	AIRTEL-THOTTADA	81.0	5.0	18.0	58.0	71.6	High
KANNUR	Chovva [6657]	AL-RAHA	81.0	0.0	11.2	69.8	86.1	Very High
KANNUR	Chovva [6657]	ALINKEEL	81.0	17.9	43.0	20.1	24.9	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chovva [6657]	AMBADI	81.0	0.0	29.1	51.9	64.0	High
KANNUR	Chovva [6657]	AMBALAKKULAM	81.0	0.0	22.3	58.7	72.5	High
KANNUR	Chovva [6657]	AMMANKUNNU	81.0	5.0	47.0	29.0	35.8	Medium
KANNUR	Chovva [6657]	AMMUPPARAMBA	81.0	0.0	6.4	74.6	92.1	Very High
KANNUR	Chovva [6657]	APCO	81.0	14.1	31.4	35.5	43.8	Medium
KANNUR	Chovva [6657]	APE	81.0	0.0	36.8	44.2	54.5	High
KANNUR	Chovva [6657]	ASSET CHAMBER	405.0	0.0	0.0	405.0	100.0	Very High
KANNUR	Chovva [6657]	ASSET SENATE	405.0	0.0	40.0	365.0	90.1	Very High
KANNUR	Chovva [6657]	ATHIRAKAM	202.0	0.0	82.4	119.6	59.2	High
KANNUR	Chovva [6657]	ATHIRAKAM HOMEIO	81.0	19.0	60.5	1.5	1.9	Very Low
KANNUR	Chovva [6657]	ATHIRAKAM UP SCHOOL	81.0	0.0	41.2	39.8	49.1	Medium
KANNUR	Chovva [6657]	ATTADAPPA	81.0	0.0	32.3	48.7	60.1	High
KANNUR	Chovva [6657]	BATHAMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	BELMARE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	BHAGAVATHI MUKKU	81.0	5.0	23.0	53.0	65.4	High
KANNUR	Chovva [6657]	BHAGAVATHI VILLA	202.0	0.0	15.0	187.0	92.6	Very High
KANNUR	Chovva [6657]	BHARGHAVA MANDIRAM	81.0	0.0	40.2	40.8	50.3	High
KANNUR	Chovva [6657]	BHUVANESWARI TEMPLE	81.0	20.0	37.0	24.0	29.6	Medium
KANNUR	Chovva [6657]	BLOCK	202.0	3.0	27.0	172.0	85.1	Very High
KANNUR	Chovva [6657]	C P STORE	81.0	12.0	48.3	20.7	25.6	Medium
KANNUR	Chovva [6657]	CANAL	81.0	3.0	77.2	0.8	1.0	Very Low
KANNUR	Chovva [6657]	CANNANORE HANDLOOMS	81.0	3.0	24.3	53.7	66.3	High
KANNUR	Chovva [6657]	CHALA-12 KANDY	81.0	0.0	39.7	41.3	51.0	High
KANNUR	Chovva [6657]	CHANGATTU KAVU	129.0	3.0	55.0	71.0	55.0	High
KANNUR	Chovva [6657]	CHARGE MOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	CHOVVA COMPLEX	162.0	0.0	0.0	162.0	100.0	Very High
KANNUR	Chovva [6657]	CITADEL TOWER	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chovva [6657]	CLASSIC BUILDING	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chovva [6657]	COLONY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	CRYSTAL TOWER	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Chovva [6657]	D-TECH	129.0	0.0	21.0	108.0	83.7	Very High
KANNUR	Chovva [6657]	DAFFODILS VILLA KAPPAD	129.0	0.0	17.9	111.1	86.1	Very High
KANNUR	Chovva [6657]	DEVAKI TIMBERS	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chovva [6657]	DINESH CURRY POWDER	129.0	0.0	47.2	81.8	63.4	High
KANNUR	Chovva [6657]	DOCTOR ROAD	81.0	0.0	14.0	67.0	82.7	Very High
KANNUR	Chovva [6657]	DR SUMAYYA	81.0	11.0	33.0	37.0	45.7	Medium
KANNUR	Chovva [6657]	DREAM VILLA	202.0	20.0	10.0	172.0	85.1	Very High
KANNUR	Chovva [6657]	DURGA	81.0	11.0	39.1	30.9	38.1	Medium
KANNUR	Chovva [6657]	EDACHOVVA	202.0	5.0	146.2	50.8	25.2	Medium
KANNUR	Chovva [6657]	EDACHOVVA UP SCHOOL	81.0	0.0	80.5	0.5	0.6	Very Low
KANNUR	Chovva [6657]	ELAYAVOOR BANK	81.0	0.0	24.7	56.3	69.5	High
KANNUR	Chovva [6657]	ELAYAVOOR COLONY	129.0	16.0	31.3	81.7	63.3	High
KANNUR	Chovva [6657]	ELAYAVOOR OFFICE	81.0	5.0	46.0	30.0	37.0	Medium
KANNUR	Chovva [6657]	ELAYAVOOR PANCHAYATH	202.0	0.0	27.6	174.4	86.4	Very High
KANNUR	Chovva [6657]	ELAYAVOOR TEMPLE	81.0	11.0	68.0	2.0	2.5	Very Low
KANNUR	Chovva [6657]	ELAYAVOOR VAYAL	129.0	4.6	43.3	81.1	62.9	High
KANNUR	Chovva [6657]	EMIRATES TOWER	324.0	0.0	0.0	324.0	100.0	Very High
KANNUR	Chovva [6657]	ESI	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chovva [6657]	EZHARA	81.0	10.0	61.4	9.6	11.8	Low
KANNUR	Chovva [6657]	FASHION TECH	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	FLOWERS TV	81.0	0.0	51.0	30.0	37.1	Medium
KANNUR	Chovva [6657]	FORD	81.0	5.0	49.0	27.0	33.3	Medium
KANNUR	Chovva [6657]	G SONS-II	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	GOLDEN ENCLAVE	81.0	0.0	80.4	0.6	0.8	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chovva [6657]	GOLDEN ROCK ROAD	81.0	0.0	23.5	57.5	71.0	High
KANNUR	Chovva [6657]	GSONS1	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	HOLY PROPES	129.0	0.0	66.5	62.5	48.4	Medium
KANNUR	Chovva [6657]	I T-I	81.0	3.0	56.0	22.0	27.1	Medium
KANNUR	Chovva [6657]	J T S	129.0	4.0	60.0	65.0	50.4	High
KANNUR	Chovva [6657]	JAWAN ROAD	81.0	0.0	18.0	63.0	77.8	Very High
KANNUR	Chovva [6657]	JOURNALIST COLONY	81.0	9.0	71.6	0.4	0.5	Very Low
KANNUR	Chovva [6657]	JYOTHI PEEDIKA	81.0	8.0	36.3	36.7	45.3	Medium
KANNUR	Chovva [6657]	K P TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chovva [6657]	KAIRALI FIBRE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	KALYAN CHIRAKU THAZHE	81.0	6.1	46.9	28.1	34.6	Medium
KANNUR	Chovva [6657]	KANHANGAD PALLY	129.0	6.0	49.0	74.0	57.4	High
KANNUR	Chovva [6657]	KANHIRA	81.0	5.0	45.0	31.0	38.3	Medium
KANNUR	Chovva [6657]	KAPPAD	129.0	16.0	56.0	57.0	44.2	Medium
KANNUR	Chovva [6657]	KAPPAD HEALTH CENTRE	81.0	3.0	26.6	51.4	63.4	High
KANNUR	Chovva [6657]	KITHAPURAM	81.0	0.0	21.5	59.5	73.4	High
KANNUR	Chovva [6657]	KIZHAKEKARA THANKEKKUNNU	129.0	5.0	27.5	96.5	74.8	High
KANNUR	Chovva [6657]	KIZHUNNAPPALI	81.0	10.0	30.0	41.0	50.6	High
KANNUR	Chovva [6657]	KIZHUNNAPPARA	129.0	6.0	51.0	72.0	55.8	High
KANNUR	Chovva [6657]	KIZHUTHALLY	81.0	3.0	36.0	42.0	51.9	High
KANNUR	Chovva [6657]	KUTTIKKAKAM	129.0	3.0	57.4	68.6	53.2	High
KANNUR	Chovva [6657]	KVR MOTOR CAR PVT LTD-JEEP	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chovva [6657]	MANJAVALAPPU	81.0	0.0	12.0	69.0	85.2	Very High
KANNUR	Chovva [6657]	MANTHAPPANKAVU	81.0	3.0	15.3	62.7	77.4	Very High
KANNUR	Chovva [6657]	MANUMATIC NISSAN APCO	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chovva [6657]	MATHRUBHUMI	81.0	5.0	3.0	73.0	90.1	Very High
KANNUR	Chovva [6657]	MAYYALAPEEDIKA	81.0	0.0	39.7	41.3	51.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chovva [6657]	MELE CHOVVA	202.0	0.0	76.2	125.8	62.3	High
KANNUR	Chovva [6657]	MG HECTOR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	MUNAMBU	81.0	5.0	29.5	46.5	57.4	High
KANNUR	Chovva [6657]	MUNDAYAD	129.0	13.0	67.8	48.2	37.3	Medium
KANNUR	Chovva [6657]	MUNDERI PEEDIKA	81.0	5.0	49.0	27.0	33.3	Medium
KANNUR	Chovva [6657]	MUTHAPPAN KAVU	81.0	0.0	35.0	46.0	56.8	High
KANNUR	Chovva [6657]	N S PETROMART	81.0	5.0	42.3	33.7	41.6	Medium
KANNUR	Chovva [6657]	NADAL TODDY SHOP	81.0	5.0	6.0	70.0	86.4	Very High
KANNUR	Chovva [6657]	NANDILATH	202.0	20.0	82.7	99.3	49.2	Medium
KANNUR	Chovva [6657]	NARANATH PALAM	81.0	0.0	26.4	54.6	67.4	High
KANNUR	Chovva [6657]	NISHAROAD	81.0	8.0	24.0	49.0	60.5	High
KANNUR	Chovva [6657]	NOBLE DECOR	81.0	0.0	80.9	0.1	0.1	Very Low
KANNUR	Chovva [6657]	OFFICE	202.0	6.0	76.3	119.7	59.2	High
KANNUR	Chovva [6657]	OVUPALAM	81.0	0.0	22.3	58.7	72.5	High
KANNUR	Chovva [6657]	P J TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chovva [6657]	PANNIKKUNNU	81.0	0.0	78.3	2.7	3.3	Very Low
KANNUR	Chovva [6657]	PARK LANE	129.0	0.0	15.0	114.0	88.4	Very High
KANNUR	Chovva [6657]	PATHIRAPARAMBU	81.0	3.0	78.0	0.0	0.0	Very Low
KANNUR	Chovva [6657]	PERFECT	81.0	13.0	24.0	44.0	54.3	High
KANNUR	Chovva [6657]	PERINGOTH TEMPLE	81.0	17.3	56.7	7.0	8.6	Very Low
KANNUR	Chovva [6657]	PLASTIC	81.0	6.0	34.0	41.0	50.6	High
KANNUR	Chovva [6657]	POPULAR	81.0	5.0	74.8	1.2	1.5	Very Low
KANNUR	Chovva [6657]	PRANAM BUILDING	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Chovva [6657]	PULUKKOPALAM	81.0	9.7	71.3	0.0	0.0	Very Low
KANNUR	Chovva [6657]	PUTHIYAKOTTAM	129.0	8.0	42.0	79.0	61.2	High
KANNUR	Chovva [6657]	PVS FLAT	255.0	0.0	0.0	255.0	100.0	Very High
KANNUR	Chovva [6657]	R K BAKERY KIZHUNNA	81.0	6.0	19.2	55.8	68.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chovva [6657]	RAFA RESIDE	162.0	0.0	3.0	159.0	98.1	Very High
KANNUR	Chovva [6657]	RAJANPEEDIKA	129.0	5.0	33.0	91.0	70.5	High
KANNUR	Chovva [6657]	RELIANCE THOTTADA	81.0	21.0	59.7	0.3	0.3	Very Low
KANNUR	Chovva [6657]	RENOLT THOTTADA	81.0	0.0	69.4	11.6	14.3	Low
KANNUR	Chovva [6657]	S N COLLEGE	81.0	8.0	51.0	22.0	27.2	Medium
KANNUR	Chovva [6657]	SALAFI PALLI	129.0	10.0	50.3	68.7	53.3	High
KANNUR	Chovva [6657]	SARAVANA MILL	81.0	16.0	53.9	11.1	13.7	Low
KANNUR	Chovva [6657]	SEA SCAPE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	SHARARA AREENA	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chovva [6657]	SHELTERS CLUB	81.0	5.0	36.0	40.0	49.4	Medium
KANNUR	Chovva [6657]	SIGMA ESTORIA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	SKY LINE WINGS	810.0	0.0	0.0	810.0	100.0	Very High
KANNUR	Chovva [6657]	SMART HOME	81.0	8.2	27.4	45.4	56.1	High
KANNUR	Chovva [6657]	SN CAMPUS	129.0	5.0	30.4	93.7	72.6	High
KANNUR	Chovva [6657]	SOORYA NAGAR	81.0	11.0	69.4	0.6	0.7	Very Low
KANNUR	Chovva [6657]	SOUTH RAIL WAY STATION	81.0	15.0	0.0	66.0	81.5	Very High
KANNUR	Chovva [6657]	SPRING FIELD	129.0	5.0	39.0	85.0	65.9	High
KANNUR	Chovva [6657]	SREENIVAS	81.0	3.0	27.9	50.1	61.8	High
KANNUR	Chovva [6657]	ST FRANCIS	81.0	0.0	10.3	70.7	87.3	Very High
KANNUR	Chovva [6657]	SURAN PEEDIKA	81.0	0.0	52.0	29.0	35.8	Medium
KANNUR	Chovva [6657]	SUZUKI	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Chovva [6657]	SWARAJ	81.0	5.0	20.0	56.0	69.1	High
KANNUR	Chovva [6657]	TATA THOTTADA	81.0	0.0	38.0	43.0	53.1	High
KANNUR	Chovva [6657]	THATTUPARAMBU	81.0	21.0	17.0	43.0	53.1	High
KANNUR	Chovva [6657]	THAZHE CHOVVA	129.0	0.0	18.3	110.7	85.8	Very High
KANNUR	Chovva [6657]	THAZHE MANDAPAM	81.0	6.0	11.3	63.7	78.6	Very High
KANNUR	Chovva [6657]	THOTTADA	129.0	0.0	33.0	96.0	74.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Chovva [6657]	UNIVERSAL CLUB	81.0	3.0	51.0	27.0	33.3	Medium
KANNUR	Chovva [6657]	URUMBACHANKOTTOM	129.0	0.0	40.5	88.5	68.6	High
KANNUR	Chovva [6657]	VALLEY VIEW APARTMENTS	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Chovva [6657]	VANI VILASAM	81.0	0.0	40.4	40.6	50.1	High
KANNUR	Chovva [6657]	VANITHA BANK	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Chovva [6657]	VANITHA ITI	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Chovva [6657]	VATTAPARAMBU	81.0	5.0	11.0	65.0	80.2	Very High
KANNUR	Chovva [6657]	VIJAYA SQUARE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	VIJAYA TIMBERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Chovva [6657]	VIVEK COMPLEX	129.0	0.0	45.8	83.2	64.5	High
KANNUR	Chovva [6657]	WATER AUTHORITY THAZHE CHOVVA	129.0	0.0	5.0	124.0	96.1	Very High
KANNUR	Chovva [6657]	WATER TANK	81.0	0.0	19.0	62.0	76.5	Very High
KANNUR	Chovva [6657]	WOLKER HERO	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Dharmadom [6677]	AKG ROAD	129.0	8.0	18.9	102.1	79.1	Very High
KANNUR	Dharmadom [6677]	ANDALOOR BALAVADI	81.0	0.0	14.0	67.0	82.7	Very High
KANNUR	Dharmadom [6677]	ANDALOOR KAVU	129.0	17.4	63.0	48.6	37.7	Medium
KANNUR	Dharmadom [6677]	APA COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	ATTARAKUNNU	81.0	8.0	25.5	47.5	58.7	High
KANNUR	Dharmadom [6677]	AYYAPPAN KOTTA	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Dharmadom [6677]	CHAKIRI	81.0	0.0	15.8	65.2	80.5	Very High
KANNUR	Dharmadom [6677]	CHATHODAM	129.0	0.0	3.0	126.0	97.7	Very High
KANNUR	Dharmadom [6677]	CHEEROTH PALLI	81.0	0.0	38.2	42.8	52.8	High
KANNUR	Dharmadom [6677]	CHILDRENS PARK	81.0	5.0	21.0	55.0	67.9	High
KANNUR	Dharmadom [6677]	CHIRAKKUNI	129.0	17.2	106.0	5.8	4.5	Very Low
KANNUR	Dharmadom [6677]	CHIRAKKUNI AIRTEL	81.0	0.0	12.7	68.3	84.3	Very High
KANNUR	Dharmadom [6677]	COLLEGE	129.0	8.0	113.7	7.3	5.7	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmadom [6677]	CORNATION	81.0	0.0	33.0	48.0	59.3	High
KANNUR	Dharmadom [6677]	D M P H E D	129.0	8.0	57.3	63.7	49.4	Medium
KANNUR	Dharmadom [6677]	DEEPTHI	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Dharmadom [6677]	DIET	81.0	0.0	25.0	56.0	69.1	High
KANNUR	Dharmadom [6677]	DISPANSARY	81.0	13.5	11.1	56.4	69.6	High
KANNUR	Dharmadom [6677]	EAST PALAYAD	129.0	0.0	42.8	86.2	66.8	High
KANNUR	Dharmadom [6677]	EDAKKAD	81.0	3.0	22.3	55.7	68.8	High
KANNUR	Dharmadom [6677]	EDAKKAD EXCHANGE	129.0	0.0	36.0	93.0	72.1	High
KANNUR	Dharmadom [6677]	EDAKKAD RAILWAY	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Dharmadom [6677]	ELAVANA	129.0	0.0	10.3	118.7	92.0	Very High
KANNUR	Dharmadom [6677]	ELIPRAM	129.0	8.0	30.2	90.8	70.4	High
KANNUR	Dharmadom [6677]	ESTATE 4 LEO	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Dharmadom [6677]	ESTATE 5	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	ESTATE IX LAKSHMI	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmadom [6677]	ESTATE VI THANKAMANI	129.0	0.0	13.1	115.9	89.9	Very High
KANNUR	Dharmadom [6677]	ESTATE VII MOSONS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	ESTATE VIII	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	ESTATE XI INDULEKHA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	ESTATE-1 SWAHA	202.0	5.0	84.4	112.6	55.7	High
KANNUR	Dharmadom [6677]	ESTATE-2	405.0	0.0	10.8	394.2	97.3	Very High
KANNUR	Dharmadom [6677]	ESTATE-3 BASE	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Dharmadom [6677]	FLY OVER	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmadom [6677]	GANGAN PEEDIKA	81.0	0.0	35.5	45.5	56.2	High
KANNUR	Dharmadom [6677]	GAS GODOWN	129.0	0.0	3.3	125.7	97.4	Very High
KANNUR	Dharmadom [6677]	GUMTI MUKKU	81.0	3.0	14.4	63.6	78.5	Very High
KANNUR	Dharmadom [6677]	HOMEO DISPENSARY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	HUSSAIN MUKU	129.0	0.0	51.3	77.7	60.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmadom [6677]	ICE FECTORY	81.0	0.0	27.0	54.0	66.7	High
KANNUR	Dharmadom [6677]	JAWAN ROAD	81.0	0.0	26.0	55.0	67.9	High
KANNUR	Dharmadom [6677]	JAYA QUATERS	81.0	0.0	46.9	34.1	42.1	Medium
KANNUR	Dharmadom [6677]	JUDGE BUNGALOW	81.0	10.0	9.4	61.6	76.0	Very High
KANNUR	Dharmadom [6677]	KADAVU	129.0	3.0	3.0	123.0	95.3	Very High
KANNUR	Dharmadom [6677]	KAIRALI	129.0	0.0	45.0	84.0	65.1	High
KANNUR	Dharmadom [6677]	KAKKATTI	81.0	8.0	40.3	32.7	40.4	Medium
KANNUR	Dharmadom [6677]	KALAMANDIRAM	129.0	3.4	79.0	46.6	36.1	Medium
KANNUR	Dharmadom [6677]	KANNAN VAYAL	81.0	6.0	33.7	41.3	51.0	High
KANNUR	Dharmadom [6677]	KETTINAKAM PALLI	81.0	0.0	26.0	55.0	67.9	High
KANNUR	Dharmadom [6677]	KURARA	81.0	0.0	28.4	52.6	64.9	High
KANNUR	Dharmadom [6677]	KURUKSHETRA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Dharmadom [6677]	KWA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	LEGAL STUDY CENTRE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	MADAM NH	129.0	3.0	34.5	91.5	70.9	High
KANNUR	Dharmadom [6677]	MADAM P H E D	81.0	0.0	35.0	46.0	56.8	High
KANNUR	Dharmadom [6677]	MADAM TOWER	81.0	0.0	7.8	73.2	90.4	Very High
KANNUR	Dharmadom [6677]	MALAKUTHAZHA	81.0	0.0	18.2	62.8	77.5	Very High
KANNUR	Dharmadom [6677]	MANIYATH SCHOOL	81.0	0.0	28.0	53.0	65.4	High
KANNUR	Dharmadom [6677]	MARIAMMAN COVIL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	MEETHALEPEEDIKA	81.0	11.0	53.2	16.8	20.7	Low
KANNUR	Dharmadom [6677]	MELUR	129.0	3.0	32.0	94.0	72.9	High
KANNUR	Dharmadom [6677]	MELUR BOAT JETTI	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Dharmadom [6677]	MIZNAS PALACE	129.0	0.0	30.0	99.0	76.7	Very High
KANNUR	Dharmadom [6677]	MOHANAN PEEDIKA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	MOIDU BRIDGE	129.0	25.0	34.0	70.0	54.3	High
KANNUR	Dharmadom [6677]	MOORKOTH	81.0	0.0	35.6	45.4	56.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmadam [6677]	MP COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadam [6677]	MULLAPRAM PALLI	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Dharmadam [6677]	MUTHALAKKALLLU	81.0	5.0	30.0	46.0	56.8	High
KANNUR	Dharmadam [6677]	MUZHAPPILANGAD DTPC	162.0	0.0	0.0	162.0	100.0	Very High
KANNUR	Dharmadam [6677]	MUZHAPPILANGAD EXCHANGE	129.0	3.0	8.0	118.0	91.5	Very High
KANNUR	Dharmadam [6677]	MUZHAPPILANGAD GATE	129.0	14.0	6.0	109.0	84.5	Very High
KANNUR	Dharmadam [6677]	NATIONAL CIRCUS ROAD	129.0	0.0	28.3	100.7	78.1	Very High
KANNUR	Dharmadam [6677]	PACHAKKARA	81.0	0.0	55.0	26.0	32.1	Medium
KANNUR	Dharmadam [6677]	PALAYAD HIGHSCHOOL	81.0	0.0	35.0	46.0	56.8	High
KANNUR	Dharmadam [6677]	PUTHU VAYAL	81.0	8.0	42.3	30.7	37.9	Medium
KANNUR	Dharmadam [6677]	RAJALAKSHMI	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Dharmadam [6677]	RAJKAMAL	81.0	0.0	11.8	69.2	85.4	Very High
KANNUR	Dharmadam [6677]	REHMANIYA MASJIDH	129.0	0.0	30.7	98.3	76.2	Very High
KANNUR	Dharmadam [6677]	S K KAVU	129.0	9.0	111.8	8.2	6.3	Very Low
KANNUR	Dharmadam [6677]	SANDHYA BEEDI	81.0	0.0	8.5	72.5	89.5	Very High
KANNUR	Dharmadam [6677]	SATHRAM	129.0	11.8	54.0	63.2	49.0	Medium
KANNUR	Dharmadam [6677]	SENEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadam [6677]	SHALIMAR	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadam [6677]	SHAPPIL PEEDIKA	81.0	0.0	46.0	35.0	43.2	Medium
KANNUR	Dharmadam [6677]	SHILPA	81.0	0.0	39.0	42.0	51.9	High
KANNUR	Dharmadam [6677]	SMASANAM	129.0	3.0	22.0	104.0	80.6	Very High
KANNUR	Dharmadam [6677]	SNEHATHEERAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadam [6677]	SREEROSH	202.0	5.3	39.5	157.2	77.8	Very High
KANNUR	Dharmadam [6677]	STATION ROAD	129.0	0.0	47.5	81.5	63.2	High
KANNUR	Dharmadam [6677]	SURYA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadam [6677]	SWAMIKUNNU	81.0	15.8	34.0	31.2	38.5	Medium
KANNUR	Dharmadam [6677]	TATA	81.0	8.0	45.4	27.6	34.1	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmadom [6677]	TECHNOPLAST	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	TEST GROUND	81.0	3.0	33.0	45.0	55.6	High
KANNUR	Dharmadom [6677]	THABLEEQ MOSQUE	81.0	3.0	19.0	59.0	72.8	High
KANNUR	Dharmadom [6677]	THAHZEPEEDIKA	81.0	10.0	36.5	34.5	42.6	Medium
KANNUR	Dharmadom [6677]	THARAVAD	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Dharmadom [6677]	THATTARIMUKKU	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Dharmadom [6677]	THAZHE KAVU	202.0	15.0	77.6	109.4	54.1	High
KANNUR	Dharmadom [6677]	THERIMMAL	81.0	5.0	36.0	40.0	49.4	Medium
KANNUR	Dharmadom [6677]	U T C	202.0	0.0	46.1	155.8	77.2	Very High
KANNUR	Dharmadom [6677]	USK TRANSFORMER	81.0	0.0	33.0	48.0	59.2	High
KANNUR	Dharmadom [6677]	USMAN ENGINEER	81.0	0.0	11.0	70.0	86.4	Very High
KANNUR	Dharmadom [6677]	UTC-II	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmadom [6677]	VELLOZHUKKU	81.0	3.0	31.3	46.7	57.7	High
KANNUR	Dharmadom [6677]	WEST COST	129.0	5.0	41.3	82.7	64.1	High
KANNUR	Dharmadom [6677]	WEST EDAKKAD	202.0	11.4	84.6	106.0	52.5	High
KANNUR	Dharmadom [6677]	WIMCO	129.0	3.0	59.9	66.1	51.2	High
KANNUR	Dharmadom [6677]	YOUTH	81.0	0.0	34.0	47.0	58.0	High
KANNUR	Dharmassala [6646]	AL JASEERA	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Dharmassala [6646]	ALINKEEL KULAM	81.0	3.0	44.0	34.0	42.0	Medium
KANNUR	Dharmassala [6646]	ALIYAS DISPOSIBLE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	ALSIRAJ	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	AMAR WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	ANCHAMPEEDIKA	81.0	0.0	55.7	25.3	31.2	Medium
KANNUR	Dharmassala [6646]	ANDOOR KAVU	81.0	0.0	22.0	59.0	72.8	High
KANNUR	Dharmassala [6646]	ANJAL INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	ANJALI HOTEL-DAS RESIDENCY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	APPAPEEDIKA	81.0	5.0	35.3	40.7	50.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmassala [6646]	APPU BOARD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	ARAYALA	81.0	3.0	63.0	15.0	18.5	Low
KANNUR	Dharmassala [6646]	ARAYALA ANGANAVADI	81.0	10.1	29.0	41.9	51.7	High
KANNUR	Dharmassala [6646]	ARUNA FLEXO PACK	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	ARUNA WOOD	129.0	0.0	28.3	100.7	78.1	Very High
KANNUR	Dharmassala [6646]	ARUNODAYA PACKAGING	81.0	50.0	0.0	31.0	38.3	Medium
KANNUR	Dharmassala [6646]	ASHA CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	AYISHA VINEERS NO-II	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	AYISHA WINNER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	AYURVEDA LADIES HOSTEL	81.0	4.0	10.0	67.0	82.7	Very High
KANNUR	Dharmassala [6646]	AYYANKOVIL	81.0	3.0	55.2	22.8	28.1	Medium
KANNUR	Dharmassala [6646]	B ED CENTRE	81.0	0.0	12.0	69.0	85.2	Very High
KANNUR	Dharmassala [6646]	BAKKALAM	129.0	8.1	113.7	7.3	5.6	Very Low
KANNUR	Dharmassala [6646]	BAKKALAM MILK SOCIETY	81.0	0.0	29.9	51.1	63.1	High
KANNUR	Dharmassala [6646]	BAKKALM TOWN	81.0	0.0	24.0	57.0	70.4	High
KANNUR	Dharmassala [6646]	BAVUPARAMBA	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Dharmassala [6646]	BAVUPPARAMBA PHC	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	BIKKIRIYAN PARAMBA	81.0	0.0	32.0	49.0	60.5	High
KANNUR	Dharmassala [6646]	BLUE WAVES	81.0	0.0	55.6	25.4	31.4	Medium
KANNUR	Dharmassala [6646]	BSNL TELE EXCHANGE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	C K KUNNU	81.0	0.0	23.0	58.0	71.6	High
KANNUR	Dharmassala [6646]	CANNANORE CERAMIC	129.0	0.0	49.0	80.0	62.0	High
KANNUR	Dharmassala [6646]	CENTRAL SCHOOL	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Dharmassala [6646]	CHITHRA GATE	81.0	10.1	39.4	31.5	38.9	Medium
KANNUR	Dharmassala [6646]	CHITHRA THEATRE	81.0	0.0	23.5	57.5	70.9	High
KANNUR	Dharmassala [6646]	CIRAMIC	81.0	3.0	64.7	13.3	16.4	Low
KANNUR	Dharmassala [6646]	COIRMATERS	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmassala [6646]	DESASNEHI	81.0	0.0	75.0	6.0	7.4	Very Low
KANNUR	Dharmassala [6646]	DETERGENT	81.0	10.2	53.3	17.5	21.6	Low
KANNUR	Dharmassala [6646]	DHARMASALA	129.0	0.0	5.0	124.0	96.1	Very High
KANNUR	Dharmassala [6646]	DUBAIKKANDY	81.0	0.0	20.7	60.3	74.4	High
KANNUR	Dharmassala [6646]	E K N WOMAN CHILD HOSPITAL	81.0	3.0	51.0	27.0	33.3	Medium
KANNUR	Dharmassala [6646]	EDAMANA TEMPLE	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Dharmassala [6646]	ELITE WOOD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	EN COLLEAGE QUARTERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	EVERGREEN	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	EVERSHINE WOOD	202.0	0.0	0.0	202.0	100.0	Very High
KANNUR	Dharmassala [6646]	EXEL AGRO FOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	FINE VENEARS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	FOUREIGHT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	GEC	81.0	0.0	23.5	57.5	71.0	High
KANNUR	Dharmassala [6646]	GEEYAR NICE FOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	GEM SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	GLORY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	GOLDEN PANAL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	GOLDEN STAR PACKGING	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	GOOD WOOD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	GREAT INDIA PARTICLE2	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	GREAT INDIA-1	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	GREEN EARTH	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	GREEN GOLD PANNEL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	HAJIMOTTA	81.0	3.0	57.2	20.8	25.6	Medium
KANNUR	Dharmassala [6646]	HANDLOOM-KSHDC	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	HARIS WOOD	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmassala [6646]	HITCH PANAL	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	ICM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	IRUMBUKALLIN THATTU	81.0	6.0	40.3	34.7	42.8	Medium
KANNUR	Dharmassala [6646]	JAMAWOO COMPANY	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	K A P-1	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	KADAMBERI	129.0	3.0	72.2	53.8	41.7	Medium
KANNUR	Dharmassala [6646]	KADAMBERI TEMPLE	81.0	3.0	22.0	56.0	69.1	High
KANNUR	Dharmassala [6646]	KADAMBERY VANITHA ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	KALLIASSERI POLY	81.0	10.1	23.0	47.9	59.1	High
KANNUR	Dharmassala [6646]	KALLOORIKKADAVU	81.0	0.0	39.0	42.0	51.9	High
KANNUR	Dharmassala [6646]	KAMBIL KADAVU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	KANAKALAYAM	81.0	0.0	47.5	33.5	41.3	Medium
KANNUR	Dharmassala [6646]	KANDANCHIRA	129.0	0.0	32.0	97.0	75.2	Very High
KANNUR	Dharmassala [6646]	KANICHERY	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Dharmassala [6646]	KANNAPILAVU	81.0	3.3	49.0	28.7	35.4	Medium
KANNUR	Dharmassala [6646]	KANOOOL	81.0	0.0	10.0	71.0	87.7	Very High
KANNUR	Dharmassala [6646]	KANOOOL TOWER	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Dharmassala [6646]	KAP2	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	KAPPOTHKAVU	81.0	5.0	53.0	23.0	28.4	Medium
KANNUR	Dharmassala [6646]	KAYEM WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	KELTRON CRYSTALS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	KELTRON RESISTORS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	KODALLUR	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Dharmassala [6646]	KOLATH VAYAL	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Dharmassala [6646]	KOLMOTTA	81.0	0.0	20.0	61.0	75.3	Very High
KANNUR	Dharmassala [6646]	KOLMOTTA PALLY	81.0	3.0	0.0	78.0	96.3	Very High
KANNUR	Dharmassala [6646]	KOLTHURUTHY	81.0	3.1	9.0	68.9	85.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmassala [6646]	KONDIKEEL	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Dharmassala [6646]	KOOLICHAL	81.0	0.0	16.0	65.0	80.2	Very High
KANNUR	Dharmassala [6646]	KORAN PEEDIKA	81.0	0.0	44.7	36.3	44.8	Medium
KANNUR	Dharmassala [6646]	KOVVAL	81.0	3.0	3.0	75.0	92.6	Very High
KANNUR	Dharmassala [6646]	KUMARS RESIDENCY	81.0	0.0	30.0	51.0	63.0	High
KANNUR	Dharmassala [6646]	KUMMANAD	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Dharmassala [6646]	KUNHARAYAL	129.0	0.0	78.9	50.1	38.9	Medium
KANNUR	Dharmassala [6646]	KUNNUMBRAM	81.0	5.1	18.4	57.5	70.9	High
KANNUR	Dharmassala [6646]	KURUKKAN KUNNU	81.0	5.0	11.0	65.0	80.2	Very High
KANNUR	Dharmassala [6646]	KUTTIPARAM	81.0	0.0	35.0	46.0	56.8	High
KANNUR	Dharmassala [6646]	KUZHICHAL	81.0	0.0	49.7	31.3	38.6	Medium
KANNUR	Dharmassala [6646]	KV INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	LADIES HOSTEL ENGCOLLAGE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	LAKSHMI PLASTIC	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	LAZAR BOARD	129.0	0.0	37.0	92.0	71.3	High
KANNUR	Dharmassala [6646]	LIBERTY BOARD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	MADAPURA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	MALABAR WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	MAMBALA	81.0	0.0	2.0	79.0	97.5	Very High
KANNUR	Dharmassala [6646]	MAMBALA PETROL PUMP	129.0	3.0	57.0	69.0	53.5	High
KANNUR	Dharmassala [6646]	MANGAD GARMENTS	129.0	8.0	29.0	92.0	71.3	High
KANNUR	Dharmassala [6646]	MANGAD MANNA	81.0	0.0	80.0	1.0	1.2	Very Low
KANNUR	Dharmassala [6646]	MANGAD REG OFFICE	81.0	4.8	76.2	0.1	0.1	Very Low
KANNUR	Dharmassala [6646]	MANGAD TOWN	129.0	0.0	38.0	91.0	70.5	High
KANNUR	Dharmassala [6646]	MANGADAVU	202.0	0.0	81.0	121.0	59.9	High
KANNUR	Dharmassala [6646]	MARIYANGALAM	81.0	5.0	57.0	19.0	23.5	Low
KANNUR	Dharmassala [6646]	MARS VEENERS BOARD	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmassala [6646]	MARS WINNERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	MAVA PLASTICS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	MAVVADI VAYAL	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Dharmassala [6646]	MKM WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	MORAZHA BANK AUDITORIUM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	MORAZHA CENTRAL	81.0	3.1	77.0	0.9	1.2	Very Low
KANNUR	Dharmassala [6646]	MORAZHA WEAVERS MANHAPEEDIKA	81.0	1.0	33.3	46.7	57.7	High
KANNUR	Dharmassala [6646]	MOTEL ARAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	MOTHI CHEMICALS	81.0	11.1	44.0	26.0	32.1	Medium
KANNUR	Dharmassala [6646]	MUNDAPRAM	81.0	0.0	3.0	78.0	96.3	Very High
KANNUR	Dharmassala [6646]	MVR BAKKALAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	MYLAD	81.0	0.0	20.2	60.8	75.0	Very High
KANNUR	Dharmassala [6646]	NAINA BOARD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	NANNISSERY	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Dharmassala [6646]	NATIONAL METAL	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	NAVADURGA	81.0	0.0	9.0	72.0	88.9	Very High
KANNUR	Dharmassala [6646]	NAVARATHNA ENTERPRIZES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	NAVEEN BOARDS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	NAYANAR	81.0	0.0	66.5	14.5	18.0	Low
KANNUR	Dharmassala [6646]	NELLIOTTU TEMPLE	81.0	3.0	52.0	26.0	32.1	Medium
KANNUR	Dharmassala [6646]	OMERS WOOD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	ORICAL	81.0	0.0	40.5	40.5	50.0	High
KANNUR	Dharmassala [6646]	ORIENTAL PLASTICS	81.0	0.0	4.9	76.1	94.0	Very High
KANNUR	Dharmassala [6646]	OZHACHROME THEPPETTI COMPANY	81.0	5.0	0.0	76.0	93.8	Very High
KANNUR	Dharmassala [6646]	OZHAKROME	81.0	11.0	51.7	18.3	22.6	Low
KANNUR	Dharmassala [6646]	P P POWDER COATING	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmassala [6646]	PALATHUMKUND	81.0	3.0	26.0	52.0	64.2	High
KANNUR	Dharmassala [6646]	PALIYATHUVALAPPU	129.0	8.0	36.0	85.0	65.9	High
KANNUR	Dharmassala [6646]	PANKULAM	81.0	0.0	6.0	75.0	92.6	Very High
KANNUR	Dharmassala [6646]	PAPPINISSERI BANK	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	PARAG PLYWOOD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	PARAMOUNT	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	PARASSINI BUS STAND	81.0	10.0	38.0	33.0	40.7	Medium
KANNUR	Dharmassala [6646]	PARASSINI KULAM	129.0	0.0	98.3	30.7	23.8	Low
KANNUR	Dharmassala [6646]	PARASSINI PALAM	81.0	0.0	5.0	76.0	93.8	Very High
KANNUR	Dharmassala [6646]	PARASSINI POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	PARASSINI TOURIST HOME	81.0	0.0	45.0	36.0	44.4	Medium
KANNUR	Dharmassala [6646]	PEELERI	81.0	3.0	42.0	36.0	44.4	Medium
KANNUR	Dharmassala [6646]	PERFECT ENGINEERING	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	PETROL PUMP	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	POOTHAPPARA	81.0	6.0	15.0	60.0	74.1	High
KANNUR	Dharmassala [6646]	POURNAMI INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	POWER PLASTIC	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	PUNATHIL WOOD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	PUNNAKULANGARA	81.0	9.1	40.6	31.3	38.7	Medium
KANNUR	Dharmassala [6646]	R W S S	81.0	5.0	41.0	35.0	43.2	Medium
KANNUR	Dharmassala [6646]	RABEE WOOD	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	RAIN BOW PACKAGE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	RED ROSE-TAPASYA P KADAVU	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	RED STAR	81.0	0.0	68.0	13.0	16.0	Low
KANNUR	Dharmassala [6646]	RELIANCE	81.0	3.0	45.0	33.0	40.7	Medium
KANNUR	Dharmassala [6646]	RIYAS WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	ROSHIN INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmassala [6646]	ROYAL NEST	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SAI KRIPA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SERVICE STATION	202.0	0.0	5.0	197.0	97.5	Very High
KANNUR	Dharmassala [6646]	SHAGU WOOD	81.0	0.0	28.0	53.0	65.4	High
KANNUR	Dharmassala [6646]	SHERLON MATRESS CENTUARY	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	SHERO DRYING	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	SHERO PLYWOODS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	SI MUKKU PARAKKADAVU	81.0	3.1	42.3	35.7	44.1	Medium
KANNUR	Dharmassala [6646]	SILCO WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SNEHA-INN	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SNEHAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SOORYA	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	SPECTRA DOORS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SREE CHAKRA POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SREE SAILAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SREENA INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	STAINLESS STEEL	81.0	0.0	52.5	28.5	35.2	Medium
KANNUR	Dharmassala [6646]	STANDARD WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SUKRIPA RESIDENCY	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SULFEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	SWATHIPACKAGINGS	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	T U MUKKU	81.0	3.0	21.0	57.0	70.4	High
KANNUR	Dharmassala [6646]	T V K	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	THAVALAPPARA	81.0	15.0	20.2	45.8	56.5	High
KANNUR	Dharmassala [6646]	TMR	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	TOOL PLAZA HAJI MOTTA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	UNIVERSITY HEIGHTS	81.0	0.0	6.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Dharmassala [6646]	UNIVERSITY QUARTERS	81.0	0.0	22.9	58.1	71.8	High
KANNUR	Dharmassala [6646]	VADAKKANCHERRY	81.0	3.0	15.0	63.0	77.8	Very High
KANNUR	Dharmassala [6646]	VADESWARAM	81.0	0.0	23.0	58.0	71.6	High
KANNUR	Dharmassala [6646]	VELIYAMBRA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	VELLIKKEEL	81.0	0.0	35.0	46.0	56.8	High
KANNUR	Dharmassala [6646]	VELLIKKEEL KADAVE	81.0	0.0	23.0	58.0	71.6	High
KANNUR	Dharmassala [6646]	VENI VAYAL	81.0	5.0	17.0	59.0	72.8	High
KANNUR	Dharmassala [6646]	VICT PLYWOOD	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	VIJAYAGOVINDA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	WESTERN BAKERS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Dharmassala [6646]	WESTERN INDUSTRIES	81.0	3.1	8.0	69.9	86.3	Very High
KANNUR	Dharmassala [6646]	WOODLANDS PLAST	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Dharmassala [6646]	YUVA SAKTHI KANOL	81.0	0.0	12.5	68.5	84.5	Very High
KANNUR	Eaichur [6659]	AL-WAFA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	ANNAKOTTANCHAL	81.0	0.0	14.5	66.5	82.1	Very High
KANNUR	Eaichur [6659]	APEX	81.0	0.0	36.1	44.9	55.4	High
KANNUR	Eaichur [6659]	ARK 3 VARAM	162.0	0.0	0.0	162.0	100.0	Very High
KANNUR	Eaichur [6659]	ARK COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	AYANKI	129.0	9.0	76.9	43.1	33.4	Medium
KANNUR	Eaichur [6659]	AYYAPPANMALA	129.0	11.0	23.7	94.3	73.1	High
KANNUR	Eaichur [6659]	AYYAPPANMALA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	CAMERIN	81.0	0.0	29.0	52.0	64.2	High
KANNUR	Eaichur [6659]	CANAL PALAM	81.0	0.0	79.6	1.4	1.7	Very Low
KANNUR	Eaichur [6659]	CANANNORE HANDLOOM	129.0	0.0	23.0	106.0	82.2	Very High
KANNUR	Eaichur [6659]	CASA HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	CHAITRAPURAM	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	CHALIN MOTTA	81.0	4.0	40.3	36.7	45.3	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Eaichur [6659]	CHANGALATT	81.0	0.0	35.6	45.4	56.0	High
KANNUR	Eaichur [6659]	CHAPPA	129.0	5.0	68.0	56.0	43.4	Medium
KANNUR	Eaichur [6659]	CHATHURAKINAR	129.0	0.0	92.9	36.1	28.0	Medium
KANNUR	Eaichur [6659]	CHATTUKAPPARA	129.0	8.0	53.0	68.0	52.7	High
KANNUR	Eaichur [6659]	CHATTUKAPPARA HS	81.0	0.0	36.0	45.0	55.6	High
KANNUR	Eaichur [6659]	CHATTUKAPPARA TOWER	81.0	8.3	11.0	61.7	76.2	Very High
KANNUR	Eaichur [6659]	CHEKKIKULAM CANAL	129.0	8.0	75.9	45.1	35.0	Medium
KANNUR	Eaichur [6659]	CHELORA	129.0	3.0	123.9	2.1	1.6	Very Low
KANNUR	Eaichur [6659]	CHEMMADAM	129.0	16.0	106.4	6.6	5.1	Very Low
KANNUR	Eaichur [6659]	CHEMMADAM VAYANASALA	81.0	7.0	44.0	30.0	37.0	Medium
KANNUR	Eaichur [6659]	CHERUVATHALA METTA	81.0	16.0	62.0	3.0	3.8	Very Low
KANNUR	Eaichur [6659]	CHIRATTUMoola	81.0	5.0	11.0	65.0	80.2	Very High
KANNUR	Eaichur [6659]	CHM	81.0	0.0	81.0	0.0	0.0	Very Low
KANNUR	Eaichur [6659]	CHOLAPPALAM	81.0	0.0	6.3	74.7	92.2	Very High
KANNUR	Eaichur [6659]	CHUDALA	81.0	5.0	49.3	26.7	32.9	Medium
KANNUR	Eaichur [6659]	CHUDALA CANAL	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Eaichur [6659]	CR FUELS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	CUT AND COVER	81.0	0.0	47.6	33.4	41.2	Medium
KANNUR	Eaichur [6659]	DHARMAKINAR	81.0	0.0	16.4	64.5	79.7	Very High
KANNUR	Eaichur [6659]	DIAMOND PAINT	81.0	0.0	15.0	66.0	81.5	Very High
KANNUR	Eaichur [6659]	EACHUR BAZAR	202.0	17.0	46.6	138.4	68.5	High
KANNUR	Eaichur [6659]	EACHUR KOTTAM	81.0	13.0	68.0	0.0	0.0	Very Low
KANNUR	Eaichur [6659]	EACHUR NAGAR	81.0	13.0	36.4	31.6	39.1	Medium
KANNUR	Eaichur [6659]	EACHUR OFFICE	202.0	3.0	74.0	125.0	61.9	High
KANNUR	Eaichur [6659]	EDAKKANAMBETH	81.0	8.0	20.6	52.4	64.7	High
KANNUR	Eaichur [6659]	EDAVACHAL	81.0	0.0	41.0	40.0	49.4	Medium
KANNUR	Eaichur [6659]	EDAYILPEEDIKA	81.0	3.0	19.0	59.0	72.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Eaichur [6659]	FORTUNE SQUARE	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	FRECH PET CHATTUKAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	HIRA STOP	129.0	0.0	45.8	83.2	64.5	High
KANNUR	Eaichur [6659]	IMT	129.0	8.0	118.1	2.9	2.2	Very Low
KANNUR	Eaichur [6659]	INDIRA NAGAR	81.0	18.0	58.0	5.0	6.2	Very Low
KANNUR	Eaichur [6659]	IRAVUMKAI	81.0	8.0	41.0	32.0	39.5	Medium
KANNUR	Eaichur [6659]	JANASAKTHI	81.0	11.0	54.3	15.7	19.4	Low
KANNUR	Eaichur [6659]	JAYAN PEEDIKA	81.0	3.0	33.0	45.0	55.6	High
KANNUR	Eaichur [6659]	KACHERY PARAMBU	81.0	6.0	41.0	34.0	42.0	Medium
KANNUR	Eaichur [6659]	KADANKODE	129.0	6.0	45.0	78.0	60.4	High
KANNUR	Eaichur [6659]	KADANKODE PALLI	81.0	0.0	18.0	63.0	77.8	Very High
KANNUR	Eaichur [6659]	KAIPPAKKAYIL MOTTA	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	KAIPPAKKAYILMOTTA PALLI	81.0	8.0	19.5	53.5	66.0	High
KANNUR	Eaichur [6659]	KAMAL PEEDIKA	129.0	3.0	37.3	88.7	68.7	High
KANNUR	Eaichur [6659]	KANACHERI CANAL	81.0	10.0	34.0	37.0	45.6	Medium
KANNUR	Eaichur [6659]	KANACHERI PALLI	129.0	8.0	38.3	82.7	64.1	High
KANNUR	Eaichur [6659]	KANACHERY	129.0	5.0	39.3	84.7	65.7	High
KANNUR	Eaichur [6659]	KANHIRODE	81.0	5.0	37.0	39.0	48.1	Medium
KANNUR	Eaichur [6659]	KANHIRODE BAZAR	81.0	5.0	38.6	37.4	46.2	Medium
KANNUR	Eaichur [6659]	KANHIRODE DINESH	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	KANHIRODE THERU	129.0	3.0	125.8	0.2	0.2	Very Low
KANNUR	Eaichur [6659]	KANNANCHAL	81.0	12.0	36.0	33.0	40.7	Medium
KANNUR	Eaichur [6659]	KARIMPUMKARA	81.0	13.0	67.0	1.0	1.2	Very Low
KANNUR	Eaichur [6659]	KARIYIL KAAVU	81.0	22.0	55.0	4.0	4.9	Very Low
KANNUR	Eaichur [6659]	KATTOLI CANAL	81.0	0.0	21.0	60.0	74.1	High
KANNUR	Eaichur [6659]	KAVUMCHAL	81.0	5.0	20.0	56.0	69.1	High
KANNUR	Eaichur [6659]	KOLINMOOLA	129.0	7.0	42.3	79.7	61.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Eaichur [6659]	KONGANAMKODE	81.0	10.0	49.3	21.7	26.8	Medium
KANNUR	Eaichur [6659]	KOORUMBAKAVU	81.0	3.0	12.7	65.3	80.6	Very High
KANNUR	Eaichur [6659]	KORALAD	81.0	6.0	11.3	63.7	78.6	Very High
KANNUR	Eaichur [6659]	KOTTANACHERI CHAKIRI	81.0	5.0	25.0	51.0	63.0	High
KANNUR	Eaichur [6659]	KOTTANACHERY	129.0	10.0	113.0	6.0	4.7	Very Low
KANNUR	Eaichur [6659]	KOTTANACHERY PALLI	51.0	8.0	43.0	0.0	0.0	Very Low
KANNUR	Eaichur [6659]	KOYYOTTUPALAM	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Eaichur [6659]	KUDUKIMOTTA	129.0	10.0	54.0	65.0	50.4	High
KANNUR	Eaichur [6659]	KUDUKKIMETTA TODDY SHOP	81.0	0.0	30.3	50.7	62.6	High
KANNUR	Eaichur [6659]	MACHERY SCHOOL	81.0	17.0	64.0	0.0	0.0	Very Low
KANNUR	Eaichur [6659]	MARIYAM TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Eaichur [6659]	MATHUKOTH	129.0	0.0	128.3	0.7	0.5	Very Low
KANNUR	Eaichur [6659]	MAVILACHAL	81.0	23.0	55.6	2.4	3.0	Very Low
KANNUR	Eaichur [6659]	MAVILACHAL CANAL	81.0	11.0	33.3	36.7	45.3	Medium
KANNUR	Eaichur [6659]	MAYANMUKK	129.0	8.0	67.0	54.0	41.9	Medium
KANNUR	Eaichur [6659]	MEENKADAVU	81.0	6.0	52.0	23.1	28.5	Medium
KANNUR	Eaichur [6659]	MOOPANS CHATHURAKINAR	81.0	0.0	36.1	44.9	55.4	High
KANNUR	Eaichur [6659]	MUNDERI CHIRA	81.0	12.0	68.3	0.7	0.9	Very Low
KANNUR	Eaichur [6659]	MUNDERI EXCHANGE	81.0	15.0	11.7	54.3	67.0	High
KANNUR	Eaichur [6659]	MUNDERI HS	81.0	5.0	64.0	12.0	14.8	Low
KANNUR	Eaichur [6659]	MUNDERI KADAVU	129.0	20.0	72.1	36.9	28.6	Medium
KANNUR	Eaichur [6659]	MUNDERI L P	81.0	5.0	22.0	54.0	66.7	High
KANNUR	Eaichur [6659]	MUNDERI MOTTA	129.0	5.0	31.0	93.0	72.1	High
KANNUR	Eaichur [6659]	MUNDERI PANCHAYATH	81.0	5.0	53.0	23.0	28.4	Medium
KANNUR	Eaichur [6659]	NAMBIAR PIDIKA	81.0	17.0	18.0	46.0	56.8	High
KANNUR	Eaichur [6659]	NAVABHARATH KALARI	81.0	11.0	28.0	42.0	51.9	High
KANNUR	Eaichur [6659]	NAVAKERALA	81.0	15.0	52.3	13.7	16.9	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Eaichur [6659]	NUCHILODE	129.0	4.0	86.4	38.6	29.9	Medium
KANNUR	Eaichur [6659]	PADANNOTT	81.0	0.0	37.0	44.0	54.3	High
KANNUR	Eaichur [6659]	PALLIYATH	81.0	0.0	55.8	25.2	31.1	Medium
KANNUR	Eaichur [6659]	PANCHAYATH KINAR	81.0	23.0	51.6	6.4	7.9	Very Low
KANNUR	Eaichur [6659]	PANNIYOTTU	129.0	0.0	20.0	109.0	84.5	Very High
KANNUR	Eaichur [6659]	PARAL ROAD	81.0	0.0	48.0	33.0	40.7	Medium
KANNUR	Eaichur [6659]	PAROTHUMCHAL	129.0	19.0	105.0	5.0	3.9	Very Low
KANNUR	Eaichur [6659]	PAROTHUMCHAL CANAL	81.0	13.0	67.0	1.0	1.2	Very Low
KANNUR	Eaichur [6659]	PATTIYAM ROAD	81.0	6.0	59.4	15.6	19.3	Low
KANNUR	Eaichur [6659]	PERINGALAYI	129.0	5.0	34.4	89.6	69.5	High
KANNUR	Eaichur [6659]	POLUPPIL KAVU	81.0	13.0	42.5	25.5	31.5	Medium
KANNUR	Eaichur [6659]	PRAGATHI FOODS	81.0	0.0	0.0	81.0	100.0	Very High
KANNUR	Eaichur [6659]	PULIDAIVAM KAVU	81.0	8.0	25.7	47.3	58.4	High
KANNUR	Eaichur [6659]	PUNNAKKAMoola	81.0	5.0	47.0	29.0	35.8	Medium
KANNUR	Eaichur [6659]	PURATHEEL	129.0	14.0	114.4	0.6	0.5	Very Low
KANNUR	Eaichur [6659]	PURAVOOR	81.0	0.0	28.0	53.0	65.4	High
KANNUR	Eaichur [6659]	PUTHUKKUDI ROAD	51.0	0.0	0.0	51.0	100.0	Very High
KANNUR	Eaichur [6659]	RISHISWARAM TEMPLE	51.0	8.0	31.6	11.4	22.3	Low
KANNUR	Eaichur [6659]	SALAFI	81.0	3.0	20.3	57.7	71.2	High
KANNUR	Eaichur [6659]	SIDDIQUE PALLI	129.0	3.0	43.0	83.0	64.3	High
KANNUR	Eaichur [6659]	SIVASAKTHI	81.0	0.0	8.0	73.0	90.1	Very High
KANNUR	Eaichur [6659]	SREEROSH-1	129.0	0.0	123.3	5.7	4.4	Very Low
KANNUR	Eaichur [6659]	SREEROSH-2	129.0	0.0	15.0	114.0	88.4	Very High
KANNUR	Eaichur [6659]	SREEROSH-III	202.0	0.0	38.0	164.0	81.2	Very High
KANNUR	Eaichur [6659]	SUBSTATION QUARTERS	81.0	0.0	17.0	64.0	79.0	Very High
KANNUR	Eaichur [6659]	SURYA-1	81.0	16.0	55.0	10.0	12.3	Low
KANNUR	Eaichur [6659]	SURYA-2	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KANNUR	Eaichur [6659]	SWADESH	129.0	5.0	29.4	94.6	73.3	High
KANNUR	Eaichur [6659]	THAKKALI PEEDIKA	129.0	16.0	88.3	24.7	19.1	Low
KANNUR	Eaichur [6659]	THANDAPPURAM	81.0	22.0	38.0	21.0	25.9	Medium
KANNUR	Eaichur [6659]	THARIYERI	81.0	8.0	30.5	42.5	52.5	High
KANNUR	Eaichur [6659]	TIP TOP	81.0	4.0	38.3	38.7	47.8	Medium
KANNUR	Eaichur [6659]	TRENCHING GROUND	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Eaichur [6659]	UMBAYI ARCADE	129.0	0.0	5.0	124.0	96.1	Very High
KANNUR	Eaichur [6659]	VALIYAKUNDU NAGAR	81.0	0.0	44.4	36.6	45.2	Medium
KANNUR	Eaichur [6659]	VALIYANNUR	81.0	3.0	75.0	3.0	3.7	Very Low
KANNUR	Eaichur [6659]	VANITHA INDUSTRY	129.0	0.0	0.0	129.0	100.0	Very High
KANNUR	Eaichur [6659]	VANIYANCHAL	81.0	13.0	51.0	17.0	20.9	Low
KANNUR	Eaichur [6659]	VARAM	129.0	58.0	33.4	37.6	29.1	Medium
KANNUR	Eaichur [6659]	VARAM CANAL	81.0	9.0	46.0	26.0	32.1	Medium
KANNUR	Eaichur [6659]	VARAM GEMINI	81.0	0.0	24.9	56.1	69.3	High
KANNUR	Eaichur [6659]	VARAM KADAV	129.0	12.0	42.1	74.9	58.1	High
KANNUR	Eaichur [6659]	VARAM KADAV JUNCTION	81.0	0.0	64.3	16.7	20.6	Low
KANNUR	Eaichur [6659]	VARAYILCHIRA	81.0	10.0	35.0	36.0	44.4	Medium
KANNUR	Eaichur [6659]	VATTAPOYIL	129.0	18.3	45.0	65.7	50.9	High
KANNUR	Eaichur [6659]	VATTAPOYIL CANAL	81.0	0.0	19.0	62.0	76.5	Very High
KANNUR	Eaichur [6659]	VATTAPOYIL DINESH	81.0	0.0	36.0	45.0	55.6	High
KANNUR	Eaichur [6659]	VEENUS CLUB	81.0	11.0	62.8	7.2	8.9	Very Low
KANNUR	Eaichur [6659]	VILLAGEMUKK	129.0	6.0	41.8	81.2	62.9	High
KANNUR	Eaichur [6659]	VR COMPLEX	81.0	3.0	24.0	54.0	66.7	High
KANNUR	Edoor [6722]	AKG NAGAR	81.0	0.0	63.0	18.0	22.2	Low
KANNUR	Edoor [6722]	AMBALAKKANDI ANGANAVADI	81.0	0.0	6.3	74.7	92.2	Very High