

KSEB Renewable Energy Feasibility Report

Generated report · 2000 transformers across 1 districts. Balance % = (Balance Available ÷ 90% DTR Capacity) × 100.

District Summary

District	Transformers	Balance (kW)	Very High	High	Medium	Low	Very Low	Unknown
KOLLAM	2000	130,487.6	928	530	283	87	172	0
TOTAL	2000	130,487.6	928	530	283	87	172	0

KOLLAM — 2000 transformers

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Anchal West [4669]	AERAM MOSQUE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal West [4669]	AERAM NO-1	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Anchal West [4669]	AERAM NO-2-THADICADU ROAD	81.0	0.0	27.1	53.9	66.5	High
KOLLAM	Anchal West [4669]	ALAMCODE-160KVA	129.0	0.0	11.0	118.0	91.5	Very High
KOLLAM	Anchal West [4669]	ALIYARUMUKKU	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Anchal West [4669]	AMBALATHUM MUKAL	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Anchal West [4669]	AMRITHA-160KVA	129.0	0.0	6.0	123.0	95.3	Very High
KOLLAM	Anchal West [4669]	ANAPUZHAKKAL	81.0	5.0	21.0	55.0	67.9	High
KOLLAM	Anchal West [4669]	ANCHAL HOSPITAL-160KVA	129.0	0.0	3.0	126.0	97.7	Very High
KOLLAM	Anchal West [4669]	ANERIMUGAL	81.0	3.3	25.0	52.7	65.1	High
KOLLAM	Anchal West [4669]	ASURAMANGALAM NO-1	81.0	0.0	25.3	55.7	68.8	High
KOLLAM	Anchal West [4669]	ASURAMANGALAM NO-2-KANNANC ODE	81.0	3.0	16.0	62.0	76.5	Very High
KOLLAM	Anchal West [4669]	AYATHIL	81.0	3.0	3.0	75.0	92.6	Very High
KOLLAM	Anchal West [4669]	BHOOTHANADHA TEMPLE	129.0	5.0	52.0	72.0	55.8	High
KOLLAM	Anchal West [4669]	CHAMAKKALA	81.0	3.0	53.0	25.0	30.9	Medium
KOLLAM	Anchal West [4669]	CHEEPPUVAYAL-160 KVA	129.0	5.0	32.0	92.0	71.3	High
KOLLAM	Anchal West [4669]	CHELAPPALLY	81.0	13.0	43.9	24.1	29.7	Medium
KOLLAM	Anchal West [4669]	CHEMPAKARAMANALLOOR	81.0	0.0	79.6	1.4	1.7	Very Low
KOLLAM	Anchal West [4669]	CHERUKULAM PAALAM	81.0	0.0	6.4	74.6	92.1	Very High
KOLLAM	Anchal West [4669]	CHETTUKUZH Y TOWER	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Anchal West [4669]	CHETTUKUZH Y WATER TANK	81.0	3.0	3.0	75.0	92.6	Very High
KOLLAM	Anchal West [4669]	CHORAKKULAM	81.0	0.0	23.3	57.7	71.2	High
KOLLAM	Anchal West [4669]	CHORANADU	81.0	3.0	12.0	66.0	81.5	Very High
KOLLAM	Anchal West [4669]	CHUNDA EXCHANGE	81.0	3.0	31.3	46.7	57.6	High
KOLLAM	Anchal West [4669]	CIVIL STATION-160KVA	129.0	0.0	23.4	105.6	81.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Anchal West [4669]	CLAVODU BALAVADY	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Anchal West [4669]	EETTIMOODU	81.0	0.0	16.3	64.7	79.9	Very High
KOLLAM	Anchal West [4669]	EETTIMOODU SNDP SAKHA MANDIRAM	81.0	13.0	22.0	46.0	56.8	High
KOLLAM	Anchal West [4669]	GANAPATHY TEMPLE-160 KVA	129.0	13.0	45.9	70.1	54.4	High
KOLLAM	Anchal West [4669]	ICE FACTORY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal West [4669]	KAIPALLY JN-250KVA	202.0	0.0	41.0	161.0	79.7	Very High
KOLLAM	Anchal West [4669]	KAIPALLY PALLY	81.0	3.0	18.0	60.0	74.1	High
KOLLAM	Anchal West [4669]	KAITHAKETTU	81.0	10.0	4.0	67.0	82.7	Very High
KOLLAM	Anchal West [4669]	KALACHANDA-250KVA	202.0	10.0	28.0	164.0	81.2	Very High
KOLLAM	Anchal West [4669]	KALARI AMBALAM 100 KVA	81.0	3.0	66.4	11.6	14.3	Low
KOLLAM	Anchal West [4669]	KANJIRATHARA	81.0	3.0	57.6	20.4	25.2	Medium
KOLLAM	Anchal West [4669]	KANNAMKAVU	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Anchal West [4669]	KAVADIKUNNUPURAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal West [4669]	KODIYATTU-160KVA	129.0	3.0	19.0	107.0	82.9	Very High
KOLLAM	Anchal West [4669]	KOMPETTIMALA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal West [4669]	KOTTARAZHIKAM	81.0	0.0	12.0	69.0	85.2	Very High
KOLLAM	Anchal West [4669]	KOTTUKKAL AGRI FARM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal West [4669]	KOTTUKKAL JN-160KVA	129.0	8.0	45.0	76.0	58.9	High
KOLLAM	Anchal West [4669]	KOTTUKKAL KRISHI BHAVAN	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal West [4669]	KOTTUKKAL SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal West [4669]	KOTTUKKAL TOWER	81.0	4.2	0.0	76.8	94.8	Very High
KOLLAM	Anchal West [4669]	KUTTANKARA WATER TANK	81.0	13.0	9.4	58.6	72.3	High
KOLLAM	Anchal West [4669]	MADHURAPPA GURUMANDIRAM	81.0	0.0	17.0	64.0	79.0	Very High
KOLLAM	Anchal West [4669]	MADHURAPPA NO1-160 KVA	129.0	3.0	52.2	73.8	57.2	High
KOLLAM	Anchal West [4669]	MALAVATTAM-160KVA	129.0	0.0	33.0	96.0	74.4	High
KOLLAM	Anchal West [4669]	MARKET ANCHAL-100 KVA	81.0	0.0	24.5	56.5	69.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Anchal West [4669]	MAROOR	81.0	5.0	34.0	42.0	51.9	High
KOLLAM	Anchal West [4669]	MELAKKADU	81.0	3.0	33.3	44.7	55.2	High
KOLLAM	Anchal West [4669]	MELATHIL BUILDING PVT-TFR	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Anchal West [4669]	MOOLAVILA	81.0	3.0	15.0	63.0	77.8	Very High
KOLLAM	Anchal West [4669]	NEDUMKOTTUKONAM	81.0	3.0	3.0	75.0	92.6	Very High
KOLLAM	Anchal West [4669]	NEDUPURAM	81.0	3.0	14.2	63.8	78.7	Very High
KOLLAM	Anchal West [4669]	NJARAKKADU	81.0	0.0	20.3	60.7	74.9	High
KOLLAM	Anchal West [4669]	OTTATENGU	81.0	0.0	37.4	43.6	53.8	High
KOLLAM	Anchal West [4669]	OXYGEN	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal West [4669]	PALAMUKKU	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Anchal West [4669]	PALLIMUKKU	81.0	5.0	32.0	44.0	54.3	High
KOLLAM	Anchal West [4669]	PANACHAVILA-160KVA	129.0	3.0	31.3	94.7	73.4	High
KOLLAM	Anchal West [4669]	PANAYAMCHERY KARAYOGAM	81.0	5.0	66.3	9.7	12.0	Low
KOLLAM	Anchal West [4669]	PHILGIRI	81.0	5.0	15.2	60.9	75.1	Very High
KOLLAM	Anchal West [4669]	PONGUMMUGAL	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Anchal West [4669]	PUTHATTU	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Anchal West [4669]	REXIN	81.0	10.0	14.0	57.0	70.4	High
KOLLAM	Anchal West [4669]	SANKARAPURAM	81.0	0.0	46.3	34.7	42.8	Medium
KOLLAM	Anchal West [4669]	SARATHY-160KVA	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Anchal West [4669]	SBI-PANACHAVILA	81.0	0.0	46.0	35.0	43.2	Medium
KOLLAM	Anchal West [4669]	SBT-ANCHAL-160KVA	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Anchal West [4669]	SHAJI ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal West [4669]	SUN FOOD-160KVA	129.0	0.0	11.6	117.4	91.0	Very High
KOLLAM	Anchal West [4669]	TELE-EXCHANGE NO-1-160KVA	129.0	0.0	49.7	79.3	61.5	High
KOLLAM	Anchal West [4669]	TELE-EXCHANGE NO-2-160KVA	129.0	3.0	43.3	82.7	64.1	High
KOLLAM	Anchal West [4669]	THADIKKADU EXCHANGE	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Anchal West [4669]	THADIKKADU MOSQUE	81.0	0.0	14.3	66.7	82.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Anchal West [4669]	THADIKKADU PULIMUKKU	129.0	3.0	59.9	66.1	51.2	High
KOLLAM	Anchal West [4669]	THADIKKADU-250KVA	202.0	9.0	15.0	178.0	88.1	Very High
KOLLAM	Anchal West [4669]	THANNIMUGAL	81.0	3.0	23.6	54.4	67.1	High
KOLLAM	Anchal West [4669]	THAZHAMEL NO-2	81.0	5.0	19.0	57.0	70.4	High
KOLLAM	Anchal West [4669]	THAZHAMEL-160KVA	129.0	5.0	25.4	98.6	76.4	Very High
KOLLAM	Anchal West [4669]	THITTANKARA KAVU	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Anchal West [4669]	THOITHALA	81.0	0.0	26.3	54.7	67.5	High
KOLLAM	Anchal West [4669]	THOLLUR	81.0	3.0	11.0	67.0	82.7	Very High
KOLLAM	Anchal West [4669]	THOONGARAVALLY	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Anchal West [4669]	THRANGODU	81.0	3.0	11.0	67.0	82.7	Very High
KOLLAM	Anchal West [4669]	THUMPASSERRY	81.0	0.0	28.0	53.0	65.4	High
KOLLAM	Anchal West [4669]	THUMPIKUNNU	81.0	3.0	33.0	45.0	55.6	High
KOLLAM	Anchal West [4669]	TIRUMENIKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Anchal West [4669]	VATTAMANPALAM NO-1-160KVA	129.0	0.0	18.8	110.2	85.4	Very High
KOLLAM	Anchal West [4669]	VATTAMANPALAM-2 OFFICE-160KVA	129.0	0.0	35.7	93.3	72.3	High
KOLLAM	Anchal West [4669]	VRINDAVANAM	129.0	3.3	76.8	48.9	37.9	Medium
KOLLAM	Anchal West [4669]	WHITE PALACE AUDITORIUM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	12 ACRE	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Anchal [4597]	2 ACRE MUKKU	81.0	3.0	15.0	63.0	77.8	Very High
KOLLAM	Anchal [4597]	AGASTHYACODE GURUMANDHIRA M	81.0	5.0	20.7	55.3	68.2	High
KOLLAM	Anchal [4597]	AGASTHYACODE NEW LPS	81.0	0.0	29.0	52.0	64.2	High
KOLLAM	Anchal [4597]	ALANCHERI CHURCH	129.0	3.0	65.5	60.5	46.9	Medium
KOLLAM	Anchal [4597]	ALANCHERRY	202.0	3.0	58.0	141.0	69.8	High
KOLLAM	Anchal [4597]	ALANCHERY CRESHURE	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Anchal [4597]	ALANCHERY JN-TOWER	81.0	5.0	20.0	56.0	69.1	High
KOLLAM	Anchal [4597]	ALAYAMON	129.0	21.0	20.0	88.0	68.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Anchal [4597]	AMBALAM MUKKU	81.0	3.0	31.0	47.0	58.0	High
KOLLAM	Anchal [4597]	ARCHANA	129.0	5.0	54.0	70.0	54.3	High
KOLLAM	Anchal [4597]	ARCHANA THEATRE	81.0	0.0	67.0	14.0	17.3	Low
KOLLAM	Anchal [4597]	AREEPLACHI	81.0	8.0	16.0	57.0	70.4	High
KOLLAM	Anchal [4597]	ASWATHY TOWER	129.0	0.0	25.0	104.0	80.6	Very High
KOLLAM	Anchal [4597]	AYILARA GURUMANDIRAM	81.0	6.0	25.5	49.5	61.1	High
KOLLAM	Anchal [4597]	AYILARA HS	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Anchal [4597]	AYILARA NO1	129.0	0.0	18.3	110.7	85.8	Very High
KOLLAM	Anchal [4597]	BHAIRAVANMUGAL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	BHARATHEEPURAM	81.0	0.0	33.5	47.5	58.7	High
KOLLAM	Anchal [4597]	CANARA BANK	129.0	0.0	8.0	121.0	93.8	Very High
KOLLAM	Anchal [4597]	CHAITHANYA	129.0	8.0	61.7	59.3	45.9	Medium
KOLLAM	Anchal [4597]	CHEEPUVAYAL	129.0	3.0	33.2	92.8	71.9	High
KOLLAM	Anchal [4597]	CHILLING PLANT	81.0	3.0	36.8	41.2	50.8	High
KOLLAM	Anchal [4597]	DARPHAPANA	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Anchal [4597]	DELTA SCHOOL	81.0	3.0	15.9	62.1	76.7	Very High
KOLLAM	Anchal [4597]	EDAKOCHI	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	ERANADU EALA	81.0	0.0	39.0	42.0	51.9	High
KOLLAM	Anchal [4597]	ERNOORKARIKKOM	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Anchal [4597]	ERUVELIKKAL	81.0	10.0	69.2	1.8	2.2	Very Low
KOLLAM	Anchal [4597]	GOKULAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	HARITHA	81.0	3.0	24.0	54.0	66.7	High
KOLLAM	Anchal [4597]	KAITHADI	202.0	5.0	63.1	133.9	66.3	High
KOLLAM	Anchal [4597]	KAITHADY WORKSHOP	129.0	10.0	82.8	36.2	28.1	Medium
KOLLAM	Anchal [4597]	KALAMANOOR NO-1	81.0	3.0	5.0	73.0	90.1	Very High
KOLLAM	Anchal [4597]	KALAMANOOR NO-II	81.0	3.0	34.4	43.6	53.8	High
KOLLAM	Anchal [4597]	KANJUVAYAL NO1	81.0	12.0	67.0	2.0	2.5	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Anchal [4597]	KANJUVAYAL NO2	81.0	0.0	79.9	1.1	1.4	Very Low
KOLLAM	Anchal [4597]	KANNADIPPALLY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	KARAYIKKONAM ELA	81.0	6.0	42.5	32.5	40.1	Medium
KOLLAM	Anchal [4597]	KATTITTA	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Anchal [4597]	KISSAN JN	81.0	3.0	13.0	65.0	80.2	Very High
KOLLAM	Anchal [4597]	KITTANKONAM	81.0	0.0	12.0	69.0	85.2	Very High
KOLLAM	Anchal [4597]	KOCHU KURUVIKONAM	81.0	3.0	42.0	36.0	44.4	Medium
KOLLAM	Anchal [4597]	KOCHUKULAM	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Anchal [4597]	KOMALAM	81.0	3.0	26.0	52.0	64.2	High
KOLLAM	Anchal [4597]	KONATH JN	81.0	0.0	29.0	52.0	64.2	High
KOLLAM	Anchal [4597]	KOZHAKATTUCHIRA	129.0	3.0	8.0	118.0	91.5	Very High
KOLLAM	Anchal [4597]	KURUVIKONAM	202.0	0.0	9.0	193.0	95.5	Very High
KOLLAM	Anchal [4597]	KUSINIMUKKU	81.0	0.0	43.0	38.0	46.9	Medium
KOLLAM	Anchal [4597]	LAVENDER PLAZA LT	255.0	81.0	0.0	174.0	68.2	High
KOLLAM	Anchal [4597]	M C A COLLEGE	81.0	17.0	37.5	26.5	32.7	Medium
KOLLAM	Anchal [4597]	MANGALATH	81.0	6.0	13.0	62.0	76.5	Very High
KOLLAM	Anchal [4597]	MELAYPANAYAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	MINNARAM	81.0	0.0	9.5	71.5	88.3	Very High
KOLLAM	Anchal [4597]	MISSION HOSPITAL	40.0	0.0	0.0	40.0	100.0	Very High
KOLLAM	Anchal [4597]	MURUKKINKODE	81.0	6.0	21.4	53.6	66.2	High
KOLLAM	Anchal [4597]	MUTHALATTU	81.0	3.0	32.0	46.0	56.8	High
KOLLAM	Anchal [4597]	MUZHATHANGU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	MUZHATHANGU TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	NADUKUNNUPURAM	81.0	0.0	28.7	52.3	64.5	High
KOLLAM	Anchal [4597]	NADUKUNNUPURAM CASHEW	81.0	8.0	13.0	60.0	74.1	High
KOLLAM	Anchal [4597]	NEDIYARA	81.0	0.0	60.4	20.6	25.4	Medium
KOLLAM	Anchal [4597]	NEDUVANNOR COLONY	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Anchal [4597]	NETTAYAM SCHOOL	81.0	5.0	8.0	68.0	84.0	Very High
KOLLAM	Anchal [4597]	NETTAYAM-II PLAPPADU	81.0	6.0	13.0	62.0	76.5	Very High
KOLLAM	Anchal [4597]	NIRAPPIL	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Anchal [4597]	NOT	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	ORUNADA	81.0	0.0	12.0	69.0	85.2	Very High
KOLLAM	Anchal [4597]	PANAYAM NO-2	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Anchal [4597]	PANAYAM-1TRIKKOIKKAL	81.0	6.0	15.0	60.0	74.1	High
KOLLAM	Anchal [4597]	PANDARAKONAM	81.0	0.0	21.3	59.7	73.7	High
KOLLAM	Anchal [4597]	PANTHADY MUGAL	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Anchal [4597]	PANTHADY MUGAL TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	PATHADY	129.0	0.0	14.0	115.0	89.1	Very High
KOLLAM	Anchal [4597]	PATHADY TOWER	81.0	10.0	18.0	53.0	65.4	High
KOLLAM	Anchal [4597]	PAZHAYEROOR	81.0	18.0	42.4	20.6	25.4	Medium
KOLLAM	Anchal [4597]	PINNACLE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	POOVANUR KALUNGU	81.0	8.0	34.8	38.2	47.1	Medium
KOLLAM	Anchal [4597]	PUNCHIRIMUKKU	81.0	5.0	21.0	55.0	67.9	High
KOLLAM	Anchal [4597]	RO JN NO-II	129.0	0.0	19.0	110.0	85.3	Very High
KOLLAM	Anchal [4597]	ROJUNCTION NO1	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Anchal [4597]	SAHYADRI	81.0	5.0	8.0	68.0	84.0	Very High
KOLLAM	Anchal [4597]	SAK	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	SNEHALAYAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	ST MARYS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	THALUVACHIRA	202.0	5.0	69.0	128.0	63.4	High
KOLLAM	Anchal [4597]	THANNIMUGAL	81.0	3.0	13.0	65.0	80.2	Very High
KOLLAM	Anchal [4597]	THEKKEMALAPPURAM	81.0	0.0	26.0	55.0	67.9	High
KOLLAM	Anchal [4597]	THOLUR	81.0	8.0	45.3	27.7	34.2	Medium
KOLLAM	Anchal [4597]	THONDIYARA	81.0	5.0	18.0	58.0	71.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Anchal [4597]	THOTTAM MUKKU	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Anchal [4597]	THUMPODU	81.0	0.0	31.0	50.0	61.7	High
KOLLAM	Anchal [4597]	VADAMON	81.0	0.0	13.0	68.0	84.0	Very High
KOLLAM	Anchal [4597]	VADAMON TEMPLE	81.0	6.0	22.0	53.0	65.4	High
KOLLAM	Anchal [4597]	VAKKAMUKKU-I	129.0	0.0	5.0	124.0	96.1	Very High
KOLLAM	Anchal [4597]	VAKKOM MUKKU-II	81.0	0.0	24.3	56.7	70.0	High
KOLLAM	Anchal [4597]	VARSHA NO-I	129.0	7.8	121.1	0.1	0.1	Very Low
KOLLAM	Anchal [4597]	VARSHA NO-II	129.0	5.0	80.0	44.0	34.1	Medium
KOLLAM	Anchal [4597]	VAYALILKADA	81.0	10.0	22.0	49.0	60.5	High
KOLLAM	Anchal [4597]	VELANKUZH	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Anchal [4597]	VILAKKUPARA	81.0	6.0	13.0	62.0	76.5	Very High
KOLLAM	Anchal [4597]	VILAKKUPARA TOWER	20.0	0.0	7.0	13.0	65.0	High
KOLLAM	Anchal [4597]	VYRABHANMUKAL	81.0	3.0	5.0	73.0	90.1	Very High
KOLLAM	Anchal [4597]	YEROOR	405.0	0.0	63.0	342.0	84.4	Very High
KOLLAM	Anchal [4597]	YEROOR LPS	81.0	6.0	17.4	57.6	71.2	High
KOLLAM	Ayathil [4565]	A R M	81.0	15.0	30.4	35.6	43.9	Medium
KOLLAM	Ayathil [4565]	ACHAPPANA	129.0	5.0	28.6	95.4	74.0	High
KOLLAM	Ayathil [4565]	ALOKAARCADE	81.0	0.0	4.0	77.0	95.1	Very High
KOLLAM	Ayathil [4565]	AMMANNADA	81.0	18.0	54.3	8.7	10.7	Low
KOLLAM	Ayathil [4565]	AMMOOMMAKAUVU	81.0	3.0	21.0	57.0	70.4	High
KOLLAM	Ayathil [4565]	APSARA	81.0	18.0	44.6	18.4	22.7	Low
KOLLAM	Ayathil [4565]	AR ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Ayathil [4565]	ARATTUKULAM	81.0	10.0	39.0	32.0	39.5	Medium
KOLLAM	Ayathil [4565]	ASWATHY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayathil [4565]	AYATHIL EAST	202.0	3.0	64.0	135.0	66.8	High
KOLLAM	Ayathil [4565]	AYATHIL WEST	202.0	0.0	21.0	181.0	89.6	Very High
KOLLAM	Ayathil [4565]	AYYARUMUKKU	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ayathil [4565]	BALANANDA SCHOOL	81.0	5.0	22.1	53.9	66.6	High
KOLLAM	Ayathil [4565]	BENGLAVIL COLONY	81.0	0.0	39.0	42.0	51.9	High
KOLLAM	Ayathil [4565]	BHOOTHATHANKAVU	81.0	3.0	24.0	54.0	66.7	High
KOLLAM	Ayathil [4565]	BY PASS	129.0	6.0	54.0	69.0	53.5	High
KOLLAM	Ayathil [4565]	CHEELANCHERY	129.0	21.0	72.0	36.0	27.9	Medium
KOLLAM	Ayathil [4565]	CHENTHAPOOR	129.0	3.0	22.3	103.7	80.4	Very High
KOLLAM	Ayathil [4565]	CHIRAYIL KULAM	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Ayathil [4565]	CO OPARATIVE HOSPITAL	81.0	3.0	24.0	54.0	66.7	High
KOLLAM	Ayathil [4565]	COLLECTION INDIA	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Ayathil [4565]	CORPORATION	129.0	6.0	18.7	104.3	80.8	Very High
KOLLAM	Ayathil [4565]	DECENT JUNCTION	129.0	5.0	13.5	110.5	85.7	Very High
KOLLAM	Ayathil [4565]	DIAMOND	81.0	0.0	28.5	52.5	64.8	High
KOLLAM	Ayathil [4565]	DIVYA	81.0	0.0	18.0	63.0	77.8	Very High
KOLLAM	Ayathil [4565]	DORA	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Ayathil [4565]	ERATTAKKULAM	129.0	14.0	66.5	48.5	37.6	Medium
KOLLAM	Ayathil [4565]	ERATTAKULAM TEMPLE	81.0	8.0	7.3	65.7	81.1	Very High
KOLLAM	Ayathil [4565]	EZHAVAPALAM	129.0	36.0	92.2	0.8	0.6	Very Low
KOLLAM	Ayathil [4565]	GVPLP SCHOOL	81.0	5.0	22.0	54.0	66.7	High
KOLLAM	Ayathil [4565]	HATCHERY	129.0	6.0	44.2	78.8	61.1	High
KOLLAM	Ayathil [4565]	I MALL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayathil [4565]	IMPERIAL	129.0	18.0	94.5	16.5	12.8	Low
KOLLAM	Ayathil [4565]	JAYASREE	129.0	3.0	25.6	100.4	77.8	Very High
KOLLAM	Ayathil [4565]	KADANCHIRA	81.0	3.0	43.0	35.0	43.2	Medium
KOLLAM	Ayathil [4565]	KALAVEDI NEW	81.0	10.0	69.5	1.5	1.9	Very Low
KOLLAM	Ayathil [4565]	KALAVEDY	129.0	7.0	76.0	46.0	35.7	Medium
KOLLAM	Ayathil [4565]	KALKULAM	81.0	5.0	24.0	52.0	64.2	High
KOLLAM	Ayathil [4565]	KALLINGAL	81.0	8.0	9.0	64.0	79.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ayathil [4565]	KALUNGU	81.0	11.0	53.0	17.0	21.0	Low
KOLLAM	Ayathil [4565]	KANIYANTHODU	81.0	21.0	25.0	35.0	43.2	Medium
KOLLAM	Ayathil [4565]	KARUTHARA	129.0	11.0	75.3	42.7	33.1	Medium
KOLLAM	Ayathil [4565]	KATTAVILA	81.0	5.0	8.0	68.0	84.0	Very High
KOLLAM	Ayathil [4565]	KATTUMPURAM	81.0	3.0	10.0	68.0	84.0	Very High
KOLLAM	Ayathil [4565]	KAVAYYAM	129.0	3.0	31.0	95.0	73.6	High
KOLLAM	Ayathil [4565]	KIA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayathil [4565]	KOCHUDECENTJUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayathil [4565]	KOCHUKULAM	81.0	5.0	16.0	60.0	74.1	High
KOLLAM	Ayathil [4565]	KODALI MUKKU	81.0	12.0	61.0	8.0	9.9	Very Low
KOLLAM	Ayathil [4565]	KONATH TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Ayathil [4565]	KOVIL	129.0	11.0	56.5	61.5	47.7	Medium
KOLLAM	Ayathil [4565]	MADATHIL	81.0	31.0	38.0	12.0	14.8	Low
KOLLAM	Ayathil [4565]	MAHARAJA	129.0	21.0	64.0	44.0	34.1	Medium
KOLLAM	Ayathil [4565]	MANGALATHU	81.0	19.0	39.5	22.4	27.7	Medium
KOLLAM	Ayathil [4565]	MANICHITHODE	81.0	9.0	40.0	32.0	39.5	Medium
KOLLAM	Ayathil [4565]	MARKET	129.0	3.0	38.7	87.3	67.7	High
KOLLAM	Ayathil [4565]	MATHAMMATHOPE	81.0	16.0	21.0	44.0	54.3	High
KOLLAM	Ayathil [4565]	MEDAYIL	81.0	10.0	73.0	0.0	0.0	Very Low
KOLLAM	Ayathil [4565]	MEENAKSHY VILASAM	129.0	19.0	111.5	0.0	0.0	Very Low
KOLLAM	Ayathil [4565]	MELEMUKKU	81.0	6.0	26.0	49.0	60.5	High
KOLLAM	Ayathil [4565]	MILK SOCIETY	81.0	0.0	49.8	31.2	38.6	Medium
KOLLAM	Ayathil [4565]	MULLUKADU	81.0	20.0	43.3	17.7	21.9	Low
KOLLAM	Ayathil [4565]	MULLUVILA	129.0	5.0	62.4	61.6	47.8	Medium
KOLLAM	Ayathil [4565]	MUMTHASTOWER	81.0	5.0	44.0	32.0	39.5	Medium
KOLLAM	Ayathil [4565]	MUNNANIKULAM	129.0	39.0	63.4	26.6	20.7	Low
KOLLAM	Ayathil [4565]	MYLADUMKUNNU	129.0	16.0	35.0	78.0	60.5	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ayathil [4565]	NAIR KULAM	81.0	0.0	30.0	51.0	63.0	High
KOLLAM	Ayathil [4565]	NORTH BROOK VILLA	202.0	0.0	8.0	194.0	96.0	Very High
KOLLAM	Ayathil [4565]	PAINT COMPANY	81.0	16.0	57.6	7.4	9.1	Very Low
KOLLAM	Ayathil [4565]	PALKULAGARA BYPASS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayathil [4565]	PALKULANGARA CASHEW	81.0	15.0	60.0	6.0	7.4	Very Low
KOLLAM	Ayathil [4565]	PALKULANGARA TEMPLE	81.0	10.0	29.0	42.0	51.9	High
KOLLAM	Ayathil [4565]	PANCHAYATHU VILA	129.0	10.0	69.0	50.0	38.8	Medium
KOLLAM	Ayathil [4565]	PANIKKAR COMPANY	81.0	0.0	41.0	40.0	49.4	Medium
KOLLAM	Ayathil [4565]	PARVATHIYAR	202.0	14.0	67.2	120.8	59.8	High
KOLLAM	Ayathil [4565]	PERUMKULAM	81.0	23.0	32.0	26.0	32.1	Medium
KOLLAM	Ayathil [4565]	PLAMOODU	81.0	18.0	43.0	20.0	24.7	Low
KOLLAM	Ayathil [4565]	PRASANNAVENUGOPAL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayathil [4565]	PUNTHALATHAZHAM	129.0	18.0	89.8	21.2	16.5	Low
KOLLAM	Ayathil [4565]	PUNTHALATHAZHAM LIBRARY	81.0	8.0	33.4	39.6	48.9	Medium
KOLLAM	Ayathil [4565]	PUNTHALATHAZHAM SAW MILL	202.0	15.3	23.0	163.7	81.0	Very High
KOLLAM	Ayathil [4565]	PUTHENCHANTHA	81.0	26.0	27.9	27.1	33.5	Medium
KOLLAM	Ayathil [4565]	RAMANUJAVILLASAM	129.0	20.0	62.0	47.0	36.4	Medium
KOLLAM	Ayathil [4565]	RANDAM NUMBER	81.0	3.0	37.0	41.0	50.6	High
KOLLAM	Ayathil [4565]	RATION KADA MUKKU	129.0	38.0	93.0	0.0	0.0	Very Low
KOLLAM	Ayathil [4565]	RAYARMUKK MAVELI STORE	81.0	16.0	24.2	40.8	50.4	High
KOLLAM	Ayathil [4565]	S G N	129.0	35.0	94.0	0.0	0.0	Very Low
KOLLAM	Ayathil [4565]	S M D	81.0	8.0	39.0	34.0	42.0	Medium
KOLLAM	Ayathil [4565]	S N PUBLIC -COLLEGE	129.0	0.0	40.0	89.0	69.0	High
KOLLAM	Ayathil [4565]	S N PUBLIC SCHOOL	81.0	0.0	46.0	35.0	43.2	Medium
KOLLAM	Ayathil [4565]	SARATHY NO-1	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayathil [4565]	SARATHY WORKSHOP	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayathil [4565]	SASI FOUNDARY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ayathil [4565]	SASTHRI	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Ayathil [4565]	SHANTI THODI	81.0	10.0	32.0	39.0	48.1	Medium
KOLLAM	Ayathil [4565]	SHIVALAYA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayathil [4565]	SILPA NAGAR	129.0	3.0	27.0	99.0	76.7	Very High
KOLLAM	Ayathil [4565]	SMRITHY	81.0	11.0	64.5	5.5	6.8	Very Low
KOLLAM	Ayathil [4565]	SREENARAYANAPURAM	81.0	5.0	51.0	25.0	30.9	Medium
KOLLAM	Ayathil [4565]	STAR	81.0	13.0	67.5	0.5	0.6	Very Low
KOLLAM	Ayathil [4565]	SUBSTATION	129.0	8.0	87.8	33.2	25.7	Medium
KOLLAM	Ayathil [4565]	SUPRIYA	81.0	8.0	19.4	53.6	66.2	High
KOLLAM	Ayathil [4565]	SURYA	81.0	0.0	27.0	54.0	66.7	High
KOLLAM	Ayathil [4565]	THAHAMUKKU	81.0	15.0	29.0	37.0	45.7	Medium
KOLLAM	Ayathil [4565]	THAMPURATTI	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Ayathil [4565]	THANGAL	81.0	8.0	15.0	58.0	71.6	High
KOLLAM	Ayathil [4565]	THEKKADAM	81.0	3.0	33.0	45.0	55.6	High
KOLLAM	Ayathil [4565]	THEKKEKAVU	81.0	0.0	25.0	56.0	69.1	High
KOLLAM	Ayathil [4565]	THENGAYYAM	129.0	8.0	19.0	102.0	79.1	Very High
KOLLAM	Ayathil [4565]	TRANSLINK	81.0	0.0	24.0	57.0	70.4	High
KOLLAM	Ayathil [4565]	TYRE WORKS	81.0	0.0	32.8	48.2	59.5	High
KOLLAM	Ayathil [4565]	UDAYA	129.0	35.0	75.4	18.6	14.5	Low
KOLLAM	Ayathil [4565]	ULLAS NAGAR	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Ayathil [4565]	VALIYAMADAM	129.0	5.0	40.2	83.8	65.0	High
KOLLAM	Ayathil [4565]	VATTAKADU	81.0	22.0	53.0	6.0	7.4	Very Low
KOLLAM	Ayathil [4565]	VAZHAYIL	81.0	0.0	13.0	68.0	84.0	Very High
KOLLAM	Ayathil [4565]	VAZHAYIL NEW	81.0	6.0	60.0	15.0	18.5	Low
KOLLAM	Ayathil [4565]	VETERINARY HOSPITAL	81.0	0.0	33.0	48.0	59.3	High
KOLLAM	Ayathil [4565]	VETILAKAAVU	81.0	8.0	14.0	59.0	72.8	High
KOLLAM	Ayathil [4565]	VETILATHAZHAM	81.0	10.0	17.0	54.0	66.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ayathil [4565]	YMA	81.0	6.0	27.0	48.0	59.3	High
KOLLAM	Ayathil [4565]	YOUNUS CASHEW	81.0	11.0	28.0	42.0	51.9	High
KOLLAM	Ayoor [4591]	AKAMON	81.0	0.0	46.7	34.3	42.4	Medium
KOLLAM	Ayoor [4591]	AKAMON COLONY	81.0	13.0	15.8	52.2	64.4	High
KOLLAM	Ayoor [4591]	AKG	81.0	3.0	54.0	24.0	29.6	Medium
KOLLAM	Ayoor [4591]	AKKAL JN	81.0	12.0	53.9	15.1	18.6	Low
KOLLAM	Ayoor [4591]	AMBADI	81.0	5.0	45.9	30.1	37.2	Medium
KOLLAM	Ayoor [4591]	AMBALAMUKKU	129.0	20.2	55.0	53.8	41.7	Medium
KOLLAM	Ayoor [4591]	ANAKOTTUR	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Ayoor [4591]	ARKKANNUR	129.0	11.0	13.0	105.0	81.4	Very High
KOLLAM	Ayoor [4591]	AYIRAVALLY	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	Ayoor [4591]	AYOOR CASHEW FACTORY	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Ayoor [4591]	AYUR MARKET	81.0	0.0	56.0	25.0	30.9	Medium
KOLLAM	Ayoor [4591]	AYUR OFFICE	202.0	16.0	80.7	105.3	52.1	High
KOLLAM	Ayoor [4591]	BHUVANESWARI	81.0	3.0	28.0	50.0	61.7	High
KOLLAM	Ayoor [4591]	BIA WATER PATTANIMUKKU	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Ayoor [4591]	BISMI	81.0	0.0	19.0	62.0	76.5	Very High
KOLLAM	Ayoor [4591]	CHANGODE	81.0	0.0	19.0	62.0	76.5	Very High
KOLLAM	Ayoor [4591]	CHERIYAVELINALOOR	129.0	8.0	37.0	84.0	65.1	High
KOLLAM	Ayoor [4591]	CHERUVAKKAL	129.0	7.2	35.0	86.8	67.2	High
KOLLAM	Ayoor [4591]	CHIRAMUKKU	81.0	21.0	35.0	25.0	30.9	Medium
KOLLAM	Ayoor [4591]	CHOO LAPALAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	CHUNDA	81.0	11.0	48.0	22.0	27.1	Medium
KOLLAM	Ayoor [4591]	CHUNDA PHC	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	CHUNDAMUGAL	81.0	3.0	48.4	29.6	36.5	Medium
KOLLAM	Ayoor [4591]	ELAMADU SOCIETY	81.0	8.0	72.0	1.0	1.2	Very Low
KOLLAM	Ayoor [4591]	ERAPPANPARA	81.0	5.0	5.0	71.0	87.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ayoor [4591]	FLY ASH	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	GOURIMUKKU	51.0	0.0	0.0	51.0	100.0	Very High
KOLLAM	Ayoor [4591]	HATCHERY	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Ayoor [4591]	IRAPPIL	81.0	5.0	3.0	73.0	90.1	Very High
KOLLAM	Ayoor [4591]	ISWARYA AUDITORIUM	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Ayoor [4591]	ITTIVAPALLY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	JHS	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Ayoor [4591]	K AND K CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Ayoor [4591]	KALAPPILA	81.0	3.0	13.7	64.3	79.4	Very High
KOLLAM	Ayoor [4591]	KALIMA SCHOOL	81.0	20.0	3.0	58.0	71.6	High
KOLLAM	Ayoor [4591]	KALLUVILA WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	KALLYANIMUKKU	81.0	0.0	28.3	52.7	65.1	High
KOLLAM	Ayoor [4591]	KAMBANCODE	81.0	24.0	28.0	29.0	35.8	Medium
KOLLAM	Ayoor [4591]	KANJIRAMMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	KANNAMCODU	81.0	0.0	78.9	2.1	2.6	Very Low
KOLLAM	Ayoor [4591]	KARALIKONAM MARKET	81.0	5.0	31.3	44.7	55.2	High
KOLLAM	Ayoor [4591]	KARALIKONNAM MOSQUE	81.0	0.0	18.0	63.0	77.8	Very High
KOLLAM	Ayoor [4591]	KARALIKONNAM-VALAVU	129.0	0.0	41.0	88.0	68.2	High
KOLLAM	Ayoor [4591]	KARAVARAM VENGOOR	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Ayoor [4591]	KASHANDIMUKKU	81.0	6.0	15.4	59.6	73.5	High
KOLLAM	Ayoor [4591]	KATTUVAMUKKU	81.0	0.0	12.5	68.5	84.6	Very High
KOLLAM	Ayoor [4591]	KAVALAKKAPACHA	81.0	0.0	3.4	77.6	95.8	Very High
KOLLAM	Ayoor [4591]	KAVANAMKONNAM	129.0	5.0	35.0	89.0	69.0	High
KOLLAM	Ayoor [4591]	KEEZHATTOOR	81.0	3.0	68.0	10.0	12.3	Low
KOLLAM	Ayoor [4591]	KOLLUKONAM	81.0	5.0	29.0	47.0	58.0	High
KOLLAM	Ayoor [4591]	KOLUVAL	81.0	0.0	11.9	69.1	85.3	Very High
KOLLAM	Ayoor [4591]	KOOLIKODE	81.0	3.0	0.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ayoor [4591]	KOSHY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	KOTTAKKAVILA	81.0	0.0	36.0	45.0	55.6	High
KOLLAM	Ayoor [4591]	KULANJI WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	KULANJIYIL	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Ayoor [4591]	KUNDAYAM	81.0	0.0	15.4	65.6	80.9	Very High
KOLLAM	Ayoor [4591]	KUZHIYAM CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	LITTLE FLOWER	81.0	6.0	26.0	49.0	60.5	High
KOLLAM	Ayoor [4591]	MAKKULAM	81.0	0.0	13.1	67.9	83.8	Very High
KOLLAM	Ayoor [4591]	MANIYAN MUKKU	81.0	5.0	27.0	49.0	60.5	High
KOLLAM	Ayoor [4591]	MANJAPPARA	81.0	5.0	15.0	61.0	75.3	Very High
KOLLAM	Ayoor [4591]	MANJAPPARA WOOD	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Ayoor [4591]	MOONU MUKKU	81.0	3.0	11.0	67.0	82.7	Very High
KOLLAM	Ayoor [4591]	MULAYAMPALLY	81.0	5.0	0.0	76.0	93.8	Very High
KOLLAM	Ayoor [4591]	NEERAICODU	81.0	0.0	37.0	44.0	54.3	High
KOLLAM	Ayoor [4591]	NSS	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Ayoor [4591]	OZHUKUPARAKKAL	81.0	0.0	20.5	60.5	74.7	High
KOLLAM	Ayoor [4591]	PARAKKADA	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	Ayoor [4591]	PATTANI MUKKU	81.0	0.0	19.0	62.0	76.5	Very High
KOLLAM	Ayoor [4591]	PAVOOR	129.0	0.0	32.0	97.0	75.2	Very High
KOLLAM	Ayoor [4591]	PERAPPAYAM	81.0	15.0	32.0	34.0	42.0	Medium
KOLLAM	Ayoor [4591]	PERINGALLOOR	81.0	5.0	27.0	49.0	60.5	High
KOLLAM	Ayoor [4591]	POIKAYIL	81.0	5.0	4.3	71.7	88.5	Very High
KOLLAM	Ayoor [4591]	PULIKUZH Y CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Ayoor [4591]	PUTHIYIDAM	81.0	5.0	0.0	76.0	93.8	Very High
KOLLAM	Ayoor [4591]	PUTHUPADAPU	81.0	0.0	36.5	44.5	54.9	High
KOLLAM	Ayoor [4591]	SALAMATH NAGAR	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Ayoor [4591]	SBI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ayoor [4591]	SUB STATION	81.0	0.0	28.0	53.0	65.4	High
KOLLAM	Ayoor [4591]	THANNIVILA	81.0	9.0	0.0	72.0	88.9	Very High
KOLLAM	Ayoor [4591]	THEMBRAKONAM	81.0	0.0	17.0	64.0	79.0	Very High
KOLLAM	Ayoor [4591]	THEVANNOOR	81.0	10.0	11.0	60.0	74.1	High
KOLLAM	Ayoor [4591]	THIRUMANGALAM	81.0	0.0	9.4	71.6	88.3	Very High
KOLLAM	Ayoor [4591]	THOTTATHARA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	VATTATHRAMALA	81.0	0.0	27.1	53.9	66.6	High
KOLLAM	Ayoor [4591]	VATTAYAM	81.0	0.0	10.0	71.0	87.6	Very High
KOLLAM	Ayoor [4591]	VAYALIKKADA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ayoor [4591]	VAYANAMoola	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Ayoor [4591]	VAYYANNAM	129.0	15.0	49.0	65.0	50.4	High
KOLLAM	Ayoor [4591]	VELLAMKOLLI	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Ayoor [4591]	VELLAvoOR	81.0	3.0	5.0	73.0	90.1	Very High
KOLLAM	Ayoor [4591]	VENGUR	81.0	3.0	9.0	69.0	85.2	Very High
KOLLAM	Ayoor [4591]	VETIKKAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	4R GRAPHICS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	A G C	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	AHAMMED TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	AJ HALL	129.0	0.0	42.0	87.0	67.5	High
KOLLAM	Cantonment Kollam [4558]	AMRITALEKSHMI TOWER	162.0	0.0	0.0	162.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	AMRITHAKULAM HOMEo	81.0	0.0	13.0	68.0	84.0	Very High
KOLLAM	Cantonment Kollam [4558]	AMRITHUKULAM	202.0	11.0	147.0	44.0	21.8	Low
KOLLAM	Cantonment Kollam [4558]	ANCHETHUKAVU	129.0	10.0	47.0	72.0	55.8	High
KOLLAM	Cantonment Kollam [4558]	ARSHA INDUSTRIES	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	AUTOWAYS	202.0	22.0	123.0	57.0	28.2	Medium
KOLLAM	Cantonment Kollam [4558]	BAKER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	BEACH	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Cantonment Kollam [4558]	BHARATA RAJNGI CHURCH	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	BHARATHA RAJNI	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	BIJLEE NAGAR	81.0	5.0	62.4	13.6	16.8	Low
KOLLAM	Cantonment Kollam [4558]	BLOOD BANK	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	BSNL	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Cantonment Kollam [4558]	CARMEL HOSTEL	81.0	0.0	59.0	22.0	27.2	Medium
KOLLAM	Cantonment Kollam [4558]	CASHEW CORPORATION	81.0	0.0	47.8	33.2	41.0	Medium
KOLLAM	Cantonment Kollam [4558]	CERAMICS	202.0	6.3	32.0	163.7	81.0	Very High
KOLLAM	Cantonment Kollam [4558]	CHAYAKKADAMUKKU	129.0	0.0	55.6	73.4	56.9	High
KOLLAM	Cantonment Kollam [4558]	CHEMMANMUKKU	202.0	0.0	50.0	152.0	75.2	Very High
KOLLAM	Cantonment Kollam [4558]	CHIKING	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	CHINNAKADA 1	405.0	40.0	24.4	340.6	84.1	Very High
KOLLAM	Cantonment Kollam [4558]	CHINNAKADA 2	405.0	0.0	15.0	390.0	96.3	Very High
KOLLAM	Cantonment Kollam [4558]	CONTONMENT	81.0	5.0	32.6	43.4	53.6	High
KOLLAM	Cantonment Kollam [4558]	COXIAL 1	121.0	0.0	15.0	106.0	87.6	Very High
KOLLAM	Cantonment Kollam [4558]	COXIAL 2	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	CREATIVE POLYMER	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	CROWN BAKERY	81.0	0.0	34.4	46.6	57.5	High
KOLLAM	Cantonment Kollam [4558]	DAIRY FARM	129.0	21.0	81.1	26.9	20.8	Low
KOLLAM	Cantonment Kollam [4558]	DDRC	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	DEFENCE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	DISTRICT HOPITAL	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	DON BOSCO	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	ELICIUM	162.0	0.0	0.0	162.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	FATHIMA ALUMINIUM	81.0	0.0	50.0	31.0	38.3	Medium
KOLLAM	Cantonment Kollam [4558]	FLAT	129.0	0.0	5.0	124.0	96.1	Very High
KOLLAM	Cantonment Kollam [4558]	FLAT-2	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Cantonment Kollam [4558]	FRIENDS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	G V ALUMINIUM	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	GANDHI PARK	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Cantonment Kollam [4558]	GANGOTHRY	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	GARBALA	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	GURUDEVAN	81.0	0.0	81.0	0.0	0.0	Very Low
KOLLAM	Cantonment Kollam [4558]	HANUMAN COVIL	129.0	10.0	0.0	119.0	92.2	Very High
KOLLAM	Cantonment Kollam [4558]	HDFC	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	HEERA PLAZA	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	HOLY CROSS	129.0	3.0	32.7	93.3	72.3	High
KOLLAM	Cantonment Kollam [4558]	HPO	129.0	0.0	30.0	99.0	76.7	Very High
KOLLAM	Cantonment Kollam [4558]	INCOME TAX	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	ISHA LODGE	129.0	10.0	51.3	67.7	52.5	High
KOLLAM	Cantonment Kollam [4558]	ISWARYA	202.0	0.0	30.0	172.0	85.1	Very High
KOLLAM	Cantonment Kollam [4558]	JAWAHAR JUNCTION	81.0	0.0	81.0	0.0	0.0	Very Low
KOLLAM	Cantonment Kollam [4558]	JEROME NAGAR 1	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	JEROME NAGAR 2	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	JEROME NAGAR 3	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	JOSE ARTS	129.0	0.0	61.0	68.0	52.7	High
KOLLAM	Cantonment Kollam [4558]	JUSTIN	129.0	23.0	64.0	42.0	32.6	Medium
KOLLAM	Cantonment Kollam [4558]	K MALL	405.0	0.0	0.0	405.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KACHIKADA	129.0	8.0	0.0	121.0	93.8	Very High
KOLLAM	Cantonment Kollam [4558]	KAILAS	405.0	0.0	0.0	405.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KALARIKAVU	129.0	8.0	76.3	44.7	34.7	Medium
KOLLAM	Cantonment Kollam [4558]	KALYAN JEWELLERS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KAMBIYITTAZHAKAM	129.0	11.0	54.0	64.0	49.6	Medium
KOLLAM	Cantonment Kollam [4558]	KAPPALANDIMUKKU	81.0	0.0	25.6	55.4	68.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Cantonment Kollam [4558]	KARTHIKA CERAMICS	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KAVERY	255.0	0.0	0.0	255.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KAYAVIL TOWERS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KELTRON	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KERALA SABDAM INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KINFRA 1	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KINFRA 2	81.0	0.0	50.0	31.0	38.3	Medium
KOLLAM	Cantonment Kollam [4558]	KINFRA 3	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KINFRA 4	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KINFRA 5	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KNF	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Cantonment Kollam [4558]	KOCHUPLAMOODU	202.0	6.0	47.2	148.8	73.7	High
KOLLAM	Cantonment Kollam [4558]	KODIMARAM	81.0	6.0	3.0	72.0	88.9	Very High
KOLLAM	Cantonment Kollam [4558]	KONDAYAM	129.0	5.0	59.0	65.0	50.4	High
KOLLAM	Cantonment Kollam [4558]	KOTTAMALA	81.0	5.0	75.7	0.3	0.3	Very Low
KOLLAM	Cantonment Kollam [4558]	KOVIL SCHOOL	129.0	5.0	69.8	54.2	42.0	Medium
KOLLAM	Cantonment Kollam [4558]	KRISTRAJ	81.0	0.0	78.8	2.2	2.8	Very Low
KOLLAM	Cantonment Kollam [4558]	KUMAR	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	KURUMPOLIL	324.0	0.0	0.0	324.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	LATHIKAMMA PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	M P FERNANDEZ	81.0	0.0	80.0	1.0	1.2	Very Low
KOLLAM	Cantonment Kollam [4558]	MA PLAST	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	MALIEAKKAL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	MANANIYA	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Cantonment Kollam [4558]	MANICHITHODE	129.0	5.0	45.6	78.4	60.8	High
KOLLAM	Cantonment Kollam [4558]	MARKET	129.0	0.0	5.0	124.0	96.1	Very High
KOLLAM	Cantonment Kollam [4558]	METRO SCAN	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Cantonment Kollam [4558]	MUNCIPAL COMPLEX	129.0	0.0	6.0	123.0	95.3	Very High
KOLLAM	Cantonment Kollam [4558]	MUNDAKKAL	81.0	9.0	62.0	10.0	12.3	Low
KOLLAM	Cantonment Kollam [4558]	MUTHOOT INDOOR	324.0	0.0	0.0	324.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	N C PILLAI	129.0	5.0	64.1	59.9	46.4	Medium
KOLLAM	Cantonment Kollam [4558]	NACHIYARMADAM	129.0	13.0	82.0	34.0	26.4	Medium
KOLLAM	Cantonment Kollam [4558]	NALUKUTTY	129.0	10.0	65.1	53.9	41.8	Medium
KOLLAM	Cantonment Kollam [4558]	NJETHUKAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	NOOH ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	O K GAS	129.0	0.0	30.0	99.0	76.7	Very High
KOLLAM	Cantonment Kollam [4558]	OORAMPALLY	81.0	0.0	66.3	14.7	18.1	Low
KOLLAM	Cantonment Kollam [4558]	OORAMPALLY INDOOR	162.0	0.0	0.0	162.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	P H E D	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Cantonment Kollam [4558]	PAIKKADA	202.0	5.0	66.0	131.0	64.9	High
KOLLAM	Cantonment Kollam [4558]	PALLITHOTTAM P O	81.0	0.0	60.2	20.8	25.7	Medium
KOLLAM	Cantonment Kollam [4558]	PAPANASAM	81.0	5.0	5.0	71.0	87.7	Very High
KOLLAM	Cantonment Kollam [4558]	PAPANASAM 2	129.0	0.0	22.0	107.0	82.9	Very High
KOLLAM	Cantonment Kollam [4558]	PARRY CO	81.0	0.0	51.0	30.0	37.0	Medium
KOLLAM	Cantonment Kollam [4558]	PARVATHY MILL	202.0	3.0	5.0	194.0	96.0	Very High
KOLLAM	Cantonment Kollam [4558]	PATTATHIL KAVU TEMPLE	129.0	8.0	38.4	82.7	64.1	High
KOLLAM	Cantonment Kollam [4558]	PATTATHILKAVE	129.0	16.0	112.9	0.1	0.1	Very Low
KOLLAM	Cantonment Kollam [4558]	PATTATHUVILA	162.0	0.0	0.0	162.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	PETER ZACHARIA INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	POLAYATHODU	405.0	18.0	92.9	294.1	72.6	High
KOLLAM	Cantonment Kollam [4558]	POLAYATHODU COMPLEX	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Cantonment Kollam [4558]	POLAYATHODU MARKET	129.0	5.0	11.0	113.0	87.6	Very High
KOLLAM	Cantonment Kollam [4558]	PONNAMMA CHAMBER	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	POWER TRACTION	202.0	15.0	87.0	100.0	49.5	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Cantonment Kollam [4558]	POWERHOUSE	202.0	0.0	19.0	183.0	90.6	Very High
KOLLAM	Cantonment Kollam [4558]	PREMIER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	PURATHE VAYAL	81.0	12.0	66.8	2.2	2.7	Very Low
KOLLAM	Cantonment Kollam [4558]	PUTHEN PURAYIL	129.0	0.0	34.6	94.4	73.2	High
KOLLAM	Cantonment Kollam [4558]	PWD	202.0	0.0	20.0	182.0	90.1	Very High
KOLLAM	Cantonment Kollam [4558]	QUILON PLASTIC	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	QUILON PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	R K MENS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	RAJHA	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	RELIANCE POLAYATHODU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	ROTO GRAPHICS	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SAI	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SAIT TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SARADA MUTT	129.0	0.0	41.0	88.0	68.2	High
KOLLAM	Cantonment Kollam [4558]	SARAVANA	202.0	0.0	5.0	197.0	97.5	Very High
KOLLAM	Cantonment Kollam [4558]	SARORA ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SEE BEE	121.0	0.0	8.0	113.0	93.4	Very High
KOLLAM	Cantonment Kollam [4558]	SHINES	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SIDHARTHA RAILWAY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SKP	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SLAUGHTER HOUSE	129.0	3.0	31.2	94.8	73.5	High
KOLLAM	Cantonment Kollam [4558]	SMP COLONY	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SN 1	129.0	0.0	11.0	118.0	91.5	Very High
KOLLAM	Cantonment Kollam [4558]	SN 2	129.0	0.0	79.4	49.6	38.5	Medium
KOLLAM	Cantonment Kollam [4558]	SN WOMENS	81.0	10.0	55.0	16.0	19.8	Low
KOLLAM	Cantonment Kollam [4558]	SNV TILES	129.0	0.0	53.0	76.0	58.9	High
KOLLAM	Cantonment Kollam [4558]	SOPANAM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Cantonment Kollam [4558]	SOPHIYA COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SP OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SPM RESIDENCY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SS WARD1	202.0	0.0	5.0	197.0	97.5	Very High
KOLLAM	Cantonment Kollam [4558]	SSWARD 2	129.0	3.0	77.1	48.9	37.9	Medium
KOLLAM	Cantonment Kollam [4558]	ST ANTONYS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	ST REDDIAR	202.0	0.0	8.0	194.0	96.0	Very High
KOLLAM	Cantonment Kollam [4558]	STADIUM	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	STANES	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SUBRAMANIA ALUMINIUM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	SWAMINATHAN	81.0	8.0	31.0	42.0	51.9	High
KOLLAM	Cantonment Kollam [4558]	TALUK CUTCHERY	129.0	3.0	34.0	92.0	71.3	High
KOLLAM	Cantonment Kollam [4558]	TB HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	TD COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	TECHNOPARK	129.0	10.0	17.5	101.5	78.7	Very High
KOLLAM	Cantonment Kollam [4558]	THAMARAKULAM 1	202.0	18.0	16.0	168.0	83.2	Very High
KOLLAM	Cantonment Kollam [4558]	THAMARAKULAM 2	202.0	5.0	25.0	172.0	85.1	Very High
KOLLAM	Cantonment Kollam [4558]	THILLERY	129.0	10.0	89.7	29.3	22.7	Low
KOLLAM	Cantonment Kollam [4558]	THILLERY CHURCH	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Cantonment Kollam [4558]	THUMPARA	129.0	26.0	101.1	1.9	1.4	Very Low
KOLLAM	Cantonment Kollam [4558]	THUMPARA FLAT	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Cantonment Kollam [4558]	UCO BANK	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	VADAYATTU KOTTAH	405.0	0.0	10.0	395.0	97.5	Very High
KOLLAM	Cantonment Kollam [4558]	VADAYATTUKOTTA - 2	202.0	0.0	3.0	199.0	98.5	Very High
KOLLAM	Cantonment Kollam [4558]	VAYALILTOPE	129.0	5.0	70.0	54.0	41.9	Medium
KOLLAM	Cantonment Kollam [4558]	VEDIKKUNNIL	129.0	0.0	6.0	123.0	95.3	Very High
KOLLAM	Cantonment Kollam [4558]	VGP RESIDENCY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Cantonment Kollam [4558]	VICTORIA	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Cantonment Kollam [4558]	VICTORIA LAUNDRY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	VT IMPEX	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Cantonment Kollam [4558]	VYAPARA BHAVAN	162.0	0.0	0.0	162.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	WATER AUTHORITY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Cantonment Kollam [4558]	YMCA	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Chadayamangalam [4672]	AKKONAM	81.0	0.0	21.0	60.0	74.1	High
KOLLAM	Chadayamangalam [4672]	ALATHARAMALA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	ALAYIL	81.0	6.0	23.0	52.0	64.2	High
KOLLAM	Chadayamangalam [4672]	ANAPPARA	81.0	0.0	8.5	72.5	89.5	Very High
KOLLAM	Chadayamangalam [4672]	ATTIYIL	81.0	10.0	20.0	51.0	63.0	High
KOLLAM	Chadayamangalam [4672]	BENGLAMKUNNU	129.0	8.0	44.5	76.5	59.3	High
KOLLAM	Chadayamangalam [4672]	BHOOTHATHANKUNNU	81.0	5.0	0.0	76.0	93.8	Very High
KOLLAM	Chadayamangalam [4672]	BUILD HUB	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	CDLM SOCITY	81.0	0.0	17.0	64.0	79.0	Very High
KOLLAM	Chadayamangalam [4672]	CHADAYAMANGALAM TOWN	129.0	5.0	25.2	98.8	76.6	Very High
KOLLAM	Chadayamangalam [4672]	CHERATTUKUZH	129.0	3.0	83.0	43.0	33.3	Medium
KOLLAM	Chadayamangalam [4672]	COMPANYMALA	81.0	6.0	71.7	3.3	4.1	Very Low
KOLLAM	Chadayamangalam [4672]	EDAKKODU	81.0	8.0	13.7	59.3	73.2	High
KOLLAM	Chadayamangalam [4672]	EDATHARA	129.0	0.0	3.0	126.0	97.7	Very High
KOLLAM	Chadayamangalam [4672]	EDUKKUPARA	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Chadayamangalam [4672]	ELAMPAZHANNOOR	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Chadayamangalam [4672]	ELAVAKKODU	81.0	0.0	17.4	63.6	78.5	Very High
KOLLAM	Chadayamangalam [4672]	FARADAY EV	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	GANAPATHI NADA	129.0	10.0	34.0	85.0	65.9	High
KOLLAM	Chadayamangalam [4672]	GOVT HOSPITAL CHADAYAMAGALAM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chadayamangalam [4672]	HARISREE HOSPITEL	81.0	0.0	19.7	61.3	75.6	Very High
KOLLAM	Chadayamangalam [4672]	HYDEN PARK	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	INDUS	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	Chadayamangalam [4672]	KADANNOOR	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Chadayamangalam [4672]	KAKKODU	81.0	0.0	28.4	52.6	64.9	High
KOLLAM	Chadayamangalam [4672]	KALAYAM	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	Chadayamangalam [4672]	KALLADATHANNI	81.0	11.0	52.0	18.0	22.2	Low
KOLLAM	Chadayamangalam [4672]	KANNAMCODE-NML	81.0	5.0	32.0	44.0	54.3	High
KOLLAM	Chadayamangalam [4672]	KARINTHALAKKODU	129.0	29.0	66.0	34.0	26.4	Medium
KOLLAM	Chadayamangalam [4672]	KATTADIMOODU	81.0	3.0	37.7	40.3	49.7	Medium
KOLLAM	Chadayamangalam [4672]	KIA MOTORS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	KIZHUTHONI	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Chadayamangalam [4672]	KOCHALUMMOODU	81.0	3.0	27.0	51.0	62.9	High
KOLLAM	Chadayamangalam [4672]	KOPPAM	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Chadayamangalam [4672]	KURIYODU	129.0	0.0	81.7	47.3	36.6	Medium
KOLLAM	Chadayamangalam [4672]	KUZHİYAM	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Chadayamangalam [4672]	MADANNADA	81.0	3.0	13.0	65.0	80.2	Very High
KOLLAM	Chadayamangalam [4672]	MAHADEVA TEMPLE	81.0	16.0	39.8	25.2	31.1	Medium
KOLLAM	Chadayamangalam [4672]	MANGALATH	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	MANNAN PARAMBU	81.0	3.0	11.0	67.0	82.7	Very High
KOLLAM	Chadayamangalam [4672]	MEDAYIL	129.0	18.0	44.0	67.0	51.9	High
KOLLAM	Chadayamangalam [4672]	MGHS	129.0	0.0	29.0	100.0	77.5	Very High
KOLLAM	Chadayamangalam [4672]	MINI	202.0	11.0	6.0	185.0	91.6	Very High
KOLLAM	Chadayamangalam [4672]	MINI ESTATE	129.0	0.0	39.3	89.7	69.5	High
KOLLAM	Chadayamangalam [4672]	MINI II	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chadayamangalam [4672]	MOOLAMCODE	81.0	3.0	33.0	45.0	55.6	High
KOLLAM	Chadayamangalam [4672]	MOOPPANMUKKU	81.0	6.0	24.0	51.0	63.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chadayamangalam [4672]	MOSQUE	81.0	0.0	26.0	55.0	67.9	High
KOLLAM	Chadayamangalam [4672]	MULAYAKKONAM	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Chadayamangalam [4672]	MULAYAM	81.0	0.0	4.0	77.0	95.1	Very High
KOLLAM	Chadayamangalam [4672]	MURUKKUMON	81.0	8.0	41.0	32.0	39.5	Medium
KOLLAM	Chadayamangalam [4672]	NETTAYAM	81.0	6.0	22.0	53.0	65.4	High
KOLLAM	Chadayamangalam [4672]	NETTETHARA	81.0	6.0	20.4	54.6	67.4	High
KOLLAM	Chadayamangalam [4672]	NILAMEL-I	202.0	10.0	36.0	156.0	77.2	Very High
KOLLAM	Chadayamangalam [4672]	NILAMEL-II	129.0	0.0	21.0	108.0	83.7	Very High
KOLLAM	Chadayamangalam [4672]	NML PANCHAYATH	81.0	10.0	15.0	56.0	69.1	High
KOLLAM	Chadayamangalam [4672]	ORION PLAZA	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	PALLIKUNNUMPURAM	81.0	12.0	55.4	13.6	16.7	Low
KOLLAM	Chadayamangalam [4672]	PALOORKONAM	81.0	8.0	39.0	34.0	42.0	Medium
KOLLAM	Chadayamangalam [4672]	PANAYIL	81.0	3.0	27.0	51.0	63.0	High
KOLLAM	Chadayamangalam [4672]	PARUTHIYIL	129.0	0.0	13.8	115.2	89.3	Very High
KOLLAM	Chadayamangalam [4672]	PATTAM	51.0	6.0	9.0	36.0	70.6	High
KOLLAM	Chadayamangalam [4672]	PITTAPPALLY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	POONKODU	129.0	5.0	30.5	93.5	72.5	High
KOLLAM	Chadayamangalam [4672]	PRASADMUKKU	81.0	5.0	3.0	73.0	90.1	Very High
KOLLAM	Chadayamangalam [4672]	PULLIPACHAYIYIL	81.0	16.0	19.0	46.0	56.8	High
KOLLAM	Chadayamangalam [4672]	PUTHENVILA	81.0	6.0	12.0	63.0	77.8	Very High
KOLLAM	Chadayamangalam [4672]	PUTHUSSERI	81.0	8.0	60.0	13.0	16.1	Low
KOLLAM	Chadayamangalam [4672]	TESLA KARAVARAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	THARA	81.0	9.0	51.0	21.0	25.9	Medium
KOLLAM	Chadayamangalam [4672]	THERUVIN BHAGAM	81.0	0.0	21.0	60.0	74.1	High
KOLLAM	Chadayamangalam [4672]	THIRUVAIKODE	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chadayamangalam [4672]	THIRUVAZHI	81.0	3.0	6.0	72.0	88.9	Very High
KOLLAM	Chadayamangalam [4672]	VALAYIDOM	81.0	6.0	32.0	43.0	53.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chadayamangalam [4672]	VALIYAVAZHY	81.0	13.0	16.0	52.0	64.2	High
KOLLAM	Chadayamangalam [4672]	VAZHODU	81.0	13.0	26.0	42.0	51.9	High
KOLLAM	Chadayamangalam [4672]	VELLAMPARA	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Chadayamangalam [4672]	VELLARY	20.0	0.0	0.0	20.0	100.0	Very High
KOLLAM	Chadayamangalam [4672]	VETTUVAZHY	129.0	0.0	44.0	85.0	65.9	High
KOLLAM	Chadayamangalam [4672]	VETTUVAZHY SCHOOL	81.0	13.0	13.0	55.0	67.9	High
KOLLAM	Chadayamangalam [4672]	VEYKAL	81.0	3.0	23.0	55.0	67.9	High
KOLLAM	Chadayamangalam [4672]	VISHWAKARMA HALL	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Chadayamangalam [4672]	ZIRA INDUSTRY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	ACHUTHAN MUKKU	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Chathannoor [4575]	ADICHANALLOOR TOWN	81.0	3.0	33.0	45.0	55.6	High
KOLLAM	Chathannoor [4575]	ADICHANALLOOR VILLAGE	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chathannoor [4575]	ADICHANALLOOR SOCIETY	81.0	0.0	33.0	48.0	59.3	High
KOLLAM	Chathannoor [4575]	ADIMUKKU	81.0	10.0	40.0	31.0	38.3	Medium
KOLLAM	Chathannoor [4575]	ADUTHALA	81.0	10.0	30.0	41.0	50.6	High
KOLLAM	Chathannoor [4575]	ADUTHALA ASWATHY CRU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	ADUTHALAKOORAPALLY	81.0	3.0	13.0	65.0	80.2	Very High
KOLLAM	Chathannoor [4575]	ALUVILA	81.0	0.0	36.3	44.7	55.2	High
KOLLAM	Chathannoor [4575]	AMBANAD	81.0	0.0	36.2	44.8	55.2	High
KOLLAM	Chathannoor [4575]	AN CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	ANAMCHAL	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Chathannoor [4575]	APPOOPPAN KAVU	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Chathannoor [4575]	ASLAM CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	BABA TECH	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	BETHEL	81.0	5.0	42.0	34.0	42.0	Medium
KOLLAM	Chathannoor [4575]	BHOOTHANATHA NO-II	81.0	15.0	37.5	28.5	35.2	Medium
KOLLAM	Chathannoor [4575]	BHOOTHATHAN NADA	81.0	0.0	79.8	1.2	1.4	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chathannoor [4575]	BLOCK OFFICE	81.0	5.0	31.4	44.6	55.0	High
KOLLAM	Chathannoor [4575]	CHAMAVILA	81.0	13.0	20.0	48.0	59.3	High
KOLLAM	Chathannoor [4575]	CHANDRIKA	129.0	0.0	47.0	82.0	63.6	High
KOLLAM	Chathannoor [4575]	CHERUPALAKKODU	81.0	5.0	23.0	53.0	65.4	High
KOLLAM	Chathannoor [4575]	CHOORAPOIKA	81.0	3.0	29.0	49.0	60.5	High
KOLLAM	Chathannoor [4575]	CHR TOWN	405.0	5.0	86.5	313.5	77.4	Very High
KOLLAM	Chathannoor [4575]	CINTEX	81.0	3.0	18.0	60.0	74.1	High
KOLLAM	Chathannoor [4575]	CIVIL STATION	81.0	8.0	23.8	49.2	60.7	High
KOLLAM	Chathannoor [4575]	CP JUNCTION	81.0	3.0	61.0	17.0	21.0	Low
KOLLAM	Chathannoor [4575]	EDANADU KANAL	81.0	0.0	41.0	40.0	49.4	Medium
KOLLAM	Chathannoor [4575]	ENAM TOWER	162.0	0.0	0.0	162.0	100.0	Very High
KOLLAM	Chathannoor [4575]	I T-I	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	ITHIKKARA BEND	129.0	3.0	67.0	59.0	45.7	Medium
KOLLAM	Chathannoor [4575]	JAFFER FOODS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	JANANI	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Chathannoor [4575]	JESMI	81.0	3.0	39.0	39.0	48.1	Medium
KOLLAM	Chathannoor [4575]	JSM	81.0	3.0	20.0	58.0	71.6	High
KOLLAM	Chathannoor [4575]	KAITHAKKUZHI LPS	81.0	0.0	28.0	53.0	65.4	High
KOLLAM	Chathannoor [4575]	KAITHAKUZHI	81.0	0.0	36.0	45.0	55.6	High
KOLLAM	Chathannoor [4575]	KALIYAKKULAM	51.0	5.0	12.6	33.4	65.5	High
KOLLAM	Chathannoor [4575]	KALLUVETTAM KUZHI	81.0	6.0	47.3	27.7	34.2	Medium
KOLLAM	Chathannoor [4575]	KANJIRAM VILA TEMBLE	81.0	0.0	78.2	2.9	3.5	Very Low
KOLLAM	Chathannoor [4575]	KANNETTA	81.0	0.0	81.0	0.0	0.0	Very Low
KOLLAM	Chathannoor [4575]	KANNETTA TEMPLE	81.0	3.0	22.0	56.0	69.1	High
KOLLAM	Chathannoor [4575]	KARAMCODE	129.0	0.0	37.3	91.7	71.1	High
KOLLAM	Chathannoor [4575]	KATTACHAL	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Chathannoor [4575]	KATTACHAL VAYAL	81.0	5.0	10.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chathannoor [4575]	KAVANAPALLY	81.0	5.0	12.3	63.7	78.6	Very High
KOLLAM	Chathannoor [4575]	KAYOLIN	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Chathannoor [4575]	KEDAS	81.0	8.0	27.0	46.0	56.8	High
KOLLAM	Chathannoor [4575]	KERALA	202.0	10.0	53.3	138.7	68.7	High
KOLLAM	Chathannoor [4575]	KINAR MUKKU	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Chathannoor [4575]	KINGSTON	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	KOCHALUMMOOD	129.0	3.0	75.0	51.0	39.5	Medium
KOLLAM	Chathannoor [4575]	KOLLAIKKAL	81.0	6.0	41.0	34.0	42.0	Medium
KOLLAM	Chathannoor [4575]	KOLLAKUZH	129.0	10.0	48.0	71.0	55.0	High
KOLLAM	Chathannoor [4575]	KOSHNAKAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	KOTHERI	81.0	8.0	53.0	20.0	24.7	Low
KOLLAM	Chathannoor [4575]	KOTTUVILA CHERIYA KALUNGU	81.0	0.0	50.0	31.0	38.3	Medium
KOLLAM	Chathannoor [4575]	KOUTUVILA	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Chathannoor [4575]	KOYIPPADU	129.0	6.0	76.0	47.0	36.4	Medium
KOLLAM	Chathannoor [4575]	KUMMALLOOR	81.0	13.0	45.0	23.0	28.4	Medium
KOLLAM	Chathannoor [4575]	KUNDUMON JUNCTION	81.0	14.0	23.0	44.0	54.3	High
KOLLAM	Chathannoor [4575]	KUNDUMON PALAM	81.0	5.0	5.0	71.0	87.7	Very High
KOLLAM	Chathannoor [4575]	KUNDUMON-1	129.0	15.0	32.0	82.0	63.6	High
KOLLAM	Chathannoor [4575]	KUNNUMPURAM	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Chathannoor [4575]	KURISHADI	81.0	5.0	32.0	44.0	54.3	High
KOLLAM	Chathannoor [4575]	KURUNGAL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	KURUNGAL NAGAR	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chathannoor [4575]	KUZHUPPIL	51.0	0.0	8.0	43.0	84.3	Very High
KOLLAM	Chathannoor [4575]	LIC	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chathannoor [4575]	LM MALL	405.0	0.0	0.0	405.0	100.0	Very High
KOLLAM	Chathannoor [4575]	LMS	81.0	0.0	61.1	19.9	24.6	Low
KOLLAM	Chathannoor [4575]	M C PURAM-ARADHANA	81.0	9.0	46.3	25.7	31.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chathannoor [4575]	MALAYATTIKKONAM	81.0	3.0	19.0	59.0	72.8	High
KOLLAM	Chathannoor [4575]	MAMPALLIKUNNAM	81.0	3.0	11.0	67.0	82.7	Very High
KOLLAM	Chathannoor [4575]	MARAKKULAM	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Chathannoor [4575]	MARAKKULAM KADAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	MARANKUZH	81.0	3.0	30.8	47.2	58.3	High
KOLLAM	Chathannoor [4575]	MEENADU EAST	81.0	0.0	23.0	58.0	71.6	High
KOLLAM	Chathannoor [4575]	MEENADU PALAM	129.0	5.0	49.4	74.6	57.8	High
KOLLAM	Chathannoor [4575]	MEENADU PUMP HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	MEENADU SIVA TEMPLE	81.0	0.0	20.3	60.7	74.9	High
KOLLAM	Chathannoor [4575]	MELAVILA	81.0	0.0	41.0	40.0	49.4	Medium
KOLLAM	Chathannoor [4575]	MES	81.0	6.0	20.0	55.0	67.9	High
KOLLAM	Chathannoor [4575]	MGM NEHRU SCHOOL	81.0	0.0	35.3	45.7	56.4	High
KOLLAM	Chathannoor [4575]	MUTTAKKAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	N S S	81.0	5.5	75.5	0.0	0.0	Very Low
KOLLAM	Chathannoor [4575]	NETHAVU MUKKU	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Chathannoor [4575]	NILAMEL VAYAL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	NJAVAROOR KADAVU	81.0	13.0	15.8	52.2	64.4	High
KOLLAM	Chathannoor [4575]	OMEGA	81.0	5.0	48.0	28.0	34.6	Medium
KOLLAM	Chathannoor [4575]	PAKALVEEDU	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Chathannoor [4575]	PANCHAMI CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	PANCHAYATH HS	81.0	3.0	45.7	32.3	39.9	Medium
KOLLAM	Chathannoor [4575]	PANIYIL	81.0	9.0	49.0	23.0	28.4	Medium
KOLLAM	Chathannoor [4575]	PANIYIL GURUMANDIRAM	81.0	3.0	5.0	73.0	90.1	Very High
KOLLAM	Chathannoor [4575]	PARAYIL KADA	129.0	0.0	32.0	97.0	75.2	Very High
KOLLAM	Chathannoor [4575]	PERUMALKUNNU	81.0	13.0	35.5	32.5	40.1	Medium
KOLLAM	Chathannoor [4575]	PLAMOODU	81.0	0.0	85.0	0.0	0.0	Very Low
KOLLAM	Chathannoor [4575]	POLICE STATION	81.0	0.0	32.0	49.0	60.5	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chathannoor [4575]	POST OFFICE	81.0	5.0	23.0	53.0	65.4	High
KOLLAM	Chathannoor [4575]	PRIYADERSINI	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Chathannoor [4575]	RAJADURAI	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	RAYON POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	S N COLLEGE	81.0	8.0	67.0	6.0	7.4	Very Low
KOLLAM	Chathannoor [4575]	S R BRICKS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	SANKER COLLEGE	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Chathannoor [4575]	SARASWATHY CRUSHER	129.0	0.0	9.5	119.5	92.6	Very High
KOLLAM	Chathannoor [4575]	SEELANTHI MUKKU	81.0	0.0	32.0	49.0	60.5	High
KOLLAM	Chathannoor [4575]	SEEMATTI	81.0	0.0	79.5	1.5	1.8	Very Low
KOLLAM	Chathannoor [4575]	SHIVALAYA BITUMIN PLANT	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Chathannoor [4575]	SHIVALAYA MIXING PLANT	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Chathannoor [4575]	SREENIKETHAN	81.0	5.0	37.0	39.0	48.1	Medium
KOLLAM	Chathannoor [4575]	SREESASTHA	81.0	18.0	44.3	18.7	23.1	Low
KOLLAM	Chathannoor [4575]	ST GEORGE CHURCH	81.0	6.0	53.2	21.8	27.0	Medium
KOLLAM	Chathannoor [4575]	STANDARD JUNCTION	81.0	3.0	41.0	37.0	45.7	Medium
KOLLAM	Chathannoor [4575]	SUBRAMANYA	81.0	10.0	55.0	16.0	19.8	Low
KOLLAM	Chathannoor [4575]	SUJILEE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	TB HOSPITAL	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Chathannoor [4575]	THEMBRA	81.0	0.0	6.5	74.5	92.0	Very High
KOLLAM	Chathannoor [4575]	THEMPARA KANAL	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	Chathannoor [4575]	THONIKKADAVU	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Chathannoor [4575]	THOTTAVARAM	81.0	0.0	36.0	45.0	55.6	High
KOLLAM	Chathannoor [4575]	ULIYANADU SCHOOL	81.0	15.0	46.0	20.0	24.7	Low
KOLLAM	Chathannoor [4575]	URAM VILA	129.0	0.0	106.0	23.0	17.8	Low
KOLLAM	Chathannoor [4575]	VAIDYARUMUKKU	81.0	3.0	20.0	58.0	71.6	High
KOLLAM	Chathannoor [4575]	VALLAKKADAVU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chathannoor [4575]	VARINJAM	81.0	3.0	38.0	40.0	49.4	Medium
KOLLAM	Chathannoor [4575]	VARINJAM KAITHARY	81.0	11.0	68.5	1.5	1.9	Very Low
KOLLAM	Chathannoor [4575]	VARINJAM KOVIL	81.0	3.0	43.0	35.0	43.2	Medium
KOLLAM	Chathannoor [4575]	VAYALILKKADA	81.0	0.0	24.0	57.0	70.4	High
KOLLAM	Chathannoor [4575]	VELLICHIKALA	81.0	0.0	41.0	40.0	49.4	Medium
KOLLAM	Chathannoor [4575]	VENAD-INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chathannoor [4575]	VETTIKKUNNU VILA	81.0	3.0	51.0	27.0	33.3	Medium
KOLLAM	Chathannoor [4575]	VILAPURAM	81.0	8.0	21.0	52.0	64.2	High
KOLLAM	Chathannoor [4575]	VIMAL STORE	81.0	9.0	28.0	44.0	54.3	High
KOLLAM	Chathannoor [4575]	VYDHUTHI BHAVAN	81.0	3.0	11.0	67.0	82.7	Very High
KOLLAM	Chavara [4571]	AK ICE PLANT	81.0	3.0	9.0	69.0	85.2	Very High
KOLLAM	Chavara [4571]	ALTHARAMOODU	81.0	38.0	43.0	0.0	0.0	Very Low
KOLLAM	Chavara [4571]	AMBILY JUNCTION	81.0	8.0	40.0	33.0	40.7	Medium
KOLLAM	Chavara [4571]	AMC	129.0	5.0	41.2	82.8	64.2	High
KOLLAM	Chavara [4571]	AMMACHAN KAVU	81.0	21.0	38.0	22.0	27.2	Medium
KOLLAM	Chavara [4571]	ARAKKAL TEMPLE	81.0	14.0	10.0	57.0	70.4	High
KOLLAM	Chavara [4571]	ARAVIND	129.0	46.0	77.3	5.7	4.4	Very Low
KOLLAM	Chavara [4571]	AVLA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	AVT	129.0	16.0	34.0	79.0	61.2	High
KOLLAM	Chavara [4571]	AYYATHANS	81.0	3.0	13.0	65.0	80.2	Very High
KOLLAM	Chavara [4571]	BAKERY JN	81.0	5.0	25.0	51.0	63.0	High
KOLLAM	Chavara [4571]	BALAVADY	81.0	31.0	50.0	0.0	0.0	Very Low
KOLLAM	Chavara [4571]	BEVERAGES	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Chavara [4571]	BHARANIKKAVU	81.0	15.0	67.7	0.0	0.0	Very Low
KOLLAM	Chavara [4571]	BINDU ICE PLANT	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Chavara [4571]	BJM COLLEGE	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Chavara [4571]	BSNL CHAVARA	129.0	3.0	13.0	113.0	87.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chavara [4571]	CHAITHRAM FOODS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	CHAITHRAM MILK SOCIETY	81.0	8.0	24.0	49.0	60.5	High
KOLLAM	Chavara [4571]	CHAKKACHINEZHUTHU	81.0	11.0	33.0	37.0	45.7	Medium
KOLLAM	Chavara [4571]	CHALLIYIL	81.0	5.0	10.0	66.0	81.5	Very High
KOLLAM	Chavara [4571]	CHAMPETTIL	81.0	8.0	53.6	19.4	24.0	Low
KOLLAM	Chavara [4571]	CHANDRAS	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Chavara [4571]	CHANDRAVILASOM BRIDGE	81.0	3.0	12.0	66.0	81.5	Very High
KOLLAM	Chavara [4571]	CHAPRAYILKADA	81.0	17.0	63.2	0.8	1.0	Very Low
KOLLAM	Chavara [4571]	CHERUKULAM	81.0	5.0	0.0	76.0	93.8	Very High
KOLLAM	Chavara [4571]	CRESCENTMUKKU	81.0	5.0	75.7	0.3	0.4	Very Low
KOLLAM	Chavara [4571]	DAIRY FARM	81.0	6.0	49.0	26.0	32.1	Medium
KOLLAM	Chavara [4571]	DALAVAPURAM BRIDGE	81.0	9.0	71.0	1.0	1.2	Very Low
KOLLAM	Chavara [4571]	DALAVAPURAM SHAPPU MUKKU	81.0	14.0	65.9	1.1	1.4	Very Low
KOLLAM	Chavara [4571]	EDATHURUTHU	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Chavara [4571]	ELAMKULAM	81.0	10.0	16.0	55.0	67.9	High
KOLLAM	Chavara [4571]	ELIZA	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Chavara [4571]	FEDERALBANK NEENDAKARA	81.0	5.0	3.0	73.0	90.1	Very High
KOLLAM	Chavara [4571]	FISHERMEN COLONY	81.0	0.0	83.0	0.0	0.0	Very Low
KOLLAM	Chavara [4571]	FISHERMEN COLONY EAST	81.0	6.0	20.0	55.0	67.9	High
KOLLAM	Chavara [4571]	FOUNDATION HOSPITAL	202.0	0.0	8.0	194.0	96.0	Very High
KOLLAM	Chavara [4571]	GIP TRANSFORMER	202.0	0.0	11.0	191.0	94.6	Very High
KOLLAM	Chavara [4571]	GUEST HOUSE	81.0	6.0	6.0	69.0	85.2	Very High
KOLLAM	Chavara [4571]	GURUMANDIRAM	81.0	9.0	44.0	28.0	34.6	Medium
KOLLAM	Chavara [4571]	HIMA	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Chavara [4571]	HOLY CROSS	81.0	0.0	31.0	50.0	61.7	High
KOLLAM	Chavara [4571]	IRE GATE	81.0	5.0	12.0	64.0	79.0	Very High
KOLLAM	Chavara [4571]	IRE132	81.0	3.0	19.0	59.0	72.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chavara [4571]	JOHN MARIYA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	JOINT JN EAST	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Chavara [4571]	JOINTJUNCTION	202.0	8.0	28.8	165.2	81.8	Very High
KOLLAM	Chavara [4571]	JOL POLE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	KADATHATTUVAYAL	81.0	13.0	24.0	44.0	54.3	High
KOLLAM	Chavara [4571]	KALLEKKULAM	81.0	11.0	33.0	37.0	45.7	Medium
KOLLAM	Chavara [4571]	KAMANKULANGARA LPS	81.0	0.0	45.0	36.0	44.4	Medium
KOLLAM	Chavara [4571]	KANNATTUKUDI	81.0	16.0	58.0	7.0	8.6	Very Low
KOLLAM	Chavara [4571]	KARALI THAICKAVU	81.0	5.0	19.0	57.0	70.4	High
KOLLAM	Chavara [4571]	KARATTALKKADAVU	81.0	8.0	35.0	38.0	46.9	Medium
KOLLAM	Chavara [4571]	KARAYIL	81.0	21.2	41.0	18.8	23.1	Low
KOLLAM	Chavara [4571]	KAREEM ARCADE	405.0	0.0	0.0	405.0	100.0	Very High
KOLLAM	Chavara [4571]	KAREETHARA KAVU	81.0	40.0	38.0	3.0	3.7	Very Low
KOLLAM	Chavara [4571]	KARITHURA	81.0	0.0	17.0	64.0	79.0	Very High
KOLLAM	Chavara [4571]	KARUNA	81.0	11.0	56.0	14.0	17.3	Low
KOLLAM	Chavara [4571]	KATTEZHATHU	81.0	9.0	14.0	58.0	71.6	High
KOLLAM	Chavara [4571]	KAVANAL KAVU	81.0	19.0	49.0	13.0	16.0	Low
KOLLAM	Chavara [4571]	KC TALKIES	81.0	8.0	0.0	73.0	90.1	Very High
KOLLAM	Chavara [4571]	KERALA SEA FOOD	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Chavara [4571]	KING FISHERIES	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	KITCHEN PLANET	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	KOCHUVEETIL COLONY	81.0	3.0	26.8	51.2	63.2	High
KOLLAM	Chavara [4571]	KOIKKAL POND	81.0	0.0	35.0	46.0	56.8	High
KOLLAM	Chavara [4571]	KOTTAKKAKAM	81.0	3.0	35.0	43.0	53.1	High
KOLLAM	Chavara [4571]	KOTTANKULANGARA	81.0	3.0	15.0	63.0	77.8	Very High
KOLLAM	Chavara [4571]	KOVILTHOTTAM CHURCH	81.0	5.0	15.0	61.0	75.3	Very High
KOLLAM	Chavara [4571]	KRISHNANNADA	81.0	23.0	37.0	21.0	25.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chavara [4571]	KUMBALATH	81.0	14.0	36.0	31.0	38.3	Medium
KOLLAM	Chavara [4571]	KUMBAZHA KAVU	81.0	5.0	5.0	71.0	87.7	Very High
KOLLAM	Chavara [4571]	KUNDATHIL KALUNGU	81.0	11.0	10.0	60.0	74.1	High
KOLLAM	Chavara [4571]	KUNJALUMMOODU	129.0	30.0	49.0	50.0	38.8	Medium
KOLLAM	Chavara [4571]	KUNNATH	81.0	14.0	6.0	61.0	75.3	Very High
KOLLAM	Chavara [4571]	KUNNUPURAM	81.0	6.0	64.7	10.3	12.8	Low
KOLLAM	Chavara [4571]	KUNNUVEETIL TEMPLE	81.0	11.0	23.0	47.0	58.0	High
KOLLAM	Chavara [4571]	KURISHUMMOODU	81.0	8.0	13.7	59.3	73.2	High
KOLLAM	Chavara [4571]	KURUVELIKKATTIL	81.0	31.0	14.0	36.0	44.4	Medium
KOLLAM	Chavara [4571]	KUTTANAZHIKAM	81.0	16.0	36.0	29.0	35.8	Medium
KOLLAM	Chavara [4571]	LIGHT HOUSE	81.0	4.0	77.0	0.0	0.0	Very Low
KOLLAM	Chavara [4571]	LOURDMATHA CONVENT	129.0	21.0	42.0	66.0	51.2	High
KOLLAM	Chavara [4571]	MADANNADA	81.0	10.0	25.0	46.0	56.8	High
KOLLAM	Chavara [4571]	MADAPPALLI	81.0	12.8	66.0	2.1	2.7	Very Low
KOLLAM	Chavara [4571]	MADAPPALLI SNDP	81.0	23.0	57.0	1.0	1.2	Very Low
KOLLAM	Chavara [4571]	MAMAMTHURUTHU WEST	81.0	8.0	8.0	65.0	80.2	Very High
KOLLAM	Chavara [4571]	MAMMANTHURUTHU	202.0	3.0	35.0	164.0	81.2	Very High
KOLLAM	Chavara [4571]	MANALY	129.0	3.0	122.6	3.4	2.7	Very Low
KOLLAM	Chavara [4571]	MANNATHARA	81.0	6.0	23.0	52.0	64.2	High
KOLLAM	Chavara [4571]	MANNATHARA WEST	81.0	6.0	32.0	43.0	53.1	High
KOLLAM	Chavara [4571]	MANNEL KADAVU	81.0	3.0	3.0	75.0	92.6	Very High
KOLLAM	Chavara [4571]	MANNOOR MUKKU	81.0	0.0	27.3	53.7	66.3	High
KOLLAM	Chavara [4571]	MARY LAND	81.0	11.0	61.0	9.0	11.1	Low
KOLLAM	Chavara [4571]	MAVELI	81.0	13.0	68.0	0.0	0.0	Very Low
KOLLAM	Chavara [4571]	MBA COLLEGE	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Chavara [4571]	MG VAYANASALA	81.0	33.0	45.0	3.0	3.7	Very Low
KOLLAM	Chavara [4571]	MINI	202.0	5.0	78.4	118.6	58.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chavara [4571]	MNPM SCHOOL	81.0	0.0	26.0	55.0	67.9	High
KOLLAM	Chavara [4571]	MONISHA	81.0	3.0	10.0	68.0	84.0	Very High
KOLLAM	Chavara [4571]	MSN INSTITUTE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	MUKKADAMUKKU	81.0	19.0	62.0	0.0	0.0	Very Low
KOLLAM	Chavara [4571]	MUKKUTHODU	81.0	5.0	24.0	52.0	64.2	High
KOLLAM	Chavara [4571]	MUKUNDAPURAM	129.0	11.0	92.0	26.0	20.2	Low
KOLLAM	Chavara [4571]	MUSALIAR ROAD	81.0	8.0	31.0	42.0	51.9	High
KOLLAM	Chavara [4571]	NADALA HOTEL	81.0	0.0	50.0	31.0	38.3	Medium
KOLLAM	Chavara [4571]	NEDUVELIL TEMPLE	81.0	11.0	16.0	54.0	66.7	High
KOLLAM	Chavara [4571]	NEELESWARAM THOPPU	81.0	10.0	43.0	28.0	34.6	Medium
KOLLAM	Chavara [4571]	NEELUVEETIL	81.0	5.0	17.0	59.0	72.8	High
KOLLAM	Chavara [4571]	NETTOS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	NJARAKKADU	81.0	3.0	54.0	24.0	29.6	Medium
KOLLAM	Chavara [4571]	ODUKKATHUMUKKU	81.0	3.0	37.0	41.0	50.6	High
KOLLAM	Chavara [4571]	PADANNA	81.0	15.0	36.0	30.0	37.0	Medium
KOLLAM	Chavara [4571]	PANACKKATTU	81.0	7.5	36.0	37.5	46.3	Medium
KOLLAM	Chavara [4571]	PANAMTHODIL	202.0	3.0	108.8	90.2	44.6	Medium
KOLLAM	Chavara [4571]	PANANTHODIL EV	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	PANDIT KARUPPAN NAGAR	81.0	11.0	22.0	48.0	59.3	High
KOLLAM	Chavara [4571]	PARIMANAM	129.0	3.0	13.0	113.0	87.6	Very High
KOLLAM	Chavara [4571]	PARIMANAM SOUTH	81.0	0.0	17.8	63.2	78.0	Very High
KOLLAM	Chavara [4571]	PATHISSERILKAVU	81.0	26.0	3.0	52.0	64.2	High
KOLLAM	Chavara [4571]	PMC HOSPITAL	81.0	24.0	49.0	8.0	9.9	Very Low
KOLLAM	Chavara [4571]	PORT	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Chavara [4571]	PULIMANA	81.0	18.0	39.7	23.3	28.8	Medium
KOLLAM	Chavara [4571]	PUNNAKULAM	81.0	3.0	5.0	73.0	90.1	Very High
KOLLAM	Chavara [4571]	PUTHEN KOVIL	81.0	23.0	50.2	7.8	9.6	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chavara [4571]	PUTHUKKADU SOCIETY	81.0	17.0	9.0	55.0	67.9	High
KOLLAM	Chavara [4571]	RAMEZHUTHU	81.0	8.0	20.0	53.0	65.4	High
KOLLAM	Chavara [4571]	ROHINI MARBLE	81.0	0.0	7.7	73.3	90.5	Very High
KOLLAM	Chavara [4571]	SAHAKARANA BANK	81.0	9.0	32.0	40.0	49.4	Medium
KOLLAM	Chavara [4571]	SAN JOSE	129.0	3.0	3.0	123.0	95.3	Very High
KOLLAM	Chavara [4571]	SANKARAMANGALAM	129.0	15.0	24.7	89.3	69.2	High
KOLLAM	Chavara [4571]	SANKARAMANGALAM GROUND	81.0	5.0	24.0	52.0	64.2	High
KOLLAM	Chavara [4571]	SBI	81.0	16.0	36.0	29.0	35.8	Medium
KOLLAM	Chavara [4571]	SHIFA	81.0	0.0	72.3	8.7	10.7	Low
KOLLAM	Chavara [4571]	SOCIETYMUKKU	81.0	34.0	43.0	4.0	4.9	Very Low
KOLLAM	Chavara [4571]	SREEBHADRA	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Chavara [4571]	SREYAS	81.0	16.0	11.0	54.0	66.7	High
KOLLAM	Chavara [4571]	SUB STATION	129.0	14.0	47.0	68.0	52.7	High
KOLLAM	Chavara [4571]	SUPREME	129.0	0.0	6.0	123.0	95.3	Very High
KOLLAM	Chavara [4571]	TAGORE JN	129.0	42.0	64.0	23.0	17.8	Low
KOLLAM	Chavara [4571]	THALAMUKIL	81.0	21.0	23.0	37.0	45.7	Medium
KOLLAM	Chavara [4571]	THALLATH	81.0	8.0	41.0	32.0	39.5	Medium
KOLLAM	Chavara [4571]	THANDALATHU	129.0	11.0	5.0	113.0	87.6	Very High
KOLLAM	Chavara [4571]	THANNIMOODU	129.0	27.0	95.0	7.0	5.4	Very Low
KOLLAM	Chavara [4571]	THATTASSERI PUTHUVEL	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Chavara [4571]	THAZHETHURUTHU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	THOTTINU VADAKKU	81.0	26.0	26.0	29.0	35.8	Medium
KOLLAM	Chavara [4571]	TMP	81.0	17.0	31.0	33.0	40.7	Medium
KOLLAM	Chavara [4571]	TSUNAMI	81.0	10.0	10.0	61.0	75.3	Very High
KOLLAM	Chavara [4571]	UDAYAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chavara [4571]	USHUS	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Chavara [4571]	VACHAZHA COLONY	81.0	16.0	10.0	55.0	67.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chavara [4571]	VAIDYASALA	81.0	21.9	57.0	2.1	2.5	Very Low
KOLLAM	Chavara [4571]	VAINGOLI	81.0	24.0	27.0	30.0	37.0	Medium
KOLLAM	Chavara [4571]	VATTATHARA	81.0	8.0	33.0	40.0	49.4	Medium
KOLLAM	Chavara [4571]	VATTAYYATH	81.0	27.0	50.0	4.0	4.9	Very Low
KOLLAM	Chavara [4571]	VAYALIL KADAV	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Chavara [4571]	VELITHURUTHU	81.0	18.0	25.0	38.0	46.9	Medium
KOLLAM	Chavara [4571]	VETTUMANNEL	81.0	26.0	54.0	1.0	1.2	Very Low
KOLLAM	Chavara [4571]	VIDYARAMBAM	81.0	9.0	72.0	0.0	0.0	Very Low
KOLLAM	Chavara [4571]	VIKAS	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Chavara [4571]	VILLAGE	81.0	15.0	10.9	55.1	68.1	High
KOLLAM	Chengamanad KTRA [4590]	AHIRTHIMUKKU	81.0	4.0	3.0	74.0	91.4	Very High
KOLLAM	Chengamanad KTRA [4590]	AIRTEL	81.0	0.0	33.0	48.0	59.3	High
KOLLAM	Chengamanad KTRA [4590]	ALAKUZH	129.0	0.0	12.0	117.0	90.7	Very High
KOLLAM	Chengamanad KTRA [4590]	AMBILARA	81.0	0.0	2.0	79.0	97.5	Very High
KOLLAM	Chengamanad KTRA [4590]	AMMAMADAM	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Chengamanad KTRA [4590]	AMMANAMCODE	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chengamanad KTRA [4590]	ANCHANAM KUZHI	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Chengamanad KTRA [4590]	ANCHANAMKUZHY KWA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chengamanad KTRA [4590]	ARINGADA	81.0	0.0	12.0	69.0	85.2	Very High
KOLLAM	Chengamanad KTRA [4590]	AROMA HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chengamanad KTRA [4590]	AS FEEDS	81.0	0.0	34.0	47.0	58.0	High
KOLLAM	Chengamanad KTRA [4590]	ASHRAMAM	129.0	6.0	62.0	61.0	47.3	Medium
KOLLAM	Chengamanad KTRA [4590]	BRM	81.0	0.0	23.0	58.0	71.6	High
KOLLAM	Chengamanad KTRA [4590]	CASHEW IRINGOOR	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Chengamanad KTRA [4590]	CHAKKUVARAKKAL	202.0	16.6	41.5	143.9	71.2	High
KOLLAM	Chengamanad KTRA [4590]	CHANGOTTU	81.0	3.0	11.4	66.6	82.2	Very High
KOLLAM	Chengamanad KTRA [4590]	CHEMPAKAMUKKU	81.0	0.0	24.0	57.0	70.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chengamanad KTRA [4590]	CHENGAMANAD VILLAGE	81.0	0.0	80.8	0.2	0.2	Very Low
KOLLAM	Chengamanad KTRA [4590]	CHENGAMANADU	129.0	0.0	14.0	115.0	89.1	Very High
KOLLAM	Chengamanad KTRA [4590]	CHENGAMANADU CASHEW	81.0	3.0	12.4	65.6	80.9	Very High
KOLLAM	Chengamanad KTRA [4590]	CHENGAMANADU WEST	81.0	0.0	37.1	43.9	54.2	High
KOLLAM	Chengamanad KTRA [4590]	CHETHADI	129.0	0.0	23.0	106.0	82.2	Very High
KOLLAM	Chengamanad KTRA [4590]	CHIRATTAKKONAM PANAVELI ROUTE	202.0	0.0	3.0	199.0	98.5	Very High
KOLLAM	Chengamanad KTRA [4590]	CHIRATTAKONAM JUNCTION	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Chengamanad KTRA [4590]	CHIRATTAKONAM PALAMUKKU	81.0	5.0	16.0	60.0	74.1	High
KOLLAM	Chengamanad KTRA [4590]	CKL CHARUMKUZHY	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Chengamanad KTRA [4590]	EETTIVILA	81.0	0.0	13.0	68.0	84.0	Very High
KOLLAM	Chengamanad KTRA [4590]	IRINGOOR	81.0	5.0	8.0	68.0	84.0	Very High
KOLLAM	Chengamanad KTRA [4590]	KADUVAPPARA	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Chengamanad KTRA [4590]	KALLUVILAKKU	81.0	0.0	28.6	52.4	64.6	High
KOLLAM	Chengamanad KTRA [4590]	KANIYANKUZHY	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Chengamanad KTRA [4590]	KANNAMCODE	81.0	3.0	21.0	57.0	70.4	High
KOLLAM	Chengamanad KTRA [4590]	KATHAVILA	81.0	5.0	31.2	44.8	55.3	High
KOLLAM	Chengamanad KTRA [4590]	KIZHAKKETHERUVU	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Chengamanad KTRA [4590]	KOKKAD AYIRAVALLY	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Chengamanad KTRA [4590]	KOKKADU	129.0	10.0	22.0	97.0	75.2	Very High
KOLLAM	Chengamanad KTRA [4590]	KOKKADU EXCHANGE	81.0	0.0	14.5	66.5	82.1	Very High
KOLLAM	Chengamanad KTRA [4590]	KOOTTARA JUNCTION	81.0	3.0	23.0	55.0	67.9	High
KOLLAM	Chengamanad KTRA [4590]	KOPPARA	81.0	3.0	6.0	72.0	88.9	Very High
KOLLAM	Chengamanad KTRA [4590]	KOTTARAM MUKKU	81.0	8.0	34.0	39.0	48.1	Medium
KOLLAM	Chengamanad KTRA [4590]	KOTTAVATTOM	81.0	3.0	5.0	73.0	90.1	Very High
KOLLAM	Chengamanad KTRA [4590]	KUMBICODE	81.0	5.0	30.5	45.5	56.1	High
KOLLAM	Chengamanad KTRA [4590]	KUMBIKKODU SS	81.0	5.0	16.0	60.0	74.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chengamanad KTRA [4590]	KURIAYANAMUKAL	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chengamanad KTRA [4590]	KURUMBELAZHIKAM	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Chengamanad KTRA [4590]	KURUMBELIL	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Chengamanad KTRA [4590]	KUTTIKONAM	81.0	0.0	21.0	60.0	74.1	High
KOLLAM	Chengamanad KTRA [4590]	KUTTIKONAM WOOD	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Chengamanad KTRA [4590]	LALBHAVAN	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	Chengamanad KTRA [4590]	MANGALASSERI	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chengamanad KTRA [4590]	MARTHOMA CHURCH	81.0	0.0	17.0	64.0	79.0	Very High
KOLLAM	Chengamanad KTRA [4590]	MARUKACHAL	81.0	0.0	36.0	45.0	55.6	High
KOLLAM	Chengamanad KTRA [4590]	MELILA	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Chengamanad KTRA [4590]	MILLUMUKKU	81.0	7.0	21.0	53.0	65.4	High
KOLLAM	Chengamanad KTRA [4590]	MOSCOW	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chengamanad KTRA [4590]	MOTTAKKUNNU	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Chengamanad KTRA [4590]	MOTTAVILA	81.0	0.0	18.0	63.0	77.8	Very High
KOLLAM	Chengamanad KTRA [4590]	MOTTAVILA KOTTOOR ROUTE	81.0	3.0	17.0	61.0	75.3	Very High
KOLLAM	Chengamanad KTRA [4590]	MULAVANAMKUZHY	81.0	0.0	23.0	58.0	71.6	High
KOLLAM	Chengamanad KTRA [4590]	MUTTODU JUNCTION	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Chengamanad KTRA [4590]	MYLADUMPARA	81.0	3.0	17.0	61.0	75.3	Very High
KOLLAM	Chengamanad KTRA [4590]	NADUKUNNU WEST	81.0	0.0	26.0	55.0	67.9	High
KOLLAM	Chengamanad KTRA [4590]	NEDUNJIRAPALLY	81.0	5.0	20.0	56.0	69.1	High
KOLLAM	Chengamanad KTRA [4590]	NEELAMVAYAL	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Chengamanad KTRA [4590]	NIRAPPIL	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Chengamanad KTRA [4590]	PACHOOR	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Chengamanad KTRA [4590]	PALANIRAPPU	129.0	0.0	41.8	87.2	67.6	High
KOLLAM	Chengamanad KTRA [4590]	PALLIMUKKU	129.0	3.0	66.9	59.1	45.8	Medium
KOLLAM	Chengamanad KTRA [4590]	PARA MUKKU	129.0	0.0	55.7	73.3	56.8	High
KOLLAM	Chengamanad KTRA [4590]	PARUTHI	81.0	5.0	3.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chengamanad KTRA [4590]	PATTAMALA	81.0	3.0	42.5	35.5	43.8	Medium
KOLLAM	Chengamanad KTRA [4590]	PATTAMALA CHENTHALA ROUTE	51.0	0.0	19.0	32.0	62.7	High
KOLLAM	Chengamanad KTRA [4590]	PODIYATTUVILA	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	Chengamanad KTRA [4590]	PRADIKONAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chengamanad KTRA [4590]	PUNNAVILA INDUSTRIES	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chengamanad KTRA [4590]	SANKARANMUKKU	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Chengamanad KTRA [4590]	SARANYA	51.0	0.0	0.0	51.0	100.0	Very High
KOLLAM	Chengamanad KTRA [4590]	SARIGA	81.0	5.0	31.0	45.0	55.6	High
KOLLAM	Chengamanad KTRA [4590]	SLEEBA FUELS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chengamanad KTRA [4590]	ST MARYS CASHEW FACTORY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chengamanad KTRA [4590]	THALACHIRA CANAL	129.0	0.0	43.0	86.0	66.7	High
KOLLAM	Chengamanad KTRA [4590]	THALACHIRA JN	81.0	0.0	7.0	74.0	91.4	Very High
KOLLAM	Chengamanad KTRA [4590]	THALACHIRA PALLI	81.0	5.0	36.9	39.1	48.3	Medium
KOLLAM	Chengamanad KTRA [4590]	THALACHIRA VYDYASALA	81.0	0.0	33.0	48.0	59.3	High
KOLLAM	Chengamanad KTRA [4590]	THAZHAM	81.0	0.0	19.0	62.0	76.5	Very High
KOLLAM	Chengamanad KTRA [4590]	THOTTASSERI	81.0	8.0	14.0	59.0	72.8	High
KOLLAM	Chengamanad KTRA [4590]	VADACODE	81.0	15.0	35.0	31.0	38.3	Medium
KOLLAM	Chengamanad KTRA [4590]	VASUDEVANCODE TEMPLE	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Chengamanad KTRA [4590]	VETTIKKAVALA TOWN	129.0	0.0	34.0	95.0	73.6	High
KOLLAM	Chengamanad KTRA [4590]	VILLOOR	81.0	5.0	40.0	36.0	44.4	Medium
KOLLAM	Chithara [4662]	ANNACHIMUKKU	81.0	22.0	58.9	0.1	0.1	Very Low
KOLLAM	Chithara [4662]	ARIPPAL	81.0	0.0	19.1	61.9	76.4	Very High
KOLLAM	Chithara [4662]	AYIRAKKUZHY	129.0	6.0	87.9	35.1	27.2	Medium
KOLLAM	Chithara [4662]	BHAJANAMADOM	81.0	10.0	14.0	57.0	70.4	High
KOLLAM	Chithara [4662]	BHOOTHATHANKAVU	51.0	0.0	0.0	51.0	100.0	Very High
KOLLAM	Chithara [4662]	BOUNDERMUKKU	129.0	12.0	31.0	86.0	66.7	High
KOLLAM	Chithara [4662]	BPCL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chithara [4662]	CHALLIMUKKU	81.0	5.0	42.0	34.0	42.0	Medium
KOLLAM	Chithara [4662]	CHIRAVOOR TEMPLE	81.0	0.0	32.2	48.8	60.2	High
KOLLAM	Chithara [4662]	CHITHARA BANK	129.0	0.0	39.4	89.7	69.5	High
KOLLAM	Chithara [4662]	CHITHARA MINI	121.0	5.0	32.9	83.1	68.7	High
KOLLAM	Chithara [4662]	CHITHARA SCHOOL	129.0	0.0	96.2	32.8	25.4	Medium
KOLLAM	Chithara [4662]	CHITHARA THADATHIL	129.0	13.0	107.6	8.4	6.5	Very Low
KOLLAM	Chithara [4662]	CHUMADUTHANGI	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chithara [4662]	CHURCH	81.0	5.0	29.0	47.0	58.0	High
KOLLAM	Chithara [4662]	DERPPAKKADU	129.0	8.0	37.0	84.0	65.1	High
KOLLAM	Chithara [4662]	EDAKKUNNU	81.0	3.0	17.2	60.8	75.0	Very High
KOLLAM	Chithara [4662]	ELAVUPALAM	81.0	15.0	9.0	57.0	70.4	High
KOLLAM	Chithara [4662]	ERAPPIL	81.0	0.0	21.0	60.0	74.1	High
KOLLAM	Chithara [4662]	ERUTHODU	51.0	0.0	20.0	31.0	60.8	High
KOLLAM	Chithara [4662]	ERUTTUKADU	81.0	8.0	16.0	57.0	70.4	High
KOLLAM	Chithara [4662]	GRAMAM	81.0	0.0	19.0	62.0	76.5	Very High
KOLLAM	Chithara [4662]	HSA	20.0	0.0	0.0	20.0	100.0	Very High
KOLLAM	Chithara [4662]	KALAYAPURAM	81.0	10.0	71.0	0.0	0.0	Very Low
KOLLAM	Chithara [4662]	KALAYAPURAM SETTELMENT	81.0	3.0	13.0	65.0	80.2	Very High
KOLLAM	Chithara [4662]	KALLUVETTAMKUZHY	202.0	3.0	46.0	153.0	75.7	Very High
KOLLAM	Chithara [4662]	KANJIRATHINMOODU JUNCTION	129.0	13.0	29.0	87.0	67.4	High
KOLLAM	Chithara [4662]	KANJIRATHINMOODU TOWER	81.0	0.0	51.4	29.6	36.5	Medium
KOLLAM	Chithara [4662]	KANNANKODU	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Chithara [4662]	KANOOR	81.0	3.0	21.0	57.0	70.4	High
KOLLAM	Chithara [4662]	KARARA TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chithara [4662]	KARICHIRA	202.0	5.0	28.0	169.0	83.7	Very High
KOLLAM	Chithara [4662]	KILITHATTU	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Chithara [4662]	KINATTUMUKKU	81.0	0.0	33.0	48.0	59.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chithara [4662]	KIZHAKKUMBHAGAM	129.0	0.0	28.0	101.0	78.3	Very High
KOLLAM	Chithara [4662]	KOCHALUMMOODU	81.0	3.0	38.3	39.7	49.0	Medium
KOLLAM	Chithara [4662]	KOCHUTHOTTAMMUKKU	81.0	0.0	15.7	65.3	80.6	Very High
KOLLAM	Chithara [4662]	KODIVILAKOM	81.0	25.0	38.0	18.0	22.2	Low
KOLLAM	Chithara [4662]	KOLLAYIL ARAKKADAYIL	129.0	3.0	33.0	93.0	72.1	High
KOLLAM	Chithara [4662]	KOLLAYIL VADAKKATHIL	129.0	5.0	69.9	54.1	42.0	Medium
KOLLAM	Chithara [4662]	KOLLAYIL-28	81.0	3.0	34.8	43.2	53.3	High
KOLLAM	Chithara [4662]	KOTHALA	81.0	0.0	25.2	55.8	68.9	High
KOLLAM	Chithara [4662]	KUNDAMANKARIKKAKAM	81.0	0.0	24.8	56.2	69.4	High
KOLLAM	Chithara [4662]	KUNJUMUKKU	81.0	0.0	13.0	68.0	84.0	Very High
KOLLAM	Chithara [4662]	KURAKKODU	81.0	5.0	6.0	70.0	86.4	Very High
KOLLAM	Chithara [4662]	KURINJI	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chithara [4662]	MADANKAVU	81.0	11.0	46.0	24.0	29.6	Medium
KOLLAM	Chithara [4662]	MADATHARA MELEMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chithara [4662]	MADATHARA PUMP	81.0	0.0	27.0	54.0	66.7	High
KOLLAM	Chithara [4662]	MADATHARA TOWN	129.0	6.0	46.5	76.5	59.3	High
KOLLAM	Chithara [4662]	MAHADEVARKUNNU	129.0	3.0	38.5	87.5	67.8	High
KOLLAM	Chithara [4662]	MANCODU	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Chithara [4662]	MANNARAKKODU	81.0	0.0	21.0	60.0	74.1	High
KOLLAM	Chithara [4662]	MECHERY	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Chithara [4662]	MTB	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Chithara [4662]	MUKKODU	81.0	3.0	16.0	62.0	76.5	Very High
KOLLAM	Chithara [4662]	MULLIKKADU	202.0	6.0	36.0	160.0	79.2	Very High
KOLLAM	Chithara [4662]	MUTHAYIL	81.0	5.0	17.0	59.0	72.8	High
KOLLAM	Chithara [4662]	NETTIKKUNNU	81.0	8.0	16.0	57.0	70.4	High
KOLLAM	Chithara [4662]	OZHUKUPARA	81.0	8.0	27.0	46.0	56.8	High
KOLLAM	Chithara [4662]	PACHAKKADU	81.0	8.0	38.0	35.0	43.2	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chithara [4662]	PALLIKUNNUMPURAM	81.0	9.8	38.0	33.2	41.0	Medium
KOLLAM	Chithara [4662]	PAMBUCHATHAMANNU	81.0	0.0	21.0	60.0	74.1	High
KOLLAM	Chithara [4662]	PERINGADU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chithara [4662]	PEZHUM MOODU	129.0	3.0	27.0	99.0	76.7	Very High
KOLLAM	Chithara [4662]	POTTAMAVU	51.0	0.0	0.0	51.0	100.0	Very High
KOLLAM	Chithara [4662]	PULIVELIKONAM	81.0	10.0	17.8	53.2	65.7	High
KOLLAM	Chithara [4662]	PUNAYAM	81.0	8.0	72.0	1.0	1.2	Very Low
KOLLAM	Chithara [4662]	PUNNAMANVAYAL	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Chithara [4662]	SAS RUBBERS	81.0	0.0	55.0	26.0	32.1	Medium
KOLLAM	Chithara [4662]	SASTHANADA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chithara [4662]	SATHYAMANGALAM	81.0	15.0	44.0	22.0	27.2	Medium
KOLLAM	Chithara [4662]	SIDEWALL	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	Chithara [4662]	SIVANMUKKU	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Chithara [4662]	SOCIAL FORESTRY	51.0	0.0	0.0	51.0	100.0	Very High
KOLLAM	Chithara [4662]	SOCIETY MUKKU	81.0	0.0	17.0	64.0	79.0	Very High
KOLLAM	Chithara [4662]	SOORYAKULAM	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Chithara [4662]	SREE DHANYA THEATRE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Chithara [4662]	SUKUMARANMUKKU	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Chithara [4662]	THACHOOR	81.0	0.0	26.0	55.0	67.9	High
KOLLAM	Chithara [4662]	THALAVARAMPU	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Chithara [4662]	THATTUPALAM	81.0	3.0	3.0	75.0	92.6	Very High
KOLLAM	Chithara [4662]	THERIYIL	81.0	17.0	39.0	25.0	30.9	Medium
KOLLAM	Chithara [4662]	THOOTTIKKAL	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Chithara [4662]	THUMPAMANTHODY VALAVIL	51.0	3.0	39.0	9.0	17.6	Low
KOLLAM	Chithara [4662]	THUMPAMANTHODYPALLI	129.0	6.0	47.1	75.9	58.8	High
KOLLAM	Chithara [4662]	VALAVUPACHA	81.0	8.0	64.0	9.0	11.1	Low
KOLLAM	Chithara [4662]	VANCHIYODU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Chithara [4662]	VAYALIKKADA	129.0	0.0	31.0	98.0	76.0	Very High
KOLLAM	Chithara [4662]	VENKOD	81.0	0.0	24.7	56.3	69.5	High
KOLLAM	Chithara [4662]	VENKOLLA	81.0	3.0	11.4	66.6	82.2	Very High
KOLLAM	East kallada [4583]	ARINALLOORKADAVU	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	East kallada [4583]	BELL FARMS	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	East kallada [4583]	BENGLAMCHARUVIL	81.0	8.0	31.0	42.0	51.9	High
KOLLAM	East kallada [4583]	CENTURY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	East kallada [4583]	CHAMUNDIMOOLA	81.0	0.0	17.0	64.0	79.0	Very High
KOLLAM	East kallada [4583]	CHANDRAVIL	81.0	0.0	18.0	63.0	77.8	Very High
KOLLAM	East kallada [4583]	CHEEKKAL	81.0	3.0	46.0	32.0	39.5	Medium
KOLLAM	East kallada [4583]	CHEEKKAL II	81.0	0.0	34.5	46.5	57.4	High
KOLLAM	East kallada [4583]	CHEMP	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	East kallada [4583]	CHERUPOIKA	81.0	6.0	9.0	66.0	81.5	Very High
KOLLAM	East kallada [4583]	CHITTUMALA	202.0	6.0	23.7	172.3	85.3	Very High
KOLLAM	East kallada [4583]	CHOKENKUZHYY	129.0	7.0	57.3	64.7	50.2	High
KOLLAM	East kallada [4583]	CHOTHIRAM	129.0	0.0	41.0	88.0	68.2	High
KOLLAM	East kallada [4583]	CHRISTHU RAJ	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	East kallada [4583]	CULTURAL JN	81.0	0.0	23.0	58.0	71.6	High
KOLLAM	East kallada [4583]	EDAMALA	81.0	5.0	30.8	45.2	55.8	High
KOLLAM	East kallada [4583]	EDIYAKKADAVU	129.0	18.0	32.0	79.0	61.2	High
KOLLAM	East kallada [4583]	ELAVOORKAVU	81.0	7.0	23.0	51.0	63.0	High
KOLLAM	East kallada [4583]	ERUTHANAMCADU	81.0	6.0	24.0	51.0	63.0	High
KOLLAM	East kallada [4583]	ESI	81.0	0.0	12.7	68.3	84.3	Very High
KOLLAM	East kallada [4583]	ESI II	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	East kallada [4583]	ITI	81.0	3.0	23.0	55.0	67.9	High
KOLLAM	East kallada [4583]	KAILATHUMUKKU	81.0	8.0	27.4	45.6	56.4	High
KOLLAM	East kallada [4583]	KAITHACODE REETHUPALLY	81.0	5.0	33.0	43.0	53.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	East kallada [4583]	KAITHAKKODU	129.0	16.0	56.0	57.0	44.2	Medium
KOLLAM	East kallada [4583]	KAKKATTUKADAVU	81.0	6.0	3.0	72.0	88.9	Very High
KOLLAM	East kallada [4583]	KAKKATTUKADAVU II	81.0	0.0	33.0	48.0	59.3	High
KOLLAM	East kallada [4583]	KALLUVILA	81.0	3.0	10.0	68.0	84.0	Very High
KOLLAM	East kallada [4583]	KAROOOTHARA KADAVU	81.0	10.0	16.0	55.0	67.9	High
KOLLAM	East kallada [4583]	KATTILKADAVU	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	East kallada [4583]	KAVIL	81.0	26.0	13.0	42.0	51.9	High
KOLLAM	East kallada [4583]	KIDAPPURAM	81.0	0.0	24.0	57.0	70.4	High
KOLLAM	East kallada [4583]	KOCHUPLAMOODU	81.0	18.0	46.4	16.6	20.5	Low
KOLLAM	East kallada [4583]	KODUVILA	129.0	0.0	29.0	100.0	77.5	Very High
KOLLAM	East kallada [4583]	KODUVILAPPALLY	81.0	3.0	23.4	54.6	67.4	High
KOLLAM	East kallada [4583]	KOTTAPPURAM	81.0	8.0	27.3	45.7	56.4	High
KOLLAM	East kallada [4583]	KUNNUTHARA	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	East kallada [4583]	LMS	81.0	6.0	31.0	44.0	54.3	High
KOLLAM	East kallada [4583]	MADANKAVU	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	East kallada [4583]	MARTHANDAPURAM	81.0	9.0	39.0	33.0	40.7	Medium
KOLLAM	East kallada [4583]	MOOZHY	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	East kallada [4583]	MULAVANA	202.0	11.0	75.0	116.0	57.4	High
KOLLAM	East kallada [4583]	MULLANCHANI	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	East kallada [4583]	MUNDIYARCKAL	81.0	3.0	6.0	72.0	88.9	Very High
KOLLAM	East kallada [4583]	MUTTOM	81.0	13.0	11.0	57.0	70.4	High
KOLLAM	East kallada [4583]	NEETINTURUTH	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	East kallada [4583]	NELLIVILA	81.0	6.0	0.0	75.0	92.6	Very High
KOLLAM	East kallada [4583]	NENMENI	81.0	0.0	13.0	68.0	84.0	Very High
KOLLAM	East kallada [4583]	NILAMEL NO 1	81.0	3.0	32.0	46.0	56.8	High
KOLLAM	East kallada [4583]	NILAMEL NO 2	81.0	0.0	63.0	18.0	22.2	Low
KOLLAM	East kallada [4583]	ONAMBALAM	81.0	16.0	14.0	51.0	63.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	East kallada [4583]	ONAMBALAM PUMP HOUSE	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	East kallada [4583]	OTHIRAMUKAL	81.0	5.0	16.0	60.0	74.1	High
KOLLAM	East kallada [4583]	PAINGAVELLY	81.0	3.0	33.0	45.0	55.6	High
KOLLAM	East kallada [4583]	PALANNIVILA	81.0	3.0	76.3	1.7	2.1	Very Low
KOLLAM	East kallada [4583]	PALANNIVILA OILMIL	81.0	0.0	28.0	53.0	65.4	High
KOLLAM	East kallada [4583]	PALAVILA	81.0	5.0	19.9	56.1	69.3	High
KOLLAM	East kallada [4583]	PALLIKKAMUKKU	81.0	9.1	19.4	52.5	64.8	High
KOLLAM	East kallada [4583]	PALLIKKAVILA	81.0	0.0	29.0	52.0	64.2	High
KOLLAM	East kallada [4583]	PALLIYARA	81.0	5.0	3.0	73.0	90.1	Very High
KOLLAM	East kallada [4583]	PANAVILA	81.0	5.0	17.0	59.0	72.8	High
KOLLAM	East kallada [4583]	PANNIKUZH	81.0	3.0	12.0	66.0	81.5	Very High
KOLLAM	East kallada [4583]	PARAMALA	129.0	12.0	38.0	79.0	61.2	High
KOLLAM	East kallada [4583]	PARAYIL	81.0	3.0	70.4	7.6	9.4	Very Low
KOLLAM	East kallada [4583]	PARICHERY	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	East kallada [4583]	PARIHARACODE	81.0	3.0	8.3	69.7	86.0	Very High
KOLLAM	East kallada [4583]	PATTAMTHURUTHU 1	81.0	3.1	11.0	66.9	82.6	Very High
KOLLAM	East kallada [4583]	PATTAMTHURUTHU 2	81.0	18.1	20.0	42.9	53.0	High
KOLLAM	East kallada [4583]	PERAYAM CHIRA	81.0	6.0	18.0	57.0	70.4	High
KOLLAM	East kallada [4583]	PERINGALAM 1	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	East kallada [4583]	PERINGALAM HS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	East kallada [4583]	PERINGALAM NO 2	81.0	5.0	8.3	67.7	83.6	Very High
KOLLAM	East kallada [4583]	PEZHUMTHURUTHU	81.0	3.0	13.0	65.0	80.2	Very High
KOLLAM	East kallada [4583]	POLICE STATION	81.0	0.0	27.0	54.0	66.7	High
KOLLAM	East kallada [4583]	POTTIMUKKU	129.0	5.0	40.4	83.6	64.8	High
KOLLAM	East kallada [4583]	PULIMOOTTIL KADAVU	81.0	0.0	7.0	74.0	91.4	Very High
KOLLAM	East kallada [4583]	SINGARAPPALLY	81.0	11.0	12.0	58.0	71.6	High
KOLLAM	East kallada [4583]	SOUNDARIA	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	East kallada [4583]	ST GEORGE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	East kallada [4583]	THAZHAM	81.0	0.0	15.3	65.7	81.1	Very High
KOLLAM	East kallada [4583]	THEKKEMURI	129.0	0.0	30.7	98.3	76.2	Very High
KOLLAM	East kallada [4583]	THOOMPUMMUKHAM	81.0	3.0	22.0	56.0	69.1	High
KOLLAM	East kallada [4583]	TWO ROAD	129.0	5.0	35.0	89.0	69.0	High
KOLLAM	East kallada [4583]	UPAHARAMATHA	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	East kallada [4583]	UPPOODU 1	129.0	0.0	6.0	123.0	95.3	Very High
KOLLAM	East kallada [4583]	UPPOODU II	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	East kallada [4583]	VARAMB	81.0	10.0	45.0	26.0	32.1	Medium
KOLLAM	East kallada [4583]	VAROOR	129.0	9.0	48.0	72.0	55.8	High
KOLLAM	East kallada [4583]	VERANOOR	81.0	0.0	44.0	37.0	45.7	Medium
KOLLAM	East kallada [4583]	VILLAGE	129.0	6.0	19.9	103.1	79.9	Very High
KOLLAM	East kallada [4583]	VMG MUNNUMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	East kallada [4583]	WILLIMANGALAM	129.0	51.0	65.0	13.0	10.1	Low
KOLLAM	Ezhukone [4582]	A M JUNCTION	81.0	3.0	14.0	64.0	79.0	Very High
KOLLAM	Ezhukone [4582]	ALTHARAMUGAL	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Ezhukone [4582]	ARAPARAKKONAM	81.0	13.0	42.5	25.5	31.5	Medium
KOLLAM	Ezhukone [4582]	ARUMURIKKADA	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Ezhukone [4582]	ASSANMUKKU	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Ezhukone [4582]	BADAM	81.0	3.0	43.8	34.2	42.2	Medium
KOLLAM	Ezhukone [4582]	CHEERANKAVU	81.0	3.0	47.0	31.0	38.3	Medium
KOLLAM	Ezhukone [4582]	CHITRA JUNCTION	81.0	8.0	65.5	7.5	9.3	Very Low
KOLLAM	Ezhukone [4582]	CHOOZHA	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Ezhukone [4582]	CHOWALLOOR	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Ezhukone [4582]	COLLECTION CENTER	81.0	3.0	28.4	49.6	61.2	High
KOLLAM	Ezhukone [4582]	EAST KUNDARA	81.0	0.0	44.0	37.0	45.7	Medium
KOLLAM	Ezhukone [4582]	EAST MARANADU	81.0	5.0	11.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ezhukone [4582]	EDAKKADAM MARKET	81.0	5.0	71.1	4.9	6.0	Very Low
KOLLAM	Ezhukone [4582]	EDAKKODU	81.0	0.0	21.8	59.2	73.1	High
KOLLAM	Ezhukone [4582]	EDAVATTOM	81.0	3.0	38.0	40.0	49.4	Medium
KOLLAM	Ezhukone [4582]	ELIYODE	81.0	9.0	11.0	61.0	75.3	Very High
KOLLAM	Ezhukone [4582]	ENDILAYAPPAN	81.0	3.0	24.0	54.0	66.7	High
KOLLAM	Ezhukone [4582]	ERADANMUKKU	81.0	0.0	37.4	43.6	53.8	High
KOLLAM	Ezhukone [4582]	ESI	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Ezhukone [4582]	EXODUS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	EZHUKONE	129.0	0.0	60.0	69.0	53.5	High
KOLLAM	Ezhukone [4582]	EZHUKONE POST OFFICE	81.0	5.0	38.0	38.0	46.9	Medium
KOLLAM	Ezhukone [4582]	GANGACLUB	81.0	11.0	62.0	8.0	9.9	Very Low
KOLLAM	Ezhukone [4582]	GOA JUNCTION	81.0	3.0	20.4	57.6	71.1	High
KOLLAM	Ezhukone [4582]	GOVT POLY	129.0	5.0	41.7	82.3	63.8	High
KOLLAM	Ezhukone [4582]	GURUMANDIRAM	129.0	0.0	32.5	96.5	74.8	High
KOLLAM	Ezhukone [4582]	GURUNATHAN MUGAL	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Ezhukone [4582]	HAWWA BEACH	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Ezhukone [4582]	IRUMPANANGADU	81.0	6.0	30.0	45.0	55.6	High
KOLLAM	Ezhukone [4582]	JAVANMUKKU	81.0	20.0	49.0	12.0	14.8	Low
KOLLAM	Ezhukone [4582]	JAYANTHI COLONY	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Ezhukone [4582]	JOHNS TOWER	81.0	0.0	31.9	49.0	60.6	High
KOLLAM	Ezhukone [4582]	KAILAS	81.0	5.0	14.0	62.0	76.5	Very High
KOLLAM	Ezhukone [4582]	KAKKAKOTTOOR	81.0	0.0	52.0	29.0	35.8	Medium
KOLLAM	Ezhukone [4582]	KAKOLIL	81.0	3.0	53.9	24.1	29.8	Medium
KOLLAM	Ezhukone [4582]	KALAMPOTTIVILA	81.0	3.0	12.0	66.0	81.5	Very High
KOLLAM	Ezhukone [4582]	KALATHATTUMUKKU	81.0	0.0	19.0	62.0	76.5	Very High
KOLLAM	Ezhukone [4582]	KALLAR	81.0	3.0	16.0	62.0	76.5	Very High
KOLLAM	Ezhukone [4582]	KANJIRAMVILA	81.0	3.0	15.0	63.0	77.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ezhukone [4582]	KANNIMELMUKKU	81.0	0.0	18.0	63.0	77.8	Very High
KOLLAM	Ezhukone [4582]	KARUVELIL	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Ezhukone [4582]	KINARUMUKKU	81.0	0.0	27.0	54.0	66.7	High
KOLLAM	Ezhukone [4582]	KINARUVILA	81.0	0.0	7.0	74.0	91.3	Very High
KOLLAM	Ezhukone [4582]	KIP	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Ezhukone [4582]	KOCHANJILUMOODU	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Ezhukone [4582]	KOCHUVILA MUKKU	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Ezhukone [4582]	KONNAKKOOTTAM	81.0	5.0	39.0	37.0	45.7	Medium
KOLLAM	Ezhukone [4582]	KOTTAIKONAM	81.0	11.0	45.0	25.0	30.9	Medium
KOLLAM	Ezhukone [4582]	KOTTAKKUZHY	81.0	3.0	32.4	45.6	56.3	High
KOLLAM	Ezhukone [4582]	KOTTEKUNNU	81.0	0.0	35.0	46.0	56.8	High
KOLLAM	Ezhukone [4582]	KOZHIKKODAN MUKKU	81.0	3.0	53.0	25.0	30.9	Medium
KOLLAM	Ezhukone [4582]	LITTLE FLOWER	81.0	0.0	47.0	34.0	42.0	Medium
KOLLAM	Ezhukone [4582]	LMS COMPLEX	129.0	0.0	47.0	82.0	63.6	High
KOLLAM	Ezhukone [4582]	MADATHILAZHIKOM	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Ezhukone [4582]	MAHAVISHNU CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	MAJISTRATE MUKKU	81.0	11.0	59.5	10.5	13.0	Low
KOLLAM	Ezhukone [4582]	MARANAD CHURCH	81.0	6.0	26.0	49.0	60.5	High
KOLLAM	Ezhukone [4582]	MARANADU	81.0	5.0	19.0	57.0	70.4	High
KOLLAM	Ezhukone [4582]	MARANADU RATION KADA	81.0	6.0	8.0	67.0	82.7	Very High
KOLLAM	Ezhukone [4582]	MATHA PHARMA	81.0	16.0	62.4	2.6	3.2	Very Low
KOLLAM	Ezhukone [4582]	MAVILA	81.0	3.0	24.3	53.7	66.3	High
KOLLAM	Ezhukone [4582]	MELEMUKKOODU	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Ezhukone [4582]	MGD	129.0	0.0	48.0	81.0	62.8	High
KOLLAM	Ezhukone [4582]	MUKKOODU	81.0	8.0	33.5	39.5	48.7	Medium
KOLLAM	Ezhukone [4582]	MULAVANA	81.0	5.0	16.3	59.7	73.7	High
KOLLAM	Ezhukone [4582]	MUNDUPOIKA	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ezhukone [4582]	MUNNOOR	81.0	8.0	32.9	40.1	49.5	Medium
KOLLAM	Ezhukone [4582]	NADAMEL	81.0	13.0	66.9	1.1	1.4	Very Low
KOLLAM	Ezhukone [4582]	NADAMEL CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	NEDUMPAIKULAM	81.0	7.0	42.1	31.9	39.3	Medium
KOLLAM	Ezhukone [4582]	NEDUMPAIKULAM OVERBRIDGE	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Ezhukone [4582]	NILA INN	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	PADIYANGIL	81.0	8.0	9.0	64.0	79.0	Very High
KOLLAM	Ezhukone [4582]	PALAKKUZHY	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Ezhukone [4582]	PARAKKADAVU	81.0	6.0	26.0	49.0	60.5	High
KOLLAM	Ezhukone [4582]	PARUTHANPARA	129.0	10.0	64.5	54.5	42.2	Medium
KOLLAM	Ezhukone [4582]	PATTAMUKKU	81.0	0.0	12.0	69.0	85.2	Very High
KOLLAM	Ezhukone [4582]	PEYMOORTHIKKAVU	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Ezhukone [4582]	PEZHOORKONAM	81.0	5.0	35.0	41.0	50.6	High
KOLLAM	Ezhukone [4582]	PLACHI	81.0	0.0	17.0	64.0	79.0	Very High
KOLLAM	Ezhukone [4582]	PLAKKADU	81.0	3.0	6.0	72.0	88.9	Very High
KOLLAM	Ezhukone [4582]	PLS	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Ezhukone [4582]	POCHAKKONAM	81.0	4.0	20.0	57.0	70.4	High
KOLLAM	Ezhukone [4582]	POCHAMKONAM PUMP HOUSE	81.0	3.0	12.0	66.0	81.5	Very High
KOLLAM	Ezhukone [4582]	PONGUVILA	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Ezhukone [4582]	PULIMUKKU	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Ezhukone [4582]	PULIPRA	81.0	3.0	48.0	30.0	37.0	Medium
KOLLAM	Ezhukone [4582]	PUNNATHADAM	81.0	21.0	55.9	4.2	5.1	Very Low
KOLLAM	Ezhukone [4582]	PUTHEN NADA	81.0	0.0	79.0	2.0	2.5	Very Low
KOLLAM	Ezhukone [4582]	PUTTAMONKARA	81.0	5.0	8.0	68.0	84.0	Very High
KOLLAM	Ezhukone [4582]	R MART	129.0	8.0	49.0	72.0	55.8	High
KOLLAM	Ezhukone [4582]	RAILWAY STATION	81.0	8.0	20.0	53.0	65.4	High
KOLLAM	Ezhukone [4582]	RAMANKUNNU	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Ezhukone [4582]	RLM	81.0	11.0	9.0	61.0	75.3	Very High
KOLLAM	Ezhukone [4582]	SBI KALLUMPURAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	SEALAND CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	SOUTHERN WOOD	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	SREELEKSHMI CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	ST JHONS	81.0	0.0	25.0	56.0	69.1	High
KOLLAM	Ezhukone [4582]	TELEPHONE EXCHANGE	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Ezhukone [4582]	THEKKEVILA	81.0	7.0	11.5	62.5	77.2	Very High
KOLLAM	Ezhukone [4582]	THENGUVILA	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Ezhukone [4582]	THRIPPILAZHIKAM	129.0	0.0	56.5	72.5	56.2	High
KOLLAM	Ezhukone [4582]	THUNDIL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	THURUTHEL MUKKU	81.0	0.0	9.0	72.0	88.9	Very High
KOLLAM	Ezhukone [4582]	TKM	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Ezhukone [4582]	TKM ARCHITECTURE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	URIYARIKUNNU	81.0	5.0	41.3	34.7	42.8	Medium
KOLLAM	Ezhukone [4582]	URIYARIKUNNU CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	VADAKKE MUKKU	81.0	6.0	73.9	1.1	1.4	Very Low
KOLLAM	Ezhukone [4582]	VAIDYARUMUKKU	81.0	5.0	12.0	64.0	79.0	Very High
KOLLAM	Ezhukone [4582]	VALAIKKODU	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Ezhukone [4582]	VANITHA INDUSTRIAL ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Ezhukone [4582]	VATTAKUNNUPARA	81.0	3.2	3.0	74.8	92.4	Very High
KOLLAM	Ezhukone [4582]	VATTAMON KAVU	81.0	3.0	51.0	27.0	33.3	Medium
KOLLAM	Ezhukone [4582]	VKM CLUB	81.0	23.8	56.0	1.2	1.4	Very Low
KOLLAM	Kadakkal [4599]	ALTHARAMOOD	202.0	13.0	67.3	121.7	60.2	High
KOLLAM	Kadakkal [4599]	ALUKUNNAM	81.0	13.0	49.0	19.0	23.5	Low
KOLLAM	Kadakkal [4599]	AMBADIMUKKU	81.0	0.0	79.9	1.1	1.3	Very Low
KOLLAM	Kadakkal [4599]	AMBALAMMUKKU	81.0	3.0	77.0	1.0	1.2	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadakkal [4599]	ANAPPADU	81.0	5.0	17.0	59.0	72.8	High
KOLLAM	Kadakkal [4599]	ANAPPARA KSEB OFFICE	81.0	4.0	76.3	0.7	0.9	Very Low
KOLLAM	Kadakkal [4599]	ANAYIL	81.0	16.0	58.3	6.7	8.3	Very Low
KOLLAM	Kadakkal [4599]	ANCHUMALAKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadakkal [4599]	ANCHUMUKKU	129.0	6.0	34.0	89.0	69.0	High
KOLLAM	Kadakkal [4599]	ARAFA	129.0	0.0	26.0	103.0	79.8	Very High
KOLLAM	Kadakkal [4599]	ARTHINGAL	81.0	5.0	27.0	49.0	60.5	High
KOLLAM	Kadakkal [4599]	ATTUPURAM	129.0	0.0	37.0	92.0	71.3	High
KOLLAM	Kadakkal [4599]	AZHANTHAKUZH	81.0	5.0	37.0	39.0	48.1	Medium
KOLLAM	Kadakkal [4599]	CHANAPPARA	81.0	10.0	35.0	36.0	44.4	Medium
KOLLAM	Kadakkal [4599]	CHANNATTIMUKKU	81.0	18.0	61.3	1.7	2.1	Very Low
KOLLAM	Kadakkal [4599]	CHARAYAM	81.0	8.0	33.0	40.0	49.4	Medium
KOLLAM	Kadakkal [4599]	CHINGELI	129.0	14.0	82.0	33.0	25.6	Medium
KOLLAM	Kadakkal [4599]	CHINGELI OILPAMP	81.0	10.0	47.0	24.0	29.6	Medium
KOLLAM	Kadakkal [4599]	CHINGELI SCHOOL	81.0	9.0	36.0	36.0	44.4	Medium
KOLLAM	Kadakkal [4599]	EDATHARA	81.0	0.0	18.0	63.0	77.8	Very High
KOLLAM	Kadakkal [4599]	ETTIMOODU	81.0	3.0	12.0	66.0	81.5	Very High
KOLLAM	Kadakkal [4599]	EYYAKKODE	81.0	3.0	16.0	62.0	76.5	Very High
KOLLAM	Kadakkal [4599]	EYYAKKODU RATIONSHOP	81.0	9.0	23.0	49.0	60.5	High
KOLLAM	Kadakkal [4599]	FOUSI-INDOR	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Kadakkal [4599]	FRANCO	81.0	7.0	38.0	36.0	44.4	Medium
KOLLAM	Kadakkal [4599]	G MART KUMMIL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadakkal [4599]	GAGO	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadakkal [4599]	GOVINDAMANGALAM	81.0	0.0	19.7	61.3	75.7	Very High
KOLLAM	Kadakkal [4599]	GOVINDAMANGALAM EX	81.0	5.0	40.0	36.0	44.4	Medium
KOLLAM	Kadakkal [4599]	GOVT HOSPITAL	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Kadakkal [4599]	INDAVILA	81.0	0.0	9.0	72.0	88.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadakkal [4599]	INDIRAPARK	405.0	0.0	30.5	374.5	92.5	Very High
KOLLAM	Kadakkal [4599]	IRATTAKKULAM	81.0	3.0	5.0	73.0	90.1	Very High
KOLLAM	Kadakkal [4599]	KADAKKAL MARKET	129.0	3.0	22.5	103.5	80.2	Very High
KOLLAM	Kadakkal [4599]	KADAKKAL SERVICE CO OP BANK	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Kadakkal [4599]	KARAKKADU	81.0	13.0	24.5	43.5	53.7	High
KOLLAM	Kadakkal [4599]	KARIYAM	81.0	5.0	56.0	20.0	24.7	Low
KOLLAM	Kadakkal [4599]	KASTHOORI	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadakkal [4599]	KIRALA	81.0	6.0	13.0	62.0	76.5	Very High
KOLLAM	Kadakkal [4599]	KODINJAM	129.0	18.0	60.0	51.0	39.5	Medium
KOLLAM	Kadakkal [4599]	KOLINCHI	81.0	0.0	8.3	72.7	89.8	Very High
KOLLAM	Kadakkal [4599]	KONDODY	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Kadakkal [4599]	KOTTAPPURAM	81.0	16.0	62.0	3.0	3.7	Very Low
KOLLAM	Kadakkal [4599]	KUMBALAM	81.0	0.0	28.0	53.0	65.4	High
KOLLAM	Kadakkal [4599]	KUMMIL KOTTAPPURAM	129.0	6.0	40.0	83.0	64.3	High
KOLLAM	Kadakkal [4599]	KUMMIL PANCHAYATH	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadakkal [4599]	KUMMIL SCHOOL	129.0	0.0	52.7	76.3	59.1	High
KOLLAM	Kadakkal [4599]	KUNNIKADA	129.0	0.0	15.0	114.0	88.4	Very High
KOLLAM	Kadakkal [4599]	KUTTIKKADU	129.0	9.0	53.3	66.7	51.7	High
KOLLAM	Kadakkal [4599]	KUTTIKKADU SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadakkal [4599]	MANALUVATTAM	129.0	5.0	47.0	77.0	59.7	High
KOLLAM	Kadakkal [4599]	MANDIRAM KUNNU	129.0	0.0	11.0	118.0	91.5	Very High
KOLLAM	Kadakkal [4599]	MANIYANMUKKU	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Kadakkal [4599]	MANKADU	81.0	9.0	47.0	25.0	30.8	Medium
KOLLAM	Kadakkal [4599]	MATHIRA SCHOOL	81.0	0.0	39.0	42.0	51.9	High
KOLLAM	Kadakkal [4599]	MATHIRA TEMPLE	81.0	0.0	80.3	0.7	0.9	Very Low
KOLLAM	Kadakkal [4599]	MEDAYIL	81.0	18.0	25.0	38.0	46.9	Medium
KOLLAM	Kadakkal [4599]	MEENMUTTI	81.0	0.0	12.0	69.0	85.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadakkal [4599]	MINI CIVIL STATION	81.0	0.0	44.4	36.6	45.1	Medium
KOLLAM	Kadakkal [4599]	MOOLABOUNDER	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Kadakkal [4599]	MUKKADA	81.0	0.0	27.0	54.0	66.7	High
KOLLAM	Kadakkal [4599]	MUKKUNNAM	129.0	10.0	67.0	52.0	40.3	Medium
KOLLAM	Kadakkal [4599]	MUKUNNERI	129.0	5.0	122.8	1.2	0.9	Very Low
KOLLAM	Kadakkal [4599]	MULANKATTUKUZHY	81.0	0.0	39.0	42.0	51.9	High
KOLLAM	Kadakkal [4599]	MUTHAYIL	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Kadakkal [4599]	NELLIVILA	81.0	13.0	54.0	14.0	17.3	Low
KOLLAM	Kadakkal [4599]	PALLIMUKKU	129.0	47.0	70.3	11.7	9.1	Very Low
KOLLAM	Kadakkal [4599]	PALONAM	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Kadakkal [4599]	PANGALUKADU	129.0	29.0	87.0	13.0	10.1	Low
KOLLAM	Kadakkal [4599]	PANTHALAM MUKU	81.0	0.0	81.0	0.0	0.0	Very Low
KOLLAM	Kadakkal [4599]	PERINGADU	81.0	16.0	12.0	53.0	65.4	High
KOLLAM	Kadakkal [4599]	PLAVARA POIKA	81.0	3.0	14.0	64.0	79.0	Very High
KOLLAM	Kadakkal [4599]	PONGUMALA	81.0	0.0	24.0	57.0	70.4	High
KOLLAM	Kadakkal [4599]	PULIMUDU	81.0	7.0	38.0	36.0	44.4	Medium
KOLLAM	Kadakkal [4599]	PULIPPARA	81.0	21.0	11.0	49.0	60.5	High
KOLLAM	Kadakkal [4599]	PULLUPANA	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Kadakkal [4599]	PUTHUKODE	81.0	15.0	21.0	45.0	55.6	High
KOLLAM	Kadakkal [4599]	PUTHUKODU MOSQUE	81.0	10.0	43.0	28.0	34.6	Medium
KOLLAM	Kadakkal [4599]	SAMBRAMAM	81.0	6.0	64.5	10.5	13.0	Low
KOLLAM	Kadakkal [4599]	SANKAR NAGAR	129.0	6.0	60.0	63.0	48.8	Medium
KOLLAM	Kadakkal [4599]	SEEDFARM	81.0	0.0	81.0	0.0	0.0	Very Low
KOLLAM	Kadakkal [4599]	SILK INDIA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadakkal [4599]	SM HOSPITAL	129.0	5.0	39.4	84.6	65.6	High
KOLLAM	Kadakkal [4599]	SN-TRUST	81.0	5.0	8.0	68.0	84.0	Very High
KOLLAM	Kadakkal [4599]	SUB TREASURY	81.0	5.0	5.0	71.0	87.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadakkal [4599]	THACHONAM	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Kadakkal [4599]	THEKKIL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadakkal [4599]	THIRUVATHIRA	129.0	13.0	38.0	78.0	60.5	High
KOLLAM	Kadakkal [4599]	THRIKANNAPURAML-LPS	81.0	9.0	9.0	63.0	77.8	Very High
KOLLAM	Kadakkal [4599]	THRIKKANNAPURAM	129.0	3.0	56.0	70.0	54.3	High
KOLLAM	Kadakkal [4599]	THULASIMUKKU	81.0	0.0	48.8	32.2	39.8	Medium
KOLLAM	Kadakkal [4599]	THUMPODU	81.0	3.0	31.0	47.0	58.0	High
KOLLAM	Kadakkal [4599]	VACHIKONAM	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Kadakkal [4599]	VALIYA VENKADU	81.0	0.0	27.0	54.0	66.7	High
KOLLAM	Kadakkal [4599]	VALUPACHA	81.0	0.0	30.0	51.0	63.0	High
KOLLAM	Kadakkal [4599]	VATTATHAMARA	129.0	8.0	34.0	87.0	67.4	High
KOLLAM	Kadakkal [4599]	VAZHVELIKONAM	81.0	11.0	4.0	66.0	81.5	Very High
KOLLAM	Kadakkal [4599]	VELLARVATTOM	81.0	26.0	54.0	1.0	1.2	Very Low
KOLLAM	Kadakkal [4599]	VYABHARABHAVAN	129.0	3.0	25.0	101.0	78.3	Very High
KOLLAM	Kadambanad [4613]	4TH MILE	81.0	8.0	21.3	51.7	63.8	High
KOLLAM	Kadambanad [4613]	7TH MILE	129.0	8.0	71.0	50.0	38.8	Medium
KOLLAM	Kadambanad [4613]	AMBALATHUMBHAGAM	81.0	3.0	19.3	58.7	72.5	High
KOLLAM	Kadambanad [4613]	AMPADI	81.0	5.0	20.3	55.7	68.8	High
KOLLAM	Kadambanad [4613]	ANAMUKKU	81.0	0.0	43.3	37.7	46.6	Medium
KOLLAM	Kadambanad [4613]	ANTHICHIRA	81.0	3.0	14.3	63.7	78.6	Very High
KOLLAM	Kadambanad [4613]	ANTHICHIRA MARTHOMA CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	ARAYALAPPURAM	81.0	8.0	43.8	29.2	36.0	Medium
KOLLAM	Kadambanad [4613]	ARAYALAPURAM GURUMANDIRAM	81.0	3.0	15.0	63.0	77.8	Very High
KOLLAM	Kadambanad [4613]	ATTUKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	BHARANIKAVU	81.0	3.0	12.0	66.0	81.5	Very High
KOLLAM	Kadambanad [4613]	BHOOTHAKKUZHY	81.0	14.0	41.0	26.0	32.1	Medium
KOLLAM	Kadambanad [4613]	C P MUKKU	81.0	8.0	39.0	34.0	42.0	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadambanad [4613]	CANAL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	CHEEKAKADAVU	129.0	14.0	25.8	89.2	69.1	High
KOLLAM	Kadambanad [4613]	CHELOOR	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	CHETTIYARUMUKKU	81.0	5.0	58.0	18.0	22.2	Low
KOLLAM	Kadambanad [4613]	CHILANKA	81.0	22.0	14.0	45.0	55.6	High
KOLLAM	Kadambanad [4613]	CHUMADUTHANGI JN	81.0	0.0	80.0	1.0	1.2	Very Low
KOLLAM	Kadambanad [4613]	DEEPAM LINE	81.0	3.0	12.0	66.0	81.5	Very High
KOLLAM	Kadambanad [4613]	DEVAGIRI	81.0	10.0	15.0	56.0	69.1	High
KOLLAM	Kadambanad [4613]	DURGA CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	EBANAZER	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Kadambanad [4613]	EDAKKAD MARKET	202.0	29.0	127.3	45.7	22.6	Low
KOLLAM	Kadambanad [4613]	EDAKKAD UNNATHY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	EDAKKAD WATER WORKS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	EDAYANPALAM	81.0	3.0	9.0	69.0	85.2	Very High
KOLLAM	Kadambanad [4613]	ELAVUM MOODU	81.0	0.0	20.3	60.7	74.9	High
KOLLAM	Kadambanad [4613]	ELLUMVILA JN	81.0	0.0	19.4	61.6	76.0	Very High
KOLLAM	Kadambanad [4613]	ESQUIRE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	FEDERAL BANK	81.0	13.0	42.0	26.0	32.1	Medium
KOLLAM	Kadambanad [4613]	GENESAVILASAM	81.0	8.0	3.0	70.0	86.4	Very High
KOLLAM	Kadambanad [4613]	GOVINDAPURAM MARKET	81.0	5.0	60.8	15.2	18.8	Low
KOLLAM	Kadambanad [4613]	IDIKKANDA	81.0	13.0	44.0	24.0	29.6	Medium
KOLLAM	Kadambanad [4613]	IVILA	81.0	5.0	2.0	74.0	91.4	Very High
KOLLAM	Kadambanad [4613]	JOTHIPURAM	81.0	0.0	19.0	62.0	76.5	Very High
KOLLAM	Kadambanad [4613]	KADAMPANAD	129.0	8.0	92.0	29.0	22.5	Low
KOLLAM	Kadambanad [4613]	KADAMPANAD PUMP	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	KADAMPANADU EXCHANGE	81.0	8.0	23.0	50.0	61.7	High
KOLLAM	Kadambanad [4613]	KAIRALI MUKKU	81.0	8.0	42.2	30.8	38.0	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadambanad [4613]	KALATHIVILA	51.0	23.6	27.0	0.4	0.8	Very Low
KOLLAM	Kadambanad [4613]	KALEELUMUKKU	81.0	11.0	12.0	58.0	71.6	High
KOLLAM	Kadambanad [4613]	KALLAYKKATTU MUKKU	81.0	16.0	39.0	26.0	32.1	Medium
KOLLAM	Kadambanad [4613]	KALLUKUZH	129.0	11.0	77.0	41.0	31.8	Medium
KOLLAM	Kadambanad [4613]	KALLUMPURAM	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Kadambanad [4613]	KANIYAMKUZHY	81.0	3.0	19.3	58.7	72.5	High
KOLLAM	Kadambanad [4613]	KANJIRAVILA	81.0	13.0	44.0	24.0	29.6	Medium
KOLLAM	Kadambanad [4613]	KANNANBRICKS	81.0	0.0	12.3	68.7	84.8	Very High
KOLLAM	Kadambanad [4613]	KARAMEL	81.0	5.0	5.0	71.0	87.7	Very High
KOLLAM	Kadambanad [4613]	KARAYODI	81.0	0.0	32.0	49.0	60.5	High
KOLLAM	Kadambanad [4613]	KARIMPARA	81.0	8.0	43.0	30.0	37.0	Medium
KOLLAM	Kadambanad [4613]	KATTUTHAMVILA	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Kadambanad [4613]	KATTUVILA	81.0	17.0	9.0	55.0	67.9	High
KOLLAM	Kadambanad [4613]	KEETTOOR KUNNUPURAM	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Kadambanad [4613]	KINARUMUKKU	81.0	8.0	19.0	54.0	66.7	High
KOLLAM	Kadambanad [4613]	KOCHU KUNNU	81.0	8.0	36.0	37.0	45.7	Medium
KOLLAM	Kadambanad [4613]	KOCHUPLAM MOODU	81.0	3.0	25.0	53.0	65.4	High
KOLLAM	Kadambanad [4613]	KOKKANKAVU	81.0	3.0	10.0	68.0	84.0	Very High
KOLLAM	Kadambanad [4613]	KOLLARA	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Kadambanad [4613]	KOLLARA CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Kadambanad [4613]	KOLOORKUZH	20.0	0.0	6.0	14.0	70.0	High
KOLLAM	Kadambanad [4613]	KUNDAVAN MALANADA	81.0	4.0	29.3	47.7	58.9	High
KOLLAM	Kadambanad [4613]	KUNNATHOOR	202.0	8.0	13.0	181.0	89.6	Very High
KOLLAM	Kadambanad [4613]	KUNNATHOOR EXCHANGE	81.0	5.0	0.0	76.0	93.8	Very High
KOLLAM	Kadambanad [4613]	KUNNUVILA	81.0	14.0	33.0	34.0	42.0	Medium
KOLLAM	Kadambanad [4613]	KURUMPAKARA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	KUTTICKAL	81.0	8.0	73.0	0.0	0.0	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadambanad [4613]	KUZHIALA	81.0	5.0	67.1	8.9	11.0	Low
KOLLAM	Kadambanad [4613]	LINEX	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	MADATHIL	81.0	20.0	60.0	1.0	1.2	Very Low
KOLLAM	Kadambanad [4613]	MAHADEVA	81.0	16.0	3.0	62.0	76.5	Very High
KOLLAM	Kadambanad [4613]	MALAMKAVU	81.0	3.0	6.0	72.0	88.9	Very High
KOLLAM	Kadambanad [4613]	MALANADA	81.0	6.3	35.3	39.4	48.6	Medium
KOLLAM	Kadambanad [4613]	MANALUVILA	81.0	31.0	43.8	6.2	7.7	Very Low
KOLLAM	Kadambanad [4613]	MANGAD	81.0	8.0	24.0	49.0	60.5	High
KOLLAM	Kadambanad [4613]	MANGALASSERY	129.0	0.0	10.0	119.0	92.2	Very High
KOLLAM	Kadambanad [4613]	MANIKKAMANGALAM	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Kadambanad [4613]	MANJALY	81.0	38.0	13.0	30.0	37.0	Medium
KOLLAM	Kadambanad [4613]	MANNAROD	51.0	5.0	0.0	46.0	90.2	Very High
KOLLAM	Kadambanad [4613]	MUDIPILAPPALLY ILLAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	MUKALETHUPADI	20.0	0.0	3.0	17.0	85.0	Very High
KOLLAM	Kadambanad [4613]	NADASALA	81.0	3.3	62.7	15.0	18.5	Low
KOLLAM	Kadambanad [4613]	NAZARETH	81.0	12.0	43.0	26.0	32.1	Medium
KOLLAM	Kadambanad [4613]	NEDIYAVILA	81.0	3.0	46.0	32.0	39.6	Medium
KOLLAM	Kadambanad [4613]	NEDIYAVILA GURUMANDIRAM	81.0	10.0	18.0	53.0	65.4	High
KOLLAM	Kadambanad [4613]	NEDUMKUNNU MALANADA	51.0	0.0	12.0	39.0	76.5	Very High
KOLLAM	Kadambanad [4613]	NELLIMUKAL	81.0	0.0	19.0	62.0	76.5	Very High
KOLLAM	Kadambanad [4613]	NILACKAL	129.0	0.0	37.0	92.0	71.3	High
KOLLAM	Kadambanad [4613]	OTTATHENGU	81.0	0.0	79.0	2.0	2.4	Very Low
KOLLAM	Kadambanad [4613]	PADAKASSERY	81.0	14.0	3.0	64.0	79.0	Very High
KOLLAM	Kadambanad [4613]	PAKISTAN MUKKU	81.0	3.0	33.0	45.0	55.6	High
KOLLAM	Kadambanad [4613]	PALLIPPADI	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Kadambanad [4613]	PANANTHOPPU	81.0	0.0	66.8	14.2	17.5	Low
KOLLAM	Kadambanad [4613]	PANCHAVADY	81.0	0.0	10.0	71.0	87.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadambanad [4613]	PANDIMALAPPURAM	129.0	6.0	16.0	107.0	82.9	Very High
KOLLAM	Kadambanad [4613]	PANDIMALAPPURAM SAMSKARIKANILA	81.0	5.0	10.0	66.0	81.5	Very High
KOLLAM	Kadambanad [4613]	PARAMALA	81.0	0.0	17.0	64.0	79.0	Very High
KOLLAM	Kadambanad [4613]	PARAMALA CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	PHC	81.0	4.0	54.0	23.0	28.4	Medium
KOLLAM	Kadambanad [4613]	PLATHARA TEMPLE	51.0	0.0	8.0	43.0	84.3	Very High
KOLLAM	Kadambanad [4613]	POOJA CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	PULLAMPALLY	81.0	0.0	21.0	60.0	74.1	High
KOLLAM	Kadambanad [4613]	PUNNAVILA	81.0	12.0	59.0	10.0	12.3	Low
KOLLAM	Kadambanad [4613]	PUTHENAMBALAM TEMPLE	81.0	11.0	27.0	43.0	53.1	High
KOLLAM	Kadambanad [4613]	RADIO MUKKU	81.0	8.3	3.0	69.7	86.0	Very High
KOLLAM	Kadambanad [4613]	SANGEETHA	81.0	8.0	13.0	60.0	74.1	High
KOLLAM	Kadambanad [4613]	SASTHAM NADA	81.0	0.0	81.0	0.0	0.0	Very Low
KOLLAM	Kadambanad [4613]	SIVAGIRI	81.0	19.0	62.0	0.0	0.0	Very Low
KOLLAM	Kadambanad [4613]	TAVANOORKAVU	129.0	8.0	3.0	118.0	91.5	Very High
KOLLAM	Kadambanad [4613]	THALAYAT	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Kadambanad [4613]	THAMPURAN FUELS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	THETTIVILA	81.0	29.0	48.0	4.0	4.9	Very Low
KOLLAM	Kadambanad [4613]	THOLICKAL	81.0	11.0	21.0	49.0	60.5	High
KOLLAM	Kadambanad [4613]	THOTTATHUMMURI	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Kadambanad [4613]	THRUKKANNAPURAM	81.0	6.0	19.0	56.0	69.1	High
KOLLAM	Kadambanad [4613]	THUMPUMPARAM	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Kadambanad [4613]	THURUTHIKKARA	129.0	5.0	28.1	95.9	74.3	High
KOLLAM	Kadambanad [4613]	THUVAYOOR	81.0	0.0	57.4	23.6	29.1	Medium
KOLLAM	Kadambanad [4613]	THUVAYOOR PUMP	81.0	0.0	7.8	73.2	90.4	Very High
KOLLAM	Kadambanad [4613]	UDAYANKAVU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadambanad [4613]	UDUMANMUKKU	81.0	16.0	35.3	29.7	36.7	Medium
KOLLAM	Kadambanad [4613]	UNION ASSOCIATES	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadambanad [4613]	VAYAL	81.0	23.0	44.0	14.0	17.3	Low
KOLLAM	Kadambanad [4613]	VAZHAVILA	81.0	3.0	22.0	56.0	69.1	High
KOLLAM	Kadambanad [4613]	VELAMMOZHIKADAVU	81.0	3.0	7.0	71.0	87.7	Very High
KOLLAM	Kadambanad [4613]	VEMBANADU	81.0	5.0	33.5	42.5	52.4	High
KOLLAM	Kadappakkada [4559]	A Y K	202.0	0.0	79.5	122.5	60.7	High
KOLLAM	Kadappakkada [4559]	AANUTS	81.0	3.0	15.0	63.0	77.8	Very High
KOLLAM	Kadappakkada [4559]	AARATTUKULAM	81.0	0.0	23.0	58.0	71.6	High
KOLLAM	Kadappakkada [4559]	AHANAS VILAPPURAM	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Kadappakkada [4559]	AKHILESH ARCADE SBI 2	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	AKSHAYA EXPORT	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	ALAYIL	129.0	8.0	55.0	66.0	51.2	High
KOLLAM	Kadappakkada [4559]	AMARJYOTHI BUSINESS CENTRE DH	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	AMARJYOTHY	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	ANERT	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Kadappakkada [4559]	ANJILI ROAD	129.0	0.0	20.0	109.0	84.5	Very High
KOLLAM	Kadappakkada [4559]	ARADHANA MADAM	81.0	0.0	38.0	43.0	53.1	High
KOLLAM	Kadappakkada [4559]	ARPAN TOWERS HT-LT	162.0	0.0	0.0	162.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	ARTECH SKY VILLAGE	810.0	0.0	10.0	800.0	98.8	Very High
KOLLAM	Kadappakkada [4559]	ASRAMAM MAIDANAM	129.0	0.0	18.0	111.0	86.0	Very High
KOLLAM	Kadappakkada [4559]	ASRAMAM TEMPLE	129.0	10.0	64.6	54.4	42.2	Medium
KOLLAM	Kadappakkada [4559]	ASRAMAM WATER TANK	202.0	0.0	45.0	157.0	77.7	Very High
KOLLAM	Kadappakkada [4559]	ASSEST HOME	324.0	0.0	0.0	324.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	ASSET SANFORD	324.0	0.0	40.0	284.0	87.7	Very High
KOLLAM	Kadappakkada [4559]	ASSOCIATED	202.0	10.0	74.5	117.5	58.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadappakkada [4559]	BAPUJI NAGAR	129.0	0.0	55.3	73.7	57.1	High
KOLLAM	Kadappakkada [4559]	BHAVANA NAGAR	129.0	8.0	40.0	81.0	62.8	High
KOLLAM	Kadappakkada [4559]	BRIGHT STAR	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	CANARA BANK	129.0	0.0	19.0	110.0	85.3	Very High
KOLLAM	Kadappakkada [4559]	CAPEX	202.0	5.0	22.1	174.8	86.6	Very High
KOLLAM	Kadappakkada [4559]	CENTRAL PARK	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	CHAKKARATHOPU	129.0	5.0	43.0	81.0	62.8	High
KOLLAM	Kadappakkada [4559]	CHANDRA SAW MILL	129.0	1.0	18.1	109.9	85.2	Very High
KOLLAM	Kadappakkada [4559]	CHEKKODE	129.0	5.0	79.0	45.0	34.9	Medium
KOLLAM	Kadappakkada [4559]	CHOTHY CASHEW	129.0	0.0	38.0	91.0	70.5	High
KOLLAM	Kadappakkada [4559]	CP JUNCTION	129.0	26.0	84.7	18.3	14.2	Low
KOLLAM	Kadappakkada [4559]	CRAVEN	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	CREATIVE COMPLEX ICICI BANK	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	CRYSTAL PLAZA	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	D CLAUSE	129.0	8.0	110.9	10.1	7.8	Very Low
KOLLAM	Kadappakkada [4559]	DEEDI MOTORS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	DEEPAM SAWMILL	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	DESINGANAD SCAN	129.0	5.0	29.0	95.0	73.6	High
KOLLAM	Kadappakkada [4559]	DHANYA	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	DIC	81.0	13.0	47.9	20.1	24.8	Low
KOLLAM	Kadappakkada [4559]	DIS CO-OP BANK	121.0	0.0	0.0	121.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	DIS CO-OP PRESS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	ELAMKULAM	129.0	18.0	52.0	59.0	45.7	Medium
KOLLAM	Kadappakkada [4559]	ENTE KERALAM DHT	405.0	0.0	0.0	405.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	FIRE STATION	81.0	0.0	35.0	46.0	56.8	High
KOLLAM	Kadappakkada [4559]	FORMAN	129.0	8.0	43.3	77.7	60.2	High
KOLLAM	Kadappakkada [4559]	GANDHINAGAR	81.0	5.0	31.0	45.0	55.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Kadappakkada [4559]	GRAMIN BANK	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	GUEST HOUSE	129.0	5.0	28.0	96.0	74.4	High
KOLLAM	Kadappakkada [4559]	HARI SREE NAGAR	81.0	10.0	31.0	40.0	49.4	Medium
KOLLAM	Kadappakkada [4559]	HDFC RANDAMKUTTY	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	HOCKEY STADIUM	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	HOUSING BOARD 1	129.0	3.0	62.5	63.5	49.2	Medium
KOLLAM	Kadappakkada [4559]	ICE PLANT 1	129.0	4.0	30.0	95.0	73.6	High
KOLLAM	Kadappakkada [4559]	INCOME TAX	81.0	3.0	31.0	47.0	58.0	High
KOLLAM	Kadappakkada [4559]	INDIRA OIL MILL	129.0	25.0	21.1	82.9	64.3	High
KOLLAM	Kadappakkada [4559]	ISSAC SQUARE	121.0	0.0	0.0	121.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	JANAYUGAM	129.0	0.0	10.0	119.0	92.2	Very High
KOLLAM	Kadappakkada [4559]	JYOTHY COLLEGE	129.0	5.0	110.5	13.5	10.5	Low
KOLLAM	Kadappakkada [4559]	K C MOHAN	129.0	18.0	97.8	13.2	10.2	Low
KOLLAM	Kadappakkada [4559]	KADAPPAKKADA	129.0	0.0	31.9	97.2	75.3	Very High
KOLLAM	Kadappakkada [4559]	KAILAS	81.0	0.0	19.9	61.1	75.4	Very High
KOLLAM	Kadappakkada [4559]	KAIRALI FORD	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	KALA GOLD	129.0	0.0	32.0	97.0	75.2	Very High
KOLLAM	Kadappakkada [4559]	KALAYIL	129.0	3.0	19.8	106.2	82.3	Very High
KOLLAM	Kadappakkada [4559]	KANDATHIL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Kadappakkada [4559]	KANDOLILTHODE	129.0	10.0	52.0	67.0	51.9	High
KOLLAM	Kadappakkada [4559]	KANNIMEL SOUTH	202.0	26.0	44.0	132.0	65.3	High
KOLLAM	Kadappakkada [4559]	KAVADIPPURAM	81.0	8.0	50.0	23.0	28.4	Medium
KOLLAM	Kadappakkada [4559]	KAVANAD TEMPLE	81.0	23.0	51.0	7.0	8.6	Very Low
KOLLAM	Kadappakkada [4559]	KAYALVARAM	81.0	0.0	31.0	50.0	61.7	High
KOLLAM	Kadappakkada [4559]	KOIKKAL	202.0	6.0	47.8	148.2	73.4	High
KOLLAM	Kadappakkada [4559]	KOPPARA PREES	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	1900-SOCIETY	81.0	6.0	74.2	0.8	1.0	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Oachira [4567]	1953 ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	A R ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	ADAK FISH FARM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	AJAYAPRASAD	81.0	3.0	5.0	73.0	90.1	Very High
KOLLAM	Oachira [4567]	AKKARATHARA	81.0	16.0	65.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	ALAPPADAN ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	ALUMCHUVADU	81.0	25.0	28.0	28.0	34.6	Medium
KOLLAM	Oachira [4567]	ALUMKULAM	129.0	6.0	122.0	1.0	0.8	Very Low
KOLLAM	Oachira [4567]	ALUMOODU ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	ALUMPEEDIKA NO 1	129.0	6.0	122.7	0.3	0.2	Very Low
KOLLAM	Oachira [4567]	ALUMPEEDIKA NO 2	81.0	16.6	63.6	0.8	1.0	Very Low
KOLLAM	Oachira [4567]	AMRITA FLAT GURUMANDIRAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	AMRITESWARI	81.0	0.0	81.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	AMRITHA-ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	ANAKUNNEL MUKKU	81.0	6.0	72.2	2.8	3.4	Very Low
KOLLAM	Oachira [4567]	AR EV CHARGING STATION	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Oachira [4567]	AS ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	AS ICE BABU RAVEENDRAN	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	ASHTAMI	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	ASHTAMI ICE 1	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	AYIRAMTHENGU NO 2	81.0	11.0	24.0	46.0	56.8	High
KOLLAM	Oachira [4567]	AYIRAMTHENGU-1	81.0	4.2	73.0	3.8	4.7	Very Low
KOLLAM	Oachira [4567]	AZHEEKAL AMRITA ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	AZHEEKKAL	81.0	32.0	48.0	1.0	1.2	Very Low
KOLLAM	Oachira [4567]	AZHEEKKAL HARBOR	81.0	6.0	75.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	AZHEEKKAL KURISADI	81.0	14.8	49.0	17.2	21.2	Low
KOLLAM	Oachira [4567]	AZHEEKKAL MANGALAM GROUND	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Oachira [4567]	BABY PAPA ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	BHAGAVATHY NAGAR	81.0	6.0	47.2	27.8	34.3	Medium
KOLLAM	Oachira [4567]	BHARANICKAVU TEMPLE	81.0	6.0	38.1	36.9	45.6	Medium
KOLLAM	Oachira [4567]	BHEEMNAGAR	81.0	11.0	69.3	0.7	0.9	Very Low
KOLLAM	Oachira [4567]	BLUE MONT ARCADE	324.0	0.0	0.0	324.0	100.0	Very High
KOLLAM	Oachira [4567]	CHANDAKKADAVU	81.0	23.0	30.0	28.0	34.6	Medium
KOLLAM	Oachira [4567]	CHANGANKULANGARA-1	81.0	43.3	84.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	CHANGANKULANGARA-2-BLOCK	129.0	21.0	76.3	31.7	24.6	Low
KOLLAM	Oachira [4567]	CHANGANKULANGARA-3 -ALF ICE	202.0	3.0	13.0	186.0	92.1	Very High
KOLLAM	Oachira [4567]	CHANGANKULANGARA-4	81.0	0.0	24.0	57.0	70.4	High
KOLLAM	Oachira [4567]	CHIRAKKADAVU	81.0	10.0	70.5	0.5	0.6	Very Low
KOLLAM	Oachira [4567]	CHITTETHU	81.0	23.0	35.0	23.0	28.4	Medium
KOLLAM	Oachira [4567]	EDACHIRA	81.0	8.0	18.0	55.0	67.9	High
KOLLAM	Oachira [4567]	EDATHITTA	81.0	3.0	41.0	37.0	45.7	Medium
KOLLAM	Oachira [4567]	EDAYANAMBALAM WEST	81.0	8.0	51.0	22.0	27.2	Medium
KOLLAM	Oachira [4567]	EDAYANAYAMBALAM	81.0	34.0	47.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	EMS	129.0	0.0	53.1	75.9	58.8	High
KOLLAM	Oachira [4567]	ERAMATHU	81.0	7.0	74.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	ERAVIMANGALAM-1	81.0	14.0	61.0	6.0	7.4	Very Low
KOLLAM	Oachira [4567]	ERAVIMANGALAM-2	81.0	9.0	72.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	GAYATHRI ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	GAYATHRI ICE 2	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	HARBOUR	81.0	3.0	0.0	78.0	96.3	Very High
KOLLAM	Oachira [4567]	INNSPARK	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	ITTICKATHARA NO 3	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	ITTICKATHARA NO II	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	ITTIKATHARA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Oachira [4567]	JANS	81.0	5.0	44.0	32.0	39.5	Medium
KOLLAM	Oachira [4567]	KALARIVATHUKKAL WEST	81.0	0.0	19.0	62.0	76.5	Very High
KOLLAM	Oachira [4567]	KALLOOR MUKKU	129.0	23.0	102.0	4.0	3.1	Very Low
KOLLAM	Oachira [4567]	KAMANDISSERY	81.0	6.0	38.0	37.0	45.7	Medium
KOLLAM	Oachira [4567]	KAMBRA AYIRAMTHENGU	81.0	11.0	21.0	49.0	60.5	High
KOLLAM	Oachira [4567]	KARELIMUKKU	81.0	6.0	74.8	0.2	0.3	Very Low
KOLLAM	Oachira [4567]	KARTHIKA	81.0	0.0	18.0	63.0	77.8	Very High
KOLLAM	Oachira [4567]	KARTHIKA EYE HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	KARUTHERIL	81.0	26.0	25.0	30.0	37.0	Medium
KOLLAM	Oachira [4567]	KAVIYIL TEMPLE	81.0	22.0	50.6	8.4	10.3	Low
KOLLAM	Oachira [4567]	KAVUMKADA	129.0	12.0	116.1	0.9	0.7	Very Low
KOLLAM	Oachira [4567]	KAZHUKANTHURUTH	81.0	0.0	28.0	53.0	65.4	High
KOLLAM	Oachira [4567]	KINARMUKKU PRAYAR	81.0	14.0	43.0	24.0	29.6	Medium
KOLLAM	Oachira [4567]	KNM UPS	81.0	2.0	78.9	0.1	0.1	Very Low
KOLLAM	Oachira [4567]	KOCHUMURI-1	81.0	4.0	24.0	53.0	65.4	High
KOLLAM	Oachira [4567]	KOCHUMURI-2	81.0	3.0	19.0	59.0	72.8	High
KOLLAM	Oachira [4567]	KOCHUVEETIL TEMPLE	81.0	3.0	3.0	75.0	92.6	Very High
KOLLAM	Oachira [4567]	KOLABHAGOM	81.0	32.3	47.7	1.0	1.2	Very Low
KOLLAM	Oachira [4567]	KORANDIPPALLY	81.0	16.0	64.0	1.0	1.2	Very Low
KOLLAM	Oachira [4567]	KOTTAKKATTU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	KUNNIMANNEL	81.0	23.0	41.0	17.0	21.0	Low
KOLLAM	Oachira [4567]	KUNNIMANNEL AMRITA FLAT	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	M N	81.0	11.0	42.3	27.7	34.2	Medium
KOLLAM	Oachira [4567]	MADATHIL TEMPLE	81.0	13.0	38.2	29.8	36.8	Medium
KOLLAM	Oachira [4567]	MAHALEKSHMI	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Oachira [4567]	MANJADI	162.0	61.0	101.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	MANJADI CONVENTION CENTER	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Oachira [4567]	MANJADI EAST	81.0	15.0	66.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	MANJADI NSS	81.0	3.0	78.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	MANJIPPUZHA	81.0	8.0	40.0	33.0	40.7	Medium
KOLLAM	Oachira [4567]	MARUTHAVANA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	MEMANA-1	121.0	31.0	52.0	38.0	31.4	Medium
KOLLAM	Oachira [4567]	MEMANA-2	81.0	0.0	14.0	67.0	82.7	Very High
KOLLAM	Oachira [4567]	MR ICE	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Oachira [4567]	MUPPATTICHIRA	81.0	9.0	42.0	30.0	37.0	Medium
KOLLAM	Oachira [4567]	MUTTATHUMANNEL	81.0	20.0	53.0	8.0	9.9	Very Low
KOLLAM	Oachira [4567]	MUZHANGODI	81.0	25.4	21.0	34.5	42.7	Medium
KOLLAM	Oachira [4567]	NAMBOZHI	81.0	9.0	51.2	20.8	25.6	Medium
KOLLAM	Oachira [4567]	NJAKKANAL	81.0	10.0	70.5	0.5	0.6	Very Low
KOLLAM	Oachira [4567]	OACHIRA NO 1 WEST	129.0	0.0	128.8	0.2	0.2	Very Low
KOLLAM	Oachira [4567]	OACHIRA NO 1- EAST	129.0	3.0	27.0	99.0	76.7	Very High
KOLLAM	Oachira [4567]	OACHIRA NO 3	81.0	29.0	51.0	1.0	1.2	Very Low
KOLLAM	Oachira [4567]	OACHIRA TEMPLE	202.0	19.0	42.4	140.6	69.6	High
KOLLAM	Oachira [4567]	OACHIRA TOWN	81.0	0.0	15.0	66.0	81.5	Very High
KOLLAM	Oachira [4567]	OTHALATHUMMOODU	81.0	8.3	71.0	1.7	2.1	Very Low
KOLLAM	Oachira [4567]	OTTATHENGIL HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	P AND T-NO 1	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Oachira [4567]	P AND T-NO 2	202.0	0.0	78.8	123.2	61.0	High
KOLLAM	Oachira [4567]	PADMA	129.0	12.0	116.9	0.1	0.0	Very Low
KOLLAM	Oachira [4567]	PALLIKADAV AMRITHA FLAT	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	PALLIKADAVU AIRTEL	81.0	10.0	10.0	61.0	75.3	Very High
KOLLAM	Oachira [4567]	PALLIKKADAVU	81.0	6.0	74.0	1.0	1.2	Very Low
KOLLAM	Oachira [4567]	PALLIMUKKU	81.0	5.0	76.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	PALLIMUKKU LAKSHAMVEEDU	81.0	5.0	22.3	53.7	66.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Oachira [4567]	PARAMPIL KADAVU	81.0	33.8	41.9	5.3	6.5	Very Low
KOLLAM	Oachira [4567]	PARAYANATHU MUKKU	81.0	10.0	70.0	1.0	1.2	Very Low
KOLLAM	Oachira [4567]	PATATHILKADAVU	81.0	12.0	67.5	1.5	1.8	Very Low
KOLLAM	Oachira [4567]	PATTASSERY	81.0	4.9	76.1	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	PATTASSERY NO II	81.0	13.0	68.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	PATTATHIL TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	POZHIMUGHAM	81.0	0.0	29.0	52.0	64.2	High
KOLLAM	Oachira [4567]	PRAGATHI	81.0	30.0	51.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	PRAGATHI BOAT YARD	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	PRAYAR RUBBER	81.0	25.0	56.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	PRAYAR SOUTH	81.0	30.0	45.0	6.0	7.4	Very Low
KOLLAM	Oachira [4567]	PRAYAR- HS	129.0	8.0	119.0	2.0	1.6	Very Low
KOLLAM	Oachira [4567]	PREMIER	81.0	5.0	17.0	59.0	72.8	High
KOLLAM	Oachira [4567]	PULINILKUMCOTTA	81.0	8.3	37.0	35.7	44.1	Medium
KOLLAM	Oachira [4567]	PULINKEEZHU	81.0	6.0	73.8	1.2	1.4	Very Low
KOLLAM	Oachira [4567]	PULITHITTA TEMPLE	81.0	3.0	33.0	45.0	55.6	High
KOLLAM	Oachira [4567]	PUNTHALA	81.0	5.0	76.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	PUTHENPURA	129.0	11.0	116.6	1.4	1.1	Very Low
KOLLAM	Oachira [4567]	PUTHENPURA NO 2	81.0	9.0	13.0	59.0	72.8	High
KOLLAM	Oachira [4567]	PUTHIYAKAVU	81.0	24.0	56.4	0.7	0.8	Very Low
KOLLAM	Oachira [4567]	R C P M- HOSPITAL	81.0	15.0	38.7	27.3	33.7	Medium
KOLLAM	Oachira [4567]	RADIOMUKKU	81.0	5.0	8.0	68.0	84.0	Very High
KOLLAM	Oachira [4567]	RAJ ICE NO 1	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	RAJ ICE NO 2	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	RAJAN SMARAKAM	81.0	21.0	39.0	21.0	25.9	Medium
KOLLAM	Oachira [4567]	RK PILLAI ARCADE	255.0	0.0	98.0	157.0	61.6	High
KOLLAM	Oachira [4567]	ROSA AUNTY ICE	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Oachira [4567]	S K V- NO 1	129.0	8.0	120.5	0.5	0.4	Very Low
KOLLAM	Oachira [4567]	S R K	81.0	13.0	66.3	1.7	2.1	Very Low
KOLLAM	Oachira [4567]	SAI- HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	SANCHARI-ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	SATHYALAYAM	81.0	29.0	36.0	16.0	19.8	Low
KOLLAM	Oachira [4567]	SNEHHA	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Oachira [4567]	SOORYA	81.0	5.0	24.6	51.4	63.5	High
KOLLAM	Oachira [4567]	SRAYIKKADU NORTH	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	SRAYIKKADU SOUTH	81.0	14.0	48.0	19.0	23.5	Low
KOLLAM	Oachira [4567]	SREENILAYAM	129.0	12.0	81.3	35.7	27.7	Medium
KOLLAM	Oachira [4567]	SVHS	81.0	2.0	79.0	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	TECHNO VALLIKKAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	THALASTHANAM	81.0	3.0	44.0	34.0	42.0	Medium
KOLLAM	Oachira [4567]	THANAKULAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	THAYYISSERY	81.0	23.0	38.0	20.0	24.7	Low
KOLLAM	Oachira [4567]	THAZHAKKUZHI	81.0	30.0	41.2	9.8	12.1	Low
KOLLAM	Oachira [4567]	THAZHAKUZHY TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	THOPPIL MUKKU	81.0	0.0	80.0	1.0	1.2	Very Low
KOLLAM	Oachira [4567]	THUMBILISSERIL	81.0	17.0	45.5	18.5	22.9	Low
KOLLAM	Oachira [4567]	TOTTATHIL MUKKU	202.0	29.0	116.0	57.0	28.2	Medium
KOLLAM	Oachira [4567]	TRANS OCEAN	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	UDHYANAM	81.0	8.0	41.0	32.0	39.5	Medium
KOLLAM	Oachira [4567]	UMMER- ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Oachira [4567]	VALAVUMUKKU	81.0	0.0	108.3	0.0	0.0	Very Low
KOLLAM	Oachira [4567]	VALETHU MUKKU	81.0	20.0	60.3	0.7	0.9	Very Low
KOLLAM	Oachira [4567]	VALIYAKULANGARA NO 2	81.0	13.0	31.0	37.0	45.7	Medium
KOLLAM	Oachira [4567]	VALIYAKULANGARA-3	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Oachira [4567]	VALIYAKULANGARA-I	81.0	11.0	16.0	54.0	66.7	High
KOLLAM	Oachira [4567]	VALLIKKAVU - P AND T	129.0	0.0	38.0	91.0	70.5	High
KOLLAM	Oachira [4567]	VALLIKKAVU GURU MANDIRAM	81.0	3.3	24.2	53.5	66.1	High
KOLLAM	Oachira [4567]	VALLIKKAVU JETTY NO 2	81.0	5.0	41.3	34.7	42.8	Medium
KOLLAM	Oachira [4567]	VALLIKKAVU KINARUMUKKU	81.0	3.0	77.3	0.7	0.9	Very Low
KOLLAM	Oachira [4567]	VALLIKKAVU NO 1	81.0	3.0	77.2	0.8	0.9	Very Low
KOLLAM	Oachira [4567]	VALLIKKAVU- NO 3	129.0	21.3	77.3	30.4	23.6	Low
KOLLAM	Oachira [4567]	VANCHITHARA	202.0	28.3	67.1	106.6	52.8	High
KOLLAM	Oachira [4567]	VASTHRA VALLIKAVE	81.0	0.0	5.0	76.0	93.8	Very High
KOLLAM	Oachira [4567]	VELLISSERIL	81.0	26.0	54.3	0.6	0.8	Very Low
KOLLAM	Oachira [4567]	VELUKUTTY SMARAKAM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	AARATTUKULAM	81.0	14.1	57.0	9.9	12.3	Low
KOLLAM	Thengamom-Pallickal [4663]	AARKKAKUZHYY	81.0	0.0	8.0	73.0	90.1	Very High
KOLLAM	Thengamom-Pallickal [4663]	ADAIPADU	81.0	0.0	28.3	52.7	65.1	High
KOLLAM	Thengamom-Pallickal [4663]	ALUMMOODU	81.0	16.0	26.0	39.0	48.1	Medium
KOLLAM	Thengamom-Pallickal [4663]	ALUMOODU VANCHI	81.0	0.0	28.0	53.0	65.4	High
KOLLAM	Thengamom-Pallickal [4663]	AMMUMMAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	AVICHAKULAM	81.0	6.0	14.0	61.0	75.3	Very High
KOLLAM	Thengamom-Pallickal [4663]	AVICHAKULAM ANGANAVADI	81.0	3.0	3.0	75.0	92.6	Very High
KOLLAM	Thengamom-Pallickal [4663]	BEST VENEERS	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	BEST WOOD	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	BHARATHI INFRATEL	81.0	5.0	6.0	70.0	86.4	Very High
KOLLAM	Thengamom-Pallickal [4663]	BUDHANAGAR	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Thengamom-Pallickal [4663]	CASHEW FACTORY	81.0	8.0	16.0	57.0	70.4	High
KOLLAM	Thengamom-Pallickal [4663]	CHAKKANCHIRA MALA	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	CHALA	81.0	6.0	16.0	59.0	72.8	High
KOLLAM	Thengamom-Pallickal [4663]	CHALUTHUNDIL	81.0	3.0	19.0	59.0	72.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Thengamom-Pallickal [4663]	CHAROORAYYATHU	81.0	3.0	8.0	70.0	86.4	Very High
KOLLAM	Thengamom-Pallickal [4663]	CHATHAKULAM	81.0	0.0	28.0	53.0	65.4	High
KOLLAM	Thengamom-Pallickal [4663]	CHENAMPUTHUR	81.0	11.0	24.0	46.0	56.8	High
KOLLAM	Thengamom-Pallickal [4663]	CHENATTUSSERY	81.0	0.0	20.0	61.0	75.3	Very High
KOLLAM	Thengamom-Pallickal [4663]	CHENGZHATHU CRUSHER	129.0	0.0	5.0	124.0	96.1	Very High
KOLLAM	Thengamom-Pallickal [4663]	CHENGILATHU	81.0	6.0	21.0	54.0	66.7	High
KOLLAM	Thengamom-Pallickal [4663]	CHERUKUNNAM	81.0	6.0	43.0	32.0	39.5	Medium
KOLLAM	Thengamom-Pallickal [4663]	CHIRAKKONICHIRA	81.0	0.0	28.0	53.0	65.4	High
KOLLAM	Thengamom-Pallickal [4663]	EDAKKADAVUKULAM	81.0	6.0	35.0	40.0	49.4	Medium
KOLLAM	Thengamom-Pallickal [4663]	EHC	81.0	0.0	11.0	70.0	86.4	Very High
KOLLAM	Thengamom-Pallickal [4663]	ELAMPALLIL	81.0	5.0	14.0	62.0	76.5	Very High
KOLLAM	Thengamom-Pallickal [4663]	ELANJIMOODU	81.0	3.0	11.0	67.0	82.7	Very High
KOLLAM	Thengamom-Pallickal [4663]	ENIYIL	81.0	9.0	13.0	59.0	72.8	High
KOLLAM	Thengamom-Pallickal [4663]	GANAPATHY	81.0	3.0	15.0	63.0	77.8	Very High
KOLLAM	Thengamom-Pallickal [4663]	GANESHAVILASOM	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	GENGA BRICKS	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	GIRIPURAM	81.0	13.0	54.0	14.0	17.3	Low
KOLLAM	Thengamom-Pallickal [4663]	GREEN TECH SOLUTION	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	KAITHACKAL	129.0	18.0	69.0	42.0	32.6	Medium
KOLLAM	Thengamom-Pallickal [4663]	KANDALASWAMY	81.0	23.0	27.0	31.0	38.3	Medium
KOLLAM	Thengamom-Pallickal [4663]	KANJIRAM KADAV NO-1	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	KANJIRAM KADAVU NO-2	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Thengamom-Pallickal [4663]	KARINTHARUVILA	81.0	0.0	12.0	69.0	85.2	Very High
KOLLAM	Thengamom-Pallickal [4663]	KOCHUTHARA	81.0	6.0	14.0	61.0	75.3	Very High
KOLLAM	Thengamom-Pallickal [4663]	KOLAMALA	81.0	10.0	24.0	47.0	58.0	High
KOLLAM	Thengamom-Pallickal [4663]	KOLLAYICKAL	129.0	5.0	33.0	91.0	70.5	High
KOLLAM	Thengamom-Pallickal [4663]	KONATHUPALLY	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Thengamom-Pallickal [4663]	KULAMULLATHIL	81.0	5.0	49.5	26.5	32.7	Medium
KOLLAM	Thengamom-Pallickal [4663]	KUNJALUMMODU	81.0	3.0	18.0	60.0	74.1	High
KOLLAM	Thengamom-Pallickal [4663]	KUNNIRADAM	81.0	5.0	6.0	70.0	86.4	Very High
KOLLAM	Thengamom-Pallickal [4663]	KUTTIYIL	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Thengamom-Pallickal [4663]	MADAPLETH	81.0	5.0	38.0	38.0	46.9	Medium
KOLLAM	Thengamom-Pallickal [4663]	MANGALETHU	51.0	0.0	16.0	35.0	68.6	High
KOLLAM	Thengamom-Pallickal [4663]	MAROOR TEMPLE	81.0	22.0	38.0	21.0	25.9	Medium
KOLLAM	Thengamom-Pallickal [4663]	MAYAKODE	81.0	3.0	6.3	71.7	88.5	Very High
KOLLAM	Thengamom-Pallickal [4663]	MELOOD WEST	81.0	3.0	3.0	75.0	92.6	Very High
KOLLAM	Thengamom-Pallickal [4663]	MOTHIRACHULLI	81.0	11.0	11.0	59.0	72.8	High
KOLLAM	Thengamom-Pallickal [4663]	MOTHIRACHULLI LEKSHAMVEEDU	81.0	3.0	5.0	73.0	90.1	Very High
KOLLAM	Thengamom-Pallickal [4663]	MUNDAPALLI SCHOOL	81.0	3.0	68.3	9.7	12.0	Low
KOLLAM	Thengamom-Pallickal [4663]	MUNNATTUKARA	81.0	32.0	22.0	27.0	33.3	Medium
KOLLAM	Thengamom-Pallickal [4663]	NELLIMUKAL ELA	129.0	3.0	39.0	87.0	67.4	High
KOLLAM	Thengamom-Pallickal [4663]	OLICKAL	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Thengamom-Pallickal [4663]	OTTUPARAMPU	81.0	5.0	47.0	29.0	35.8	Medium
KOLLAM	Thengamom-Pallickal [4663]	PACHAKKADU	81.0	22.0	55.3	3.7	4.6	Very Low
KOLLAM	Thengamom-Pallickal [4663]	PALLICKAL	81.0	3.0	21.0	57.0	70.4	High
KOLLAM	Thengamom-Pallickal [4663]	PAPPADI KUNNU	81.0	0.0	12.0	69.0	85.2	Very High
KOLLAM	Thengamom-Pallickal [4663]	PARAKOOTAM	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Thengamom-Pallickal [4663]	PAYYANALLORE	81.0	21.0	32.0	28.0	34.6	Medium
KOLLAM	Thengamom-Pallickal [4663]	POOMOODU	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Thengamom-Pallickal [4663]	POST OFFICE	81.0	27.0	54.0	0.0	0.0	Very Low
KOLLAM	Thengamom-Pallickal [4663]	PRIYADARSHINI	81.0	19.0	40.8	21.2	26.1	Medium
KOLLAM	Thengamom-Pallickal [4663]	PULLIPARA	81.0	0.0	18.0	63.0	77.8	Very High
KOLLAM	Thengamom-Pallickal [4663]	PUNNAKODE	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	RELIANCE	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Thengamom-Pallickal [4663]	TECHNIBS ENGINEERING	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	TELEPHONE EXCHANGE	81.0	8.0	8.0	65.0	80.2	Very High
KOLLAM	Thengamom-Pallickal [4663]	THENGAMOM	81.0	28.0	16.0	37.0	45.7	Medium
KOLLAM	Thengamom-Pallickal [4663]	THENGINAL	81.0	13.0	8.0	60.0	74.1	High
KOLLAM	Thengamom-Pallickal [4663]	THENNAPARAMBIL	51.0	3.0	11.0	37.0	72.5	High
KOLLAM	Thengamom-Pallickal [4663]	THOTTUVA	81.0	6.0	12.3	62.7	77.4	Very High
KOLLAM	Thengamom-Pallickal [4663]	UDICKAL KULAM	81.0	5.0	20.0	56.0	69.1	High
KOLLAM	Thengamom-Pallickal [4663]	ULLOORMUKAL	81.0	6.8	11.0	63.2	78.0	Very High
KOLLAM	Thengamom-Pallickal [4663]	VAZHUVELI PADI	81.0	0.0	6.0	75.0	92.6	Very High
KOLLAM	Thengamom-Pallickal [4663]	VELLACHIRA	81.0	6.0	39.0	36.0	44.4	Medium
KOLLAM	Thengamom-Pallickal [4663]	VETERINARY	81.0	5.0	43.0	33.0	40.7	Medium
KOLLAM	Thengamom-Pallickal [4663]	WATER WORKS	81.0	5.0	20.0	56.0	69.1	High
KOLLAM	Vallikunnam [5754]	ALTHARAVILA	81.0	8.9	72.0	0.1	0.1	Very Low
KOLLAM	Vallikunnam [5754]	AMRUTHA	81.0	3.0	23.0	55.0	67.9	High
KOLLAM	Vallikunnam [5754]	ANGANVADI	81.0	30.7	50.3	0.0	0.0	Very Low
KOLLAM	Vallikunnam [5754]	BUND	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Vallikunnam [5754]	CHAMAYAM	129.0	3.0	79.6	46.4	36.0	Medium
KOLLAM	Vallikunnam [5754]	CHANGALAPPALLY	129.0	10.0	50.3	68.7	53.3	High
KOLLAM	Vallikunnam [5754]	CHANGOOR	81.0	3.0	39.3	38.7	47.8	Medium
KOLLAM	Vallikunnam [5754]	CHATHAVANA	81.0	6.0	35.3	39.7	49.0	Medium
KOLLAM	Vallikunnam [5754]	CHIRACKAL V	81.0	0.0	25.0	56.0	69.1	High
KOLLAM	Vallikunnam [5754]	CHOONAD SOUTH	81.0	5.0	37.0	39.0	48.1	Medium
KOLLAM	Vallikunnam [5754]	CRUSHER CHATHIYARA V	202.0	0.0	0.0	202.0	100.0	Very High
KOLLAM	Vallikunnam [5754]	ELANGATHU	202.0	8.0	90.3	103.7	51.3	High
KOLLAM	Vallikunnam [5754]	ELAVIN MOOD	129.0	0.0	14.3	114.7	88.9	Very High
KOLLAM	Vallikunnam [5754]	ELIPAKULAM	81.0	16.0	43.7	21.3	26.3	Medium
KOLLAM	Vallikunnam [5754]	GURUMANDIRAM	81.0	0.0	20.0	61.0	75.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Vallikunnam [5754]	HIBAS	81.0	5.0	38.0	38.0	46.9	Medium
KOLLAM	Vallikunnam [5754]	INDUS	81.0	0.0	22.0	59.0	72.8	High
KOLLAM	Vallikunnam [5754]	KADAICKAL	129.0	6.0	58.3	64.7	50.2	High
KOLLAM	Vallikunnam [5754]	KAKKURUMB	81.0	0.0	10.0	71.0	87.7	Very High
KOLLAM	Vallikunnam [5754]	KALAKKATTU	81.0	0.0	21.3	59.7	73.7	High
KOLLAM	Vallikunnam [5754]	KAMBISSERI	81.0	18.0	61.7	1.3	1.7	Very Low
KOLLAM	Vallikunnam [5754]	KANIYAMUKKU	81.0	0.0	81.0	0.0	0.0	Very Low
KOLLAM	Vallikunnam [5754]	KANJIRATHIN MOODU	81.0	10.0	47.3	23.7	29.3	Medium
KOLLAM	Vallikunnam [5754]	KANNACHAL	129.0	0.0	24.0	105.0	81.4	Very High
KOLLAM	Vallikunnam [5754]	KANNANAKUZHI	129.0	5.0	26.0	98.0	76.0	Very High
KOLLAM	Vallikunnam [5754]	KARIMUTTOM	129.0	3.0	25.0	101.0	78.3	Very High
KOLLAM	Vallikunnam [5754]	KARTHIYAYENIPURAM	81.0	0.0	46.3	34.7	42.8	Medium
KOLLAM	Vallikunnam [5754]	KATTOOR	81.0	0.0	21.0	60.0	74.1	High
KOLLAM	Vallikunnam [5754]	KHADI BOARD	81.0	8.0	33.0	40.0	49.4	Medium
KOLLAM	Vallikunnam [5754]	KOLLANTAYATH	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Vallikunnam [5754]	KUMBALAM	81.0	5.0	21.0	55.0	67.9	High
KOLLAM	Vallikunnam [5754]	KUNNAM	81.0	17.0	37.0	27.0	33.3	Medium
KOLLAM	Vallikunnam [5754]	MALAMEL	129.0	23.0	105.5	0.5	0.4	Very Low
KOLLAM	Vallikunnam [5754]	MANACKADUKUTTIYIL	129.0	8.0	24.0	97.0	75.2	Very High
KOLLAM	Vallikunnam [5754]	MANGALASSERY	81.0	3.0	6.0	72.0	88.9	Very High
KOLLAM	Vallikunnam [5754]	MANJADI	81.0	8.0	60.0	13.0	16.0	Low
KOLLAM	Vallikunnam [5754]	MARUTHI	81.0	0.0	0.0	81.0	100.0	Very High
KOLLAM	Vallikunnam [5754]	MATHRUBHOOMI STUDY CIRCLE	81.0	3.0	77.6	0.4	0.5	Very Low
KOLLAM	Vallikunnam [5754]	MAVANAKUTTY	81.0	9.0	41.8	30.2	37.3	Medium
KOLLAM	Vallikunnam [5754]	MILMA	81.0	3.0	76.0	2.0	2.5	Very Low
KOLLAM	Vallikunnam [5754]	MM COLONY	81.0	3.0	21.7	56.3	69.5	High
KOLLAM	Vallikunnam [5754]	MR JUNCTION	81.0	3.0	58.6	19.4	24.0	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Vallikunnam [5754]	NAMPUKULAM	81.0	5.0	18.0	58.0	71.6	High
KOLLAM	Vallikunnam [5754]	OMPALLIMADAM	81.0	8.0	34.4	38.6	47.6	Medium
KOLLAM	Vallikunnam [5754]	PADAYANIVATTOM	81.0	3.0	23.0	55.0	67.9	High
KOLLAM	Vallikunnam [5754]	PADAYANIVATTOM CRESURE	81.0	0.0	3.0	78.0	96.3	Very High
KOLLAM	Vallikunnam [5754]	PALLICKATHARA	81.0	14.0	25.0	42.0	51.9	High
KOLLAM	Vallikunnam [5754]	PALLIKUTTY	81.0	6.0	35.0	40.0	49.4	Medium
KOLLAM	Vallikunnam [5754]	PALLIMUKKU	81.0	5.0	44.0	32.0	39.5	Medium
KOLLAM	Vallikunnam [5754]	PALLIVILA	129.0	0.0	65.3	63.7	49.4	Medium
KOLLAM	Vallikunnam [5754]	PANAYILKUTTY	81.0	0.0	23.8	57.2	70.7	High
KOLLAM	Vallikunnam [5754]	PATHIYARATHUKULANGARA	81.0	13.0	56.4	11.6	14.3	Low
KOLLAM	Vallikunnam [5754]	PLAVILA	81.0	16.0	36.9	28.1	34.7	Medium
KOLLAM	Vallikunnam [5754]	POKKATTU	81.0	6.0	16.0	59.0	72.8	High
KOLLAM	Vallikunnam [5754]	POLICE STATION	81.0	5.0	3.0	73.0	90.1	Very High
KOLLAM	Vallikunnam [5754]	POLO	81.0	11.0	25.0	45.0	55.6	High
KOLLAM	Vallikunnam [5754]	POOVAADITHARA	81.0	11.0	55.3	14.7	18.1	Low
KOLLAM	Vallikunnam [5754]	PULLATTUTHARA	81.0	26.0	55.0	0.0	0.0	Very Low
KOLLAM	Vallikunnam [5754]	PUNJA	202.0	0.0	153.5	48.5	24.0	Low
KOLLAM	Vallikunnam [5754]	PUTHENCHANDA	81.0	0.0	32.0	49.0	60.5	High
KOLLAM	Vallikunnam [5754]	PUTHENVEETIL HILLS	129.0	0.0	0.0	129.0	100.0	Very High
KOLLAM	Vallikunnam [5754]	RAMANCHIRA	129.0	27.0	94.7	7.3	5.6	Very Low
KOLLAM	Vallikunnam [5754]	RAMANCHIRA COLONY NO-2	12.0	0.0	0.0	12.0	100.0	Very High
KOLLAM	Vallikunnam [5754]	RAMANCHIRA COLONY NO1	12.0	0.0	0.0	12.0	100.0	Very High
KOLLAM	Vallikunnam [5754]	SASTHANADA	81.0	0.0	39.0	42.0	51.8	High
KOLLAM	Vallikunnam [5754]	TATA	81.0	10.0	71.0	0.0	0.0	Very Low
KOLLAM	Vallikunnam [5754]	TELEPHONE	81.0	11.0	30.9	39.1	48.3	Medium
KOLLAM	Vallikunnam [5754]	THOPPIL	129.0	14.5	93.0	21.5	16.7	Low
KOLLAM	Vallikunnam [5754]	THOPPIL BHASI	81.0	6.0	39.0	36.0	44.4	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOLLAM	Vallikunnam [5754]	THUNDATHIL	81.0	14.3	65.0	1.7	2.1	Very Low
KOLLAM	Vallikunnam [5754]	VADUTHALA	81.0	16.0	37.0	28.0	34.6	Medium
KOLLAM	Vallikunnam [5754]	VALAYANTHARA JN	81.0	8.0	26.0	47.0	58.0	High
KOLLAM	Vallikunnam [5754]	VALLIKUNNAM CHIRA	81.0	5.0	14.0	62.0	76.5	Very High
KOLLAM	Vallikunnam [5754]	VATTACKADU TEMPLE	81.0	9.0	72.0	0.0	0.0	Very Low
KOLLAM	Vallikunnam [5754]	VATTAKATTU	129.0	3.0	50.2	75.8	58.7	High
KOLLAM	Vallikunnam [5754]	VATTATHARA	81.0	0.0	16.0	65.0	80.2	Very High
KOLLAM	Vallikunnam [5754]	VAZHUVELI	81.0	13.0	66.3	1.7	2.1	Very Low
KOLLAM	Vallikunnam [5754]	VELOOR LPS	81.0	5.0	27.0	49.0	60.5	High
KOLLAM	Vallikunnam [5754]	VIVEKANANDA	81.0	3.0	20.0	58.0	71.6	High