

KSEB Renewable Energy Feasibility Report

Generated report · 2000 transformers across 1 districts. Balance % = (Balance Available ÷ 90% DTR Capacity) × 100.

District Summary

District	Transformers	Balance (kW)	Very High	High	Medium	Low	Very Low	Unknown
KOZHIKODE	2000	192,114.0	1306	474	151	35	34	0
TOTAL	2000	192,114.0	1306	474	151	35	34	0

KOZHIKODE — 2000 transformers

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Areekkad [6789]	ALLIED - MIE 7-3A	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	ANA ROAD - AR28	129.0	5.0	31.4	92.6	71.8	High
KOZHIKODE	Areekkad [6789]	ARUN POLYMER - NH94	202.0	0.0	33.0	169.0	83.7	Very High
KOZHIKODE	Areekkad [6789]	AVILL MILL - JR28-9	202.0	0.0	18.0	184.0	91.1	Very High
KOZHIKODE	Areekkad [6789]	B SONS - PP 36	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Areekkad [6789]	BLACK STONE - NH96-5X	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	BLUE CHIP - PP 5-2	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	BSNL AREEKADE- NH 37	81.0	3.0	49.3	28.7	35.4	Medium
KOZHIKODE	Areekkad [6789]	CHALATTY-NBS 32-2	81.0	0.0	31.3	49.7	61.4	High
KOZHIKODE	Areekkad [6789]	CHEMICAL - B23	255.0	4.0	93.5	157.5	61.8	High
KOZHIKODE	Areekkad [6789]	CHRISTOPHER - NB97-10	81.0	5.0	19.0	57.0	70.4	High
KOZHIKODE	Areekkad [6789]	CHUMMAN ROAD	81.0	5.0	70.8	5.2	6.4	Very Low
KOZHIKODE	Areekkad [6789]	CHUNGAM -MK 144X	81.0	11.0	18.0	52.0	64.2	High
KOZHIKODE	Areekkad [6789]	CIPLA - NH81-1F	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	COMMERCIAL COMPLEX ID	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	COOL LAND ICE -MIE 12A	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	COTTUMMAL - CM81	81.0	3.0	28.0	50.0	61.7	High
KOZHIKODE	Areekkad [6789]	CRESCENT BAZAR MK80-8	81.0	18.0	53.0	10.0	12.3	Low
KOZHIKODE	Areekkad [6789]	DIVAKAR-AVILL MILL II-JR28-6	129.0	0.0	13.0	116.0	89.9	Very High
KOZHIKODE	Areekkad [6789]	DIVISION OFFICE - AR4	81.0	0.0	18.7	62.3	76.9	Very High
KOZHIKODE	Areekkad [6789]	DURACOTE - MK123	202.0	5.0	10.0	187.0	92.6	Very High
KOZHIKODE	Areekkad [6789]	EURO STAR - JR28-3B	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	FACO - MK50	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	FAMILY PALACE - JR18	81.0	5.0	6.0	70.0	86.4	Very High
KOZHIKODE	Areekkad [6789]	FERRARO-FRK - MK134	81.0	0.0	15.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Areekkad [6789]	FERRARRO - NH96-5	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	FIN FIN - KJ12	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	FIRE FORCE -NH1-IA	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	FORTUNE - NH134A	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	GALEELA TOWER - GN2X	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	GEETHANJALI - 3 - NH159-2	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	GEETHANJALI - NH157	202.0	0.0	10.0	192.0	95.0	Very High
KOZHIKODE	Areekkad [6789]	GEETHANJALI-2 - NH161	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	GIREESH NAGAR - NH12	129.0	0.0	119.0	10.0	7.8	Very Low
KOZHIKODE	Areekkad [6789]	GREEN VALLY - MIE 8-2X	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	HEALTH CENTER- MN5	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Areekkad [6789]	HIGH SCHOOL-CHALATTY-NBS 22	202.0	0.0	71.5	130.5	64.6	High
KOZHIKODE	Areekkad [6789]	HORISON- SMR14	129.0	0.0	18.4	110.6	85.7	Very High
KOZHIKODE	Areekkad [6789]	INDUSTRIAL ESTATE CVR-NH104-8X	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	JAMENS - MK34-1F	202.0	3.0	3.0	196.0	97.0	Very High
KOZHIKODE	Areekkad [6789]	JAYA NO 1 - MK34-1-H	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Areekkad [6789]	JAYA POLYMER - MK34-8-1	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	JAYANTHI ROAD - JR1	129.0	0.0	45.0	84.0	65.1	High
KOZHIKODE	Areekkad [6789]	JISHI - NH71-6X	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	K C K - MK106	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Areekkad [6789]	K D P P - NH73	81.0	0.0	40.5	40.5	50.0	Medium
KOZHIKODE	Areekkad [6789]	KALLUVETTUKUZH -MK-24	81.0	0.0	4.0	77.0	95.1	Very High
KOZHIKODE	Areekkad [6789]	KANDAL- CMF 17	81.0	0.0	32.3	48.7	60.1	High
KOZHIKODE	Areekkad [6789]	KARIPAL THODY - NB114	81.0	0.0	8.4	72.6	89.6	Very High
KOZHIKODE	Areekkad [6789]	KAVALLUR - NH168	81.0	5.0	39.8	36.2	44.7	Medium
KOZHIKODE	Areekkad [6789]	KDPP COMPOUND -1	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	KOLAMBALATH - AV14	81.0	5.0	40.3	35.7	44.1	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Areekkad [6789]	KOLATHARA - MK99A	129.0	8.0	46.8	74.2	57.5	High
KOZHIKODE	Areekkad [6789]	KOLATHARA II - MK 81	129.0	5.0	24.0	100.0	77.5	Very High
KOZHIKODE	Areekkad [6789]	KOTTALADA - PP 6	81.0	0.0	45.0	36.0	44.4	Medium
KOZHIKODE	Areekkad [6789]	KOYAPARAMB THAZHAM - NH123-24	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Areekkad [6789]	KOYAPARAMBA NB78-6A	129.0	0.0	68.0	61.0	47.3	Medium
KOZHIKODE	Areekkad [6789]	KRISHNARJUNA - NB4	81.0	0.0	80.0	1.0	1.2	Very Low
KOZHIKODE	Areekkad [6789]	KUDUMBASREE - NH152A	81.0	0.0	23.0	58.0	71.6	High
KOZHIKODE	Areekkad [6789]	KUNDAYITHODE NO 1 - NH147	129.0	0.0	3.0	126.0	97.7	Very High
KOZHIKODE	Areekkad [6789]	KUNNUMMAL - MN27-1	255.0	5.0	111.0	139.0	54.5	High
KOZHIKODE	Areekkad [6789]	LAKSHAM VEEDU-MANKUNI- NB34	202.0	0.0	41.0	161.0	79.7	Very High
KOZHIKODE	Areekkad [6789]	LAKSHMI - MK23	202.0	0.0	19.5	182.5	90.3	Very High
KOZHIKODE	Areekkad [6789]	MADRASSANGADI - MK69	129.0	15.0	108.3	5.7	4.4	Very Low
KOZHIKODE	Areekkad [6789]	MAHALAKSHMI- NH122	405.0	0.0	76.0	329.0	81.2	Very High
KOZHIKODE	Areekkad [6789]	MALABAR FOOT - NH96-3A	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	MANKUNI TEMPLE- NB 28	81.0	7.0	17.5	56.5	69.7	High
KOZHIKODE	Areekkad [6789]	MANOJ PACKING - NH139	81.0	0.0	3.3	77.7	95.9	Very High
KOZHIKODE	Areekkad [6789]	MATHILOLLI THAZHAM-NBS32-20	81.0	0.0	22.0	59.0	72.8	High
KOZHIKODE	Areekkad [6789]	MAVELI -CM122	202.0	0.0	85.8	116.2	57.5	High
KOZHIKODE	Areekkad [6789]	MECHANICAL FESILITY I-MK12C	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	MECHANICAL FESILITY II-MK12I	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	MEENCHANDA BYE PASS-NH7A	405.0	0.0	80.7	324.3	80.1	Very High
KOZHIKODE	Areekkad [6789]	MELACHIRA - MC1	129.0	0.0	30.0	99.0	76.7	Very High
KOZHIKODE	Areekkad [6789]	MIE -GATE - MN12	81.0	6.0	17.0	58.0	71.6	High
KOZHIKODE	Areekkad [6789]	MODERN -NH73	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	MODERN ICEPLANT - MIE8-X-1	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	MODERN TOWER - NH81-3	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	MUNDOPADAM - NH63-10	81.0	0.0	12.0	69.0	85.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Areekkad [6789]	N C K - MK45	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	N S S - CM105	129.0	0.0	64.0	65.0	50.4	High
KOZHIKODE	Areekkad [6789]	NAIRMADAM - B9-1A	129.0	0.0	42.6	86.3	66.9	High
KOZHIKODE	Areekkad [6789]	NALLALAM BAZAR - NB74A	81.0	0.0	27.7	53.3	65.8	High
KOZHIKODE	Areekkad [6789]	NATIONAL - MK47	129.0	0.0	10.0	119.0	92.2	Very High
KOZHIKODE	Areekkad [6789]	NC POLYMERS - MK53	255.0	10.0	26.0	219.0	85.9	Very High
KOZHIKODE	Areekkad [6789]	NEW TECH - NH71-6X	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	NHALIYANPARAMBA - NH102A	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	NM ROAD- NM 23	81.0	5.0	44.0	32.0	39.5	Medium
KOZHIKODE	Areekkad [6789]	O D E P C -OC 6A	81.0	0.0	30.3	50.7	62.6	High
KOZHIKODE	Areekkad [6789]	OG ROAD - MM57	129.0	0.0	50.0	79.0	61.2	High
KOZHIKODE	Areekkad [6789]	OLAVANNA - NB 14	202.0	0.0	49.0	153.0	75.7	Very High
KOZHIKODE	Areekkad [6789]	ORIENT POLYMERS - NH140	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Areekkad [6789]	ORPHANAGE-CICS -KJ1A	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Areekkad [6789]	P AND T - AR21-1	129.0	0.0	39.0	90.0	69.8	High
KOZHIKODE	Areekkad [6789]	PADAM STOP-NB 49	202.0	3.0	98.3	100.7	49.9	Medium
KOZHIKODE	Areekkad [6789]	PALATHIPPADAM PP 38-1	129.0	6.0	47.0	76.0	58.9	High
KOZHIKODE	Areekkad [6789]	PALATT NAGAR - CL20	81.0	8.0	73.0	0.0	0.0	Very Low
KOZHIKODE	Areekkad [6789]	PANAGATUPARAMB ERLD LINE-EL18	129.0	0.0	52.7	76.3	59.2	High
KOZHIKODE	Areekkad [6789]	PARAPPURAM -NH81-11	81.0	3.0	9.0	69.0	85.2	Very High
KOZHIKODE	Areekkad [6789]	PARAPPURAM TEMPLE -NH81-32	81.0	0.0	10.2	70.8	87.4	Very High
KOZHIKODE	Areekkad [6789]	PLUSPOLY - PP26	81.0	3.0	9.0	69.0	85.2	Very High
KOZHIKODE	Areekkad [6789]	POLICE STATION- NH 48	129.0	0.0	38.0	91.0	70.5	High
KOZHIKODE	Areekkad [6789]	POOLAKADAVE - NB98	202.0	0.0	91.0	111.0	55.0	High
KOZHIKODE	Areekkad [6789]	PRESTIGE-SMR22	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	PSA - MK105	129.0	8.0	8.2	112.8	87.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Areekkad [6789]	PTRU	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	PULLUNIPADAM - CM 46	81.0	5.0	42.0	34.0	42.0	Medium
KOZHIKODE	Areekkad [6789]	RAFEEQ-NEW PALATU NAGAR-CL 9A	81.0	3.0	25.0	53.0	65.4	High
KOZHIKODE	Areekkad [6789]	RAHIMAN BAZAR- MK34	255.0	0.0	42.0	213.0	83.5	Very High
KOZHIKODE	Areekkad [6789]	RELIANCE AREEEKKAD - NH 33	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	SANCO - MK39	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	SBT AREEEKKAD - NH24	202.0	0.0	87.1	114.9	56.9	High
KOZHIKODE	Areekkad [6789]	SCODA AREEKADE - NB7	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	SHANKUTHALA - NH62	81.0	0.0	14.7	66.3	81.8	Very High
KOZHIKODE	Areekkad [6789]	SILVER LINDEN 1	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	SNDP AREEEKKAD - NB 10	129.0	0.0	12.9	116.1	90.0	Very High
KOZHIKODE	Areekkad [6789]	SNEHATHEERAM -KJ21A	129.0	0.0	21.0	108.0	83.7	Very High
KOZHIKODE	Areekkad [6789]	SOLAR PAKAGE - MIE 6X	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	SRAMBIA - NH188	202.0	0.0	60.0	142.0	70.3	High
KOZHIKODE	Areekkad [6789]	STEEL - NH102	129.0	0.0	8.0	121.0	93.8	Very High
KOZHIKODE	Areekkad [6789]	SUB STATION	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	TEFLONE KOLATHARA - MK108	129.0	0.0	13.0	116.0	89.9	Very High
KOZHIKODE	Areekkad [6789]	TEXO - MIE 1	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	THACHILOTTU PARAMBU-NBS47	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Areekkad [6789]	THIRUVACHIRA UK 24	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Areekkad [6789]	TREATMENT YARD - MK15	129.0	0.0	32.0	97.0	75.2	Very High
KOZHIKODE	Areekkad [6789]	TREE TOP - MIE 13A	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	TROOPPER - PP 10E	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	U C NO -2 - UC16	129.0	10.0	27.0	92.0	71.3	High
KOZHIKODE	Areekkad [6789]	U C ROAD - UC1	81.0	0.0	79.7	1.4	1.7	Very Low
KOZHIKODE	Areekkad [6789]	UDUMBRA CENTRAL - U14X1	129.0	0.0	41.2	87.8	68.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Areekkad [6789]	UDUMBRA KADAVU - U17	129.0	6.0	35.0	88.0	68.2	High
KOZHIKODE	Areekkad [6789]	UDUMBRA THODE - U9	129.0	0.0	27.0	102.0	79.1	Very High
KOZHIKODE	Areekkad [6789]	ULLISSERYKUNNU UK6	129.0	0.0	24.0	105.0	81.4	Very High
KOZHIKODE	Areekkad [6789]	URUVANKULAM - CM 17	129.0	10.0	54.0	65.0	50.4	High
KOZHIKODE	Areekkad [6789]	V K C - NH133A	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	VEE KAY CEE OFFICE - NH96-1X	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	VIJAYAPRAKASH - NH110	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	VIMSON - NH134A	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	WELL TEK - MIE - 7-1A	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Areekkad [6789]	WOMENS INDUSTRIAL ESTATE-KJ33F	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkulam [6767]	A ONE	81.0	8.0	9.0	64.0	79.0	Very High
KOZHIKODE	Areekkulam [6767]	AG-PALACE	81.0	0.0	23.6	57.4	70.8	High
KOZHIKODE	Areekkulam [6767]	ARANYA	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Areekkulam [6767]	ARIKKULAM MUKKU	129.0	8.0	36.9	84.1	65.2	High
KOZHIKODE	Areekkulam [6767]	ARIKKULAM PANCHAYATH	81.0	6.0	8.0	67.0	82.7	Very High
KOZHIKODE	Areekkulam [6767]	ARIKKULAM PHC	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Areekkulam [6767]	ARIKKULAM TALKIES	81.0	0.0	13.3	67.7	83.6	Very High
KOZHIKODE	Areekkulam [6767]	AWAD PLASTIC	81.0	5.0	23.0	53.0	65.4	High
KOZHIKODE	Areekkulam [6767]	BISCUIT FACTORY	81.0	5.0	10.0	66.0	81.5	Very High
KOZHIKODE	Areekkulam [6767]	CHALIL PALLI	81.0	6.0	32.0	43.0	53.1	High
KOZHIKODE	Areekkulam [6767]	CHANGARAMVALLI PUMP	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Areekkulam [6767]	CHAVATTU	81.0	5.0	26.6	49.4	60.9	High
KOZHIKODE	Areekkulam [6767]	CHEMMALAPURAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkulam [6767]	CHIROL	81.0	0.0	3.2	77.8	96.0	Very High
KOZHIKODE	Areekkulam [6767]	CRUSHER UNIT	129.0	0.0	11.0	118.0	91.5	Very High
KOZHIKODE	Areekkulam [6767]	EKKATTUR	202.0	13.0	61.0	128.0	63.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Areekkulam [6767]	ELAMKAMAL PALLI	81.0	9.0	11.0	61.0	75.3	Very High
KOZHIKODE	Areekkulam [6767]	ELANKAMAL	81.0	3.0	16.6	61.4	75.8	Very High
KOZHIKODE	Areekkulam [6767]	GAYATHRI MUKKU	81.0	5.0	12.0	64.0	79.0	Very High
KOZHIKODE	Areekkulam [6767]	INDUS TOWER PARAMBATH	81.0	0.0	26.8	54.2	67.0	High
KOZHIKODE	Areekkulam [6767]	KAITHA VAYAL	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Areekkulam [6767]	KALIYATH MUKKU	81.0	5.0	13.0	63.0	77.7	Very High
KOZHIKODE	Areekkulam [6767]	KARAYAD AKG CENTRE	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Areekkulam [6767]	KEEZHARIYUR	129.0	3.0	43.0	83.0	64.3	High
KOZHIKODE	Areekkulam [6767]	KEEZHARIYUR SMARAKAM	81.0	5.0	3.3	72.7	89.8	Very High
KOZHIKODE	Areekkulam [6767]	KORETTY	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Areekkulam [6767]	KOZHIPURATH COLONY	81.0	6.0	19.0	56.0	69.1	High
KOZHIKODE	Areekkulam [6767]	KUNHALI MUKKU	81.0	5.0	29.7	46.3	57.1	High
KOZHIKODE	Areekkulam [6767]	KUNNOTH MUKKU	81.0	8.0	21.0	52.0	64.2	High
KOZHIKODE	Areekkulam [6767]	KURUDI VEEDU	129.0	0.0	18.0	111.0	86.0	Very High
KOZHIKODE	Areekkulam [6767]	KURUMAYIL THAZHA	81.0	5.0	3.0	73.0	90.1	Very High
KOZHIKODE	Areekkulam [6767]	MADATHIL KUNI	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Areekkulam [6767]	MADATHIL THAZHA	81.0	3.0	3.0	75.0	92.6	Very High
KOZHIKODE	Areekkulam [6767]	MANJILATUKUNNU	51.0	3.0	20.0	28.0	54.9	High
KOZHIKODE	Areekkulam [6767]	MANNADY	81.0	3.0	11.0	67.0	82.7	Very High
KOZHIKODE	Areekkulam [6767]	MAVATTU	81.0	0.0	4.3	76.7	94.7	Very High
KOZHIKODE	Areekkulam [6767]	MOOLAKKAL THAZHA	81.0	3.0	26.0	52.0	64.2	High
KOZHIKODE	Areekkulam [6767]	MUTHAMBI	81.0	8.0	28.0	45.0	55.6	High
KOZHIKODE	Areekkulam [6767]	NADERY WOOD	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Areekkulam [6767]	NADUVATHOOR	81.0	3.0	16.0	62.0	76.5	Very High
KOZHIKODE	Areekkulam [6767]	NADUVATHUR THERU	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Areekkulam [6767]	NAVEENA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkulam [6767]	NAYADAN PUZHA	81.0	0.0	23.3	57.7	71.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Areekkulam [6767]	NIDUMPOYIL	81.0	0.0	24.7	56.3	69.5	High
KOZHIKODE	Areekkulam [6767]	OOTTERY	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Areekkulam [6767]	OTTAKANDAM	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Areekkulam [6767]	PAAROL MUKKU	81.0	6.0	0.0	75.0	92.6	Very High
KOZHIKODE	Areekkulam [6767]	PALLIKKAL	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Areekkulam [6767]	PALLITHAZHAE	81.0	3.0	14.0	64.0	79.0	Very High
KOZHIKODE	Areekkulam [6767]	PANHATTU SCHOOL	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Areekkulam [6767]	PARAMPATH	81.0	3.0	22.0	56.0	69.1	High
KOZHIKODE	Areekkulam [6767]	POONCHOLA	81.0	0.0	5.4	75.6	93.4	Very High
KOZHIKODE	Areekkulam [6767]	POOTHERIPPARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkulam [6767]	PULIKKOOL MUKKU	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Areekkulam [6767]	PUTHANPALLI	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Areekkulam [6767]	PUTHUPATTA	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Areekkulam [6767]	PUTHUSSEERITHAZHE	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Areekkulam [6767]	RAJEEV COLONY	81.0	0.0	3.3	77.7	95.9	Very High
KOZHIKODE	Areekkulam [6767]	SIVAKSHETRAM	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Areekkulam [6767]	THANDAYIL THAZHA	81.0	5.0	27.4	48.6	60.1	High
KOZHIKODE	Areekkulam [6767]	THIRUVANGAYOOR	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Areekkulam [6767]	THURUTHIMUKKU	81.0	6.0	6.0	69.0	85.2	Very High
KOZHIKODE	Areekkulam [6767]	URALLOOR	81.0	0.0	37.0	44.0	54.3	High
KOZHIKODE	Areekkulam [6767]	VAKAMOLY	81.0	3.0	8.0	70.0	86.4	Very High
KOZHIKODE	Areekkulam [6767]	VALERIMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkulam [6767]	VATTAKANDI PORAYI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Areekkulam [6767]	VELIYANNOOR CHELLY	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Atholi [6615]	ADUVATTU	81.0	3.0	19.2	58.8	72.6	High
KOZHIKODE	Atholi [6615]	AIRTEL KOOMULLY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	AIRTEL VELOOR	129.0	0.0	40.0	89.0	69.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Atholi [6615]	AL AFSA KUNIYIL KADAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	ANAPPARA KONGANNUR	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Atholi [6615]	ANDIKODE	129.0	5.0	14.0	110.0	85.3	Very High
KOZHIKODE	Atholi [6615]	ANNAKOTTAN VAYAL	81.0	0.0	4.0	77.0	95.1	Very High
KOZHIKODE	Atholi [6615]	ANNASSERI ROAD	81.0	14.0	18.0	49.0	60.5	High
KOZHIKODE	Atholi [6615]	ATHANI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	ATHOLIKAVU TEMPLE	81.0	5.0	0.0	76.0	93.8	Very High
KOZHIKODE	Atholi [6615]	ATHOLY NO-1	202.0	0.0	26.7	175.3	86.8	Very High
KOZHIKODE	Atholi [6615]	ATHOLY NO-2	129.0	8.0	81.5	39.5	30.7	Medium
KOZHIKODE	Atholi [6615]	ATHOLY TELE EXCHANGE	129.0	0.0	24.0	105.0	81.4	Very High
KOZHIKODE	Atholi [6615]	BLUEMERIDIAN	129.0	0.0	20.0	109.0	84.5	Very High
KOZHIKODE	Atholi [6615]	CHANGAROTH COLONY	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Atholi [6615]	CHATHANATTU KADAVU VELUR	81.0	3.0	66.0	12.0	14.8	Low
KOZHIKODE	Atholi [6615]	CHAYADATHPARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	CHEMMEEN COMPANY	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Atholi [6615]	CHOYIKULAM	81.0	0.0	29.5	51.5	63.6	High
KOZHIKODE	Atholi [6615]	CO OPERATIVE HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	COIR SOCEITY	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Atholi [6615]	DECCAN KOLATHUR	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Atholi [6615]	E4EV - EVCS MODAKKALLUR	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Atholi [6615]	EDKKATTUMKARA	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Atholi [6615]	ELIYOTTAMBALAM	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Atholi [6615]	ERATTORA THAZHA	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Atholi [6615]	GOVINDA NALLOR TEMPLE	81.0	8.0	14.0	59.0	72.8	High
KOZHIKODE	Atholi [6615]	ICE PLANT	81.0	6.0	6.0	69.0	85.2	Very High
KOZHIKODE	Atholi [6615]	IDEA PARAMBATH	81.0	5.0	39.0	37.0	45.7	Medium
KOZHIKODE	Atholi [6615]	KANNIPOYIL SCHOOL	81.0	3.0	48.0	30.0	37.0	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Atholi [6615]	KANNIPPOYIL	81.0	3.0	19.5	58.5	72.2	High
KOZHIKODE	Atholi [6615]	KARIMBAYIL THAZHAM	81.0	5.0	30.0	46.0	56.8	High
KOZHIKODE	Atholi [6615]	KODAKKALLU	129.0	0.0	22.0	107.0	82.9	Very High
KOZHIKODE	Atholi [6615]	KODASSERY	129.0	12.0	14.0	103.0	79.8	Very High
KOZHIKODE	Atholi [6615]	KODASSERY KUNNU	81.0	9.0	3.0	69.0	85.2	Very High
KOZHIKODE	Atholi [6615]	KOLAKKAD	129.0	0.0	6.4	122.6	95.0	Very High
KOZHIKODE	Atholi [6615]	KOLATHUR NORTH	81.0	6.0	28.5	46.5	57.4	High
KOZHIKODE	Atholi [6615]	KOLIYOTTU THAZHAM	81.0	11.0	16.0	54.0	66.7	High
KOZHIKODE	Atholi [6615]	KONGANNUR	81.0	5.0	24.0	52.0	64.2	High
KOZHIKODE	Atholi [6615]	KONGANNUR SCHOOL	81.0	3.0	46.4	31.6	39.0	Medium
KOZHIKODE	Atholi [6615]	KOOMULLY	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Atholi [6615]	KOONANCHERI ROAD	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	KOONANCHERY	81.0	0.0	47.9	33.1	40.9	Medium
KOZHIKODE	Atholi [6615]	KOTHANGAL	81.0	3.0	12.0	66.0	81.5	Very High
KOZHIKODE	Atholi [6615]	KOTHANGAPARAMBU	81.0	3.0	11.0	67.0	82.7	Very High
KOZHIKODE	Atholi [6615]	KOTTAKKUNNU THORAYI	20.0	0.0	0.0	20.0	100.0	Very High
KOZHIKODE	Atholi [6615]	KUNDILRY KSHETHRAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	KUNIYILKADAVU	81.0	0.0	64.0	17.0	21.0	Low
KOZHIKODE	Atholi [6615]	KUNNATH THAZHAM PALLI	81.0	3.0	15.0	63.0	77.8	Very High
KOZHIKODE	Atholi [6615]	KUNNATHARA	81.0	0.0	15.7	65.3	80.6	Very High
KOZHIKODE	Atholi [6615]	KURUPPAMKANDY	81.0	5.0	24.3	51.7	63.8	High
KOZHIKODE	Atholi [6615]	KURUVALOOR TEMPLE	81.0	0.0	23.0	58.0	71.6	High
KOZHIKODE	Atholi [6615]	MALABAR SHOPPING COMPLEX	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Atholi [6615]	MANGALASSERY THAZHAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	MASS ARCADE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Atholi [6615]	MATHILAKAM KSHETHRAM	81.0	3.0	17.0	61.0	75.3	Very High
KOZHIKODE	Atholi [6615]	MIAMI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Atholi [6615]	MODAKKALLUR	81.0	0.0	22.2	58.8	72.5	High
KOZHIKODE	Atholi [6615]	MOORKANAD	81.0	3.0	16.0	62.0	76.5	Very High
KOZHIKODE	Atholi [6615]	NAMBEETIL THAZHAM	81.0	11.0	30.0	40.0	49.4	Medium
KOZHIKODE	Atholi [6615]	NARATH	81.0	0.0	11.4	69.6	85.9	Very High
KOZHIKODE	Atholi [6615]	NARATH PALLY	81.0	3.3	33.9	43.8	54.1	High
KOZHIKODE	Atholi [6615]	NUZHANHILAKUNNU	81.0	3.0	14.0	64.0	79.0	Very High
KOZHIKODE	Atholi [6615]	OCEAN ATHANI	81.0	0.0	48.3	32.7	40.4	Medium
KOZHIKODE	Atholi [6615]	OLLOOR	129.0	11.0	24.1	94.0	72.8	High
KOZHIKODE	Atholi [6615]	OLLUR BAY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	OTTAMBALAM	81.0	3.0	37.3	40.7	50.2	High
KOZHIKODE	Atholi [6615]	OTTAMBALAM CANAL	81.0	8.0	0.0	73.0	90.1	Very High
KOZHIKODE	Atholi [6615]	OTTAMBALAM TOWER	81.0	0.0	46.0	35.0	43.2	Medium
KOZHIKODE	Atholi [6615]	PADANNAKALAM	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Atholi [6615]	PALLIKUNNU	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Atholi [6615]	PALORATHUKAVU	81.0	0.0	4.3	76.7	94.7	Very High
KOZHIKODE	Atholi [6615]	PANANDITHAZHAM	129.0	6.0	27.3	95.7	74.2	High
KOZHIKODE	Atholi [6615]	PARAKKULAM	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Atholi [6615]	PARAMBATH	202.0	0.0	23.0	179.0	88.6	Very High
KOZHIKODE	Atholi [6615]	PAVAYIL CHEERPU	129.0	8.0	15.6	105.4	81.7	Very High
KOZHIKODE	Atholi [6615]	PERALIMALA	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Atholi [6615]	PETROL PUMP ATHOLI	81.0	0.0	39.0	42.0	51.9	High
KOZHIKODE	Atholi [6615]	PONGILODI PARA	81.0	5.0	21.0	55.0	67.9	High
KOZHIKODE	Atholi [6615]	PONNUVAYAL COLONY	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Atholi [6615]	PORAKKOLI POYIL	81.0	3.0	27.4	50.6	62.4	High
KOZHIKODE	Atholi [6615]	POYILINGATHAZHE	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Atholi [6615]	PULIKKOOL KADAVU	81.0	0.0	10.4	70.6	87.1	Very High
KOZHIKODE	Atholi [6615]	PULIKKUPARA	81.0	5.0	3.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Atholi [6615]	PULLILLAMALA	81.0	5.0	17.0	59.0	72.8	High
KOZHIKODE	Atholi [6615]	PUTHALATHU THAZHAM	81.0	5.0	0.0	76.0	93.8	Very High
KOZHIKODE	Atholi [6615]	PUTHAN PEEDIKA	81.0	0.0	40.0	41.0	50.6	High
KOZHIKODE	Atholi [6615]	PUTHANCHERY SCHOOL	81.0	0.0	23.3	57.7	71.2	High
KOZHIKODE	Atholi [6615]	PUTHENCHERY	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Atholi [6615]	PUTHOORVATTOM	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Atholi [6615]	RELIANCE MOORKANADU	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Atholi [6615]	RELIANCE PARAMBATH	81.0	32.0	42.0	7.0	8.6	Very Low
KOZHIKODE	Atholi [6615]	SAHARA KOOMULLY	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Atholi [6615]	SBI ATHOLI	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Atholi [6615]	SNEHANAGAR	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Atholi [6615]	TELE EXCHANGE THALAKKULATHUR	81.0	3.0	14.7	63.3	78.2	Very High
KOZHIKODE	Atholi [6615]	THEERAM	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Atholi [6615]	THORAYI	81.0	15.0	22.0	44.0	54.3	High
KOZHIKODE	Atholi [6615]	THORAYIKADAVE	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Atholi [6615]	THYKANDYMEETHAL	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Atholi [6615]	UDAYANAGAR	81.0	8.0	42.0	31.0	38.3	Medium
KOZHIKODE	Atholi [6615]	VELLILADE MALA	81.0	3.0	20.0	58.0	71.6	High
KOZHIKODE	Atholi [6615]	VELUR	81.0	5.0	11.0	65.0	80.2	Very High
KOZHIKODE	Atholi [6615]	VELUR WEST	81.0	5.0	14.0	62.0	76.5	Very High
KOZHIKODE	Atholi [6615]	VETTUVACHERY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Atholi [6615]	VK ROAD	129.0	10.0	32.2	86.8	67.3	High
KOZHIKODE	Atholi [6615]	VK ROAD WEST-VALLILKADAVU	81.0	3.0	22.4	55.6	68.6	High
KOZHIKODE	Atholi [6615]	VK ROAD-FATHIMA	81.0	5.0	15.0	61.0	75.3	Very High
KOZHIKODE	Ayenchery [6624]	AKKOOL	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	AMMARAPPALLY	81.0	3.0	28.0	50.0	61.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Ayenchery [6624]	ANCHUMURI	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Ayenchery [6624]	ARAPPEEDIKA	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Ayenchery [6624]	AROOR BHAJANA MADAM	81.0	0.0	39.0	42.0	51.9	High
KOZHIKODE	Ayenchery [6624]	AROOR SCHOOL	129.0	0.0	3.0	126.0	97.7	Very High
KOZHIKODE	Ayenchery [6624]	AROOR TELE EXCANGE TR	81.0	0.0	52.0	29.0	35.8	Medium
KOZHIKODE	Ayenchery [6624]	AROOR-II-POSTOFFICE	81.0	3.0	36.3	41.7	51.5	High
KOZHIKODE	Ayenchery [6624]	ASPIRE HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	AYANCHERY PANCHAYATH OFFICE	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Ayenchery [6624]	AYANCHERY SERVICE STATION	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	AYANCHERY THERU	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Ayenchery [6624]	AYANCHERY THERU AMBALAM	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Ayenchery [6624]	AYENCHERY TOWN	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	CHALIKULAM	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Ayenchery [6624]	CHALILKUNI	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Ayenchery [6624]	CHALILPPARA	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Ayenchery [6624]	CHANDAM MUKKU	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Ayenchery [6624]	CHANGANAMKODU KUNNU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	CHANGARATH THAZHE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	CHERAPURAM PALLI	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Ayenchery [6624]	CHERAPURAM TOWN	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Ayenchery [6624]	CHERUVATH NADA	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	CHETTYAM PARAMBA	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Ayenchery [6624]	COCO KEY PEES	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	DAFFODILS	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Ayenchery [6624]	EDAVANATHAZHAM	81.0	0.0	28.9	52.1	64.3	High
KOZHIKODE	Ayenchery [6624]	ELAYADAM	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	ERATH MUKKU	81.0	0.0	18.4	62.6	77.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Ayenchery [6624]	GOLDEN PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	HARITHA VAYAL	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Ayenchery [6624]	JILANY	81.0	0.0	50.8	30.2	37.3	Medium
KOZHIKODE	Ayenchery [6624]	KADAMERY RATION SHOP	81.0	0.0	26.6	54.4	67.1	High
KOZHIKODE	Ayenchery [6624]	KAIRALI	81.0	0.0	28.0	53.0	65.4	High
KOZHIKODE	Ayenchery [6624]	KAKKUNI AROOR ROAD	129.0	0.0	8.0	121.0	93.8	Very High
KOZHIKODE	Ayenchery [6624]	KAKUNI TOWN	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Ayenchery [6624]	KALLUMPURAM SCHOOL	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Ayenchery [6624]	KANAVATH COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	KARAKKUNNU PALLI	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Ayenchery [6624]	KARAYIL CANAL	129.0	0.0	6.0	123.0	95.3	Very High
KOZHIKODE	Ayenchery [6624]	KEERIYANGADI KANAL	81.0	0.0	40.0	41.0	50.6	High
KOZHIKODE	Ayenchery [6624]	KEEZHATTIL MUKKU	81.0	0.0	14.1	66.9	82.5	Very High
KOZHIKODE	Ayenchery [6624]	KELOTHMUKK	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Ayenchery [6624]	KERALA BANK	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	KOMATH AMBALAM	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Ayenchery [6624]	KOROTH MUKKU	81.0	0.0	20.7	60.3	74.4	High
KOZHIKODE	Ayenchery [6624]	KOTTAPPALLY THIRUVALLUR ROAD	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	KOTTAPPALLY TOWN	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Ayenchery [6624]	KOTTAPPARAMALA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	KOYOORA KUNNU	81.0	0.0	32.0	49.0	60.5	High
KOZHIKODE	Ayenchery [6624]	KSEB OFFICE	81.0	0.0	9.3	71.7	88.5	Very High
KOZHIKODE	Ayenchery [6624]	KUTTYADIPOYIL	129.0	0.0	46.3	82.7	64.1	High
KOZHIKODE	Ayenchery [6624]	MAKKAM MUKKU KATAMERI	81.0	0.0	9.4	71.6	88.4	Very High
KOZHIKODE	Ayenchery [6624]	MALAYADA POYIL-II	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Ayenchery [6624]	MALAYADAMPOIL	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Ayenchery [6624]	MALAYIL THAZHE	81.0	0.0	18.0	63.0	77.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Ayenchery [6624]	MANGALAD AQUADATE	81.0	0.0	17.9	63.1	77.9	Very High
KOZHIKODE	Ayenchery [6624]	MANGALAD BORDER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	MANGODE	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Ayenchery [6624]	MANIYOTH	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	MARUNNOLI MUKKU	81.0	0.0	4.0	77.0	95.1	Very High
KOZHIKODE	Ayenchery [6624]	MEADOW VIEW THULATTUM NADA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	MISRIYA COLLEGE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	MOYILOTH AMBALAM	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Ayenchery [6624]	MUKKADATHUM VAYAL	129.0	0.0	14.7	114.3	88.6	Very High
KOZHIKODE	Ayenchery [6624]	MUKKADATHUM VAYAL BHAJANAMADAM	129.0	0.0	16.0	113.0	87.6	Very High
KOZHIKODE	Ayenchery [6624]	MULLAN MUKKU AROOR	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	MURCHILOT	81.0	0.0	17.7	63.3	78.2	Very High
KOZHIKODE	Ayenchery [6624]	MURICHANDY MUKKU	81.0	0.0	30.0	51.0	62.9	High
KOZHIKODE	Ayenchery [6624]	NADEMMAL	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Ayenchery [6624]	NADEMMAL TOWN	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Ayenchery [6624]	NALOM KOROL	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Ayenchery [6624]	NAMBAM VAYAL	81.0	0.0	23.0	58.0	71.6	High
KOZHIKODE	Ayenchery [6624]	NANDOTH	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Ayenchery [6624]	NARANGOLI MUKKU	81.0	0.0	39.0	42.0	51.9	High
KOZHIKODE	Ayenchery [6624]	NARAYANI KUNNU	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	NAYARKANDI	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Ayenchery [6624]	NELLI MUKKU	81.0	3.0	10.0	68.0	84.0	Very High
KOZHIKODE	Ayenchery [6624]	NHALIYIL MUKKU	81.0	0.0	13.6	67.4	83.2	Very High
KOZHIKODE	Ayenchery [6624]	PAINGOTTAYI	202.0	0.0	45.0	157.0	77.7	Very High
KOZHIKODE	Ayenchery [6624]	PALAMTHALAKKAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	PALODIKKUNNU	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Ayenchery [6624]	PANTHAPOYIL	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	PATHALAKKUNNU	81.0	0.0	45.2	35.8	44.2	Medium
KOZHIKODE	Ayenchery [6624]	PERUMUNDASSERY MASJID	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	PERUVACHERY NADA	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Ayenchery [6624]	PERYANGAD KUNN	81.0	3.0	14.1	63.9	78.9	Very High
KOZHIKODE	Ayenchery [6624]	POKLAARATH THAAZHA	81.0	0.0	29.0	52.0	64.2	High
KOZHIKODE	Ayenchery [6624]	POOLAKKOOL VETTERINARY	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	POOLAKUL	129.0	0.0	25.6	103.4	80.2	Very High
KOZHIKODE	Ayenchery [6624]	POOMCHOLA	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Ayenchery [6624]	POOMUKHAM	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Ayenchery [6624]	POTTAN MUKKU	129.0	0.0	20.0	109.0	84.5	Very High
KOZHIKODE	Ayenchery [6624]	PULLIKANDY MUKKU	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Ayenchery [6624]	PUTHIYEDATH THAZE	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Ayenchery [6624]	RAC KADAMERI	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Ayenchery [6624]	RAJEEV NAGAR	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Ayenchery [6624]	RUBIYAN	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	SASIMUKKU	81.0	0.0	31.0	50.0	61.7	High
KOZHIKODE	Ayenchery [6624]	SBT AYANCHERY	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Ayenchery [6624]	SMART CENTER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	THANDOTY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	THAROPOYIL	129.0	0.0	11.6	117.4	91.0	Very High
KOZHIKODE	Ayenchery [6624]	THEEKUNI	129.0	0.0	5.0	124.0	96.1	Very High
KOZHIKODE	Ayenchery [6624]	THEEKUNI MILL	81.0	8.0	26.0	47.0	58.0	High
KOZHIKODE	Ayenchery [6624]	THEKKE THARAMMAL	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Ayenchery [6624]	THIRUMANA-1	81.0	0.0	60.0	21.0	25.9	Medium
KOZHIKODE	Ayenchery [6624]	THIRUMANA-2	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Ayenchery [6624]	THOOWA MALA	81.0	0.0	6.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Ayenchery [6624]	THOOWA MALA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	UDAYA CLUB	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Ayenchery [6624]	VADIYIL KUNNU-THAROPOIL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	VALANHI COLONY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	VALLIAD SCHOOL	81.0	0.0	34.1	46.9	57.8	High
KOZHIKODE	Ayenchery [6624]	VALLIYAD AVIL MILL	81.0	0.0	20.3	60.7	74.9	High
KOZHIKODE	Ayenchery [6624]	VK COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Ayenchery [6624]	VODAPHONE NARIKKATTERY	81.0	0.0	11.2	69.8	86.2	Very High
KOZHIKODE	Ayenchery [6624]	WATER COMPANY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	100 KVA CARRE FRESH	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	3RD GATE	81.0	0.0	39.7	41.3	51.0	High
KOZHIKODE	Azhiyoor [6743]	A K 5	81.0	10.0	62.0	9.0	11.1	Low
KOZHIKODE	Azhiyoor [6743]	A K 9	81.0	8.0	72.0	1.0	1.2	Very Low
KOZHIKODE	Azhiyoor [6743]	AE OFFICE	81.0	5.0	50.0	26.0	32.1	Medium
KOZHIKODE	Azhiyoor [6743]	AIRTEL	81.0	0.0	28.5	52.5	64.8	High
KOZHIKODE	Azhiyoor [6743]	AKG ROAD	81.0	3.0	9.0	69.0	85.2	Very High
KOZHIKODE	Azhiyoor [6743]	AMBADY APPARTMENT	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	ANCHAM PEEDIKA	81.0	0.0	31.2	49.8	61.4	High
KOZHIKODE	Azhiyoor [6743]	ANDI COMPANY	129.0	3.0	33.0	93.0	72.1	High
KOZHIKODE	Azhiyoor [6743]	ASYA ROAD	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Azhiyoor [6743]	ASYA ROAD BEACH	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	ATHANIKKAL	129.0	3.0	29.0	97.0	75.2	Very High
KOZHIKODE	Azhiyoor [6743]	ATHANIKKAL SCHOOL	81.0	0.0	13.1	67.9	83.8	Very High
KOZHIKODE	Azhiyoor [6743]	AVIKKARA	81.0	4.0	17.0	60.0	74.1	High
KOZHIKODE	Azhiyoor [6743]	AZHIYOOR CHUNGAM	202.0	5.0	43.0	154.0	76.2	Very High
KOZHIKODE	Azhiyoor [6743]	AZHIYUR TSUNAMI COLONY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	BEACH JUMA MASJID	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Azhiyoor [6743]	BISMILLAHA ICE PLANT	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	BLOCK BEACH	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Azhiyoor [6743]	BLOCK OFFICE	129.0	0.0	49.9	79.1	61.3	High
KOZHIKODE	Azhiyoor [6743]	BLOCK STADIUM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	BOARD SCHOOL BEACH	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Azhiyoor [6743]	CENTRAL MUKKALI	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Azhiyoor [6743]	CHARANKAYIL	81.0	0.0	6.4	74.6	92.0	Very High
KOZHIKODE	Azhiyoor [6743]	DOBIKULAM	81.0	0.0	22.0	59.0	72.8	High
KOZHIKODE	Azhiyoor [6743]	ELAMANKANDY	81.0	0.0	22.0	59.0	72.8	High
KOZHIKODE	Azhiyoor [6743]	ELEPHANT ROAD	81.0	0.0	16.7	64.3	79.4	Very High
KOZHIKODE	Azhiyoor [6743]	ERIKKAL	81.0	0.0	25.0	56.0	69.1	High
KOZHIKODE	Azhiyoor [6743]	ERIKKAL BEACH	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Azhiyoor [6743]	GULFTECH	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	GURUMADAM	129.0	0.0	43.0	86.0	66.7	High
KOZHIKODE	Azhiyoor [6743]	HAJIYAR PALLY	129.0	5.0	15.0	109.0	84.5	Very High
KOZHIKODE	Azhiyoor [6743]	HARBOUR	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Azhiyoor [6743]	HARBOUR ROAD	81.0	6.0	0.0	75.0	92.6	Very High
KOZHIKODE	Azhiyoor [6743]	INDUSTRIAL ESTATE NO 4	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	INDUSTRIAL ESTATE NO1	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	INDUSTRIAL ESTATE NO2	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	INDUSTRIAL ESTATE NO3	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	JIJITH ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	JP ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	K P R	81.0	0.0	32.3	48.7	60.1	High
KOZHIKODE	Azhiyoor [6743]	KAKKADAVU	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Azhiyoor [6743]	KALLAMALA	129.0	3.0	26.0	100.0	77.5	Very High
KOZHIKODE	Azhiyoor [6743]	KALLAMALA CANAL	81.0	3.0	40.8	37.2	45.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Azhiyoor [6743]	KALLAMALA SRAMBI	81.0	0.0	25.0	56.0	69.1	High
KOZHIKODE	Azhiyoor [6743]	KALLAROTH	81.0	0.0	22.0	59.0	72.8	High
KOZHIKODE	Azhiyoor [6743]	KANDAPPANKUNDU	81.0	0.0	22.8	58.2	71.9	High
KOZHIKODE	Azhiyoor [6743]	KANNOOKKARA TODDY SHOP	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	KANNOTH PALAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Azhiyoor [6743]	KANNUKKARA	81.0	0.0	38.0	43.0	53.1	High
KOZHIKODE	Azhiyoor [6743]	KANNUKKARA TOWN	129.0	5.0	22.0	102.0	79.1	Very High
KOZHIKODE	Azhiyoor [6743]	KARAPPAKKUNNU	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Azhiyoor [6743]	KARAYI	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Azhiyoor [6743]	KARIVAYAL	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Azhiyoor [6743]	KDC BANK	81.0	0.0	49.7	31.3	38.7	Medium
KOZHIKODE	Azhiyoor [6743]	KODAKKAT	81.0	0.0	15.5	65.5	80.8	Very High
KOZHIKODE	Azhiyoor [6743]	KOLARAD	129.0	0.0	38.0	91.0	70.6	High
KOZHIKODE	Azhiyoor [6743]	KOLARAD CANAL	81.0	4.0	35.0	42.0	51.9	High
KOZHIKODE	Azhiyoor [6743]	KOROTH PUMP	81.0	3.0	23.0	55.0	67.9	High
KOZHIKODE	Azhiyoor [6743]	KOROTH TEMPLE	81.0	5.0	8.0	68.0	84.0	Very High
KOZHIKODE	Azhiyoor [6743]	KOTTAMALA KUNNU	81.0	0.0	12.6	68.4	84.4	Very High
KOZHIKODE	Azhiyoor [6743]	KUNHIPALLY THAZHE	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Azhiyoor [6743]	KUNHIPALLY TOWN	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	KURICHIKKARA	81.0	3.0	3.1	74.8	92.4	Very High
KOZHIKODE	Azhiyoor [6743]	M-P-ROAD	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Azhiyoor [6743]	MADAKKARA BEACH	81.0	0.0	3.4	77.6	95.8	Very High
KOZHIKODE	Azhiyoor [6743]	MADAKKARA ROAD	81.0	5.0	26.0	50.0	61.7	High
KOZHIKODE	Azhiyoor [6743]	MAHE GATE	129.0	3.0	27.5	98.5	76.3	Very High
KOZHIKODE	Azhiyoor [6743]	MAHE STATION	129.0	0.0	14.5	114.5	88.7	Very High
KOZHIKODE	Azhiyoor [6743]	MANAMCHALIL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	MANANCHALIL	81.0	0.0	12.4	68.6	84.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Azhiyoor [6743]	MANDOLA	81.0	5.0	13.0	63.0	77.8	Very High
KOZHIKODE	Azhiyoor [6743]	MAVILAKUNNU	81.0	3.0	30.0	48.0	59.3	High
KOZHIKODE	Azhiyoor [6743]	MEETHALE MUKKALI	129.0	0.0	19.0	110.0	85.3	Very High
KOZHIKODE	Azhiyoor [6743]	MIX MAX	81.0	11.0	40.6	29.4	36.3	Medium
KOZHIKODE	Azhiyoor [6743]	MONTHAL	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Azhiyoor [6743]	NADUCHAL	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Azhiyoor [6743]	OLIVE	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Azhiyoor [6743]	PALLI PARAMBU	81.0	0.0	34.0	47.0	58.0	High
KOZHIKODE	Azhiyoor [6743]	PANADAM PALLI	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Azhiyoor [6743]	PODIKKALAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	POOZHITHALA	81.0	5.0	21.0	55.0	67.9	High
KOZHIKODE	Azhiyoor [6743]	POTHIYOTTA JUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	PRANAVAM	81.0	5.0	18.0	58.0	71.6	High
KOZHIKODE	Azhiyoor [6743]	PULIYERI NADA	81.0	13.0	18.3	49.7	61.4	High
KOZHIKODE	Azhiyoor [6743]	RELIANCE	81.0	3.1	11.0	66.9	82.5	Very High
KOZHIKODE	Azhiyoor [6743]	SEA BIRD	129.0	0.0	3.0	126.0	97.7	Very High
KOZHIKODE	Azhiyoor [6743]	SEA BIRD ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	SEETHI PEEDIKA	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Azhiyoor [6743]	SHAMS AUDITORIUM	81.0	3.0	18.0	60.0	74.1	High
KOZHIKODE	Azhiyoor [6743]	SHARBEENA SALEEM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Azhiyoor [6743]	SNEHAPATHA	81.0	8.0	35.0	38.0	46.9	Medium
KOZHIKODE	Azhiyoor [6743]	TELEPHONE EX CHOMBALA	81.0	3.0	18.0	60.0	74.1	High
KOZHIKODE	Azhiyoor [6743]	THATTOLIKKARA SCHOOL	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Azhiyoor [6743]	VANNARATH	81.0	5.0	28.1	47.9	59.1	High
KOZHIKODE	Azhiyoor [6743]	VATTAKANDY RATIONSHOP	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Azhiyoor [6743]	VELLACHAL	81.0	0.0	51.8	29.2	36.0	Medium
KOZHIKODE	Balusseri [6613]	ADIVARAM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Balusser y [6613]	AMARAPURI	81.0	3.4	11.0	66.6	82.2	Very High
KOZHIKODE	Balusser y [6613]	AMBALAM KANDY	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Balusser y [6613]	ANAKUNDUNGAL	129.0	0.0	23.0	106.0	82.2	Very High
KOZHIKODE	Balusser y [6613]	ARAKKAL PANAYI	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Balusser y [6613]	ARAPEEDIKA	81.0	0.0	12.7	68.3	84.3	Very High
KOZHIKODE	Balusser y [6613]	ARAPEEDIKA SAW MILL	129.0	0.0	25.4	103.6	80.3	Very High
KOZHIKODE	Balusser y [6613]	AREEPPURAM MUKKU	129.0	0.0	50.6	78.4	60.8	High
KOZHIKODE	Balusser y [6613]	ARYANKUNNATH	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Balusser y [6613]	ASMAN PLAZA	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	BADUSHA SUPERMARKET	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	BAJANAMADAM	81.0	6.0	0.0	75.0	92.6	Very High
KOZHIKODE	Balusser y [6613]	BALUSSERY BLOCK OFFICE	81.0	3.0	35.6	42.4	52.3	High
KOZHIKODE	Balusser y [6613]	BALUSSERY MUKKU TOWER	81.0	0.0	48.0	33.0	40.7	Medium
KOZHIKODE	Balusser y [6613]	BALUSSERY TOWN	202.0	0.0	3.0	199.0	98.5	Very High
KOZHIKODE	Balusser y [6613]	BSNL	81.0	0.0	4.0	77.0	95.1	Very High
KOZHIKODE	Balusser y [6613]	BUS STAND	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	BUS STAND NORTH	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	CENTURY COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	CHATHAN KULANGARA	81.0	0.0	7.0	74.0	91.4	Very High
KOZHIKODE	Balusser y [6613]	CHENATTU MUKKU	81.0	10.0	39.5	31.5	38.9	Medium
KOZHIKODE	Balusser y [6613]	CHINTHRAMANGALAM	129.0	6.0	17.0	106.0	82.2	Very High
KOZHIKODE	Balusser y [6613]	CHIRAKALKAVU	129.0	3.0	32.0	94.0	72.9	High
KOZHIKODE	Balusser y [6613]	CO-OPERATIVE COLLEGE DTR	81.0	0.0	29.7	51.3	63.4	High
KOZHIKODE	Balusser y [6613]	DARUKALA	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Balusser y [6613]	DIVISION BALUSSERY	129.0	0.0	8.0	121.0	93.8	Very High
KOZHIKODE	Balusser y [6613]	DIVISION TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	E-MART BALUSSERY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Balusser y [6613]	EMPLOYMENT EXCHANGE	81.0	5.0	11.0	65.0	80.2	Very High
KOZHIKODE	Balusser y [6613]	EMS BALUSSERY	129.0	0.0	8.0	121.0	93.8	Very High
KOZHIKODE	Balusser y [6613]	ERAMANGALAM	81.0	8.0	15.0	58.0	71.6	High
KOZHIKODE	Balusser y [6613]	ERAMANGALAM QUARY ROAD	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Balusser y [6613]	ERAMANGALAM TOWER	81.0	3.0	13.0	65.0	80.2	Very High
KOZHIKODE	Balusser y [6613]	EUROPET BOTTLE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	FEDERAL BANK BALUSSERY	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Balusser y [6613]	GANDHI PARK	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	GOKULAM COLLEGE	162.0	0.0	80.0	82.0	50.6	High
KOZHIKODE	Balusser y [6613]	GOVT HOSPITAL	202.0	0.0	27.3	174.7	86.5	Very High
KOZHIKODE	Balusser y [6613]	HIGH SCHOOL TOWER	81.0	16.0	46.5	18.5	22.9	Low
KOZHIKODE	Balusser y [6613]	HIGHSCHOOL BALUSSERY	81.0	3.0	66.0	12.0	14.8	Low
KOZHIKODE	Balusser y [6613]	HNP OILMILL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	IRIS MALL LT	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	JAYA AUDITORIUM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	K K HOSPITAL	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	KACHERYKANDY	129.0	0.0	32.0	97.0	75.2	Very High
KOZHIKODE	Balusser y [6613]	KAIRALI MALL	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	KANHIKKAVU	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Balusser y [6613]	KANNADIPOYIL	81.0	5.0	23.0	53.0	65.4	High
KOZHIKODE	Balusser y [6613]	KAPPIKUNNU-1	81.0	6.0	14.0	61.0	75.3	Very High
KOZHIKODE	Balusser y [6613]	KAPPURAM ROAD	81.0	5.0	5.0	71.0	87.7	Very High
KOZHIKODE	Balusser y [6613]	KARALAPOYIL	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Balusser y [6613]	KARATTU PARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	KARAYATHODI	81.0	0.0	17.9	63.1	77.9	Very High
KOZHIKODE	Balusser y [6613]	KARORA MUKKU	81.0	3.0	12.0	66.0	81.5	Very High
KOZHIKODE	Balusser y [6613]	KATTODE OIL MILL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Balusser y [6613]	KC BUILDING	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	KHADI ROAD	81.0	0.0	23.0	58.0	71.6	High
KOZHIKODE	Balusser y [6613]	KINARULLATHIL	81.0	0.0	18.3	62.7	77.4	Very High
KOZHIKODE	Balusser y [6613]	KIZHAKEY KURUMPOYIL	20.0	0.0	0.0	20.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	KOCHAMVALLY	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Balusser y [6613]	KOKKALLUR	129.0	3.0	49.0	77.0	59.7	High
KOZHIKODE	Balusser y [6613]	KOKKALLUR FUELS	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	KONKODE	81.0	0.0	25.0	56.0	69.1	High
KOZHIKODE	Balusser y [6613]	KOTTANADA	129.0	0.0	23.0	106.0	82.2	Very High
KOZHIKODE	Balusser y [6613]	KOZHIKODE ROAD	81.0	0.0	14.7	66.3	81.9	Very High
KOZHIKODE	Balusser y [6613]	KOZHIKODEN KANDY	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Balusser y [6613]	KRC	81.0	8.0	17.0	56.0	69.1	High
KOZHIKODE	Balusser y [6613]	KSFE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	KTK	129.0	0.0	9.0	120.0	93.0	Very High
KOZHIKODE	Balusser y [6613]	KUNDUCHALIL	81.0	3.0	34.0	44.0	54.3	High
KOZHIKODE	Balusser y [6613]	KUNNAKODI	81.0	0.0	33.0	48.0	59.3	High
KOZHIKODE	Balusser y [6613]	KUNNATHERU	81.0	3.0	29.5	48.5	59.9	High
KOZHIKODE	Balusser y [6613]	KUNNIKOOTTAM	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Balusser y [6613]	KURUMPOYIL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	MANHAPALAM	81.0	3.0	15.7	62.3	76.9	Very High
KOZHIKODE	Balusser y [6613]	MANIKKOTH THAZHE	81.0	0.0	15.8	65.2	80.5	Very High
KOZHIKODE	Balusser y [6613]	MANJAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	MANNAMPOYIL	81.0	3.0	14.0	64.0	79.0	Very High
KOZHIKODE	Balusser y [6613]	MANNATHIKADAVE	129.0	5.0	13.0	111.0	86.0	Very High
KOZHIKODE	Balusser y [6613]	MARAPPALAM	129.0	0.0	16.0	113.0	87.6	Very High
KOZHIKODE	Balusser y [6613]	MATHOTH PARA	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Balusser y [6613]	MATTAKKULAM	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Balusser y [6613]	MEDIMS	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	MOOZH IYOTTU THAZHAM	81.0	0.0	32.0	49.0	60.5	High
KOZHIKODE	Balusser y [6613]	MP JUNCTION	129.0	0.0	27.2	101.8	78.9	Very High
KOZHIKODE	Balusser y [6613]	MUDUVATH	81.0	0.0	17.7	63.3	78.1	Very High
KOZHIKODE	Balusser y [6613]	MUNDAKKARA	81.0	4.0	21.0	56.0	69.1	High
KOZHIKODE	Balusser y [6613]	MUTHAPPAN THODE	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Balusser y [6613]	NANGELIKANDY	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Balusser y [6613]	NANMANDA-14 SAW MILL	129.0	0.0	80.1	48.9	37.9	Medium
KOZHIKODE	Balusser y [6613]	NHC PANANGAD	81.0	0.0	24.5	56.5	69.7	High
KOZHIKODE	Balusser y [6613]	NOORUM KODU	81.0	5.0	29.8	46.2	57.0	High
KOZHIKODE	Balusser y [6613]	PADAMBATH	129.0	0.0	20.0	109.0	84.5	Very High
KOZHIKODE	Balusser y [6613]	PALAMTHALAKKAL	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Balusser y [6613]	PANANGAD NORTH	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Balusser y [6613]	PANANGAD-KETTIL	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Balusser y [6613]	PANAYI	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Balusser y [6613]	PANAYI AALINCHUVADU	81.0	0.0	21.1	59.9	73.9	High
KOZHIKODE	Balusser y [6613]	PANAYI ALINCHUVAD	81.0	0.0	29.0	52.0	64.2	High
KOZHIKODE	Balusser y [6613]	PANAYI TOWER	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Balusser y [6613]	PARAMBIN MUKAL	81.0	0.0	31.9	49.1	60.7	High
KOZHIKODE	Balusser y [6613]	PARAMBIN MUKAL MINI	405.0	0.0	9.0	396.0	97.8	Very High
KOZHIKODE	Balusser y [6613]	PERATHUM POYIL	81.0	0.0	17.8	63.2	78.0	Very High
KOZHIKODE	Balusser y [6613]	PONNARAM THERU	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Balusser y [6613]	POST OFFICE	202.0	0.0	3.0	199.0	98.5	Very High
KOZHIKODE	Balusser y [6613]	PUTHIYAKAVE	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Balusser y [6613]	PUTHOORVATTAM	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Balusser y [6613]	RAROTHMUKKU	81.0	4.0	8.0	69.0	85.2	Very High
KOZHIKODE	Balusser y [6613]	RED SEA MALL	129.0	50.0	50.0	29.0	22.5	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Balusser y [6613]	RITZ AVANUE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	S P TOWER BALUSSERY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	SAMANWAYA	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Balusser y [6613]	SANDHYA CINE HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	SANTHWANAM	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Balusser y [6613]	SBI REGENCY ARAPEEDIKA	81.0	0.0	45.9	35.1	43.4	Medium
KOZHIKODE	Balusser y [6613]	SHOPPING COMPLEX VAIKUNDAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	SITHARA COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	SMART KOKKALLUR	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Balusser y [6613]	SNEHAPURAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Balusser y [6613]	ST MARRYS TRANSFORMER	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Balusser y [6613]	STADIUM ROAD	81.0	0.0	15.4	65.6	81.0	Very High
KOZHIKODE	Balusser y [6613]	TATA TOWER BLSY	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Balusser y [6613]	THAKKOTHTHAZHAM	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Balusser y [6613]	THATHANBATH	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Balusser y [6613]	THATTANTE PURAYIL	81.0	3.0	13.0	65.0	80.2	Very High
KOZHIKODE	Balusser y [6613]	THAYYIL PEEDIKA	81.0	5.0	12.0	64.0	79.0	Very High
KOZHIKODE	Balusser y [6613]	THIRUVANCHERI POYIL	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Balusser y [6613]	THORAD	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	UDAYAM COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	VAIKUNDAM	202.0	0.0	21.0	181.0	89.6	Very High
KOZHIKODE	Balusser y [6613]	VATTOLI TATA TOWER	81.0	0.0	13.6	67.4	83.3	Very High
KOZHIKODE	Balusser y [6613]	VATTOLY	255.0	5.0	65.0	185.0	72.5	High
KOZHIKODE	Balusser y [6613]	VAYALADA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	VAYALADA RESORT	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Balusser y [6613]	VAZHORAMALA	81.0	0.0	17.7	63.3	78.1	Very High
KOZHIKODE	Balusser y [6613]	VELLACHALIL TOWER	81.0	0.0	23.0	58.0	71.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Balusseri [6613]	WE ONE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	AKG	81.0	8.0	42.6	30.4	37.5	Medium
KOZHIKODE	Beach Kozhikkode [6603]	AL HIND SEA FORT-INDOOR	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	ALSA PALM SPRINGS-INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	ANGANWADI	81.0	3.0	60.9	17.1	21.1	Low
KOZHIKODE	Beach Kozhikkode [6603]	BAY WATER-INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	BEACH VENDING MARKET	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	BICHU SAW MILLS	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	BIG BAZAR	202.0	0.0	9.7	192.3	95.2	Very High
KOZHIKODE	Beach Kozhikkode [6603]	CALICUT GIRLS	202.0	0.0	128.4	73.6	36.4	Medium
KOZHIKODE	Beach Kozhikkode [6603]	CASINO	81.0	0.0	50.0	31.0	38.3	Medium
KOZHIKODE	Beach Kozhikkode [6603]	CENTRAL MARKET	405.0	0.0	9.9	395.1	97.6	Very High
KOZHIKODE	Beach Kozhikkode [6603]	CHEMMANGAD	405.0	8.0	168.2	228.8	56.5	High
KOZHIKODE	Beach Kozhikkode [6603]	CHURCH R C ROAD	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Beach Kozhikkode [6603]	CITADEL	129.0	0.0	23.0	106.0	82.2	Very High
KOZHIKODE	Beach Kozhikkode [6603]	CONVENT ROAD	202.0	10.0	88.5	103.5	51.2	High
KOZHIKODE	Beach Kozhikkode [6603]	CORPORATION OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	COSMOPOLITAN CLUB	81.0	0.0	47.0	34.0	42.0	Medium
KOZHIKODE	Beach Kozhikkode [6603]	COURT COMPLEX	81.0	0.0	30.0	51.0	63.0	High
KOZHIKODE	Beach Kozhikkode [6603]	COURT ROAD	255.0	0.0	10.0	245.0	96.1	Very High
KOZHIKODE	Beach Kozhikkode [6603]	COXSWAIN COMMERCIAL-INDOOR	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	COXSWAIN DOMESTIC-INDOOR	510.0	0.0	0.0	510.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	CRESENT MERVUE-INDOOR	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	CTO	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Beach Kozhikkode [6603]	DOHA COMPLEX-INDOOR	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	ELLIZIUM COURT-INDOOR	510.0	0.0	0.0	510.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	ENNAPPADAM	81.0	0.0	84.7	0.0	0.0	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Beach Kozhikkode [6603]	FALCON TOWER-INDOOR	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	FERRARI APPARTMENTS	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	FRANCIS ROAD	129.0	0.0	128.7	0.3	0.2	Very Low
KOZHIKODE	Beach Kozhikkode [6603]	G D SOMAYYA PALM BEACH-INDOOR	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	GALAXY-CORNISH CASTLE-INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	GRAND	405.0	5.0	89.2	310.8	76.8	Very High
KOZHIKODE	Beach Kozhikkode [6603]	GRAND PLAZA	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	GUJARATHI STREET	202.0	0.0	39.0	163.0	80.7	Very High
KOZHIKODE	Beach Kozhikkode [6603]	HALWA BAZAR	255.0	0.0	54.0	201.0	78.8	Very High
KOZHIKODE	Beach Kozhikkode [6603]	HEALTH CENTRE	81.0	0.0	23.1	57.9	71.4	High
KOZHIKODE	Beach Kozhikkode [6603]	IBRAHIM PALAM	202.0	0.0	105.5	96.5	47.8	Medium
KOZHIKODE	Beach Kozhikkode [6603]	IDIYANGARA	202.0	5.0	196.1	0.9	0.5	Very Low
KOZHIKODE	Beach Kozhikkode [6603]	INDO ARCADE-INDOOR	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	K P FOUSI	81.0	0.0	40.0	41.0	50.6	High
KOZHIKODE	Beach Kozhikkode [6603]	KANNANPARAMBA	202.0	3.0	22.2	176.8	87.5	Very High
KOZHIKODE	Beach Kozhikkode [6603]	KOTHI BRIDGE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	KUNDUNGAL MOSQUE	202.0	5.0	42.1	154.9	76.7	Very High
KOZHIKODE	Beach Kozhikkode [6603]	KURIAL LANE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	KUTHUKALLU	405.0	0.0	119.1	285.9	70.6	High
KOZHIKODE	Beach Kozhikkode [6603]	KUTTICHIRA	202.0	0.0	51.9	150.1	74.3	High
KOZHIKODE	Beach Kozhikkode [6603]	LEE TAJ	81.0	0.0	22.0	59.0	72.8	High
KOZHIKODE	Beach Kozhikkode [6603]	LORRY STAND	405.0	0.0	5.0	400.0	98.8	Very High
KOZHIKODE	Beach Kozhikkode [6603]	LUKUMAN-INDOOR	129.0	0.0	15.0	114.0	88.4	Very High
KOZHIKODE	Beach Kozhikkode [6603]	M SONS ARCADE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	M TECH	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	MADEENA	202.0	0.0	8.0	194.0	96.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Beach Kozhikkode [6603]	MANANCHIRA TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	MANANTHALA	255.0	11.0	155.0	89.0	34.9	Medium
KOZHIKODE	Beach Kozhikkode [6603]	MARIYAM GROVE-INDOOR	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	MATHRUBHUMI	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	MISKAL PALLI	81.0	5.0	75.4	0.6	0.7	Very Low
KOZHIKODE	Beach Kozhikkode [6603]	MK ROAD	405.0	3.0	133.8	268.2	66.2	High
KOZHIKODE	Beach Kozhikkode [6603]	MK-1 MUGADAR BEACH	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	MM PRESS	405.0	0.0	53.2	351.8	86.9	Very High
KOZHIKODE	Beach Kozhikkode [6603]	MOONALINGAL	255.0	0.0	31.3	223.7	87.7	Very High
KOZHIKODE	Beach Kozhikkode [6603]	NAGARAM	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	NAINAM VALAPPU	202.0	0.0	16.0	186.0	92.1	Very High
KOZHIKODE	Beach Kozhikkode [6603]	NEDUNGADI	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	NORTH PIER	405.0	15.0	9.0	381.0	94.1	Very High
KOZHIKODE	Beach Kozhikkode [6603]	OCEANIC-INDOOR	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	OFFICE	202.0	0.0	3.0	199.0	98.5	Very High
KOZHIKODE	Beach Kozhikkode [6603]	OYSTER BAY-INDOOR	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	P K COMPLEX-INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	PALLIKANDY	202.0	6.0	50.2	145.8	72.2	High
KOZHIKODE	Beach Kozhikkode [6603]	PANKAJ APPARTMENT	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	PARAPPIL	405.0	10.0	129.9	265.1	65.5	High
KOZHIKODE	Beach Kozhikkode [6603]	PULINCHODE	405.0	0.0	64.9	340.1	84.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	PUZHAVAKKU	405.0	0.0	9.0	396.0	97.8	Very High
KOZHIKODE	Beach Kozhikkode [6603]	RAYMONDS	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	SAKEENA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	SEAGULL APARTMENT-INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	SHEHARSHAD MALL-INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	SI WEST COVE-INDOOR	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Beach Kozhikkode [6603]	SLOUDHA SAW MILLS	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	SOUTH BEACH	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Beach Kozhikkode [6603]	SOUTH PIER	202.0	0.0	8.0	194.0	96.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	STATUE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	TAJ	129.0	0.0	32.2	96.8	75.1	Very High
KOZHIKODE	Beach Kozhikkode [6603]	THANGALS ROAD	405.0	0.0	81.2	323.8	79.9	Very High
KOZHIKODE	Beach Kozhikkode [6603]	THRIKKOVIL TEMPLE	81.0	5.0	16.3	59.7	73.7	High
KOZHIKODE	Beach Kozhikkode [6603]	TOWN BANK	81.0	0.0	49.0	32.0	39.5	Medium
KOZHIKODE	Beach Kozhikkode [6603]	TULIP ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beach Kozhikkode [6603]	UMMER HAJI	129.0	0.0	11.0	118.0	91.5	Very High
KOZHIKODE	Beach Kozhikkode [6603]	VATTAMPOYIL	129.0	0.0	51.6	77.4	60.0	High
KOZHIKODE	Beach Kozhikkode [6603]	WEST KALLAI	255.0	10.0	93.8	151.2	59.3	High
KOZHIKODE	Beypur [6635]	A R K ICE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beypur [6635]	AMAMKUNI	81.0	11.0	5.0	65.0	80.2	Very High
KOZHIKODE	Beypur [6635]	AMECO	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	ANJOOM	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beypur [6635]	ARAKKINAR 4 CENT COLONY	81.0	3.0	3.0	75.0	92.6	Very High
KOZHIKODE	Beypur [6635]	ARAKKINAR EAST	129.0	0.0	64.3	64.7	50.2	High
KOZHIKODE	Beypur [6635]	ARAKKINAR TOWN	255.0	3.0	43.0	209.0	82.0	Very High
KOZHIKODE	Beypur [6635]	ARAKKINAR WEST	129.0	10.0	63.8	55.2	42.8	Medium
KOZHIKODE	Beypur [6635]	ASWATHI ICE	202.0	0.0	38.0	164.0	81.2	Very High
KOZHIKODE	Beypur [6635]	B C ROAD	202.0	3.0	55.3	143.7	71.1	High
KOZHIKODE	Beypur [6635]	B C ROAD WEST	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Beypur [6635]	B S F	255.0	4.0	10.0	241.0	94.5	Very High
KOZHIKODE	Beypur [6635]	BEACH COLD ICE	129.0	0.0	5.0	124.0	96.1	Very High
KOZHIKODE	Beypur [6635]	BEYPORE PORT	202.0	0.0	8.0	194.0	96.0	Very High
KOZHIKODE	Beypur [6635]	BEYPORE SOUTH	81.0	3.0	48.9	29.1	36.0	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Beypur [6635]	BEYPORE TOWN	202.0	0.0	76.0	126.0	62.4	High
KOZHIKODE	Beypur [6635]	BHAJANAMADAM	129.0	3.0	36.0	90.0	69.8	High
KOZHIKODE	Beypur [6635]	CANAL	129.0	13.0	34.0	82.0	63.6	High
KOZHIKODE	Beypur [6635]	CHAKKERIKADE	81.0	6.0	21.0	54.0	66.7	High
KOZHIKODE	Beypur [6635]	CHAPPA	202.0	5.0	8.0	189.0	93.6	Very High
KOZHIKODE	Beypur [6635]	CHEERPALAMFRK	81.0	0.0	31.0	50.0	61.7	High
KOZHIKODE	Beypur [6635]	CHENOTH WEST	81.0	8.0	50.0	23.0	28.4	Medium
KOZHIKODE	Beypur [6635]	CHINDHA ARAKKINAR	81.0	0.0	40.0	41.0	50.6	High
KOZHIKODE	Beypur [6635]	CHULLIYAM VALAPPU	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Beypur [6635]	COIR NORTH	81.0	3.0	19.0	59.0	72.8	High
KOZHIKODE	Beypur [6635]	CRYSTAL ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	DAIRY SOUTH	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Beypur [6635]	DHENDANKAVE	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Beypur [6635]	DIAMOND ICE PLANT	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	EDATHODY	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Beypur [6635]	ERATTACHRA	81.0	6.0	11.0	64.0	79.0	Very High
KOZHIKODE	Beypur [6635]	FARVEENA ICE PLANT	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	FIVE STAR AQUA	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Beypur [6635]	FOREST WEST	81.0	5.0	26.3	49.7	61.4	High
KOZHIKODE	Beypur [6635]	GANGA THAMBIROAD	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	GOKULAM ICE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beypur [6635]	GOLDEN ICE	129.0	9.0	81.2	38.8	30.1	Medium
KOZHIKODE	Beypur [6635]	GOTHEESHWARAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	GOVINDAVILASAM	255.0	10.0	90.4	154.6	60.6	High
KOZHIKODE	Beypur [6635]	GOVINDAVILASAM EAST	129.0	12.6	37.0	79.5	61.6	High
KOZHIKODE	Beypur [6635]	GOVINDAVILASAM WEST	129.0	5.0	35.0	89.0	69.0	High
KOZHIKODE	Beypur [6635]	GURU KRIPA ICE	129.0	0.0	13.3	115.7	89.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Beypur [6635]	GURUKKAL KAVU	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Beypur [6635]	HARBOUR ICE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beypur [6635]	HARBOUR JETTY	202.0	3.0	5.0	194.0	96.0	Very High
KOZHIKODE	Beypur [6635]	HAWA ALUMINIUM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	HIGH SCHOOL NORTH	81.0	2.5	20.0	58.5	72.2	High
KOZHIKODE	Beypur [6635]	HISTORIC HOMES	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	INDUSTRIAL ESTATE	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Beypur [6635]	J M RUBBER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	JOY RUBBER	202.0	0.0	100.7	101.3	50.1	High
KOZHIKODE	Beypur [6635]	KADAMBARI	81.0	0.0	30.6	50.4	62.3	High
KOZHIKODE	Beypur [6635]	KAIRALI EXTRACTION	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	KALKUNATH TEMBLE	81.0	3.0	6.0	72.0	88.9	Very High
KOZHIKODE	Beypur [6635]	KALLUNGAL	81.0	0.0	29.0	52.0	64.2	High
KOZHIKODE	Beypur [6635]	KARIMBADAM	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Beypur [6635]	KARUMAKANKAVU	81.0	3.0	17.3	60.7	74.9	High
KOZHIKODE	Beypur [6635]	KAYYADITHODE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beypur [6635]	KERALA RUBBER	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Beypur [6635]	KINGDOM	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Beypur [6635]	KUTHUKALLU	129.0	3.0	62.8	63.2	49.0	Medium
KOZHIKODE	Beypur [6635]	LOVELY CORNER	129.0	0.0	18.0	111.0	86.0	Very High
KOZHIKODE	Beypur [6635]	MAHADEVA CHEMICALS	202.0	16.6	87.7	97.7	48.4	Medium
KOZHIKODE	Beypur [6635]	MANALODY VAYAL	81.0	3.0	8.0	70.0	86.4	Very High
KOZHIKODE	Beypur [6635]	MARAD BEACH	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Beypur [6635]	MARAD POLICE STATION	129.0	0.0	3.3	125.7	97.4	Very High
KOZHIKODE	Beypur [6635]	MARUTHI STOP	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	MATHOTTAM	202.0	0.0	71.8	130.2	64.4	High
KOZHIKODE	Beypur [6635]	MATHOTTAM SCHOOL	255.0	14.2	78.3	162.5	63.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Beypur [6635]	MAVINCHUVADU	81.0	2.0	20.3	58.7	72.5	High
KOZHIKODE	Beypur [6635]	MILMA TRANSFORMER	202.0	0.0	10.0	192.0	95.0	Very High
KOZHIKODE	Beypur [6635]	MOMS RUBBER	129.0	18.0	14.0	97.0	75.2	Very High
KOZHIKODE	Beypur [6635]	MUBHARAC ICE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beypur [6635]	MUNDAKAMPADAM	81.0	3.0	8.0	70.0	86.4	Very High
KOZHIKODE	Beypur [6635]	MUTHUNILAM VAYAL	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Beypur [6635]	NADUVATTAM EAST	81.0	8.0	17.0	56.0	69.1	High
KOZHIKODE	Beypur [6635]	NADUVATTAM MADRASSA	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Beypur [6635]	NADUVATTAM VAYANASALA	129.0	4.0	84.2	40.8	31.6	Medium
KOZHIKODE	Beypur [6635]	NECHULI KAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	NEKSHATHRA ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	NSS HOSTEL	81.0	3.0	52.0	26.0	32.1	Medium
KOZHIKODE	Beypur [6635]	ONB CHENOTH	129.0	0.0	36.9	92.1	71.4	High
KOZHIKODE	Beypur [6635]	OTTATHENGU	81.0	0.0	65.8	15.2	18.8	Low
KOZHIKODE	Beypur [6635]	PANIKKAMADAM	129.0	0.0	40.0	89.0	69.0	High
KOZHIKODE	Beypur [6635]	PARAPPURAM	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Beypur [6635]	PEECHANARY	129.0	4.2	65.3	59.4	46.0	Medium
KOZHIKODE	Beypur [6635]	PERACHANGADY	81.0	5.0	59.7	16.3	20.1	Low
KOZHIKODE	Beypur [6635]	PINNANATH	202.0	15.0	51.3	135.7	67.2	High
KOZHIKODE	Beypur [6635]	PONGILOTTU VAYAL	129.0	0.0	26.0	103.0	79.8	Very High
KOZHIKODE	Beypur [6635]	PONNATH TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	POONARVALAPPU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	POONATTIL LINE	129.0	5.0	49.0	75.0	58.1	High
KOZHIKODE	Beypur [6635]	PREMIER ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	PUNCHAPADAM	129.0	18.0	32.3	78.7	61.0	High
KOZHIKODE	Beypur [6635]	PUTHUKKUDI	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Beypur [6635]	PUZHAKKAL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Beypur [6635]	R M HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	RAILWAY LINE	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Beypur [6635]	RATION SHOPE	81.0	5.0	30.0	46.0	56.8	High
KOZHIKODE	Beypur [6635]	REVATHY ICE	129.0	0.0	3.7	125.3	97.1	Very High
KOZHIKODE	Beypur [6635]	RM EAST	129.0	5.0	71.2	52.8	41.0	Medium
KOZHIKODE	Beypur [6635]	ROYAL RUBBER	129.0	6.0	42.0	81.0	62.8	High
KOZHIKODE	Beypur [6635]	SAFA ICE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beypur [6635]	SAGARA SARANI	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Beypur [6635]	SAJ BATTERY	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Beypur [6635]	SASTHA WOODS	81.0	3.0	5.0	73.0	90.1	Very High
KOZHIKODE	Beypur [6635]	SBI BEYPORE TOWN	129.0	5.0	15.0	109.0	84.5	Very High
KOZHIKODE	Beypur [6635]	SERINA	202.0	0.0	21.0	181.0	89.6	Very High
KOZHIKODE	Beypur [6635]	SIVAPURY ROAD	129.0	0.0	47.6	81.4	63.1	High
KOZHIKODE	Beypur [6635]	SULAJA	129.0	0.0	27.0	102.0	79.1	Very High
KOZHIKODE	Beypur [6635]	SUNI ICE	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Beypur [6635]	SUPPORT SHOE	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Beypur [6635]	SWARALAYAM	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Beypur [6635]	THAMBI ROAD	129.0	8.0	16.7	104.3	80.8	Very High
KOZHIKODE	Beypur [6635]	THAMBURAN ROAD	129.0	3.0	63.9	62.1	48.2	Medium
KOZHIKODE	Beypur [6635]	THARUVILA PADAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	THAVALAKKULAM	129.0	3.0	47.7	78.3	60.7	High
KOZHIKODE	Beypur [6635]	THONICHIRA	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Beypur [6635]	TSUNAMI COLONY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Beypur [6635]	VIJITH	202.0	0.0	33.8	168.2	83.3	Very High
KOZHIKODE	Beypur [6635]	VYKAM MUHAMMED BASHEER	202.0	11.0	55.8	135.2	66.9	High
KOZHIKODE	Beypur [6635]	WATER TANK	255.0	10.0	34.0	211.0	82.7	Very High
KOZHIKODE	Beypur [6635]	WEST MAHE	81.0	4.0	49.0	28.0	34.6	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Central Kozhikode [6602]	AARPEES ARCADE	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ADDRESS MALL	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	AIDEED COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ALHIND GRAND	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	AMBEDKAR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	APCO TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ARAYIDATHUPALAM	255.0	0.0	5.0	250.0	98.0	Very High
KOZHIKODE	Central Kozhikode [6602]	AROOZA PLAZA	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ASHOKA HOSPITAL	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ASMA	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ASWINI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ATLAS	81.0	0.0	14.2	66.8	82.5	Very High
KOZHIKODE	Central Kozhikode [6602]	AYMISH ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	B E M	255.0	0.0	74.8	180.2	70.7	High
KOZHIKODE	Central Kozhikode [6602]	B M T	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	BIRLA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	BUS STAND EAST	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	BUSSTAND WEST	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CALICUT NURSING HOME	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CENTRAL ARCADE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CENTRAL LIBRARY	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CENTURY TOWER	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CHAITHANYA	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CHANDRIKA	405.0	0.0	61.0	344.0	84.9	Very High
KOZHIKODE	Central Kozhikode [6602]	CHEST LT	405.0	0.0	30.0	375.0	92.6	Very High
KOZHIKODE	Central Kozhikode [6602]	CHINTHAVALAP FLAT	405.0	0.0	30.8	374.2	92.4	Very High
KOZHIKODE	Central Kozhikode [6602]	CHINTHAVALAP POLICE QUARTERS	162.0	0.0	0.0	162.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Central Kozhikode [6602]	CITIZEN TOURIST HOME	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CITRA TOWER	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CITY AVENUE THALI	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CITY GALLERY	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CITY MALL	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CITY PLAZA	129.0	0.0	14.4	114.6	88.8	Very High
KOZHIKODE	Central Kozhikode [6602]	CITY TOWER-2	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CITY TOWER-I	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CITYMALL-2	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CLASSIC	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CLIFF DALE APPARTMET	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	COPPER VISTA	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CORNATION CENEMA	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CRESENT VATHIAD	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	CROWN	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	DARUSSALAM	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	DAVISON	405.0	0.0	39.3	365.7	90.3	Very High
KOZHIKODE	Central Kozhikode [6602]	DEIRA BAZAR	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	DUMMY-MN AVENUE	20.0	0.0	0.0	20.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	EEPEES ARCADE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	EMERALD MALL	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	EMIRATES TOWER PVT	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ERROTH CENTRE	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ESSAY TOWER	129.0	0.0	48.5	80.5	62.4	High
KOZHIKODE	Central Kozhikode [6602]	FAIRMOUNT TOWER	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	FLOOD LIGHT	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	FOCUS MALL LT	405.0	0.0	0.0	405.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Central Kozhikode [6602]	FOCUS MALL LT 2	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	FOURA COMPLEX	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	GALLERIA TRADE CENTRE	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	GANGA	129.0	0.0	5.0	124.0	96.1	Very High
KOZHIKODE	Central Kozhikode [6602]	GOLDEN PLAZA	405.0	0.0	17.9	387.1	95.6	Very High
KOZHIKODE	Central Kozhikode [6602]	GOLDEN TOWER	81.0	0.0	30.0	51.0	63.0	High
KOZHIKODE	Central Kozhikode [6602]	GOVT HOSPITAL	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	GRAND AVENUE PUTHIYARA	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	GRAND BAZAR	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	HANTEX	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	HAPPY TOWER	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	HIGHFIELDAPPARTMENTS	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	HOLIDAY CITY CENTRE	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	HOMELANDAVANUE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	HOTEL HIVE INN	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	HOUSE CON SOC	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	HYSON	255.0	0.0	5.0	250.0	98.0	Very High
KOZHIKODE	Central Kozhikode [6602]	IMPERIAL	202.0	0.0	8.8	193.2	95.6	Very High
KOZHIKODE	Central Kozhikode [6602]	INDOOR STADIUM	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	JAIL ROAD	129.0	0.0	65.1	63.9	49.5	Medium
KOZHIKODE	Central Kozhikode [6602]	JAYANTHI BUILDING	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	K S R T C	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	KAIRALI	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	KALPAKA	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	KAMALAM	202.0	0.0	46.0	156.1	77.3	Very High
KOZHIKODE	Central Kozhikode [6602]	KAMMATH LANE	202.0	0.0	9.0	193.0	95.5	Very High
KOZHIKODE	Central Kozhikode [6602]	KANCHAS	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Central Kozhikode [6602]	KANDAMKULAM	255.0	0.0	42.0	213.0	83.5	Very High
KOZHIKODE	Central Kozhikode [6602]	KASHKANT CHAMBER	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	KAVITHA APPARTMENT	202.0	0.0	36.0	166.0	82.2	Very High
KOZHIKODE	Central Kozhikode [6602]	KDC BANK	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	KEVI COMPLEX	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	KEY STONE	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	KOYENCO BAZAR	510.0	0.0	0.0	510.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	KUREETHADAM ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	KVRTOWERPRIVATE	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	LADDER LT-INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	LAND WORLD	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	LANDMARK CENTRIO-LT	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	LANDSHIP MALL	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	M A BAZAR	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MAKKOLATH LANE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MALABAR GATE LT	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MALABAR-INN	405.0	8.0	86.0	311.0	76.8	Very High
KOZHIKODE	Central Kozhikode [6602]	MANIYATTUKUDI AFSA-IB PLAZA	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MANUEL SONS	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MARAKAZ	405.0	0.0	50.0	355.0	87.7	Very High
KOZHIKODE	Central Kozhikode [6602]	MARIKKAR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MARINA MALL	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MARIYA	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MARSHIQ COMPLEX	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MATTUMMEL	405.0	0.0	16.0	389.0	96.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MEA COMPLEX	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	METRO TOWER	255.0	0.0	0.0	255.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Central Kozhikode [6602]	MMO BUILDING	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MOON TOUCH TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MORA COMPLEX	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MPS TOWER	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MULLATH	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	MUTHALAKULAM	202.0	0.0	42.0	160.0	79.2	Very High
KOZHIKODE	Central Kozhikode [6602]	NAGARAM	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	NEW BAZAR	405.0	0.0	6.0	399.0	98.5	Very High
KOZHIKODE	Central Kozhikode [6602]	NIAS RASAK	162.0	66.0	0.0	96.0	59.3	High
KOZHIKODE	Central Kozhikode [6602]	NOBLE	510.0	0.0	0.0	510.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	NOOR COMPLEX	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	NORKA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	OVER BRIDGE-OY	129.0	0.0	25.0	104.0	80.6	Very High
KOZHIKODE	Central Kozhikode [6602]	PARAMOUNT TOWER	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PARCO COMPLEX	202.0	0.0	27.0	175.0	86.6	Very High
KOZHIKODE	Central Kozhikode [6602]	PARCO MANSION	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PARCO TOWER TAJ ROAD	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PARK	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PARSI-I	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PARSI-II	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PERACHUNNI TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PUTHIYARA HEIGHTS-INDOOR	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PVS 50 CROSS ROADS	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PVS APPARTMENTS MADHAVI	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PVS NAKSHATRA	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	PWD COMPLEX RAPDRP	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	R P MALL	324.0	0.0	0.0	324.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Central Kozhikode [6602]	RC ROAD	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	REGENCY EAST	255.0	9.8	5.0	240.2	94.2	Very High
KOZHIKODE	Central Kozhikode [6602]	REGENCY WEST	255.0	0.0	114.2	140.8	55.2	High
KOZHIKODE	Central Kozhikode [6602]	RENAISSANCE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ROTANA	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	ROYAL PALACE	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	S K S S F	129.0	0.0	18.0	111.0	86.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SABHA CENTRE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SAHAKARANA	255.0	3.0	78.0	174.0	68.3	High
KOZHIKODE	Central Kozhikode [6602]	SANGEETH COTTON	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SARADHA	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SATHRAM	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SBI FLAT	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SHARARA	202.0	0.0	25.0	177.0	87.6	Very High
KOZHIKODE	Central Kozhikode [6602]	SILVER PLAZA	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SIMLA BUILDING	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SKY TOWER	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SKYLINE GRAND TERRACE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SM ARCADE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SMASANAM	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SOBHA TOWER	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SPAN LT- TT COMPLEX INDOOR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SPORTS COUNCIL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	STADIUM SOUTH	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	SUB WAY	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	TAAS PRIME BUILDING	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	TAJ ROAD	202.0	0.0	30.0	172.0	85.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Central Kozhikode [6602]	TALI-2 MANKAVE	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Central Kozhikode [6602]	TECHNO TOP	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	THARIFF ARCADE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	THAVOT BUILDING LT MULTIPLE	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	TOWN HALL	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	TP BUILDING	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	TT MANSION - PARAG MALL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	UNITED COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	URBAN BANK	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	V H ROAD	129.0	0.0	46.0	83.0	64.3	High
KOZHIKODE	Central Kozhikode [6602]	VAZAN EYE CARE	202.0	0.0	40.0	162.0	80.2	Very High
KOZHIKODE	Central Kozhikode [6602]	VELLARIYIL GARDEN	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	VH HOROIZON	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	VIKAS	405.0	0.0	50.0	355.0	87.7	Very High
KOZHIKODE	Central Kozhikode [6602]	VNM	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	VYAPARA BHAVAN	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	WOODWORKSHOP	121.0	0.0	0.0	121.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	Y M C A	405.0	0.0	15.0	390.0	96.3	Very High
KOZHIKODE	Central Kozhikode [6602]	YAMUNA ARCADE	405.0	0.0	0.0	405.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	YARA	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Central Kozhikode [6602]	YMCA CULTURAL	255.0	0.0	0.0	255.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	21 PALAM	81.0	0.0	6.3	74.7	92.2	Very High
KOZHIKODE	Chakkittapara [6716]	4TH BLOCK	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chakkittapara [6716]	AMBEDKAR MUKKU	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Chakkittapara [6716]	ANNAKOTTANCHAL	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Chakkittapara [6716]	APPATTAMEETHAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	ARAKKAPPARAMBIL	81.0	0.0	21.7	59.3	73.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Chakkittapara [6716]	ARS FARM	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	ARS KOOTHALI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	ASARIKANDI	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Chakkittapara [6716]	BANK CHAKKITTAPARA	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	CHAKIRI COMPANY	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Chakkittapara [6716]	CHAKKITTAPARA CHAKIRIKKAMBAN I	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	CHAKKITTAPARA PANCHAYATH	81.0	5.0	20.3	55.7	68.8	High
KOZHIKODE	Chakkittapara [6716]	CHAKKITTAPARA TOWN	129.0	0.0	24.4	104.7	81.1	Very High
KOZHIKODE	Chakkittapara [6716]	CHAKKITTAPARA-IDEA	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Chakkittapara [6716]	CHATHAN KANDY MUKKU	81.0	3.0	21.0	57.0	70.4	High
KOZHIKODE	Chakkittapara [6716]	CHEMBANODA	129.0	0.0	9.0	120.0	93.0	Very High
KOZHIKODE	Chakkittapara [6716]	CHEMBRA	129.0	3.0	32.3	93.7	72.6	High
KOZHIKODE	Chakkittapara [6716]	CHENGOTTAKOLLY	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chakkittapara [6716]	CHERUKUNNU	81.0	0.0	32.0	49.0	60.5	High
KOZHIKODE	Chakkittapara [6716]	CHERUVALLI MUKKU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	CSI CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	CURRY POWDER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	DEIVATHUMTHARA	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chakkittapara [6716]	EANGORACHAL	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Chakkittapara [6716]	FILTERING PLANT	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	FLORAZA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	HIBA HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	I I S R	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	IHDP CHARTHIPPARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	IRRIGATION	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	JOYE EMBRAYIL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Chakkittapara [6716]	K V K	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	KALLANKANDITHAZHE	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Chakkittapara [6716]	KALLINGAL	81.0	0.0	17.8	63.2	78.0	Very High
KOZHIKODE	Chakkittapara [6716]	KATTIKULAM	81.0	0.0	6.5	74.5	92.0	Very High
KOZHIKODE	Chakkittapara [6716]	KAYANOTH	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Chakkittapara [6716]	KELOTHUVAYAL	129.0	4.0	9.0	116.0	89.9	Very High
KOZHIKODE	Chakkittapara [6716]	KODERICAL	129.0	0.0	34.0	95.0	73.6	High
KOZHIKODE	Chakkittapara [6716]	KOKKADE	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chakkittapara [6716]	KOKKUNNU	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Chakkittapara [6716]	KOLATHOOR ESTATE	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chakkittapara [6716]	KODEMKOLLY	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Chakkittapara [6716]	KOOVAPOYIL	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Chakkittapara [6716]	KORATHIPPARA	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Chakkittapara [6716]	KOTHIYAPARA	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Chakkittapara [6716]	KUNNASSERY	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Chakkittapara [6716]	KUTTIPPILAYI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	LAKSHAM VEEDU CHAKKITAPARA	81.0	5.0	26.0	50.0	61.7	High
KOZHIKODE	Chakkittapara [6716]	LAST PANTHIRI	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Chakkittapara [6716]	MADDRASSA	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Chakkittapara [6716]	MANIKULUKKI	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Chakkittapara [6716]	MARUMANNU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	MEDAPPALLIL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	MOOZHI VATTAKKAYAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	MOOZHI-IDEA	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Chakkittapara [6716]	MUDIYANCHAL	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Chakkittapara [6716]	MUKKALLIL	81.0	0.0	28.0	53.0	65.4	High
KOZHIKODE	Chakkittapara [6716]	MUKKAVALA	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Chakkittapara [6716]	NARIMANJA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	NARINADA	81.0	0.0	13.3	67.7	83.6	Very High
KOZHIKODE	Chakkittapara [6716]	NARINADA ANGADI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	NARINADA TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	OTTAKANDAM	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Chakkittapara [6716]	PALLIKKUNNU	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Chakkittapara [6716]	PANNIKKOTTOOR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	PANTHIRI TOWN	129.0	0.0	22.8	106.2	82.3	Very High
KOZHIKODE	Chakkittapara [6716]	PANTHIRI VODAFONE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	PARAMBAL	81.0	0.0	12.6	68.4	84.5	Very High
KOZHIKODE	Chakkittapara [6716]	PERAMBRA ESTATE	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	PILLAPPERUVANNA	81.0	0.0	18.3	62.7	77.4	Very High
KOZHIKODE	Chakkittapara [6716]	POOZHITHODE	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Chakkittapara [6716]	SEETHAPPARA	81.0	0.0	9.6	71.4	88.1	Very High
KOZHIKODE	Chakkittapara [6716]	SHEP PERUVANNAMOOZHI	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	SOOPPIKKADA	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Chakkittapara [6716]	TELEPHONE EXCHANGE CKP	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	THAMARAMUKKU	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Chakkittapara [6716]	THANDORAPPARA	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Chakkittapara [6716]	THANIYODE	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Chakkittapara [6716]	THARIPPILODE	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Chakkittapara [6716]	THAZHE ANGADI	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Chakkittapara [6716]	VALAYAMKANDAM	81.0	0.0	18.2	62.8	77.5	Very High
KOZHIKODE	Chakkittapara [6716]	VALIYAPARAMBA	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chakkittapara [6716]	VELLACHAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chakkittapara [6716]	VENGAPPATTA	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Chakkittapara [6716]	VENGERI	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Chakkittapara [6716]	VILAYATTUKANDY MUKKU	81.0	0.0	9.3	71.7	88.5	Very High
KOZHIKODE	Chakkittapara [6716]	VILAYATTUKANDY MUKKU PALLI	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chelannur [6744]	ADUVARAKKAL	129.0	3.0	41.3	84.7	65.7	High
KOZHIKODE	Chelannur [6744]	ADUVARAKKAL MASJID	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Chelannur [6744]	AISWARYA	81.0	0.0	22.0	59.0	72.8	High
KOZHIKODE	Chelannur [6744]	AKKR	81.0	5.0	19.0	57.0	70.4	High
KOZHIKODE	Chelannur [6744]	AMBALAPPAD	129.0	5.0	24.6	99.4	77.1	Very High
KOZHIKODE	Chelannur [6744]	AMBALATHUKULANGARA	81.0	6.0	36.8	38.2	47.2	Medium
KOZHIKODE	Chelannur [6744]	AMBAYAPPURATH	81.0	0.0	6.4	74.6	92.1	Very High
KOZHIKODE	Chelannur [6744]	ANKATHAYI	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Chelannur [6744]	ANNASSERY	81.0	9.0	30.0	42.0	51.9	High
KOZHIKODE	Chelannur [6744]	ANNASSERY KULAM	129.0	3.0	18.8	107.2	83.1	Very High
KOZHIKODE	Chelannur [6744]	ANNASSERY PALAM	81.0	0.0	19.3	61.7	76.2	Very High
KOZHIKODE	Chelannur [6744]	ANNASSERY SCHOOL	202.0	5.0	46.7	150.3	74.4	High
KOZHIKODE	Chelannur [6744]	ANNASSERY TOWN	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Chelannur [6744]	ASWATHI	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Chelannur [6744]	ATHIYATTIL	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Chelannur [6744]	AYYAPPANKANDY	81.0	8.0	11.0	62.0	76.5	Very High
KOZHIKODE	Chelannur [6744]	CHAKKIATH	81.0	0.0	3.3	77.7	96.0	Very High
KOZHIKODE	Chelannur [6744]	CHAMAKALA	81.0	3.0	14.0	64.0	79.0	Very High
KOZHIKODE	Chelannur [6744]	CHELANNUR 7-6	202.0	3.0	71.2	127.8	63.3	High
KOZHIKODE	Chelannur [6744]	CHELANNUR 8-2	81.0	0.0	36.7	44.3	54.7	High
KOZHIKODE	Chelannur [6744]	CHENGOTTUTHAZHAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chelannur [6744]	CHIRAKKUZHI	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chelannur [6744]	CHITADIMUKKU	81.0	7.0	33.1	40.9	50.5	High
KOZHIKODE	Chelannur [6744]	EDAKKARA	81.0	8.0	18.6	54.4	67.2	High
KOZHIKODE	Chelannur [6744]	EDAKKARA HEALTH CENTRE	81.0	0.0	34.0	47.0	58.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Chelannur [6744]	EDAKKARA SCHOOL	81.0	0.0	24.3	56.7	70.0	High
KOZHIKODE	Chelannur [6744]	EDAKKARA SYPHON	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Chelannur [6744]	ELIYOTUMALA	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Chelannur [6744]	ERANHODI MUKKU	81.0	6.0	9.0	66.0	81.5	Very High
KOZHIKODE	Chelannur [6744]	FATHIMA	81.0	5.0	56.2	19.8	24.5	Low
KOZHIKODE	Chelannur [6744]	HOMEO	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Chelannur [6744]	ICHANNUR	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Chelannur [6744]	IDUKKAPPARA	129.0	0.0	33.3	95.7	74.2	High
KOZHIKODE	Chelannur [6744]	IOC AMBALATHUKULANGARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chelannur [6744]	JANAPRIYA ROAD	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Chelannur [6744]	JANATHA THAZHAM	81.0	5.0	36.0	40.0	49.4	Medium
KOZHIKODE	Chelannur [6744]	KAKKUR MALA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chelannur [6744]	KALLITTA PALAM	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Chelannur [6744]	KANDANNUR	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Chelannur [6744]	KANOTH MEETHAL	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Chelannur [6744]	KATTILERI	81.0	0.0	6.4	74.6	92.0	Very High
KOZHIKODE	Chelannur [6744]	KAVU	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Chelannur [6744]	KORAYI	81.0	3.0	9.0	69.0	85.2	Very High
KOZHIKODE	Chelannur [6744]	KOROTHUPOYIL	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Chelannur [6744]	KRISHIBHVAN	81.0	5.0	15.0	61.0	75.3	Very High
KOZHIKODE	Chelannur [6744]	KUMARASWAMY	129.0	3.0	33.3	92.7	71.9	High
KOZHIKODE	Chelannur [6744]	KUNIYATTUMMAL	81.0	0.0	22.3	58.7	72.5	High
KOZHIKODE	Chelannur [6744]	KUTTIYIL	81.0	5.0	25.3	50.7	62.6	High
KOZHIKODE	Chelannur [6744]	KUTTOTH	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Chelannur [6744]	MAKKADATH	81.0	6.0	20.0	55.0	67.9	High
KOZHIKODE	Chelannur [6744]	MAMMILITHAZHAM	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Chelannur [6744]	MANNAKKAL THAZHAM	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Chelannur [6744]	MANNANKANDY THAZHAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chelannur [6744]	MARUTHAD	81.0	0.0	56.9	24.1	29.8	Medium
KOZHIKODE	Chelannur [6744]	MARUTHI	81.0	0.0	55.5	25.5	31.5	Medium
KOZHIKODE	Chelannur [6744]	MR FREEZE ZONE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Chelannur [6744]	MUNDAKKATIL	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Chelannur [6744]	MUTHUVATTU THAZHAM	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Chelannur [6744]	NELLIATH THAZHAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chelannur [6744]	NJHARAKKATT	81.0	3.0	11.0	67.0	82.7	Very High
KOZHIKODE	Chelannur [6744]	NOONJODI THAZHAM	81.0	6.0	32.6	42.4	52.3	High
KOZHIKODE	Chelannur [6744]	OLOPARA-I	81.0	5.0	18.9	57.0	70.4	High
KOZHIKODE	Chelannur [6744]	OLOPARA-II	81.0	6.0	27.0	48.0	59.3	High
KOZHIKODE	Chelannur [6744]	OOTUKULAM	81.0	0.0	7.5	73.5	90.8	Very High
KOZHIKODE	Chelannur [6744]	PALATH-I	405.0	4.0	28.5	372.5	92.0	Very High
KOZHIKODE	Chelannur [6744]	PALATH-II	129.0	0.0	25.3	103.7	80.4	Very High
KOZHIKODE	Chelannur [6744]	PALLIPPOYIL	81.0	8.0	72.7	0.3	0.3	Very Low
KOZHIKODE	Chelannur [6744]	PALLIPPOYIL CANAL	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Chelannur [6744]	PANAMA	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Chelannur [6744]	PARAPPARA	81.0	0.0	7.0	74.0	91.4	Very High
KOZHIKODE	Chelannur [6744]	PARAPPARA JUNCTION	81.0	0.0	20.6	60.4	74.6	High
KOZHIKODE	Chelannur [6744]	PATTAR PALAM	81.0	3.0	25.2	52.8	65.2	High
KOZHIKODE	Chelannur [6744]	PAYYADATHAZHAM	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Chelannur [6744]	PERUMPOYIL	81.0	0.0	64.4	16.6	20.5	Low
KOZHIKODE	Chelannur [6744]	POKKALI	81.0	3.0	34.0	44.0	54.3	High
KOZHIKODE	Chelannur [6744]	POOCHOLI PALAM	81.0	10.0	12.0	59.0	72.8	High
KOZHIKODE	Chelannur [6744]	POOKKOTTUMALA	81.0	0.0	42.4	38.6	47.6	Medium
KOZHIKODE	Chelannur [6744]	POZHIKKAVU	81.0	10.0	15.0	56.0	69.1	High
KOZHIKODE	Chelannur [6744]	PULI BAZAR	81.0	3.0	6.3	71.7	88.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Chelannur [6744]	PUTHALATH THAZHAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chelannur [6744]	PUTHIYEDATH THAZHAM	202.0	0.0	21.0	181.0	89.6	Very High
KOZHIKODE	Chelannur [6744]	RELIANCE	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chelannur [6744]	SAFA	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Chelannur [6744]	SAMADARSHINI GROUND	81.0	0.0	22.1	58.9	72.7	High
KOZHIKODE	Chelannur [6744]	SN MANDIRAM	81.0	8.0	39.0	34.0	42.0	Medium
KOZHIKODE	Chelannur [6744]	SNG	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Chelannur [6744]	THEKEDATH THAZHAM	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Chelannur [6744]	THERUVATH THAZHAM	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Chelannur [6744]	THIYYAKANDY THAZHZM	81.0	4.0	7.0	70.0	86.4	Very High
KOZHIKODE	Chelannur [6744]	UNIPARAMBATH THAZHAM	81.0	0.0	23.2	57.8	71.4	High
KOZHIKODE	Chelannur [6744]	VALAPPILTHAZHAM	81.0	3.0	27.0	51.0	63.0	High
KOZHIKODE	Chelannur [6744]	VALAYANNURKAVU	81.0	0.0	7.7	73.3	90.6	Very High
KOZHIKODE	Chelannur [6744]	VALLIKKATTUKAVU	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Chelannur [6744]	VYLORA	81.0	13.0	31.3	36.7	45.3	Medium
KOZHIKODE	Edacherri [6627]	ACHAMKANDY	81.0	15.0	47.5	18.5	22.8	Low
KOZHIKODE	Edacherri [6627]	ALFA KAKKAMVALLY	81.0	8.0	5.0	68.0	84.0	Very High
KOZHIKODE	Edacherri [6627]	ALLESSERY	81.0	0.0	22.3	58.7	72.5	High
KOZHIKODE	Edacherri [6627]	ALLYSSERY ROAD	81.0	5.0	25.0	51.0	63.0	High
KOZHIKODE	Edacherri [6627]	AMAYIMUKKU	81.0	4.0	59.3	17.7	21.8	Low
KOZHIKODE	Edacherri [6627]	ANERT	81.0	0.0	58.1	22.9	28.3	Medium
KOZHIKODE	Edacherri [6627]	AREEKKARA	81.0	4.0	25.0	52.0	64.2	High
KOZHIKODE	Edacherri [6627]	CHALAPPURAM	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Edacherri [6627]	CHUNDAYIL	129.0	0.0	29.9	99.1	76.8	Very High
KOZHIKODE	Edacherri [6627]	DAMODHARANPEEDIKA	81.0	5.0	6.0	70.0	86.4	Very High
KOZHIKODE	Edacherri [6627]	EDACHERI I	202.0	3.0	37.7	161.3	79.8	Very High
KOZHIKODE	Edacherri [6627]	EDACHERY PANCHAYATH	129.0	0.0	59.6	69.4	53.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Edacherri [6627]	GOEC CHARGING STATION	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Edacherri [6627]	GULF ROAD	81.0	0.0	69.4	11.6	14.3	Low
KOZHIKODE	Edacherri [6627]	JWALA VAYANASALA	81.0	5.0	15.0	61.0	75.3	Very High
KOZHIKODE	Edacherri [6627]	KACHERY BALAVADI	81.0	0.0	12.3	68.7	84.8	Very High
KOZHIKODE	Edacherri [6627]	KAKKANNUR TEMPLE	81.0	0.0	37.9	43.1	53.2	High
KOZHIKODE	Edacherri [6627]	KALATHIL	81.0	0.0	40.0	41.0	50.6	High
KOZHIKODE	Edacherri [6627]	KALLIKOODATHIL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Edacherri [6627]	KANAVATH	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Edacherri [6627]	KANOTHMUKKU	81.0	0.0	45.5	35.5	43.9	Medium
KOZHIKODE	Edacherri [6627]	KARAMA	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Edacherri [6627]	KAYAPPANACHI	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Edacherri [6627]	KOMMINI PALLY	81.0	5.0	41.0	35.0	43.2	Medium
KOZHIKODE	Edacherri [6627]	KOTTAYAMBRAM	81.0	3.0	23.0	55.0	67.9	High
KOZHIKODE	Edacherri [6627]	KUNHALLUR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Edacherri [6627]	KUNHEKKAN PEEDIKA	81.0	5.0	22.7	53.3	65.8	High
KOZHIKODE	Edacherri [6627]	KUNINGAD CHIRAYIL	129.0	0.0	30.4	98.6	76.4	Very High
KOZHIKODE	Edacherri [6627]	KUTTIYIL MUKKU	81.0	0.0	25.2	55.8	68.9	High
KOZHIKODE	Edacherri [6627]	MADATHIL	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Edacherri [6627]	MALUMUKKU	81.0	3.0	31.3	46.7	57.7	High
KOZHIKODE	Edacherri [6627]	MAVALLYMUKKU	81.0	0.0	47.0	34.0	42.0	Medium
KOZHIKODE	Edacherri [6627]	MEESAMUKKU	81.0	0.0	35.2	45.8	56.5	High
KOZHIKODE	Edacherri [6627]	MUTHUVADATHUR UP SCHOOL	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Edacherri [6627]	NHEROTH PEEDIKA	81.0	5.0	0.0	76.0	93.8	Very High
KOZHIKODE	Edacherri [6627]	NOC MUKKU	81.0	0.0	41.0	40.0	49.4	Medium
KOZHIKODE	Edacherri [6627]	PADIKKALAKKANDYMUKKU	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Edacherri [6627]	PANOLANDI MUKKU	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Edacherri [6627]	PAROTHAPEEDIKA	81.0	3.0	6.3	71.7	88.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Edacherri [6627]	PILACHERI	81.0	0.0	29.0	52.0	64.2	High
KOZHIKODE	Edacherri [6627]	PILAKANDY MUKKU	81.0	0.0	30.0	51.0	63.0	High
KOZHIKODE	Edacherri [6627]	PILAVILTHAZHA	81.0	0.0	17.8	63.2	78.0	Very High
KOZHIKODE	Edacherri [6627]	POLICE STATION	81.0	0.0	23.0	58.0	71.6	High
KOZHIKODE	Edacherri [6627]	POYIL PEEDIKA	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Edacherri [6627]	PURAMERI PHED	129.0	0.0	9.0	120.0	93.0	Very High
KOZHIKODE	Edacherri [6627]	PURAMERI POSTOFFICE	129.0	11.0	35.0	83.0	64.3	High
KOZHIKODE	Edacherri [6627]	PURAMERI SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Edacherri [6627]	PURAMERI TOWN	129.0	0.0	36.0	93.0	72.1	High
KOZHIKODE	Edacherri [6627]	RELIANCE	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Edacherri [6627]	THALAYI MASJID	129.0	0.0	43.0	86.0	66.7	High
KOZHIKODE	Edacherri [6627]	THALAYI PALAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Edacherri [6627]	THALAYI PHED	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Edacherri [6627]	THANAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Edacherri [6627]	THAYYIL	129.0	0.0	5.0	124.0	96.1	Very High
KOZHIKODE	Edacherri [6627]	THEKEYIL MUKKU	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Edacherri [6627]	THURUTHY	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Edacherri [6627]	VENGOLI	81.0	0.0	35.0	46.0	56.8	High
KOZHIKODE	Edacherri [6627]	VILATHAPURAM	129.0	0.0	23.8	105.2	81.5	Very High
KOZHIKODE	Edacherri [6627]	VVLP SCHOOL	81.0	3.0	37.2	40.8	50.4	High
KOZHIKODE	Eranhikkal [6606]	A M MOTORS	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	AMBALAPADI	202.0	0.0	5.0	197.0	97.5	Very High
KOZHIKODE	Eranhikkal [6606]	ANDI ROAD	405.0	10.0	65.7	329.3	81.3	Very High
KOZHIKODE	Eranhikkal [6606]	ARC PUTHIYAPPA	129.0	3.0	16.0	110.0	85.3	Very High
KOZHIKODE	Eranhikkal [6606]	ASHER TECH	81.0	0.0	61.0	20.0	24.7	Low
KOZHIKODE	Eranhikkal [6606]	AUDDY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	AYYAPPAN KAVU	202.0	0.0	105.2	96.8	47.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Eranhikkal [6606]	AZHEEKKAL BEACH	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	BHAVANS	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	BSNL ELATHUR	81.0	0.0	71.9	9.1	11.2	Low
KOZHIKODE	Eranhikkal [6606]	BUS BAY PAVANGAD	129.0	5.0	89.7	34.3	26.6	Medium
KOZHIKODE	Eranhikkal [6606]	CANAL ROAD-PD 7	129.0	9.0	16.0	104.0	80.6	Very High
KOZHIKODE	Eranhikkal [6606]	CANAL WEST	81.0	0.0	42.9	38.1	47.0	Medium
KOZHIKODE	Eranhikkal [6606]	CHALI ROAD	81.0	10.0	29.5	41.5	51.2	High
KOZHIKODE	Eranhikkal [6606]	CHEENADATH	81.0	0.0	18.5	62.5	77.2	Very High
KOZHIKODE	Eranhikkal [6606]	CHENGOTTUMALA COLONY	81.0	3.0	12.8	65.2	80.5	Very High
KOZHIKODE	Eranhikkal [6606]	CHETTIKULAM 1	129.0	11.0	99.1	18.9	14.6	Low
KOZHIKODE	Eranhikkal [6606]	CHETTIKULAM 2	129.0	0.0	38.4	90.6	70.2	High
KOZHIKODE	Eranhikkal [6606]	CHETTIKULAM EAST	81.0	16.0	38.7	26.3	32.5	Medium
KOZHIKODE	Eranhikkal [6606]	CHETTIKULAM WEST	81.0	3.0	62.0	16.0	19.8	Low
KOZHIKODE	Eranhikkal [6606]	CHITTADIKADAVU	81.0	6.0	47.2	27.8	34.3	Medium
KOZHIKODE	Eranhikkal [6606]	COSTAL ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	ELATHUR BAZAR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	ELATHUR BEACH	129.0	0.0	8.0	121.0	93.8	Very High
KOZHIKODE	Eranhikkal [6606]	ERAM MOTORS	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	ERANHICKAL	202.0	0.0	24.5	177.5	87.9	Very High
KOZHIKODE	Eranhikkal [6606]	ERUMOLI	129.0	18.0	35.5	75.5	58.5	High
KOZHIKODE	Eranhikkal [6606]	FATHIMA ICE	202.0	0.0	34.0	168.0	83.1	Very High
KOZHIKODE	Eranhikkal [6606]	FISHER MAN	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	GRAINS PALORA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	HARBOUR GUEST HOUSE	129.0	5.0	35.2	88.8	68.8	High
KOZHIKODE	Eranhikkal [6606]	HIMALAYA ICE	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Eranhikkal [6606]	INDUSTRIAL ESTATE	81.0	0.0	15.2	65.8	81.2	Very High
KOZHIKODE	Eranhikkal [6606]	JAYBHARATH	129.0	5.0	61.2	62.8	48.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Eranhikkal [6606]	JETTY ROAD NO 1	129.0	4.0	20.0	105.0	81.4	Very High
KOZHIKODE	Eranhikkal [6606]	JETTY ROAD NO 2	81.0	0.0	25.8	55.2	68.2	High
KOZHIKODE	Eranhikkal [6606]	K S R T C KANDAMKULAM	129.0	0.0	3.0	126.0	97.7	Very High
KOZHIKODE	Eranhikkal [6606]	KACHERI	255.0	5.0	126.0	124.0	48.6	Medium
KOZHIKODE	Eranhikkal [6606]	KAIPURATH PALAM	129.0	3.0	39.0	87.0	67.4	High
KOZHIKODE	Eranhikkal [6606]	KAKKATTU TEMPLE	129.0	6.0	51.7	71.3	55.3	High
KOZHIKODE	Eranhikkal [6606]	KAMPURATH KAVU NEW	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	KANDAKULGARA	81.0	0.0	34.0	47.0	58.0	High
KOZHIKODE	Eranhikkal [6606]	KARAMVELLY	81.0	55.0	3.0	23.0	28.4	Medium
KOZHIKODE	Eranhikkal [6606]	KERA FED	129.0	0.0	8.0	121.0	93.8	Very High
KOZHIKODE	Eranhikkal [6606]	KONNARIMOOLA	129.0	18.0	88.6	22.4	17.4	Low
KOZHIKODE	Eranhikkal [6606]	KORAMBYIL BEACH	129.0	0.0	12.5	116.5	90.3	Very High
KOZHIKODE	Eranhikkal [6606]	KORAPUZHA	129.0	0.0	8.0	121.0	93.8	Very High
KOZHIKODE	Eranhikkal [6606]	KOYAKKANARI	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Eranhikkal [6606]	KVK ICE PLANT	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	M H COLONY	129.0	6.0	58.1	64.8	50.3	High
KOZHIKODE	Eranhikkal [6606]	MAKKANCHERY	81.0	20.0	26.9	34.0	42.0	Medium
KOZHIKODE	Eranhikkal [6606]	MANASA	129.0	0.0	3.0	126.0	97.7	Very High
KOZHIKODE	Eranhikkal [6606]	MEDAYILTHAZHAM	81.0	5.0	26.0	50.0	61.7	High
KOZHIKODE	Eranhikkal [6606]	MEHABOOB	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	METHALAYIL	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Eranhikkal [6606]	MOKAVOOR	129.0	0.0	39.4	89.6	69.4	High
KOZHIKODE	Eranhikkal [6606]	MOOLIYAR NADA	129.0	0.0	52.2	76.8	59.5	High
KOZHIKODE	Eranhikkal [6606]	MOORKHANAD	81.0	3.0	43.0	35.0	43.2	Medium
KOZHIKODE	Eranhikkal [6606]	MUKKAM KADAVU -11	129.0	3.0	17.0	109.0	84.5	Very High
KOZHIKODE	Eranhikkal [6606]	MUKKAMKADAVE	81.0	20.0	53.3	7.7	9.5	Very Low
KOZHIKODE	Eranhikkal [6606]	NADUTHURUTHI	81.0	7.0	3.0	71.0	87.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Eranhikkal [6606]	NATIONAL COLLEGE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	NAVACHETHANA	81.0	3.0	3.0	75.0	92.6	Very High
KOZHIKODE	Eranhikkal [6606]	NH BY PASS KACHERY	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Eranhikkal [6606]	PALAKKADA	129.0	3.4	52.7	72.9	56.5	High
KOZHIKODE	Eranhikkal [6606]	PALAKKADA ROAD -KE 34	81.0	0.0	18.3	62.7	77.4	Very High
KOZHIKODE	Eranhikkal [6606]	PALORA	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Eranhikkal [6606]	PARAMMAL	202.0	4.0	82.5	115.5	57.2	High
KOZHIKODE	Eranhikkal [6606]	PAVANGAD	255.0	21.0	45.7	188.3	73.8	High
KOZHIKODE	Eranhikkal [6606]	PERUMTHURUTHI 1	81.0	6.0	13.5	61.5	76.0	Very High
KOZHIKODE	Eranhikkal [6606]	PERUMTHURUTHI 2	81.0	9.0	21.0	51.0	62.9	High
KOZHIKODE	Eranhikkal [6606]	PETROLIUM BEACH	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Eranhikkal [6606]	POOLADIKUNNU	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Eranhikkal [6606]	PURAKKATIRI	81.0	6.0	34.0	41.0	50.6	High
KOZHIKODE	Eranhikkal [6606]	PURAKKATTIRI PALAM	81.0	13.0	57.0	11.0	13.6	Low
KOZHIKODE	Eranhikkal [6606]	PURAKKATTIRI TOWN	255.0	8.0	133.3	113.7	44.6	Medium
KOZHIKODE	Eranhikkal [6606]	PUTHIYANIRATH	129.0	0.0	47.0	82.0	63.6	High
KOZHIKODE	Eranhikkal [6606]	PUTHIYAPPA HARBOUR SOUTH	81.0	3.0	28.0	50.0	61.7	High
KOZHIKODE	Eranhikkal [6606]	PUTHIYAPPA TEMPLE	129.0	0.0	21.0	108.0	83.7	Very High
KOZHIKODE	Eranhikkal [6606]	PUTHIYOTTIL KADAVE	129.0	5.0	3.5	120.5	93.4	Very High
KOZHIKODE	Eranhikkal [6606]	PUTHUKAT KADAV	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Eranhikkal [6606]	PUTHUR	202.0	0.0	78.2	123.8	61.3	High
KOZHIKODE	Eranhikkal [6606]	PUZHAVAKKU	129.0	3.0	49.0	77.0	59.7	High
KOZHIKODE	Eranhikkal [6606]	PVS CHERUKULAM	81.0	20.0	33.4	27.6	34.0	Medium
KOZHIKODE	Eranhikkal [6606]	RABLAS KACHERI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	RAIL OVERBRIDGE	129.0	0.0	42.6	86.4	66.9	High
KOZHIKODE	Eranhikkal [6606]	RAILTEL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	RAJEEV	202.0	0.0	30.0	172.0	85.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Eranhikkal [6606]	RATNAMMA	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Eranhikkal [6606]	REENA	255.0	3.0	51.0	201.0	78.8	Very High
KOZHIKODE	Eranhikkal [6606]	SAMAJAM TRANSFORMER	81.0	11.0	15.0	55.0	67.9	High
KOZHIKODE	Eranhikkal [6606]	SB KOVIL 1	129.0	5.0	46.4	77.7	60.2	High
KOZHIKODE	Eranhikkal [6606]	SB KOVIL 2	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Eranhikkal [6606]	SBI PUTHUR	81.0	5.0	73.3	2.7	3.4	Very Low
KOZHIKODE	Eranhikkal [6606]	SETHU SEETHARAM SCHOOL	202.0	10.0	39.0	153.0	75.7	Very High
KOZHIKODE	Eranhikkal [6606]	SINCERE ICE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	SIRAJ	81.0	0.0	19.9	61.1	75.4	Very High
KOZHIKODE	Eranhikkal [6606]	SKYLINE BLUE VISTA	648.0	0.0	60.0	588.0	90.7	Very High
KOZHIKODE	Eranhikkal [6606]	SOOPIKUNI	81.0	3.0	9.0	69.0	85.2	Very High
KOZHIKODE	Eranhikkal [6606]	SUBSTATION	255.0	5.0	58.0	192.0	75.3	Very High
KOZHIKODE	Eranhikkal [6606]	SUGANTHAMANI PARA	81.0	5.0	45.0	31.0	38.2	Medium
KOZHIKODE	Eranhikkal [6606]	SUPERSTONE	510.0	0.0	0.0	510.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	TELEPHONE EXCHANGE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	TERIMERIC APPARTMENT PRIVATE	162.0	0.0	0.0	162.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	THADANGATTUVAYAL	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Eranhikkal [6606]	TV CENTER MOKAVOOR	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Eranhikkal [6606]	UNITED DISTILARY	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Eranhikkal [6606]	VALIYATHIRUTHI	81.0	5.0	18.9	57.1	70.5	High
KOZHIKODE	Eranhikkal [6606]	VENGALI	202.0	0.0	28.3	173.7	86.0	Very High
KOZHIKODE	Feroke [6631]	ALUMINIUM COMPANY	129.0	6.0	74.8	48.2	37.4	Medium
KOZHIKODE	Feroke [6631]	AMBALANGADI	81.0	3.0	22.0	56.0	69.2	High
KOZHIKODE	Feroke [6631]	AMPLE SHOES	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Feroke [6631]	ANAND SAWMILL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	APPLE TOWER	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Feroke [6631]	ARIYEKKAL	129.0	8.0	25.9	95.1	73.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Feroke [6631]	AVF AVENUE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	BALAKRISHNA FURNITURE	81.0	0.0	44.4	36.6	45.2	Medium
KOZHIKODE	Feroke [6631]	BINDU	202.0	0.0	19.0	183.0	90.6	Very High
KOZHIKODE	Feroke [6631]	BMO-ITI	81.0	18.0	38.0	25.0	30.9	Medium
KOZHIKODE	Feroke [6631]	CENTURY BOARD	405.0	5.0	69.1	330.9	81.7	Very High
KOZHIKODE	Feroke [6631]	CH TOWER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	CHANDA	202.0	5.0	67.0	130.0	64.4	High
KOZHIKODE	Feroke [6631]	CHANDAKADAVU	202.0	0.0	28.0	174.0	86.1	Very High
KOZHIKODE	Feroke [6631]	CHERUVANNUR SUPPLYCO	81.0	12.5	68.0	0.5	0.6	Very Low
KOZHIKODE	Feroke [6631]	CHUNGAM	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Feroke [6631]	CIBI EQUIPMENTS	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	COFFE	405.0	0.0	39.8	365.2	90.2	Very High
KOZHIKODE	Feroke [6631]	COLOUR	129.0	0.0	31.7	97.3	75.4	Very High
KOZHIKODE	Feroke [6631]	COMMUNITY HALL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	CONTINENTAL	255.0	0.0	38.0	217.0	85.1	Very High
KOZHIKODE	Feroke [6631]	CONVENT RAPDRP	81.0	8.0	20.9	52.1	64.3	High
KOZHIKODE	Feroke [6631]	DEEPA	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Feroke [6631]	ELAYADATHUKUNNU	81.0	3.0	6.0	72.0	88.9	Very High
KOZHIKODE	Feroke [6631]	ESCOTEL	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Feroke [6631]	ESI QUARTERS	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Feroke [6631]	EXCEL	202.0	0.0	104.0	98.0	48.5	Medium
KOZHIKODE	Feroke [6631]	FAROOK HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	FATHIMA TOWER	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Feroke [6631]	FEROKE BRICKS	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	FEROKE COMMERCIAL COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Feroke [6631]	FEROKE TOWN	405.0	0.0	30.8	374.2	92.4	Very High
KOZHIKODE	Feroke [6631]	FLEET ROYS	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Feroke [6631]	GAFOOR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Feroke [6631]	GGHS FEROKE	81.0	0.0	35.0	46.0	56.8	High
KOZHIKODE	Feroke [6631]	HARIJAN BRICK	129.0	0.0	31.0	98.0	76.0	Very High
KOZHIKODE	Feroke [6631]	HIGH WAY GARDEN	202.0	0.0	40.0	162.0	80.2	Very High
KOZHIKODE	Feroke [6631]	HINDHUSTHAN	202.0	35.0	26.8	140.2	69.4	High
KOZHIKODE	Feroke [6631]	HINDUSTNROAD	81.0	40.0	17.0	24.0	29.6	Medium
KOZHIKODE	Feroke [6631]	KAKKATTUPARA	81.0	0.0	79.1	1.9	2.3	Very Low
KOZHIKODE	Feroke [6631]	KALLITHODI	129.0	13.2	63.7	52.1	40.4	Medium
KOZHIKODE	Feroke [6631]	KALLITHODI MASJID	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Feroke [6631]	KALLITHODI-2	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	KAMANAPPALAM	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Feroke [6631]	KANNATTIKULAM	81.0	5.0	54.2	21.8	26.9	Medium
KOZHIKODE	Feroke [6631]	KARIMPADAM COLONY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	KARUNA	202.0	5.0	33.3	163.7	81.0	Very High
KOZHIKODE	Feroke [6631]	KIZHAKKE KULAM	81.0	13.0	47.0	21.0	25.9	Medium
KOZHIKODE	Feroke [6631]	KM CORPORATES	81.0	10.0	15.0	56.0	69.1	High
KOZHIKODE	Feroke [6631]	KODAMPUZHA	202.0	5.0	76.4	120.6	59.7	High
KOZHIKODE	Feroke [6631]	KOHINNOR PLASTICS	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Feroke [6631]	KOHINOOR OIL MILL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	KOTHARTHODU	202.0	9.0	69.9	123.1	61.0	High
KOZHIKODE	Feroke [6631]	KOTTAPADAM	81.0	0.0	79.3	1.7	2.1	Very Low
KOZHIKODE	Feroke [6631]	KRUVANTHIRUTHY KADAVU	81.0	22.4	51.3	7.3	9.0	Very Low
KOZHIKODE	Feroke [6631]	KWA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	LAMIYA	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Feroke [6631]	MADATHILPPADAM	129.0	0.0	128.6	0.4	0.3	Very Low
KOZHIKODE	Feroke [6631]	MALABAR	129.0	0.0	20.0	109.0	84.5	Very High
KOZHIKODE	Feroke [6631]	MALABAR PLYWOOD	405.0	0.0	0.0	405.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Feroke [6631]	MALLIKA THEATER	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Feroke [6631]	MAMMILI KADAVU	405.0	0.0	62.0	343.0	84.7	Very High
KOZHIKODE	Feroke [6631]	MANASI	129.0	0.0	7.8	121.2	94.0	Very High
KOZHIKODE	Feroke [6631]	MANNARPPADAM	129.0	3.0	72.3	53.7	41.6	Medium
KOZHIKODE	Feroke [6631]	MARINA AUDITORIUM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	MASJID	81.0	9.0	23.0	49.0	60.5	High
KOZHIKODE	Feroke [6631]	MENOKI	129.0	4.0	30.0	95.0	73.6	High
KOZHIKODE	Feroke [6631]	MILK SOCIETY NALLUR	129.0	0.0	54.0	75.0	58.1	High
KOZHIKODE	Feroke [6631]	MOONILAMPADAM	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Feroke [6631]	MPJ FOOTWEAR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	MUKKONAM	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Feroke [6631]	MULLASSERY	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Feroke [6631]	MUTHUVATTUPARA	81.0	5.0	31.0	45.0	55.6	High
KOZHIKODE	Feroke [6631]	NALLUR NARAYANA MENON SCHOOL	81.0	0.0	12.3	68.7	84.8	Very High
KOZHIKODE	Feroke [6631]	NATHUNIPADAM	202.0	120.0	8.0	74.0	36.6	Medium
KOZHIKODE	Feroke [6631]	NATIONAL-RKARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	ORMA	129.0	3.0	10.0	116.0	89.9	Very High
KOZHIKODE	Feroke [6631]	PALLITHARA	81.0	9.0	19.0	53.0	65.4	High
KOZHIKODE	Feroke [6631]	PARIVARTHANA	129.0	3.0	54.3	71.7	55.6	High
KOZHIKODE	Feroke [6631]	PATHIRIKKATT	81.0	3.0	62.0	16.0	19.8	Low
KOZHIKODE	Feroke [6631]	PERUMUGHAM	129.0	0.0	34.2	94.8	73.4	High
KOZHIKODE	Feroke [6631]	PETTA	202.0	0.0	35.8	166.2	82.3	Very High
KOZHIKODE	Feroke [6631]	POOTHOLAM	129.0	5.0	35.0	89.0	69.0	High
KOZHIKODE	Feroke [6631]	POTTICHIRI	81.0	3.0	36.0	42.0	51.8	High
KOZHIKODE	Feroke [6631]	PREETHI	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Feroke [6631]	PREETHI PLASTIC	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Feroke [6631]	PRIVATE ROAD	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Feroke [6631]	PUTHUKKAZHI PADAM	81.0	5.0	3.0	73.0	90.1	Very High
KOZHIKODE	Feroke [6631]	PUTTEKKAD	81.0	3.0	47.3	30.7	37.9	Medium
KOZHIKODE	Feroke [6631]	PUTTEKKAD MOSQUE	129.0	41.0	65.7	22.3	17.3	Low
KOZHIKODE	Feroke [6631]	QUALITY MILL	255.0	0.0	28.0	227.0	89.0	Very High
KOZHIKODE	Feroke [6631]	RABACK	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	RABACK-2	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	RAFEEQUE-PP	81.0	10.0	13.6	57.4	70.8	High
KOZHIKODE	Feroke [6631]	RAMAN CLAY	51.0	0.0	0.0	51.0	100.0	Very High
KOZHIKODE	Feroke [6631]	RANI METAL	129.0	18.1	22.0	88.9	68.9	High
KOZHIKODE	Feroke [6631]	RELIANCE TRENDZ	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	ROLLRING	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Feroke [6631]	ROYAL AUDITORIUM	202.0	7.1	96.6	98.3	48.7	Medium
KOZHIKODE	Feroke [6631]	ROYAL CARTON	202.0	10.0	116.7	75.3	37.3	Medium
KOZHIKODE	Feroke [6631]	SAFE RUBBER NO-1	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Feroke [6631]	SAFE RUBBER NO-2	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	SAIMADAM	129.0	0.0	27.0	102.0	79.1	Very High
KOZHIKODE	Feroke [6631]	SCICO	255.0	0.0	54.0	201.0	78.8	Very High
KOZHIKODE	Feroke [6631]	SEAOUX DOORS	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Feroke [6631]	SEEMANI TRANSFORMER	81.0	0.0	35.0	46.0	56.8	High
KOZHIKODE	Feroke [6631]	SHYAMALA BHALAKRISHN	129.0	8.0	43.2	77.8	60.3	High
KOZHIKODE	Feroke [6631]	SIVAGANGA	202.0	0.0	11.0	191.0	94.6	Very High
KOZHIKODE	Feroke [6631]	SIVAGIRI	81.0	5.0	35.0	41.0	50.6	High
KOZHIKODE	Feroke [6631]	SMARTEK	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Feroke [6631]	SMASANAM	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Feroke [6631]	SOLUTION	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Feroke [6631]	SRANK LINE	129.0	14.2	10.0	104.8	81.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Feroke [6631]	STAR	129.0	5.0	46.0	78.0	60.5	High
KOZHIKODE	Feroke [6631]	SURABHI	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Feroke [6631]	SWADESHI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	T P ROAD	129.0	0.0	74.8	54.2	42.0	Medium
KOZHIKODE	Feroke [6631]	TALUK HOSPITAL	129.0	11.6	101.3	16.1	12.5	Low
KOZHIKODE	Feroke [6631]	TEAKWOOD	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	UNICONE	81.0	0.0	38.0	43.0	53.1	High
KOZHIKODE	Feroke [6631]	V T RUBBER	129.0	10.0	111.4	7.6	5.9	Very Low
KOZHIKODE	Feroke [6631]	VAIDYAMANDHIRAM	129.0	8.0	73.6	47.4	36.7	Medium
KOZHIKODE	Feroke [6631]	VALANCHERITHAZHAM	81.0	0.0	25.0	56.0	69.1	High
KOZHIKODE	Feroke [6631]	VALENCERI	81.0	5.0	44.0	32.0	39.5	Medium
KOZHIKODE	Feroke [6631]	VELLILA VAYAL	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Feroke [6631]	WEB GEETHANJALI	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Feroke [6631]	WEL PACK	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Feroke [6631]	WEST NALLUR	129.0	0.0	3.0	126.0	97.7	Very High
KOZHIKODE	Feroke [6631]	WEST NALLUR SCHOOL	81.0	13.0	38.0	30.0	37.0	Medium
KOZHIKODE	Kadalundi [6632]	A P ROAD	129.0	0.0	94.2	34.8	27.0	Medium
KOZHIKODE	Kadalundi [6632]	ABAD II	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	ABAD NO1	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	ALAIJA	202.0	0.0	10.0	192.0	95.0	Very High
KOZHIKODE	Kadalundi [6632]	ALUNGAL	129.0	0.0	48.8	80.2	62.2	High
KOZHIKODE	Kadalundi [6632]	ANJOOM RESIDENCE	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Kadalundi [6632]	AVOKI	129.0	0.0	47.0	82.0	63.6	High
KOZHIKODE	Kadalundi [6632]	AYISHA	129.0	0.0	39.0	90.0	69.8	High
KOZHIKODE	Kadalundi [6632]	AYYAMBAKKI	81.0	0.0	30.0	51.0	63.0	High
KOZHIKODE	Kadalundi [6632]	AYYAPPANKAVU	81.0	0.0	33.5	47.5	58.7	High
KOZHIKODE	Kadalundi [6632]	BANU RUBBER	81.0	0.0	27.3	53.7	66.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kadalundi [6632]	BHAJANAMADOM	81.0	0.0	46.8	34.2	42.2	Medium
KOZHIKODE	Kadalundi [6632]	CHALIPARAMBU	129.0	10.0	67.5	51.5	39.9	Medium
KOZHIKODE	Kadalundi [6632]	CHALIPARMBA COLONY	81.0	0.0	29.8	51.2	63.2	High
KOZHIKODE	Kadalundi [6632]	CHALIYAM BEACH	202.0	0.0	28.0	174.0	86.1	Very High
KOZHIKODE	Kadalundi [6632]	CHALIYAM MARKET	202.0	0.0	83.8	118.2	58.5	High
KOZHIKODE	Kadalundi [6632]	CHALIYAM VATTATH	202.0	5.0	92.0	105.0	52.0	High
KOZHIKODE	Kadalundi [6632]	CHALIYAPADAM	81.0	0.0	30.5	50.5	62.3	High
KOZHIKODE	Kadalundi [6632]	CHEERANTHODI	81.0	0.0	31.0	50.0	61.7	High
KOZHIKODE	Kadalundi [6632]	CHELEMBRA TELE EXCHANGE	81.0	4.4	13.2	63.3	78.2	Very High
KOZHIKODE	Kadalundi [6632]	CHELOOPADAM PALLY	81.0	0.0	32.0	49.0	60.5	High
KOZHIKODE	Kadalundi [6632]	CHELOOR PADAM	129.0	0.0	67.5	61.5	47.7	Medium
KOZHIKODE	Kadalundi [6632]	CHEMBAITHODE	81.0	0.0	27.1	53.9	66.6	High
KOZHIKODE	Kadalundi [6632]	CHITHRA CINEPLEX	81.0	0.0	50.0	31.0	38.3	Medium
KOZHIKODE	Kadalundi [6632]	CICO	81.0	0.0	32.0	49.0	60.5	High
KOZHIKODE	Kadalundi [6632]	COIR SOCIETY	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Kadalundi [6632]	EDACHIRA	202.0	3.0	62.0	137.0	67.8	High
KOZHIKODE	Kadalundi [6632]	EDAKAZHIKADAVE	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Kadalundi [6632]	ENNAKATTU PALLI	81.0	5.0	40.5	35.5	43.9	Medium
KOZHIKODE	Kadalundi [6632]	FERRY	81.0	5.0	49.1	26.9	33.1	Medium
KOZHIKODE	Kadalundi [6632]	FISHERIS	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Kadalundi [6632]	GULF ROAD	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Kadalundi [6632]	IMATE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	IND ESTATE CALVARI HILL	405.0	6.0	96.8	302.2	74.6	High
KOZHIKODE	Kadalundi [6632]	JARAM CHALIYAM	129.0	0.0	47.0	82.0	63.6	High
KOZHIKODE	Kadalundi [6632]	JAZ ICE PLANT	129.0	20.0	5.0	104.0	80.6	Very High
KOZHIKODE	Kadalundi [6632]	KADALUNDI	202.0	0.0	51.0	151.0	74.8	High
KOZHIKODE	Kadalundi [6632]	KADALUNDI EAST	129.0	0.0	21.0	108.0	83.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kadalundi [6632]	KADALUNDI KADAVU	81.0	0.0	53.0	28.0	34.6	Medium
KOZHIKODE	Kadalundi [6632]	KADALUNDI MARKET	81.0	15.0	63.0	3.0	3.7	Very Low
KOZHIKODE	Kadalundi [6632]	KADALUNDI TELE EXCHANGE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	KADALUNDI WEST	81.0	0.0	54.7	26.3	32.4	Medium
KOZHIKODE	Kadalundi [6632]	KADUKKA BAZAR	81.0	0.0	24.0	57.0	70.4	High
KOZHIKODE	Kadalundi [6632]	KAITHA VALAPPIL	202.0	0.0	12.0	190.0	94.1	Very High
KOZHIKODE	Kadalundi [6632]	KALLAMPARA	202.0	3.0	63.0	136.0	67.3	High
KOZHIKODE	Kadalundi [6632]	KALLUVALAPPU	129.0	10.0	30.0	89.0	69.0	High
KOZHIKODE	Kadalundi [6632]	KAPPALANGADI	81.0	0.0	63.0	18.1	22.3	Low
KOZHIKODE	Kadalundi [6632]	KARAKALI	129.0	0.0	73.8	55.2	42.8	Medium
KOZHIKODE	Kadalundi [6632]	KAYANIPADAM	81.0	0.0	25.0	56.0	69.1	High
KOZHIKODE	Kadalundi [6632]	KEEZHKODE	81.0	0.0	31.1	49.9	61.5	High
KOZHIKODE	Kadalundi [6632]	KIZHAKKUMBAD	81.0	0.0	39.0	42.0	51.9	High
KOZHIKODE	Kadalundi [6632]	KODAPPURAMTHODE	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Kadalundi [6632]	KONATH	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Kadalundi [6632]	KONATHKUZHI	81.0	45.0	32.3	3.7	4.6	Very Low
KOZHIKODE	Kadalundi [6632]	KOONOOR VALAVU	129.0	0.0	51.0	78.0	60.5	High
KOZHIKODE	Kadalundi [6632]	KOTTAKKADAVU	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Kadalundi [6632]	KUNNATHU PADI	129.0	0.0	43.0	86.0	66.7	High
KOZHIKODE	Kadalundi [6632]	KUTTIPALA	129.0	0.0	14.5	114.5	88.8	Very High
KOZHIKODE	Kadalundi [6632]	LAKSHMI	202.0	0.0	72.0	130.0	64.4	High
KOZHIKODE	Kadalundi [6632]	LIGHT HOUSE	129.0	0.0	11.0	118.0	91.5	Very High
KOZHIKODE	Kadalundi [6632]	LOVELYCORNER	129.0	6.0	39.0	84.0	65.1	High
KOZHIKODE	Kadalundi [6632]	M I E NALLUR	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	M I E SREEPURI ROAD	81.0	0.0	42.1	38.9	48.0	Medium
KOZHIKODE	Kadalundi [6632]	MALAYIL THAZHAM	129.0	5.0	34.8	89.2	69.1	High
KOZHIKODE	Kadalundi [6632]	MANGATTUKULAM	81.0	3.0	44.2	33.8	41.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kadalundi [6632]	MANNUR RAIL	129.0	0.0	69.0	60.0	46.5	Medium
KOZHIKODE	Kadalundi [6632]	MANNUR TEMPLE	81.0	0.0	31.0	50.0	61.7	High
KOZHIKODE	Kadalundi [6632]	MANNUR VALAVU	129.0	0.0	24.0	105.0	81.4	Very High
KOZHIKODE	Kadalundi [6632]	MARVA RUBBER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	MORBIDO	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	MUKKATH KADAVE	81.0	4.6	43.3	33.1	40.9	Medium
KOZHIKODE	Kadalundi [6632]	MURUKALLINGAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	NAZA PLASTIC	129.0	3.0	14.0	112.0	86.8	Very High
KOZHIKODE	Kadalundi [6632]	NIKHIL PLASTIC	129.0	3.0	29.0	97.0	75.2	Very High
KOZHIKODE	Kadalundi [6632]	OLD BANK	129.0	0.0	50.0	79.0	61.2	High
KOZHIKODE	Kadalundi [6632]	PADIKKALTHAZHAM	81.0	3.1	9.0	68.9	85.0	Very High
KOZHIKODE	Kadalundi [6632]	PALAKKATHAZHAM	81.0	5.0	35.0	41.0	50.6	High
KOZHIKODE	Kadalundi [6632]	PANAYAPURAM	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Kadalundi [6632]	PANCHAYATH OFFICE	81.0	0.0	39.0	42.0	51.9	High
KOZHIKODE	Kadalundi [6632]	PARAVANCHERI PADAM	81.0	0.0	33.0	48.0	59.3	High
KOZHIKODE	Kadalundi [6632]	PARAYIL	129.0	0.0	61.7	67.3	52.1	High
KOZHIKODE	Kadalundi [6632]	PAZHANCHANNUR TEMPLE	81.0	5.0	23.2	52.8	65.2	High
KOZHIKODE	Kadalundi [6632]	PEDIYATTUKUNNU	81.0	16.0	22.3	42.7	52.7	High
KOZHIKODE	Kadalundi [6632]	PERUMUGHAM ANGADI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	PERUNNEERI	81.0	0.0	23.3	57.7	71.2	High
KOZHIKODE	Kadalundi [6632]	PERUNTHODI PADAM	129.0	6.6	21.9	100.5	77.9	Very High
KOZHIKODE	Kadalundi [6632]	PHARMACY COLLEGE CHELEMBRA	81.0	5.0	32.0	44.0	54.3	High
KOZHIKODE	Kadalundi [6632]	POOCHERIKUNNU	129.0	3.0	55.8	70.2	54.5	High
KOZHIKODE	Kadalundi [6632]	PROBHODHINI	81.0	0.0	28.0	53.0	65.4	High
KOZHIKODE	Kadalundi [6632]	PULLIPARAMBU ANGADI	129.0	9.6	88.9	30.5	23.6	Low
KOZHIKODE	Kadalundi [6632]	PULLIPARAMBU SCHOOL	129.0	10.0	28.0	91.0	70.5	High
KOZHIKODE	Kadalundi [6632]	SHIFA HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kadalundi [6632]	SRANKUPADI	129.0	0.0	14.0	115.0	89.1	Very High
KOZHIKODE	Kadalundi [6632]	T M H HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	TENERIPARA	129.0	0.0	28.8	100.2	77.7	Very High
KOZHIKODE	Kadalundi [6632]	THAIKKADAPPURAM	129.0	0.0	13.3	115.7	89.7	Very High
KOZHIKODE	Kadalundi [6632]	THANNEERCHAL	129.0	3.0	61.0	65.0	50.4	High
KOZHIKODE	Kadalundi [6632]	THIRUTHI	81.0	3.0	39.0	39.0	48.1	Medium
KOZHIKODE	Kadalundi [6632]	UNITED POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kadalundi [6632]	VADAKKUMBAD RAIL	81.0	0.0	25.5	55.5	68.5	High
KOZHIKODE	Kadalundi [6632]	VADAKKUMPAD	81.0	0.0	15.6	65.4	80.7	Very High
KOZHIKODE	Kadalundi [6632]	VAKKADAVE	129.0	0.0	127.5	1.5	1.2	Very Low
KOZHIKODE	Kadalundi [6632]	VALIYAL	81.0	0.0	44.0	37.0	45.6	Medium
KOZHIKODE	Kadalundi [6632]	VATTAPARAMB	129.0	13.0	116.0	0.0	0.0	Very Low
KOZHIKODE	Kadalundi [6632]	VKC FOOT GEAR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	AMBALAKULANGARA	81.0	0.0	30.0	51.0	63.0	High
KOZHIKODE	Kakkattil [6735]	ANAKUZH	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Kakkattil [6735]	ARAYAKOOL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	BSNL KAKKATTIL	129.0	5.0	15.0	109.0	84.5	Very High
KOZHIKODE	Kakkattil [6735]	C P MUKKU	81.0	3.0	14.0	64.0	79.0	Very High
KOZHIKODE	Kakkattil [6735]	CHAKKARATHODU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	CHALIYILTHODE	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	CHAVITTUPARA	129.0	0.0	42.0	87.0	67.4	High
KOZHIKODE	Kakkattil [6735]	CHEEKONNU	129.0	3.0	34.9	91.1	70.6	High
KOZHIKODE	Kakkattil [6735]	CHEKYADU	81.0	3.0	3.0	75.0	92.6	Very High
KOZHIKODE	Kakkattil [6735]	CHUNDAKKAD	20.0	0.0	0.0	20.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	CITY CENTRE	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Kakkattil [6735]	CITY COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	COMPANYMUKKU	81.0	0.0	59.5	21.5	26.5	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kakkattil [6735]	DAY MART	81.0	0.0	60.0	21.0	25.9	Medium
KOZHIKODE	Kakkattil [6735]	DOUBLE ENTRY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	EDONI	20.0	0.0	0.0	20.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	EECHAKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	ERATTENCHAL	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	IRUMPANTHADAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	IRUMPANTHADAM CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	JATHIYORA	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Kakkattil [6735]	K MALL - 400KVA DTR	324.0	0.0	0.0	324.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	KAAPPUMCHAAL	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Kakkattil [6735]	KAIRALI TOWER KAKKATTIL	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Kakkattil [6735]	KAITHACHAL	81.0	3.0	15.0	63.0	77.8	Very High
KOZHIKODE	Kakkattil [6735]	KAIVELI AIRCEL-EKARAMPARAMBAT	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Kakkattil [6735]	KAIVELI TODDYSHOP-VODAFONE	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Kakkattil [6735]	KAIVELI TOWN	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Kakkattil [6735]	KAKKATTIL TOWN	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	KAKKATTIL-1 KAIVELI ROAD	129.0	0.0	14.0	115.0	89.1	Very High
KOZHIKODE	Kakkattil [6735]	KAKKATTIL-2 AJANTHA	81.0	0.0	27.0	54.0	66.7	High
KOZHIKODE	Kakkattil [6735]	KALAMULLATHIL	81.0	0.0	16.0	65.0	80.2	Very High
KOZHIKODE	Kakkattil [6735]	KALAMULLATHIL-NADUPOYIL-2	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	KALLANKODE	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Kakkattil [6735]	KANAYAMKODE	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	KANDOTHU KUNI	81.0	5.0	21.0	55.0	67.9	High
KOZHIKODE	Kakkattil [6735]	KANHIRAPPARA	81.0	6.0	16.0	59.0	72.8	High
KOZHIKODE	Kakkattil [6735]	KANNOTH PALLI	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	KAPPUMMAL INDUS	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kakkattil [6735]	KATTIPPARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	KAYAKKOOL RELIANCE	81.0	15.0	14.0	52.0	64.2	High
KOZHIKODE	Kakkattil [6735]	KOOMULLUMMAL-PALYAD	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	KOROTHMUKKU	81.0	8.0	15.0	58.0	71.6	High
KOZHIKODE	Kakkattil [6735]	KOVUKKUNNU BAJANAMADAM	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	KOYYAL	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Kakkattil [6735]	KSEB OFFICE KAKKAT	81.0	0.0	37.5	43.5	53.7	High
KOZHIKODE	Kakkattil [6735]	KULANGARATH	129.0	0.0	24.6	104.4	80.9	Very High
KOZHIKODE	Kakkattil [6735]	KUNIYAPOYIL	81.0	3.0	27.2	50.8	62.7	High
KOZHIKODE	Kakkattil [6735]	KUNIYIL LP SCHOOL	81.0	5.0	36.3	39.7	49.0	Medium
KOZHIKODE	Kakkattil [6735]	KUNNUMMAL	81.0	5.0	48.0	28.0	34.6	Medium
KOZHIKODE	Kakkattil [6735]	KUNNUMMAL TEMPLE	81.0	5.0	14.0	62.0	76.5	Very High
KOZHIKODE	Kakkattil [6735]	KUZHICKATT	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	MADHUKUNNU	81.0	0.0	25.0	56.0	69.1	High
KOZHIKODE	Kakkattil [6735]	MAMBOYIL MUKK	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	MANDOKANDI	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	MANIYOORTHAZHA	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Kakkattil [6735]	MANNANKANDY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	MEETHALVAYAL	81.0	0.0	4.0	77.0	95.1	Very High
KOZHIKODE	Kakkattil [6735]	METHALA VADAYAM	81.0	0.0	18.5	62.5	77.1	Very High
KOZHIKODE	Kakkattil [6735]	MINI STADIUM VATTOLI	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	MOKERI GOVT COLLEGE	129.0	3.0	7.8	118.2	91.6	Very High
KOZHIKODE	Kakkattil [6735]	MOKERI RELIANCE	81.0	0.0	13.9	67.1	82.9	Very High
KOZHIKODE	Kakkattil [6735]	MOKERI TOWN	129.0	0.0	28.0	101.0	78.3	Very High
KOZHIKODE	Kakkattil [6735]	MOKERI VODAFONE	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Kakkattil [6735]	MONTHEMMAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	MULLAMBATH	81.0	0.0	25.0	56.0	69.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kakkattil [6735]	MULLAMBATH-1	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	MURUVASSERY	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Kakkattil [6735]	MUYYOTUCHAL	81.0	4.0	6.0	71.0	87.7	Very High
KOZHIKODE	Kakkattil [6735]	NADAKKUMEETHAL	81.0	3.0	32.1	45.9	56.7	High
KOZHIKODE	Kakkattil [6735]	NADUPOYIL	81.0	8.0	5.0	68.0	84.0	Very High
KOZHIKODE	Kakkattil [6735]	NADUPOYIL SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	NARIKKATTERI	81.0	18.0	16.9	46.1	57.0	High
KOZHIKODE	Kakkattil [6735]	NARIKKATTERI ILLAM	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Kakkattil [6735]	NARIKKATTERY SCHOOL	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	NARIPATA IDEA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	NARIPPATA FIBER-COMPANYMUKKU	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	NARIPPATTA RATION SHOP	81.0	5.0	11.0	65.0	80.2	Very High
KOZHIKODE	Kakkattil [6735]	NIDUMANNUR	81.0	0.0	9.8	71.2	87.9	Very High
KOZHIKODE	Kakkattil [6735]	NITTOOR	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	NITTOOR AMBALAM	81.0	0.0	7.0	74.0	91.4	Very High
KOZHIKODE	Kakkattil [6735]	NITTOOR MUKKU	81.0	0.0	15.9	65.1	80.4	Very High
KOZHIKODE	Kakkattil [6735]	NJALLORA PALLI	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	OTHAYOTH	81.0	5.0	38.0	38.0	46.9	Medium
KOZHIKODE	Kakkattil [6735]	PALLIYARA	81.0	0.0	6.5	74.5	92.0	Very High
KOZHIKODE	Kakkattil [6735]	PANDYAM PURAM	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	PASHNIKUNNU	20.0	0.0	3.0	17.0	85.0	Very High
KOZHIKODE	Kakkattil [6735]	PATHIRIPATA SREEKRISHNA TEMPLE	81.0	0.0	4.0	77.0	95.1	Very High
KOZHIKODE	Kakkattil [6735]	PATHIRIPATTA	81.0	0.0	26.0	55.0	67.9	High
KOZHIKODE	Kakkattil [6735]	PAYEKANDI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	PILACHERY	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	POURNAMI	81.0	3.0	31.5	46.5	57.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kakkattil [6735]	PULICHADI	20.0	0.0	0.0	20.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	PULIMUKKU	81.0	10.0	8.0	63.0	77.8	Very High
KOZHIKODE	Kakkattil [6735]	SANSKRIT SCHOOL	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Kakkattil [6735]	THAVULLAKOLLI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	THAYYULLATHIL MUKKU	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	THEJAS MOKERI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	THEKKEYIL MUKKU	81.0	4.0	8.5	68.5	84.6	Very High
KOZHIKODE	Kakkattil [6735]	THINOR	129.0	0.0	26.0	103.0	79.8	Very High
KOZHIKODE	Kakkattil [6735]	THINOR-NAMBIYATHANKUND	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	TR NILL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	UNIYARKANDI	129.0	4.0	29.0	96.0	74.4	High
KOZHIKODE	Kakkattil [6735]	UPPUMMAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	VALIYAKANDATHIL - NARIPPATTA	81.0	3.0	12.0	66.0	81.5	Very High
KOZHIKODE	Kakkattil [6735]	VALLILTHARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	VANITHA VYAVASAYAM-ITI	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	VATTAKANDIPARA	81.0	10.0	26.0	45.0	55.6	High
KOZHIKODE	Kakkattil [6735]	VATTAKKAT	81.0	0.0	22.0	59.0	72.8	High
KOZHIKODE	Kakkattil [6735]	VATTOLI	129.0	0.0	23.0	106.0	82.2	Very High
KOZHIKODE	Kakkattil [6735]	VATTOLI MINI	129.0	3.0	9.0	117.0	90.7	Very High
KOZHIKODE	Kakkattil [6735]	VELLOLIPPIL	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Kakkattil [6735]	VENKALLULLATHARA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkattil [6735]	VODAFONE KANDOTHKUNI	81.0	3.0	24.3	53.7	66.3	High
KOZHIKODE	Kakkodi [6599]	7 NATURE DRINKING WATER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	ADIYOLIL	129.0	0.0	3.0	126.0	97.7	Very High
KOZHIKODE	Kakkodi [6599]	AQUADECT	81.0	0.0	19.4	61.6	76.0	Very High
KOZHIKODE	Kakkodi [6599]	ARATTUPOYIL	81.0	0.0	10.0	71.0	87.7	Very High
KOZHIKODE	Kakkodi [6599]	ARYAVAIDYAVIKASINI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kakkodi [6599]	AYYAPPADAM	81.0	0.0	34.0	47.0	58.0	High
KOZHIKODE	Kakkodi [6599]	AYYAPPANPARA	81.0	3.0	9.0	69.0	85.2	Very High
KOZHIKODE	Kakkodi [6599]	BADIROOR I I	81.0	3.0	38.0	40.0	49.4	Medium
KOZHIKODE	Kakkodi [6599]	BADIROOR-1	81.0	3.0	35.5	42.5	52.5	High
KOZHIKODE	Kakkodi [6599]	BIFURCATION -VELLIMADUKULNNU	4.0	0.0	0.0	4.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	CANAL	81.0	11.0	53.0	17.0	21.0	Low
KOZHIKODE	Kakkodi [6599]	CHALILTHAZHAM	129.0	13.0	39.7	76.3	59.1	High
KOZHIKODE	Kakkodi [6599]	CHANDANANCHERI THAZHAM	81.0	0.0	23.4	57.6	71.1	High
KOZHIKODE	Kakkodi [6599]	CHEEROTTIL THAZHAM	81.0	3.0	17.0	61.0	75.3	Very High
KOZHIKODE	Kakkodi [6599]	CHELAPPRAM BAZAR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	CHELAPPURAM	81.0	5.0	21.0	55.0	67.9	High
KOZHIKODE	Kakkodi [6599]	CHENNIKKOTTU THAZHAM	81.0	0.0	33.4	47.6	58.8	High
KOZHIKODE	Kakkodi [6599]	CHERUKADU	81.0	3.0	24.0	54.0	66.7	High
KOZHIKODE	Kakkodi [6599]	CHERUKULAM	129.0	0.0	35.0	94.0	72.9	High
KOZHIKODE	Kakkodi [6599]	CHIRATTA COMPANY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	CHIRATTATTUTHAZHAM	81.0	3.0	40.5	37.5	46.3	Medium
KOZHIKODE	Kakkodi [6599]	CHITTADIKADAVU	81.0	10.0	31.0	40.0	49.4	Medium
KOZHIKODE	Kakkodi [6599]	CHITTAMVEEDU	81.0	0.0	25.7	55.3	68.3	High
KOZHIKODE	Kakkodi [6599]	CHOYI BAZAR	129.0	3.0	30.0	96.0	74.4	High
KOZHIKODE	Kakkodi [6599]	CHOYIKUTTY ROAD	81.0	6.0	15.0	60.0	74.1	High
KOZHIKODE	Kakkodi [6599]	CMG LINE	81.0	3.0	6.0	72.0	88.9	Very High
KOZHIKODE	Kakkodi [6599]	DISPENSARY LINE	81.0	0.0	21.3	59.7	73.7	High
KOZHIKODE	Kakkodi [6599]	ERAKKULAM	81.0	8.0	54.0	19.0	23.5	Low
KOZHIKODE	Kakkodi [6599]	ERANJOTHU THAZHAM	129.0	5.0	47.3	76.7	59.5	High
KOZHIKODE	Kakkodi [6599]	ESTATE THAZHAM	81.0	0.0	32.5	48.5	59.9	High
KOZHIKODE	Kakkodi [6599]	GOOD LUCK LIBRARY	129.0	6.0	43.0	80.0	62.0	High
KOZHIKODE	Kakkodi [6599]	GULF BAZAR	129.0	4.0	89.3	35.7	27.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kakkodi [6599]	GULF BAZAR CHAPPAL- ALBA	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	IOC PARAMBIL BAZAR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	JAYASREE LINE	129.0	0.0	20.0	109.0	84.5	Very High
KOZHIKODE	Kakkodi [6599]	KACHERI KUNNU	129.0	3.0	25.7	100.3	77.7	Very High
KOZHIKODE	Kakkodi [6599]	KAITHAMOLI THAZHAM	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Kakkodi [6599]	KAKKODI -3- PANCHAYATH	81.0	0.0	52.0	29.0	35.8	Medium
KOZHIKODE	Kakkodi [6599]	KAKKODI 1 POKKIRATH	202.0	0.0	38.0	164.0	81.2	Very High
KOZHIKODE	Kakkodi [6599]	KAKKODI MUKKU	202.0	4.0	40.5	157.5	78.0	Very High
KOZHIKODE	Kakkodi [6599]	KAKKODI-2 SRAMBIA	81.0	0.0	17.0	64.0	79.0	Very High
KOZHIKODE	Kakkodi [6599]	KALLITTAPALAM	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Kakkodi [6599]	KALLUMPURATH THAZHAM	81.0	5.0	18.5	57.5	71.0	High
KOZHIKODE	Kakkodi [6599]	KAMALAKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	KANDIYIL THAZHAM	81.0	23.0	41.8	16.2	20.0	Low
KOZHIKODE	Kakkodi [6599]	KANIYATTU THAZHAM	81.0	3.0	24.3	53.7	66.3	High
KOZHIKODE	Kakkodi [6599]	KANNADICHAL	129.0	8.0	35.4	85.6	66.4	High
KOZHIKODE	Kakkodi [6599]	KANNATTU PARAMBATH MEETHAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	KARALITHAZHAM	81.0	13.0	29.0	39.0	48.1	Medium
KOZHIKODE	Kakkodi [6599]	KARATTU TEMPLE	81.0	17.0	42.5	21.5	26.5	Medium
KOZHIKODE	Kakkodi [6599]	KARICHAL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	KAROTHTHAZHAM	129.0	0.0	27.0	102.0	79.1	Very High
KOZHIKODE	Kakkodi [6599]	KEEZHALLOOR	81.0	6.0	38.3	36.7	45.3	Medium
KOZHIKODE	Kakkodi [6599]	KIZHAKKAL KADAVU	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	KIZHAKKANDITHAZHAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Kakkodi [6599]	KOODATHUMPOYIL	129.0	15.0	114.0	0.0	0.0	Very Low
KOZHIKODE	Kakkodi [6599]	KOTTUKULANGARA	81.0	0.0	33.0	48.0	59.2	High
KOZHIKODE	Kakkodi [6599]	KOTTUPADAM	81.0	0.0	19.0	62.0	76.5	Very High
KOZHIKODE	Kakkodi [6599]	KULAMULLAYIL THAZHAM	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kakkodi [6599]	KUMMANGOTTU THAZHAM	202.0	6.0	69.9	126.1	62.4	High
KOZHIKODE	Kakkodi [6599]	KURUVATTUR	129.0	5.0	29.0	95.0	73.6	High
KOZHIKODE	Kakkodi [6599]	KWA PERUVATTY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	MAKKADA	129.0	3.0	23.0	103.0	79.8	Very High
KOZHIKODE	Kakkodi [6599]	MALIKKADAVU	81.0	10.0	69.0	2.0	2.5	Very Low
KOZHIKODE	Kakkodi [6599]	MANTHOTTATHIL	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Kakkodi [6599]	MAROLITHAZHAM	81.0	8.0	12.3	60.7	74.9	High
KOZHIKODE	Kakkodi [6599]	MES ENG COLLAGE	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	MODUVIL	81.0	3.0	37.3	40.7	50.2	High
KOZHIKODE	Kakkodi [6599]	MOOLAPILAVU	81.0	5.0	20.0	56.0	69.1	High
KOZHIKODE	Kakkodi [6599]	MOOTHEDATHU THAZHAM	81.0	0.0	38.0	43.0	53.1	High
KOZHIKODE	Kakkodi [6599]	MOOTTOLI	81.0	10.0	30.0	41.0	50.6	High
KOZHIKODE	Kakkodi [6599]	MS LINE	81.0	3.0	16.3	61.7	76.2	Very High
KOZHIKODE	Kakkodi [6599]	MUKKAMKADAVU	81.0	3.0	43.0	35.0	43.2	Medium
KOZHIKODE	Kakkodi [6599]	NAYARPEEDIKA	81.0	17.8	50.0	13.2	16.3	Low
KOZHIKODE	Kakkodi [6599]	NECHOOOI POYIL	81.0	3.0	35.0	43.0	53.1	High
KOZHIKODE	Kakkodi [6599]	NEW BAZAR	202.0	8.0	38.0	156.0	77.2	Very High
KOZHIKODE	Kakkodi [6599]	NJARAKKATTU MEETHAL	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Kakkodi [6599]	NM LINE	129.0	3.0	55.7	70.3	54.5	High
KOZHIKODE	Kakkodi [6599]	NV CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	NV ROAD	81.0	8.0	58.0	15.0	18.5	Low
KOZHIKODE	Kakkodi [6599]	OTTATHENGU	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Kakkodi [6599]	PADINJATTUMURI	81.0	8.0	33.0	40.0	49.4	Medium
KOZHIKODE	Kakkodi [6599]	PARAMANNIL	129.0	11.0	40.0	78.0	60.5	High
KOZHIKODE	Kakkodi [6599]	PARAMBIL KADAVU	202.0	0.0	49.0	153.0	75.7	Very High
KOZHIKODE	Kakkodi [6599]	PATHENGALTHAZHAM	81.0	0.0	21.0	60.0	74.1	High
KOZHIKODE	Kakkodi [6599]	PAYAMBRA	81.0	0.0	17.0	64.0	79.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kakkodi [6599]	PAYIMBRA KAVU	81.0	3.0	17.0	61.0	75.3	Very High
KOZHIKODE	Kakkodi [6599]	PERUVATTY	202.0	8.0	14.0	180.0	89.1	Very High
KOZHIKODE	Kakkodi [6599]	PERUVATTY CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	POLOOR	129.0	9.0	25.0	95.0	73.6	High
KOZHIKODE	Kakkodi [6599]	POOVATHUR	81.0	5.0	37.7	38.3	47.2	Medium
KOZHIKODE	Kakkodi [6599]	POTTAMMURI	202.0	3.0	53.3	145.7	72.1	High
KOZHIKODE	Kakkodi [6599]	POYIL THAZHAM	81.0	0.0	16.5	64.5	79.6	Very High
KOZHIKODE	Kakkodi [6599]	POYIL THAZHAM BAZAR	81.0	3.0	0.0	78.0	96.3	Very High
KOZHIKODE	Kakkodi [6599]	PRINTING COMPLEX	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Kakkodi [6599]	PUTHALATH KAVU	81.0	3.0	31.0	47.0	58.0	High
KOZHIKODE	Kakkodi [6599]	PUTTHALATTH THAZHAM	81.0	5.0	52.0	24.0	29.6	Medium
KOZHIKODE	Kakkodi [6599]	RELIANCE	81.0	3.0	75.7	2.3	2.8	Very Low
KOZHIKODE	Kakkodi [6599]	SASINDRA BANK	81.0	15.0	43.0	23.0	28.4	Medium
KOZHIKODE	Kakkodi [6599]	TATA	81.0	18.0	20.8	42.2	52.1	High
KOZHIKODE	Kakkodi [6599]	TELEPHONE EXCHANGE	129.0	0.0	42.4	86.6	67.1	High
KOZHIKODE	Kakkodi [6599]	THEKKANNI THAZHAM	81.0	13.0	31.0	37.0	45.7	Medium
KOZHIKODE	Kakkodi [6599]	THUVAKKOTTU THAZHAM	81.0	5.0	39.4	36.6	45.1	Medium
KOZHIKODE	Kakkodi [6599]	UNNIMUKKU	81.0	6.0	28.8	46.2	57.0	High
KOZHIKODE	Kakkodi [6599]	VADAKKEKKARA THAZHAM	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Kakkodi [6599]	VARIKKOLI	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Kakkodi [6599]	VAYANALI KAVU ROAD	81.0	8.1	29.3	43.6	53.9	High
KOZHIKODE	Kakkodi [6599]	VAYAPPURATHTHAZHAM	81.0	3.3	35.7	42.0	51.8	High
KOZHIKODE	Kakkodi [6599]	VEDA	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Kakkodi [6599]	VELUTHEDAYH THAZHAM	81.0	3.0	36.4	41.6	51.3	High
KOZHIKODE	Kakkodi [6599]	VIVEKA	81.0	7.0	56.5	17.5	21.6	Low
KOZHIKODE	Kakkoor [6764]	ADIYODIMUKKU RGGVY	20.0	3.0	4.7	12.3	61.4	High
KOZHIKODE	Kakkoor [6764]	ALACHATT	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Kakkoor [6764]	AMAMANGALAM	129.0	0.0	14.0	115.0	89.1	Very High
KOZHIKODE	Kakkoor [6764]	AMBADIMUKKU	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Kakkoor [6764]	AMBALAPOYIL	81.0	0.0	23.0	58.0	71.6	High
KOZHIKODE	Kakkoor [6764]	ARENAPOIL	81.0	9.0	41.2	30.8	38.0	Medium
KOZHIKODE	Kakkoor [6764]	BALABODHINI	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Kakkoor [6764]	BRAHMAKULAM	129.0	0.0	37.0	92.0	71.3	High
KOZHIKODE	Kakkoor [6764]	CHAKIRI P C PALAM	81.0	7.0	17.0	57.0	70.4	High
KOZHIKODE	Kakkoor [6764]	CHEEKIODE MAPILA SCHOOL	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Kakkoor [6764]	CHEEKIODE NO1	129.0	3.0	19.0	107.0	82.9	Very High
KOZHIKODE	Kakkoor [6764]	CHEEKIODE RELIANCE	81.0	14.0	61.0	6.0	7.4	Very Low
KOZHIKODE	Kakkoor [6764]	CHEEKIODE SAWMILL	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Kakkoor [6764]	CHEEKIODE HC	81.0	0.0	22.0	59.0	72.8	High
KOZHIKODE	Kakkoor [6764]	DEVADAS ROAD	81.0	0.0	12.5	68.5	84.6	Very High
KOZHIKODE	Kakkoor [6764]	EENTHADE	81.0	5.0	25.0	51.0	63.0	High
KOZHIKODE	Kakkoor [6764]	EZHUKULAM	81.0	7.0	11.2	62.8	77.6	Very High
KOZHIKODE	Kakkoor [6764]	GULF ROAD PAVANDoor	81.0	0.0	14.2	66.8	82.4	Very High
KOZHIKODE	Kakkoor [6764]	IYYAKUZH	81.0	0.0	44.5	36.5	45.0	Medium
KOZHIKODE	Kakkoor [6764]	KAKKUR SERVICE CO-OP BANK	129.0	0.0	7.4	121.6	94.2	Very High
KOZHIKODE	Kakkoor [6764]	KAKKUR TOWN	202.0	0.0	40.3	161.7	80.1	Very High
KOZHIKODE	Kakkoor [6764]	KAKKUR-11	81.0	0.0	42.1	38.9	48.0	Medium
KOZHIKODE	Kakkoor [6764]	KALLANGADI	81.0	0.0	28.0	53.0	65.4	High
KOZHIKODE	Kakkoor [6764]	KANDIYIL THAZHAM	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Kakkoor [6764]	KANDIYOTH THAZHE	81.0	30.0	20.7	30.3	37.4	Medium
KOZHIKODE	Kakkoor [6764]	KANDOTHPARA	81.0	3.0	29.7	48.3	59.6	High
KOZHIKODE	Peringathur [6817]	AHAMMED CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	ANIYARAM	81.0	5.0	35.9	40.1	49.5	Medium
KOZHIKODE	Peringathur [6817]	ANIYARAM TEMPLE	81.0	0.0	23.0	58.0	71.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Peringathur [6817]	BALAN PEEDIKA	129.0	10.0	81.2	37.8	29.3	Medium
KOZHIKODE	Peringathur [6817]	BAVACHI ROAD	129.0	20.0	34.0	75.0	58.1	High
KOZHIKODE	Peringathur [6817]	BAVOT KUNIYIL	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Peringathur [6817]	BHARATHIPURAM	81.0	0.0	6.0	75.0	92.6	Very High
KOZHIKODE	Peringathur [6817]	BHOSE KHADER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	BOARD SCHOOL	81.0	0.0	27.9	53.1	65.5	High
KOZHIKODE	Peringathur [6817]	BSNL KADAVATHUR	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	CENTRE POINT	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	CHOVVAL PEEDIKA	129.0	5.0	22.7	101.3	78.5	Very High
KOZHIKODE	Peringathur [6817]	ELITHODU PALAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Peringathur [6817]	ERANHIYIN KEEZHIL	129.0	10.0	76.0	43.0	33.3	Medium
KOZHIKODE	Peringathur [6817]	EROTH PEEDIKA	81.0	0.0	24.4	56.6	69.8	High
KOZHIKODE	Peringathur [6817]	GAS HOUSE	81.0	3.0	56.0	22.0	27.1	Medium
KOZHIKODE	Peringathur [6817]	HUTCH	81.0	18.0	31.0	32.0	39.5	Medium
KOZHIKODE	Peringathur [6817]	KACHERY MOTTA	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Peringathur [6817]	KADAVATHUR TOWN	202.0	0.0	35.6	166.4	82.4	Very High
KOZHIKODE	Peringathur [6817]	KALLACHERY KADAVU	129.0	5.0	47.3	76.7	59.5	High
KOZHIKODE	Peringathur [6817]	KALLARA	81.0	0.0	29.0	52.0	64.2	High
KOZHIKODE	Peringathur [6817]	KALLIKANDY ROAD	81.0	4.0	41.0	36.0	44.4	Medium
KOZHIKODE	Peringathur [6817]	KANAKAMALA	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Peringathur [6817]	KANNAMKODE	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Peringathur [6817]	KARAPOIL	81.0	0.0	76.0	5.0	6.2	Very Low
KOZHIKODE	Peringathur [6817]	KARGIL	81.0	8.0	3.0	70.0	86.4	Very High
KOZHIKODE	Peringathur [6817]	KARIYAD PANCHAYATH	129.0	0.0	10.0	119.0	92.2	Very High
KOZHIKODE	Peringathur [6817]	KARIYAD THERU	81.0	0.0	9.0	72.0	88.9	Very High
KOZHIKODE	Peringathur [6817]	KATTIL PALLY	129.0	5.0	55.4	68.6	53.1	High
KOZHIKODE	Peringathur [6817]	KAYAPANACHI	81.0	0.0	3.4	77.6	95.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Peringathur [6817]	KAYAPANACHI SAWMILL	81.0	0.0	8.0	73.0	90.1	Very High
KOZHIKODE	Peringathur [6817]	KAYAPANACHI THURUTHU	81.0	0.0	12.0	69.0	85.2	Very High
KOZHIKODE	Peringathur [6817]	KEERIYAVU PALLY	81.0	0.0	56.0	25.0	30.9	Medium
KOZHIKODE	Peringathur [6817]	KEEZHMADAM	81.0	3.0	11.4	66.6	82.2	Very High
KOZHIKODE	Peringathur [6817]	KEEZHMADAM SAWMILL	81.0	12.0	68.8	0.2	0.3	Very Low
KOZHIKODE	Peringathur [6817]	KIDANJI	129.0	7.7	51.0	70.3	54.5	High
KOZHIKODE	Peringathur [6817]	KIDANJI RATION SHOP	81.0	0.0	18.0	63.0	77.8	Very High
KOZHIKODE	Peringathur [6817]	KIDANJI TOWER	129.0	5.0	58.5	65.5	50.8	High
KOZHIKODE	Peringathur [6817]	KIDANJI U P SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	KIDANJIPALLI	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Peringathur [6817]	KOCHIYANGADY	81.0	0.0	32.9	48.1	59.4	High
KOZHIKODE	Peringathur [6817]	KOLAYI	81.0	0.0	17.7	63.3	78.1	Very High
KOZHIKODE	Peringathur [6817]	KOOLIYIL	129.0	5.0	16.0	108.0	83.7	Very High
KOZHIKODE	Peringathur [6817]	KRISHI BHAVAN	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	KUNIYIL PEEDIKA	129.0	3.0	115.5	10.5	8.1	Very Low
KOZHIKODE	Peringathur [6817]	KURULIKKAVU	81.0	5.0	27.5	48.5	59.9	High
KOZHIKODE	Peringathur [6817]	KURUNGAD	129.0	0.0	62.9	66.1	51.2	High
KOZHIKODE	Peringathur [6817]	LOVE SHORE	81.0	10.0	69.5	1.5	1.8	Very Low
KOZHIKODE	Peringathur [6817]	MEKKUNNU	129.0	5.0	25.0	99.0	76.7	Very High
KOZHIKODE	Peringathur [6817]	MEKKUNNU SAWMILL	81.0	5.0	39.4	36.6	45.1	Medium
KOZHIKODE	Peringathur [6817]	MOONANGADY	81.0	0.0	58.0	23.0	28.4	Medium
KOZHIKODE	Peringathur [6817]	MOOTHEDATH TEMPLE	81.0	0.0	11.0	70.0	86.4	Very High
KOZHIKODE	Peringathur [6817]	MUKKALIKKARA	81.0	0.0	25.0	56.0	69.1	High
KOZHIKODE	Peringathur [6817]	MUKKIL PEEDIKA	129.0	0.0	49.0	80.0	62.0	High
KOZHIKODE	Peringathur [6817]	MUKKILPEEDIKA SAWMILL	81.0	0.0	15.0	66.0	81.5	Very High
KOZHIKODE	Peringathur [6817]	MUKKILPEEDIKA TOWER	81.0	5.0	13.0	63.0	77.8	Very High
KOZHIKODE	Peringathur [6817]	MUNDATHODE	81.0	3.0	45.0	33.0	40.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Peringathur [6817]	NADAMMAL PEEDIKA	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Peringathur [6817]	NAM ROAD	81.0	5.0	17.9	58.1	71.8	High
KOZHIKODE	Peringathur [6817]	NANGANDY PALLY	81.0	13.0	33.1	34.9	43.1	Medium
KOZHIKODE	Peringathur [6817]	NANNARATHIL PEEDIKA	81.0	0.0	33.8	47.2	58.3	High
KOZHIKODE	Peringathur [6817]	NASSERPEEDIKA	81.0	0.0	20.0	61.0	75.3	Very High
KOZHIKODE	Peringathur [6817]	NELLIKKA	202.0	0.0	60.0	142.0	70.3	High
KOZHIKODE	Peringathur [6817]	NIA COLLEGE	129.0	0.0	38.0	91.0	70.5	High
KOZHIKODE	Peringathur [6817]	NIDOOOR	81.0	0.0	61.0	20.0	24.7	Low
KOZHIKODE	Peringathur [6817]	NKM COMPLEX ANIYARAM	202.0	0.0	0.0	202.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	OLIPPIL	129.0	25.0	80.3	23.7	18.3	Low
KOZHIKODE	Peringathur [6817]	OLIPPIL SCHOOL	81.0	0.0	25.0	56.0	69.1	High
KOZHIKODE	Peringathur [6817]	P K MARBLES	81.0	0.0	13.0	68.0	84.0	Very High
KOZHIKODE	Peringathur [6817]	PADANNAKKARA	81.0	5.0	13.0	63.0	77.8	Very High
KOZHIKODE	Peringathur [6817]	PADANNAKKARA MADAM	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Peringathur [6817]	PALILANDI PEEDIKA	129.0	6.0	64.9	58.1	45.0	Medium
KOZHIKODE	Peringathur [6817]	PALLIKKUNI AMBALAM	81.0	0.0	5.0	76.0	93.8	Very High
KOZHIKODE	Peringathur [6817]	PALORATH PALLY	81.0	0.0	26.3	54.7	67.5	High
KOZHIKODE	Peringathur [6817]	PANCHARA MUKKU	81.0	3.0	37.3	40.7	50.2	High
KOZHIKODE	Peringathur [6817]	PAREMMAL PALLY	81.0	5.0	29.0	47.0	58.0	High
KOZHIKODE	Peringathur [6817]	PATHEMARY	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	PERIGATHUR PLAZA -PVT	129.0	0.0	0.0	129.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	PERINGATHUR	202.0	0.0	35.0	167.0	82.7	Very High
KOZHIKODE	Peringathur [6817]	PERINGATHUR PALAM	81.0	0.0	3.0	78.0	96.3	Very High
KOZHIKODE	Peringathur [6817]	POOMARAM	129.0	10.0	76.0	43.0	33.3	Medium
KOZHIKODE	Peringathur [6817]	POTTANKANDY	81.0	5.0	54.0	22.0	27.2	Medium
KOZHIKODE	Peringathur [6817]	POYIL	81.0	0.0	30.0	51.0	63.0	High
KOZHIKODE	Peringathur [6817]	PUTHEN PEEDIKA	129.0	0.0	42.7	86.3	66.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
KOZHIKODE	Peringathur [6817]	PUTHIYAPEEDIKA	81.0	0.0	14.0	67.0	82.7	Very High
KOZHIKODE	Peringathur [6817]	PUTHUSSEERI PALLY	129.0	0.0	35.0	94.0	72.9	High
KOZHIKODE	Peringathur [6817]	RABIYATH MUKKU	81.0	0.0	7.3	73.7	91.0	Very High
KOZHIKODE	Peringathur [6817]	RAJAN CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	SULAIMAN MILL	81.0	5.0	21.0	55.0	67.9	High
KOZHIKODE	Peringathur [6817]	THATTANKANDY	81.0	0.0	61.7	19.3	23.9	Low
KOZHIKODE	Peringathur [6817]	THOKKOTTUVAYAL	129.0	0.0	38.0	91.0	70.5	High
KOZHIKODE	Peringathur [6817]	THYKKANDY MUKKU	81.0	0.0	49.6	31.4	38.8	Medium
KOZHIKODE	Peringathur [6817]	UNNIYANKADAVU	81.0	10.0	69.0	2.0	2.5	Very Low
KOZHIKODE	Peringathur [6817]	V K C PALLY	81.0	0.0	59.1	21.9	27.0	Medium
KOZHIKODE	Peringathur [6817]	VALIYANDIPEEDIKA	129.0	5.0	67.0	57.0	44.2	Medium
KOZHIKODE	Peringathur [6817]	VAYALOTH	81.0	15.0	0.0	66.0	81.5	Very High
KOZHIKODE	Peringathur [6817]	VAZHAYIL ROAD	81.0	0.0	0.0	81.0	100.0	Very High
KOZHIKODE	Peringathur [6817]	VILANGAD TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High