

KSEB Renewable Energy Feasibility Report

Generated report · 2000 transformers across 1 districts. Balance % = (Balance Available ÷ 90% DTR Capacity) × 100.

District Summary

District	Transformers	Balance (kW)	Very High	High	Medium	Low	Very Low	Unknown
MALAPPURAM	2000	144,819.6	1164	499	249	46	42	0
TOTAL	2000	144,819.6	1164	499	249	46	42	0

MALAPPURAM — 2000 transformers

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Akambadam [6796]	10 TH BLOCK	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	14 TH BLOCK	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	6 TH BLOCK-NEAR AB SWITCH	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	7 TH BLOCK	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	8 TH BLOCK	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ADYANPARA DAM SITE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ADYANPARA-POWER HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	AKAMPADAM HIGHSCHOOL	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Akambadam [6796]	AKAMPADAM P H C	81.0	0.0	40.0	41.0	50.6	High
MALAPPURAM	Akambadam [6796]	AKAMPADAM THAZHEYANGADI	81.0	0.0	45.3	35.7	44.1	Medium
MALAPPURAM	Akambadam [6796]	AKAMPADAM TOWN	129.0	0.0	26.2	102.8	79.7	Very High
MALAPPURAM	Akambadam [6796]	AKAMPADAM-MILMA	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Akambadam [6796]	AKKAPPADI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ALACKAL	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ALODY-FOREST OUT POST	20.0	0.0	6.9	13.1	65.6	High
MALAPPURAM	Akambadam [6796]	ALODY-THEEKADI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	AMBUMALA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ANAKULAM	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ANAPPARA	81.0	5.0	39.4	36.6	45.1	Medium
MALAPPURAM	Akambadam [6796]	ANATHARA	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ANGAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ARANKODE	81.0	0.0	26.0	55.0	67.9	High
MALAPPURAM	Akambadam [6796]	ARAYAAD BRIDGE	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ARAYAD ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	ATHIKKAAD	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Akambadam [6796]	CHAKKANAANIPPADI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	CHEENKANNIPPAALI-1	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	CHEENKANNIPPAALI-2	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	CHERIYAMKUTH	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	CHERIYAMKUTH TEMPLE	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	CHURULIYIL	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	EDIVANNA	81.0	0.0	44.0	37.0	45.7	Medium
MALAPPURAM	Akambadam [6796]	ELAMPILAKODE	51.0	0.0	8.0	43.0	84.3	Very High
MALAPPURAM	Akambadam [6796]	ERANHIMANGAD	81.0	5.0	75.0	1.0	1.2	Very Low
MALAPPURAM	Akambadam [6796]	GANDHI NAGAR	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	H-BLOCK	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Akambadam [6796]	HILWA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	IKKARASSERYPPADY	20.0	0.0	5.0	15.0	75.0	Very High
MALAPPURAM	Akambadam [6796]	KAKKADAMPOYIL RELIANCE TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	KAKKADAMPOYIL-FOREST OUTPOST	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	KAKKADAMPOYIL-RESORT	20.0	0.0	3.0	17.0	85.0	Very High
MALAPPURAM	Akambadam [6796]	KALAKKUNNU	81.0	0.0	26.4	54.6	67.4	High
MALAPPURAM	Akambadam [6796]	KALLUNDA	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Akambadam [6796]	KANDILAPARA	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	KARUKAPALLY	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	KONAMUNDA	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Akambadam [6796]	KOORIKKATTIL	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	KUNNATHUCHAAL	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Akambadam [6796]	KURUMKULAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	MAHAGANI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	MANNUPADAM	81.0	0.0	21.5	59.5	73.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Akambadam [6796]	MATHILMOOLA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	MELE THOTTAPALLY	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	MELEMANGADU	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	MELEVENDEKUMPOIL-NEAR KP ABS	20.0	0.0	10.0	10.0	50.0	High
MALAPPURAM	Akambadam [6796]	MODAVANNA	81.0	0.0	3.4	77.6	95.8	Very High
MALAPPURAM	Akambadam [6796]	MOOLEPAADAM-KURISHUMPADI	20.0	0.0	3.0	17.0	85.0	Very High
MALAPPURAM	Akambadam [6796]	MOOLEPADAM BRIDGE	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	MOOLEPADAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	MUTTIYEL	81.0	0.0	11.2	69.8	86.2	Very High
MALAPPURAM	Akambadam [6796]	MYLAADI	81.0	0.0	37.0	44.0	54.3	High
MALAPPURAM	Akambadam [6796]	MYLAADI BRIDGE	81.0	0.0	33.0	48.0	59.3	High
MALAPPURAM	Akambadam [6796]	MYLADI POTTI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	NAAYAADAMPOYIL JUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	NAMBOORIPOTTY	81.0	3.0	44.5	33.5	41.4	Medium
MALAPPURAM	Akambadam [6796]	NARIPARAMBU	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Akambadam [6796]	PAIGAKODE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	PALAKATHODU	20.0	0.0	8.0	12.0	60.0	High
MALAPPURAM	Akambadam [6796]	PALAKKAYAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	PALLIPPADI-VENDEKUMPOYIL	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	PANAPOYIL	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Akambadam [6796]	PATHAMCOLONY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	PERAMBRA	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	PERUMBATHOOR	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Akambadam [6796]	PERUVAMPAADAM	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Akambadam [6796]	PERUVAMPADAM-II	81.0	0.0	7.7	73.3	90.5	Very High
MALAPPURAM	Akambadam [6796]	PLACKACHOLA	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Akambadam [6796]	PLACKACHOLA JUNCTION	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	POKKODE	51.0	0.0	0.0	51.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	POOLAPOTTY-1	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Akambadam [6796]	POOVATHINGAL	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	POTTAMPARA	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	RANCH VENDEKUMPOYIL	51.0	0.0	0.0	51.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	THALAKKULAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	THARAMATTAM JUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	THARAMATTOM	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	THARANIPADI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	THOTTAPALLI CHURCH	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	THOTTUPOYIL	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Akambadam [6796]	VADAKKEMURI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	VALANTHODE SCHOOL	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Akambadam [6796]	VANIYAPPURA	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Akambadam [6796]	VATTIKKUNNU	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Akambadam [6796]	VENDAKKUMPOYIL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	VENDEKKUM POYIL SCHOOL	20.0	0.0	9.7	10.3	51.4	High
MALAPPURAM	Akambadam [6796]	VENDEKKUMPOIL JUNCTION	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	VENNEKODE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	VENNEKODE CHECK DAM	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	VETTEKKODE	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	VETTEKKODE-HILL	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Akambadam [6796]	VIJAYAPURAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	VIJAYAPURAM CHURCH	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Akambadam [6796]	VYLASSERI	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Akambadam [6796]	VYLASSERI TEMPLE	81.0	0.0	11.0	70.0	86.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Alathiyur [6574]	A M MOTORS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	A ONE MALL	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	A R PLAST	81.0	0.0	65.0	16.0	19.8	Low
MALAPPURAM	Alathiyur [6574]	AL AFİYAH MEDICAL CENTRE	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Alathiyur [6574]	ALATHIYOOR SHOPPING COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	ALATHIYUR SCHOOL	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Alathiyur [6574]	ALFA OIL MILL	81.0	0.0	22.0	59.0	72.9	High
MALAPPURAM	Alathiyur [6574]	ALI HAJI COMPLEX	81.0	3.1	13.0	64.9	80.2	Very High
MALAPPURAM	Alathiyur [6574]	ALINGAL	81.0	2.0	63.0	16.0	19.8	Low
MALAPPURAM	Alathiyur [6574]	ALINGAL SHOPPING COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	ALINGAL TOWER	81.0	4.0	16.0	61.0	75.3	Very High
MALAPPURAM	Alathiyur [6574]	ANAPADI	81.0	7.0	54.0	20.0	24.7	Low
MALAPPURAM	Alathiyur [6574]	ANAYOZHUKKUPALAM	129.0	17.0	34.0	78.0	60.5	High
MALAPPURAM	Alathiyur [6574]	ANNASSERY	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Alathiyur [6574]	AR TOWER	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Alathiyur [6574]	AVIL MILL	129.0	0.0	26.0	103.0	79.8	Very High
MALAPPURAM	Alathiyur [6574]	AYYAPPANKAVU	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Alathiyur [6574]	BAPPU ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	BAPPU HAJI ARCADE	81.0	0.0	69.0	12.0	14.8	Low
MALAPPURAM	Alathiyur [6574]	BAPPU SHOPPING COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	BP ANGADI	129.0	10.0	47.0	72.0	55.8	High
MALAPPURAM	Alathiyur [6574]	BYPASS ROAD	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Alathiyur [6574]	CADSON POLYMER	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	CANARA BANK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	CHAKYATTU ROAD	129.0	4.0	48.2	76.8	59.5	High
MALAPPURAM	Alathiyur [6574]	CHERIYAPARAPPOOR	129.0	4.0	28.2	96.8	75.1	Very High
MALAPPURAM	Alathiyur [6574]	CNC CINEMAS	129.0	0.0	79.0	50.0	38.8	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Alathiyur [6574]	CPM WOOD	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Alathiyur [6574]	CSI CHURCH	129.0	13.0	42.0	74.0	57.4	High
MALAPPURAM	Alathiyur [6574]	DHARUL QURAN	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	DIET	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Alathiyur [6574]	DOCTOR TRANSFORMER ALATHIYUR	81.0	3.0	28.0	50.0	61.7	High
MALAPPURAM	Alathiyur [6574]	DURGA NAGAR	81.0	3.0	40.0	38.0	46.9	Medium
MALAPPURAM	Alathiyur [6574]	GARUDANKAVU	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Alathiyur [6574]	HANUMANKAVU	81.0	0.0	27.0	54.0	66.7	High
MALAPPURAM	Alathiyur [6574]	IBLIS PALAM	81.0	0.0	40.0	41.0	50.6	High
MALAPPURAM	Alathiyur [6574]	INDUS MOTORS	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	JANATHA GLUCOSE	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Alathiyur [6574]	JARAM	129.0	3.0	82.0	44.0	34.1	Medium
MALAPPURAM	Alathiyur [6574]	JUBAIRIYA TOWER	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Alathiyur [6574]	K M TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	K R AUDITORIUM	81.0	0.0	32.0	49.0	60.5	High
MALAPPURAM	Alathiyur [6574]	KADAPALLY	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Alathiyur [6574]	KAIMALASSERY	81.0	3.0	46.8	31.2	38.5	Medium
MALAPPURAM	Alathiyur [6574]	KAIMALASSERY SCHOOL	81.0	5.0	30.0	46.0	56.8	High
MALAPPURAM	Alathiyur [6574]	KAINIKKARA	129.0	4.0	38.3	86.7	67.2	High
MALAPPURAM	Alathiyur [6574]	KAINIKKARA JUMA MASJID	81.0	0.0	39.0	42.0	51.9	High
MALAPPURAM	Alathiyur [6574]	KAKKADI	81.0	0.0	37.0	44.0	54.3	High
MALAPPURAM	Alathiyur [6574]	KALPARAMB	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Alathiyur [6574]	KANAKKANAKATH	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Alathiyur [6574]	KANAL PALAM	81.0	4.0	26.0	51.0	63.0	High
MALAPPURAM	Alathiyur [6574]	KANNAMKULAM	129.0	6.0	40.0	83.0	64.3	High
MALAPPURAM	Alathiyur [6574]	KARAYIL	81.0	5.0	24.0	52.0	64.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Alathiyur [6574]	KATTACHIRA	81.0	8.0	40.0	33.0	40.7	Medium
MALAPPURAM	Alathiyur [6574]	KATTACHIRA DISPENSARY	81.0	8.0	47.0	26.0	32.1	Medium
MALAPPURAM	Alathiyur [6574]	KATTACHIRA HEALTH CENTRE	81.0	5.0	17.0	59.0	72.8	High
MALAPPURAM	Alathiyur [6574]	KOLOOPALAM	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	KOOTTAYI KADAVU	81.0	5.0	0.0	76.0	93.8	Very High
MALAPPURAM	Alathiyur [6574]	KOTTARAMPALLI	81.0	3.0	19.0	59.0	72.8	High
MALAPPURAM	Alathiyur [6574]	KPM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	KUTTAMAKKAL	81.0	0.0	53.8	27.2	33.6	Medium
MALAPPURAM	Alathiyur [6574]	KUTTICHATHAN PADY	129.0	0.0	10.0	119.0	92.2	Very High
MALAPPURAM	Alathiyur [6574]	LB CANAL	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Alathiyur [6574]	MAHIMA SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	MALAYAMPADI	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Alathiyur [6574]	MANAKKALE PARAMBU	81.0	10.0	31.0	40.0	49.4	Medium
MALAPPURAM	Alathiyur [6574]	MANGALAM JUMA MASJID	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Alathiyur [6574]	MANGATTIRI KOTTA	129.0	3.3	36.0	89.7	69.5	High
MALAPPURAM	Alathiyur [6574]	MANNARAD	81.0	0.0	41.0	40.0	49.4	Medium
MALAPPURAM	Alathiyur [6574]	MARS TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	MEHAQUE TOWER	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	MELEPARAMBU	81.0	8.0	12.0	61.0	75.3	Very High
MALAPPURAM	Alathiyur [6574]	MYTHRI ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	NA FIBER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	NADINAGAR	81.0	3.0	21.0	57.0	70.4	High
MALAPPURAM	Alathiyur [6574]	NALISSERY	81.0	6.0	57.4	17.6	21.7	Low
MALAPPURAM	Alathiyur [6574]	NEELIKULAM	81.0	4.0	15.0	62.0	76.5	Very High
MALAPPURAM	Alathiyur [6574]	NILAYORAM	81.0	3.0	13.0	65.0	80.2	Very High
MALAPPURAM	Alathiyur [6574]	OTTUMPURAM	81.0	0.0	38.0	43.0	53.1	High
MALAPPURAM	Alathiyur [6574]	P S P	81.0	4.0	5.0	72.0	88.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Alathiyur [6574]	PADIYAMTHIRUTHY	81.0	5.0	8.0	68.0	84.0	Very High
MALAPPURAM	Alathiyur [6574]	PALLIPADI	81.0	0.0	37.0	44.0	54.3	High
MALAPPURAM	Alathiyur [6574]	PANATT	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	PANCHANPADY	81.0	4.0	47.8	29.2	36.0	Medium
MALAPPURAM	Alathiyur [6574]	PARAPPERI	129.0	2.0	21.0	106.0	82.2	Very High
MALAPPURAM	Alathiyur [6574]	PARASSERY	81.0	31.0	45.0	5.0	6.2	Very Low
MALAPPURAM	Alathiyur [6574]	PARAYIL	81.0	0.0	27.0	54.0	66.7	High
MALAPPURAM	Alathiyur [6574]	PERUMPARAMBIL	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Alathiyur [6574]	PERUMTHALLOOR TOWN	81.0	2.0	8.0	71.0	87.7	Very High
MALAPPURAM	Alathiyur [6574]	PERUNTHALLOOR PUMP HOUSE	81.0	3.0	3.0	75.0	92.6	Very High
MALAPPURAM	Alathiyur [6574]	PERUNTHALLOOR SCHOOL	202.0	0.0	50.3	151.7	75.1	Very High
MALAPPURAM	Alathiyur [6574]	PKH	81.0	0.0	73.9	7.1	8.8	Very Low
MALAPPURAM	Alathiyur [6574]	POILISSERY	129.0	3.0	42.0	84.0	65.1	High
MALAPPURAM	Alathiyur [6574]	POOKAITHA	202.0	0.0	99.0	103.0	51.0	High
MALAPPURAM	Alathiyur [6574]	POOVAMKULANGARA	81.0	4.0	30.8	46.2	57.0	High
MALAPPURAM	Alathiyur [6574]	POOZHICKUNNU	202.0	8.0	83.3	110.7	54.8	High
MALAPPURAM	Alathiyur [6574]	POTTODY	81.0	0.0	4.0	77.0	95.1	Very High
MALAPPURAM	Alathiyur [6574]	PULINCHODU	81.0	0.0	80.6	0.4	0.5	Very Low
MALAPPURAM	Alathiyur [6574]	PULLOONI	202.0	5.0	57.0	140.0	69.3	High
MALAPPURAM	Alathiyur [6574]	PULLOONIKAVU	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Alathiyur [6574]	RAHMATH PALAM	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Alathiyur [6574]	ROYAL VILLA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	SURYA HOSPITAL	129.0	0.0	60.0	69.0	53.5	High
MALAPPURAM	Alathiyur [6574]	T V SAW MILL	81.0	6.0	43.0	32.0	39.5	Medium
MALAPPURAM	Alathiyur [6574]	TATA MOTORS	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	TAZA SOUK	202.0	0.0	38.6	163.4	80.9	Very High
MALAPPURAM	Alathiyur [6574]	THALOOKKARA	81.0	0.0	19.0	62.0	76.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Alathiyur [6574]	THAMIKUTTY	129.0	12.6	63.4	53.0	41.1	Medium
MALAPPURAM	Alathiyur [6574]	THIRUTHUMMEL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	THOTTILANGADI	81.0	0.0	20.9	60.1	74.2	High
MALAPPURAM	Alathiyur [6574]	TKH AUODITORIUM	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Alathiyur [6574]	TRANSCONTINENTAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Alathiyur [6574]	TRIPRANGODE TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Alathiyur [6574]	UNITED RUBBER	81.0	0.0	17.7	63.3	78.2	Very High
MALAPPURAM	Alathiyur [6574]	VASANTHA	202.0	15.0	36.0	151.0	74.8	High
MALAPPURAM	Alathiyur [6574]	VAYUJA	81.0	9.0	19.0	53.0	65.4	High
MALAPPURAM	Alathiyur [6574]	VELLAMASSERY	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Alathiyur [6574]	VENNAYILANGADI	81.0	2.0	19.0	60.0	74.1	High
MALAPPURAM	Alathiyur [6574]	VILLAGE OFFICE	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Alathiyur [6574]	WEST COST POLYMER	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	ALUNGAL	129.0	0.0	20.0	109.0	84.5	Very High
MALAPPURAM	Anakkayam [6756]	AMBALAVATTOM	81.0	3.0	7.0	71.0	87.7	Very High
MALAPPURAM	Anakkayam [6756]	ANAKKAYAM	129.0	0.0	57.0	72.0	55.8	High
MALAPPURAM	Anakkayam [6756]	ANAKKAYAM CHECK POST	129.0	0.0	31.0	98.0	76.0	Very High
MALAPPURAM	Anakkayam [6756]	ANAKKAYAM PHED	81.0	0.0	19.4	61.6	76.0	Very High
MALAPPURAM	Anakkayam [6756]	ANAKKAYAMCRS	129.0	8.0	61.8	59.2	45.9	Medium
MALAPPURAM	Anakkayam [6756]	AYANIKKUNDU	81.0	0.0	58.5	22.5	27.8	Medium
MALAPPURAM	Anakkayam [6756]	AYYAPPANCHOLA	81.0	0.0	28.0	53.0	65.4	High
MALAPPURAM	Anakkayam [6756]	CHANDANAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	CHEERAKUZH	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Anakkayam [6756]	CHEPPUR	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Anakkayam [6756]	CHEPPUR CRUSER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	CHITTATHUPARA	129.0	0.0	13.0	116.0	89.9	Very High
MALAPPURAM	Anakkayam [6756]	CHUVANNAPARAMBA	81.0	0.0	23.0	58.0	71.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Anakkayam [6756]	DREAM POLYMER	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	ENAGAMPARAMBA	81.0	0.0	31.4	49.6	61.2	High
MALAPPURAM	Anakkayam [6756]	ERAMUDUKKU	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Anakkayam [6756]	ERAMUDUKKU MILL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	HAMRAN	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	IBR INDUSTRIES CHUVANNAPARAM B	255.0	0.0	0.0	255.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	IBR VADAKKUMURI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	IRUMBHUZHI	129.0	0.0	75.0	54.0	41.9	Medium
MALAPPURAM	Anakkayam [6756]	IRUMBHUZHI TOWN	129.0	0.0	52.1	76.9	59.6	High
MALAPPURAM	Anakkayam [6756]	IRUMBUZHI JALALIYA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	KADAMBODE	129.0	0.0	68.4	60.6	46.9	Medium
MALAPPURAM	Anakkayam [6756]	KADAMBODE TOWN	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Anakkayam [6756]	KALANGATTUMUKKU	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Anakkayam [6756]	KALATHINGAL PADI	81.0	5.0	5.0	71.0	87.7	Very High
MALAPPURAM	Anakkayam [6756]	KALATHINGALPADI PALLIYALI	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Anakkayam [6756]	KALLIYATH INDUSTRIES	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	KANJAMANNA	81.0	13.0	39.7	28.3	35.0	Medium
MALAPPURAM	Anakkayam [6756]	KANNAMKULAM	129.0	0.0	5.0	124.0	96.1	Very High
MALAPPURAM	Anakkayam [6756]	KARATPARAMBA	129.0	8.0	34.0	87.0	67.4	High
MALAPPURAM	Anakkayam [6756]	KARIKKAKULAM	81.0	0.0	25.3	55.7	68.8	High
MALAPPURAM	Anakkayam [6756]	KARUVANCHERIPARAMBA	129.0	6.0	39.7	83.3	64.5	High
MALAPPURAM	Anakkayam [6756]	KAVALAPPARA	129.0	0.0	66.5	62.5	48.4	Medium
MALAPPURAM	Anakkayam [6756]	KIZAKKUMPARAMBA CRUS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	KIZHAKKEKKARAPPURAM	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Anakkayam [6756]	KIZHAKKUM PARAMBA	129.0	0.0	22.7	106.3	82.4	Very High
MALAPPURAM	Anakkayam [6756]	KOLAPPARAMB	81.0	3.0	3.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Anakkayam [6756]	KONIKALLU	81.0	0.0	21.0	60.0	74.1	High
MALAPPURAM	Anakkayam [6756]	KOTTAMMAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	KUNDILPADI	81.0	0.0	27.0	54.0	66.7	High
MALAPPURAM	Anakkayam [6756]	KUZHICKADAN KUNDU	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Anakkayam [6756]	MADASSERIKKUNDU	129.0	5.0	80.9	43.1	33.4	Medium
MALAPPURAM	Anakkayam [6756]	MANNAMPARA	129.0	0.0	96.8	32.2	25.0	Low
MALAPPURAM	Anakkayam [6756]	MANNASSERI	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Anakkayam [6756]	MELE CHEPPUR	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Anakkayam [6756]	MODAPPINAPALLI	81.0	3.0	26.3	51.7	63.8	High
MALAPPURAM	Anakkayam [6756]	MOSCO NAGAR	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Anakkayam [6756]	MUDIKKODE	81.0	0.0	49.0	32.0	39.5	Medium
MALAPPURAM	Anakkayam [6756]	MULLUCOMPANY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	MUNDAYILPADI	81.0	5.0	59.0	17.0	21.0	Low
MALAPPURAM	Anakkayam [6756]	NANIANGADI	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Anakkayam [6756]	NARASAKUNNU	81.0	0.0	37.0	44.0	54.3	High
MALAPPURAM	Anakkayam [6756]	NARIYATTUPPARA	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Anakkayam [6756]	NENMINI CHURCH	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Anakkayam [6756]	NENMINI HILLS	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Anakkayam [6756]	NUA DRINKING WATER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	PADINHAREKUNDU	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Anakkayam [6756]	PADINHATTUMURI TOWN	81.0	0.0	78.8	2.2	2.7	Very Low
MALAPPURAM	Anakkayam [6756]	PALLIPPURAM	81.0	2.0	19.0	60.0	74.1	High
MALAPPURAM	Anakkayam [6756]	PALLIPPURAM PHED	202.0	5.0	45.3	151.7	75.1	Very High
MALAPPURAM	Anakkayam [6756]	PALLIPPURAM TOWER	129.0	0.0	94.8	34.2	26.5	Medium
MALAPPURAM	Anakkayam [6756]	PANAYI	129.0	0.0	26.0	103.0	79.8	Very High
MALAPPURAM	Anakkayam [6756]	PANDALLUR CHURCH	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Anakkayam [6756]	PANDALLUR HILLS	81.0	3.0	3.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Anakkayam [6756]	PANDALLUR KWA	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Anakkayam [6756]	PANDALLUR MILLUMPADI	129.0	0.0	20.0	109.0	84.5	Very High
MALAPPURAM	Anakkayam [6756]	PANDALLUR TOWN	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Anakkayam [6756]	PARAMMAL	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Anakkayam [6756]	PATTIYIL PARAMBA	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Anakkayam [6756]	PERIMBALAM	129.0	0.0	9.0	120.0	93.0	Very High
MALAPPURAM	Anakkayam [6756]	PERIMBALAM PALLIPADI	81.0	5.0	12.0	64.0	79.0	Very High
MALAPPURAM	Anakkayam [6756]	PERIMBALAM POLYMERS	129.0	0.0	16.4	112.6	87.3	Very High
MALAPPURAM	Anakkayam [6756]	PERIMBALAM POTTAMMAL	81.0	3.0	45.3	32.7	40.4	Medium
MALAPPURAM	Anakkayam [6756]	PULLIYENGAL	81.0	0.0	29.2	51.8	63.9	High
MALAPPURAM	Anakkayam [6756]	PULLIYILANGADI	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Anakkayam [6756]	PULLIYILANGADICRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	PUZHANKAVU	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Anakkayam [6756]	SAFA MARKAZ CRUSER	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	SASCO METAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	SAUDI PADI	129.0	15.0	18.0	96.0	74.4	High
MALAPPURAM	Anakkayam [6756]	SIDDIKKIYA	81.0	0.0	26.0	55.0	67.9	High
MALAPPURAM	Anakkayam [6756]	THANAL GRAMAM	81.0	0.0	26.0	55.0	67.9	High
MALAPPURAM	Anakkayam [6756]	THEKKEKARA	81.0	4.0	0.0	77.0	95.1	Very High
MALAPPURAM	Anakkayam [6756]	THEKKUMPAD	81.0	0.0	35.7	45.3	56.0	High
MALAPPURAM	Anakkayam [6756]	THENGINTHODI	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Anakkayam [6756]	THIRUTHUPARAMBA	81.0	5.0	25.4	50.6	62.5	High
MALAPPURAM	Anakkayam [6756]	TREE G ANAKKAYAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	UDUMBATHAPADI	129.0	3.0	44.0	82.0	63.6	High
MALAPPURAM	Anakkayam [6756]	UTHALAKUNDU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	VADAKKUMMURI	129.0	5.0	17.0	107.0	82.9	Very High
MALAPPURAM	Anakkayam [6756]	VADAKKUMURI PALLIPADI	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Anakkayam [6756]	VADAKKUPARAMBA	81.0	0.0	34.0	47.0	58.0	High
MALAPPURAM	Anakkayam [6756]	VALAPARAMBA	81.0	11.0	61.0	9.0	11.1	Low
MALAPPURAM	Anakkayam [6756]	VALLIKKAPATTA	129.0	0.0	14.0	115.0	89.1	Very High
MALAPPURAM	Anakkayam [6756]	VALLIKKAPATTA TOWER	81.0	5.0	29.0	47.0	58.0	High
MALAPPURAM	Anakkayam [6756]	VEETTPADI	81.0	0.0	22.0	59.0	72.8	High
MALAPPURAM	Anakkayam [6756]	VENGALLOOR	81.0	3.0	21.0	57.0	70.4	High
MALAPPURAM	Anakkayam [6756]	VETTEKKODE	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Anakkayam [6756]	VETTEKKODE SCHOOL	81.0	3.0	23.7	54.3	67.0	High
MALAPPURAM	Anakkayam [6756]	VETTEKKODE TOWER	129.0	0.0	22.3	106.7	82.7	Very High
MALAPPURAM	Anakkayam [6756]	VILAKKATHAPADI	81.0	10.0	24.3	46.7	57.7	High
MALAPPURAM	Anakkayam [6756]	VIMAS METAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	ABDU HAJI	202.0	0.0	17.0	185.0	91.6	Very High
MALAPPURAM	Angadippuram [6748]	AMBADI NAGAR	81.0	5.0	42.6	33.4	41.2	Medium
MALAPPURAM	Angadippuram [6748]	ANGADIPPURAM KAVU	129.0	3.0	73.9	52.1	40.4	Medium
MALAPPURAM	Angadippuram [6748]	ANGADIPPURAM PARA	129.0	0.0	20.0	109.0	84.5	Very High
MALAPPURAM	Angadippuram [6748]	ANGADIPPURAM SERVICE BANK	129.0	0.0	30.0	99.0	76.7	Very High
MALAPPURAM	Angadippuram [6748]	ASHARIPPADI	81.0	8.0	26.4	46.6	57.5	High
MALAPPURAM	Angadippuram [6748]	ASTEN VILLA	202.0	0.0	55.0	147.0	72.8	High
MALAPPURAM	Angadippuram [6748]	BANGLADESH COLONY	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Angadippuram [6748]	BLUE METALS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	BOMBAY GARAGE	255.0	0.0	15.6	239.4	93.9	Very High
MALAPPURAM	Angadippuram [6748]	BRICKS PLANT CHIRATTAMALA	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	CENTRAL CINEMAS	81.0	3.0	8.0	70.0	86.4	Very High
MALAPPURAM	Angadippuram [6748]	CHAKKAMPALLIYALIL TOWER	81.0	15.0	17.0	49.0	60.5	High
MALAPPURAM	Angadippuram [6748]	CHATHOLIKUNDU	81.0	0.0	47.0	34.0	42.0	Medium
MALAPPURAM	Angadippuram [6748]	CHEERATTAAMALA	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Angadippuram [6748]	CHEERATTAMALA LP SCHOOL	81.0	0.0	43.0	38.0	46.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Angadippuram [6748]	CHEERATTAMALA TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	CHEMMANADI	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Angadippuram [6748]	CHENGARA	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Angadippuram [6748]	CHERAKKAPARAMBA	202.0	0.0	40.0	162.0	80.2	Very High
MALAPPURAM	Angadippuram [6748]	CHERAKKAPARAMBA TEMPLE	81.0	0.0	33.4	47.6	58.7	High
MALAPPURAM	Angadippuram [6748]	CHITHRALAYA	202.0	0.0	19.2	182.8	90.5	Very High
MALAPPURAM	Angadippuram [6748]	CHOLAKKULAM	81.0	0.0	27.0	54.0	66.7	High
MALAPPURAM	Angadippuram [6748]	CHOLAKKULAMBU	81.0	2.0	23.0	56.0	69.1	High
MALAPPURAM	Angadippuram [6748]	CHOLAKKULAMBU NO-2	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Angadippuram [6748]	CHRIST RAJ CHEERATTAMALA	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Angadippuram [6748]	CHUTTUVATTAM	81.0	2.0	49.5	29.5	36.4	Medium
MALAPPURAM	Angadippuram [6748]	CRICKET STADIUM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	ERA PARK	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	ERANTHODE CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	ERANTHODE LP SCHOOL	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Angadippuram [6748]	HAMZA WOOD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	HAZEL DROPS	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	ICE COMPANY	202.0	0.0	45.0	157.0	77.7	Very High
MALAPPURAM	Angadippuram [6748]	IHRD	81.0	0.0	41.0	40.0	49.4	Medium
MALAPPURAM	Angadippuram [6748]	JAIJAVAN VALIYAVEETIL PADI	20.0	0.0	5.0	15.0	75.0	Very High
MALAPPURAM	Angadippuram [6748]	JAWA MOTORS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	JB MALL	129.0	0.0	17.0	112.0	86.8	Very High
MALAPPURAM	Angadippuram [6748]	K V R NEXA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	KARIMALA	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Angadippuram [6748]	KARUVETTIKURISH	81.0	10.0	3.0	68.0	84.0	Very High
MALAPPURAM	Angadippuram [6748]	KATTAPARAK	81.0	0.0	45.9	35.1	43.3	Medium
MALAPPURAM	Angadippuram [6748]	KAYAKUNDU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Angadippuram [6748]	KIZHAKKEMUKKU	81.0	0.0	32.0	49.0	60.5	High
MALAPPURAM	Angadippuram [6748]	KOLLAKKODE MUKKU	81.0	3.0	6.0	72.0	88.9	Very High
MALAPPURAM	Angadippuram [6748]	KOLLAKKODE MUTTIPPALAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	KOLLARAM MUKKU	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Angadippuram [6748]	KOPRA	81.0	3.0	21.0	57.0	70.4	High
MALAPPURAM	Angadippuram [6748]	KOYA WOOD	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Angadippuram [6748]	KVR	129.0	0.0	11.0	118.0	91.5	Very High
MALAPPURAM	Angadippuram [6748]	KVR HOUSE	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Angadippuram [6748]	KVR TATA	129.0	0.0	25.0	104.0	80.6	Very High
MALAPPURAM	Angadippuram [6748]	MAAKS SQUARE STATION	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	MABCO CLOUD VILLAS	202.0	0.0	28.6	173.4	85.8	Very High
MALAPPURAM	Angadippuram [6748]	MACHEERIPARAMBU	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Angadippuram [6748]	MANDAKINI	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	MANIKYAPURAM	202.0	20.0	64.6	117.4	58.1	High
MALAPPURAM	Angadippuram [6748]	MANJERI ROAD NO - 1	81.0	10.0	26.0	45.0	55.6	High
MALAPPURAM	Angadippuram [6748]	MANJERI ROAD NO-2	129.0	0.0	40.1	88.9	68.9	High
MALAPPURAM	Angadippuram [6748]	MANNUMKULAM	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Angadippuram [6748]	MANNUMKULAM GATEPADI	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Angadippuram [6748]	MANNUMKULAM RGGVY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	MANNUMKULAM VARIKKATHADAM	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Angadippuram [6748]	MARINGATH	129.0	3.0	78.0	48.0	37.2	Medium
MALAPPURAM	Angadippuram [6748]	MARK MOTORS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	MEENKULATHI KAVU	202.0	5.0	61.0	136.0	67.3	High
MALAPPURAM	Angadippuram [6748]	MEENKULATHI KAVU NO-2	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	MENON PADI	81.0	6.0	50.9	24.1	29.8	Medium
MALAPPURAM	Angadippuram [6748]	MULLAKKAR TEMPLE	81.0	3.0	21.0	57.0	70.4	High
MALAPPURAM	Angadippuram [6748]	MUTTIPPALAM	81.0	2.0	5.0	74.0	91.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Angadippuram [6748]	NELLIKAPARAMBA	81.0	5.0	36.0	40.0	49.4	Medium
MALAPPURAM	Angadippuram [6748]	NEW SBI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	OLIVE APPARTMENT	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	ONAMALA	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Angadippuram [6748]	ORADAMPALAM	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Angadippuram [6748]	OTTUPARA	81.0	6.0	46.0	29.0	35.8	Medium
MALAPPURAM	Angadippuram [6748]	PADINHARE PADAM	81.0	0.0	46.0	35.0	43.2	Medium
MALAPPURAM	Angadippuram [6748]	PANCHAYATH	129.0	0.0	56.0	73.0	56.6	High
MALAPPURAM	Angadippuram [6748]	PANIKKARU KADU	81.0	3.0	17.0	61.0	75.3	Very High
MALAPPURAM	Angadippuram [6748]	PARIYAPURAM HIGH SCHOOL	129.0	6.0	45.7	77.3	59.9	High
MALAPPURAM	Angadippuram [6748]	PARIYAPURAM HOMEIO	81.0	2.0	17.0	62.0	76.5	Very High
MALAPPURAM	Angadippuram [6748]	PARIYAPURAM KHADI	81.0	3.0	9.8	68.2	84.2	Very High
MALAPPURAM	Angadippuram [6748]	PARIYAPURAM LP SCHOOL	129.0	5.0	37.8	86.2	66.8	High
MALAPPURAM	Angadippuram [6748]	PARIYAPURAM MINI INDUSTRIES	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Angadippuram [6748]	PARIYAPURAM TOWN	202.0	5.0	60.0	137.0	67.8	High
MALAPPURAM	Angadippuram [6748]	PATHARI	81.0	0.0	72.0	9.0	11.1	Low
MALAPPURAM	Angadippuram [6748]	PATTIKKUNNU	81.0	5.0	27.0	49.0	60.5	High
MALAPPURAM	Angadippuram [6748]	PEECHANIPARAMBA	81.0	15.0	20.0	46.0	56.8	High
MALAPPURAM	Angadippuram [6748]	PERAYIL WOOD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	POLYTECHNIC	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Angadippuram [6748]	POLYTECHNIC NO - 2	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	POONTHANAM NAGAR	81.0	5.0	13.0	63.0	77.8	Very High
MALAPPURAM	Angadippuram [6748]	POOPPALAM ROAD	81.0	17.0	36.0	28.0	34.6	Medium
MALAPPURAM	Angadippuram [6748]	PUTHANANGAADI TOWN	129.0	0.0	25.0	104.0	80.6	Very High
MALAPPURAM	Angadippuram [6748]	PUTHANANGADI PALLIPPADI	129.0	0.0	40.0	89.0	69.0	High
MALAPPURAM	Angadippuram [6748]	PUTHANANGADI SAW MILL	129.0	8.0	61.5	59.5	46.1	Medium
MALAPPURAM	Angadippuram [6748]	PUTHANANGADI ST MARYS	202.0	0.0	90.0	112.0	55.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Angadippuram [6748]	PUTHANVEETIL APPARTMENT	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	RAILWAY GATE ANGADIPPURAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	RAILWAY STATION	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	RELIANCE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	ROSHNI PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	ROYAL TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	S B T ANGADIPPURAM	129.0	5.0	101.0	23.1	17.9	Low
MALAPPURAM	Angadippuram [6748]	SAUHRUDA NAGAR	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Angadippuram [6748]	SRS POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	T B G HYUNDAI	81.0	3.0	8.0	70.0	86.4	Very High
MALAPPURAM	Angadippuram [6748]	T B S TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	TATA TOWER	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Angadippuram [6748]	THADATHIL VALAVU	129.0	3.3	66.0	59.7	46.3	Medium
MALAPPURAM	Angadippuram [6748]	THADATHIL VALAVU SERVICE STATI	81.0	10.0	32.0	39.0	48.1	Medium
MALAPPURAM	Angadippuram [6748]	THATTARAKKAD NO-1	81.0	3.0	50.0	28.0	34.6	Medium
MALAPPURAM	Angadippuram [6748]	THATTARAKKAD NO-2	81.0	5.0	26.0	50.0	61.7	High
MALAPPURAM	Angadippuram [6748]	THAVALENGAL KULAMBU	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Angadippuram [6748]	THIRUMANDHAMKUNNU TEMPLE	202.0	0.0	114.1	87.9	43.5	Medium
MALAPPURAM	Angadippuram [6748]	THIRURKAD CHETTIYANKAVU	81.0	0.0	41.3	39.7	49.0	Medium
MALAPPURAM	Angadippuram [6748]	THIRURKKAD HIGH SCHOOL	129.0	9.4	105.7	13.9	10.8	Low
MALAPPURAM	Angadippuram [6748]	THIRURKKAD ITC	129.0	0.0	18.0	111.0	86.0	Very High
MALAPPURAM	Angadippuram [6748]	THIRURKKAD PALLIPPADI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	THIRURKKAD PARA	129.0	0.0	62.8	66.2	51.3	High
MALAPPURAM	Angadippuram [6748]	THIRURKKAD TOWN	202.0	0.0	72.7	129.3	64.0	High
MALAPPURAM	Angadippuram [6748]	THONIKKARA ROAD	81.0	0.0	58.0	23.0	28.4	Medium
MALAPPURAM	Angadippuram [6748]	THONIKKARA TEMPLE	81.0	0.0	45.0	36.0	44.4	Medium
MALAPPURAM	Angadippuram [6748]	TUBE WELL	81.0	0.0	28.0	53.0	65.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Angadippuram [6748]	VADAKKEKARA	81.0	0.0	46.0	35.0	43.2	Medium
MALAPPURAM	Angadippuram [6748]	VALAMBOOR CHURCH	81.0	0.0	35.0	46.0	56.8	High
MALAPPURAM	Angadippuram [6748]	VALAMBOOR HEALTH CENTRE	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Angadippuram [6748]	VALAMBOOR IDEA TOWER	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Angadippuram [6748]	VALAMBOOR PATTIKKAD ROAD	81.0	5.0	33.0	43.0	53.1	High
MALAPPURAM	Angadippuram [6748]	VALAMBOOR TOWN	129.0	19.0	67.0	43.0	33.3	Medium
MALAPPURAM	Angadippuram [6748]	VALAMBUR BANGLADESH COLANI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	VALAMBUR HARIJAN COLONY	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Angadippuram [6748]	VALIYAVEETIL PADI	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Angadippuram [6748]	VALLUVANADU TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	VAZHIPPARA	81.0	0.0	28.0	53.0	65.4	High
MALAPPURAM	Angadippuram [6748]	VAZHIPPARA ATHANI	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Angadippuram [6748]	VAZHIPPARA THAZHATHENGADU	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Angadippuram [6748]	VIDYANIKETHAN	81.0	12.0	59.0	10.0	12.3	Low
MALAPPURAM	Angadippuram [6748]	VISHNU TEMPLE	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Angadippuram [6748]	VK TOWER THIRURKKAD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Angadippuram [6748]	VYLONGARA	129.0	0.0	88.0	41.0	31.8	Medium
MALAPPURAM	Areekode [6549]	AJESH WOODS VADAKKUMMALA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areekode [6549]	ALUKKAL	81.0	8.0	50.0	23.0	28.4	Medium
MALAPPURAM	Areekode [6549]	ALUKKAL HAJIYAR PADI	364.0	0.0	3.0	361.0	99.2	Very High
MALAPPURAM	Areekode [6549]	ANAPRACHALIL	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Areekode [6549]	ARAKKANCHERY	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Areekode [6549]	AREACODE BANK	202.0	0.0	41.4	160.6	79.5	Very High
MALAPPURAM	Areekode [6549]	AREACODE BRIDGE	81.0	0.0	39.0	42.0	51.9	High
MALAPPURAM	Areekode [6549]	AREACODE ICE	129.0	0.0	61.0	68.0	52.7	High
MALAPPURAM	Areekode [6549]	AREACODE KWA	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Areekode [6549]	AREACODE TAXI STAND	81.0	0.0	17.0	64.0	79.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Areecode [6549]	ASARITHODE	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	CHEERAKUZHI	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Areecode [6549]	CHELAPPURAM	81.0	0.0	20.8	60.2	74.3	High
MALAPPURAM	Areecode [6549]	CHEMBAPARAMB BASE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	CHEMBAPARAMBA	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Areecode [6549]	CHEMBAPARAMBA GROUND	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Areecode [6549]	CHEMBAPARAMBA TAKA	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Areecode [6549]	CHEMRAKATTUR	129.0	5.0	33.0	91.0	70.5	High
MALAPPURAM	Areecode [6549]	CHEMRAKATTUR SCHOOL	81.0	5.0	54.3	21.7	26.8	Medium
MALAPPURAM	Areecode [6549]	CHERANGAKUNDU	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Areecode [6549]	CHITTIAPARAMBA	81.0	0.0	29.0	52.0	64.2	High
MALAPPURAM	Areecode [6549]	CHOLAKUNDAN	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	CHUNDATH	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Areecode [6549]	ELAYOOR	129.0	0.0	36.0	93.0	72.1	High
MALAPPURAM	Areecode [6549]	ELAYOOR MUBARAK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	ELAYUR CHOLA	129.0	3.0	13.0	113.0	87.6	Very High
MALAPPURAM	Areecode [6549]	ELAYUR YATHEEMKHANA	81.0	0.0	18.9	62.1	76.7	Very High
MALAPPURAM	Areecode [6549]	ELIAPARAMBA	81.0	0.0	46.0	35.0	43.2	Medium
MALAPPURAM	Areecode [6549]	ELIAPARAMBA THADAYI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	FAMOUS CLAY	81.0	0.0	7.0	74.0	91.4	Very High
MALAPPURAM	Areecode [6549]	GHS PERUPARAMBA	81.0	0.0	42.0	39.0	48.1	Medium
MALAPPURAM	Areecode [6549]	IRUVETTY	81.0	0.0	34.8	46.2	57.1	High
MALAPPURAM	Areecode [6549]	IRUVETTY EAST	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Areecode [6549]	IRUVETTY SCHOOL	129.0	0.0	23.0	106.0	82.2	Very High
MALAPPURAM	Areecode [6549]	IRUVETTY TEMPLE	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	ITI	129.0	0.0	8.0	121.0	93.8	Very High
MALAPPURAM	Areecode [6549]	ITI ATHANI	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Areecode [6549]	ITI CAMPUS	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Areecode [6549]	ITI KWA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KAIPAKKULAM	129.0	10.0	39.5	79.5	61.6	High
MALAPPURAM	Areecode [6549]	KAIPAKKULAM-11-INDUS	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KAKKATHODU	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Areecode [6549]	KAKKODE CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KAKKODE CRUSHUR-2	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KANNANCHERIPADI KVR-12	81.0	3.0	14.5	63.5	78.4	Very High
MALAPPURAM	Areecode [6549]	KARIPARAMB UNNIKALI	129.0	0.0	8.0	121.0	93.8	Very High
MALAPPURAM	Areecode [6549]	KARIPARAMBA	81.0	0.0	12.0	69.0	85.2	Very High
MALAPPURAM	Areecode [6549]	KASAVU KENDRA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KAVANOOR TOWN	202.0	35.0	48.0	119.0	58.9	High
MALAPPURAM	Areecode [6549]	KAVANOOR-12	129.0	0.0	34.8	94.2	73.0	High
MALAPPURAM	Areecode [6549]	KAVANUR IRIVETTY ROAD	129.0	0.0	13.0	116.0	89.9	Very High
MALAPPURAM	Areecode [6549]	KAVANUR MATTADA ROAD	129.0	3.0	18.8	107.2	83.1	Very High
MALAPPURAM	Areecode [6549]	KAVANUR STADIUM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KAVANUR TILES	81.0	0.0	22.0	59.0	72.8	High
MALAPPURAM	Areecode [6549]	KAVANUR VILLAGE	129.0	30.0	48.0	51.0	39.5	Medium
MALAPPURAM	Areecode [6549]	KEMKA-FOODPARK-KILIKKAL	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KILIKALL KWA KAVANOOR PLANT	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KILIKALL KWA MANJERY PLANT	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KILIKALLUNGAL	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Areecode [6549]	KILIKALLUNGAL IDEA	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KILIKKALLUNGAL CHAKIRI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	KILIKKALLUNGAL KWA	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Areecode [6549]	KK TOWER	129.0	0.0	37.6	91.4	70.9	High
MALAPPURAM	Areecode [6549]	KOLLANPADI	81.0	0.0	21.7	59.3	73.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Areecode [6549]	KSEB OFFICE	129.0	0.0	17.0	112.0	86.8	Very High
MALAPPURAM	Areecode [6549]	KUNDUVAZHI	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Areecode [6549]	KUTHUPARAMBU	81.0	0.0	32.2	48.8	60.2	High
MALAPPURAM	Areecode [6549]	KUTHUPARAMBU KOTTIYALI	81.0	0.0	34.3	46.7	57.7	High
MALAPPURAM	Areecode [6549]	KUZHIMOOI	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Areecode [6549]	MADARAKUNDU	81.0	5.0	41.5	34.5	42.7	Medium
MALAPPURAM	Areecode [6549]	MAITHRA KWA	81.0	0.0	9.9	71.1	87.8	Very High
MALAPPURAM	Areecode [6549]	MAITHRA PALLI	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	MAITHRA SCHOOL	81.0	0.0	22.0	59.0	72.8	High
MALAPPURAM	Areecode [6549]	MANGALASSERI	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Areecode [6549]	MANNARAKUNNU	81.0	0.0	3.5	77.5	95.7	Very High
MALAPPURAM	Areecode [6549]	MATHAKODE	81.0	5.0	22.0	54.0	66.7	High
MALAPPURAM	Areecode [6549]	MATHAKODE AGHANAVADI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	MEENCHIRA	81.0	0.0	15.2	65.8	81.2	Very High
MALAPPURAM	Areecode [6549]	MEPRAPAD	81.0	10.0	8.0	63.0	77.8	Very High
MALAPPURAM	Areecode [6549]	METHALANGADI	81.0	0.0	9.8	71.2	87.9	Very High
MALAPPURAM	Areecode [6549]	MIDDLE VALLEY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	MOOZHIPADAM	81.0	0.0	12.6	68.4	84.4	Very High
MALAPPURAM	Areecode [6549]	MOTHER HOSPITAL	129.0	8.0	117.0	4.0	3.1	Very Low
MALAPPURAM	Areecode [6549]	MOZHIPPADAM TIPPU JN	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Areecode [6549]	MSP CAMP	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Areecode [6549]	MUTHALAM	81.0	5.0	10.0	66.0	81.5	Very High
MALAPPURAM	Areecode [6549]	MUTHALAM PUZHAYOORAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	MUTTUNGAL	81.0	0.0	54.0	27.0	33.3	Medium
MALAPPURAM	Areecode [6549]	MYTHRA YATHEEM KHANA	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	NADAKKAVUNGAL	81.0	5.0	51.7	24.3	30.0	Medium
MALAPPURAM	Areecode [6549]	NELLI KUNNU	81.0	0.0	9.0	72.0	88.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Areecode [6549]	NELLIKUNNU MSAND	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Areecode [6549]	NORTH KOZHAKOTTUR	81.0	0.0	55.0	26.0	32.1	Medium
MALAPPURAM	Areecode [6549]	NORTH KOZHAKOTTUR SCHOOL	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	NV HEIGHTS	324.0	20.0	0.0	304.0	93.8	Very High
MALAPPURAM	Areecode [6549]	OTTUPARAKKAL	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Areecode [6549]	PADIKATHODI	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	PALACHUVADU-KVR12	81.0	3.0	16.0	62.0	76.5	Very High
MALAPPURAM	Areecode [6549]	PALAKKAPARAMBA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	PALAKKAPARAMBA KUNNATH	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	PALAKKATHADAM	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Areecode [6549]	PANTHAPPAD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	PARAKADAVATH	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	PARATTUKUNDU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	PARIYARAKKAL	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Areecode [6549]	PARIYARAKKAL MILL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	PARODI	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	PERANATHUMMAL	81.0	0.0	32.0	49.0	60.5	High
MALAPPURAM	Areecode [6549]	PERUMPARAMBA KALIYAMKULAM	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Areecode [6549]	PONNAMCHIRA	81.0	10.0	13.0	58.0	71.6	High
MALAPPURAM	Areecode [6549]	POOKOTTU CHOLA PIPE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	POOKOTTUCHOLA	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Areecode [6549]	POOMKUDY	81.0	0.0	8.0	73.0	90.2	Very High
MALAPPURAM	Areecode [6549]	PULINCHUVAD VELLERI	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Areecode [6549]	PULINGOTTUPURAM ROAD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	PULIYAR KUNNU	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Areecode [6549]	PULLANCHERI VALAYIL KULAM	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Areecode [6549]	PUMPKIN	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Areecode [6549]	PUTHUVANAKKUNNU	81.0	0.0	40.0	41.0	50.6	High
MALAPPURAM	Areecode [6549]	RELIANCE TOWER	81.0	0.0	32.0	49.0	60.5	High
MALAPPURAM	Areecode [6549]	S-KOZHAKOTTUR	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Areecode [6549]	SALIGRAM	129.0	0.0	45.0	84.0	65.1	High
MALAPPURAM	Areecode [6549]	SBI AREACODE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	SHILPI	129.0	0.0	26.0	103.0	79.8	Very High
MALAPPURAM	Areecode [6549]	SOUTHPUTHALAM	81.0	0.0	34.0	47.0	58.0	High
MALAPPURAM	Areecode [6549]	SRANCHIKAI	81.0	0.0	21.0	60.0	74.1	High
MALAPPURAM	Areecode [6549]	SURYANAGAR	81.0	0.0	68.0	13.0	16.0	Low
MALAPPURAM	Areecode [6549]	TALUK HOSPITAL	202.0	0.0	24.9	177.1	87.7	Very High
MALAPPURAM	Areecode [6549]	THAKVABAD	81.0	5.0	45.2	30.8	38.0	Medium
MALAPPURAM	Areecode [6549]	THALAKODE	81.0	0.0	40.9	40.1	49.6	Medium
MALAPPURAM	Areecode [6549]	THANIMA	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Areecode [6549]	THAVARAPARMBA	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Areecode [6549]	THAZHATHANGADI PALLI	81.0	0.0	44.8	36.2	44.7	Medium
MALAPPURAM	Areecode [6549]	THAZHATHUMURY	81.0	3.0	30.0	48.0	59.3	High
MALAPPURAM	Areecode [6549]	THOTTILANGADY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	UGRAPURAM	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Areecode [6549]	UGRAPURAM HOMEIO	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	VADAKKUMALA PARA	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Areecode [6549]	VADAKKUMALA SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	VADAKKUMMALA MILL	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Areecode [6549]	VADAKKUMMALA NEDUMGOD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	VADASSERI	81.0	0.0	27.9	53.1	65.6	High
MALAPPURAM	Areecode [6549]	VAKKALUR	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Areecode [6549]	VAKKALUR TOWN	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Areecode [6549]	VALLAYIL	81.0	0.0	21.0	60.0	74.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Areekode [6549]	VATTAPARAMBA	81.0	0.0	45.0	36.0	44.5	Medium
MALAPPURAM	Areekode [6549]	VAZHAKKAD ROAD	129.0	0.0	18.0	111.0	86.0	Very High
MALAPPURAM	Areekode [6549]	VELLERI	129.0	0.0	61.7	67.3	52.2	High
MALAPPURAM	Areekode [6549]	VK PADI	81.0	0.0	38.0	43.0	53.1	High
MALAPPURAM	Areekode [6549]	WORLD BANK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	A M MOTERS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	ACHAYATHUKUNNU	129.0	3.0	39.9	86.1	66.7	High
MALAPPURAM	Changaramkulam [6585]	ALIKKA KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	AMAYAM	81.0	5.0	8.0	68.0	84.0	Very High
MALAPPURAM	Changaramkulam [6585]	ANUGRAHA	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Changaramkulam [6585]	AREEKADE	81.0	0.0	77.8	3.2	4.0	Very Low
MALAPPURAM	Changaramkulam [6585]	ARUN	129.0	0.0	30.0	99.0	76.7	Very High
MALAPPURAM	Changaramkulam [6585]	ASANKETTU KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	ATC	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Changaramkulam [6585]	ATTAYIL KUNNU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	AVARANPADI	81.0	0.0	53.8	27.2	33.6	Medium
MALAPPURAM	Changaramkulam [6585]	AYATH MALL LT-INDOOR	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	AYNICHODE	129.0	3.0	26.3	99.7	77.3	Very High
MALAPPURAM	Changaramkulam [6585]	AYURGREN	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Changaramkulam [6585]	B S N L	81.0	0.0	11.3	69.7	86.0	Very High
MALAPPURAM	Changaramkulam [6585]	BABY PADY	81.0	0.0	19.1	61.9	76.4	Very High
MALAPPURAM	Changaramkulam [6585]	BADARIYA MASJID	81.0	0.0	32.3	48.7	60.1	High
MALAPPURAM	Changaramkulam [6585]	BTM UP	81.0	5.0	25.0	51.0	63.0	High
MALAPPURAM	Changaramkulam [6585]	BUILD BASE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	BYMIN APARTMENT	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	CHANGARAMKULAM 500	405.0	5.0	52.0	348.0	85.9	Very High
MALAPPURAM	Changaramkulam [6585]	CHATHANKULANGARA	81.0	0.0	62.1	18.9	23.3	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Changaramkulam [6585]	CHELAKADAVU	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Changaramkulam [6585]	CHENKOTTA	81.0	0.0	17.9	63.1	77.9	Very High
MALAPPURAM	Changaramkulam [6585]	CHERAVALOOR	129.0	0.0	25.3	103.7	80.4	Very High
MALAPPURAM	Changaramkulam [6585]	CHERAYAM KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	CHIYANOOR BAR	81.0	5.0	33.0	43.0	53.1	High
MALAPPURAM	Changaramkulam [6585]	CHIYYANOOR COLONY	81.0	5.0	14.0	62.0	76.5	Very High
MALAPPURAM	Changaramkulam [6585]	CHULLIYIL	81.0	13.0	11.0	57.0	70.4	High
MALAPPURAM	Changaramkulam [6585]	CITYMALL	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	CO OPERATIVE BANK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	COMPANYPADI	81.0	5.0	19.0	57.0	70.4	High
MALAPPURAM	Changaramkulam [6585]	COSMETIC	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	CREATIVE	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	DDUGJY HIGHWAY	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Changaramkulam [6585]	ERAVAKKAD	81.0	2.0	38.6	40.4	49.9	Medium
MALAPPURAM	Changaramkulam [6585]	EVIRON EV CHARGING	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	GALAXY	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Changaramkulam [6585]	GLASSCO	81.0	3.0	45.1	32.9	40.6	Medium
MALAPPURAM	Changaramkulam [6585]	GOOD HOPE	81.0	3.0	43.3	34.7	42.8	Medium
MALAPPURAM	Changaramkulam [6585]	GOPIKA FURNITURE	129.0	29.0	47.0	53.0	41.1	Medium
MALAPPURAM	Changaramkulam [6585]	HAYATH JEWELLERY LT-INDOOR	129.0	0.0	50.0	79.0	61.2	High
MALAPPURAM	Changaramkulam [6585]	HIGH SCHOOL	129.0	0.0	68.4	60.6	47.0	Medium
MALAPPURAM	Changaramkulam [6585]	INDUS	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Changaramkulam [6585]	K V M	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	KACHERI CKM	129.0	16.0	41.0	72.0	55.8	High
MALAPPURAM	Changaramkulam [6585]	KAKKIDIKKAL	81.0	0.0	55.3	25.7	31.7	Medium
MALAPPURAM	Changaramkulam [6585]	KAKKIDIPURAM	129.0	0.0	32.2	96.8	75.1	Very High
MALAPPURAM	Changaramkulam [6585]	KALACHAL	81.0	0.0	3.3	77.7	95.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Changaramkulam [6585]	KALADITHARA	129.0	10.0	42.3	76.7	59.5	High
MALAPPURAM	Changaramkulam [6585]	KALAPPOOTTUKANDAM	81.0	13.0	28.0	40.0	49.4	Medium
MALAPPURAM	Changaramkulam [6585]	KALARIKKAL AMBALAM	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Changaramkulam [6585]	KALLOORMA	202.0	14.3	88.0	99.7	49.4	Medium
MALAPPURAM	Changaramkulam [6585]	KANJIYOOR	129.0	0.0	65.9	63.1	48.9	Medium
MALAPPURAM	Changaramkulam [6585]	KANNANKAVE	129.0	11.0	85.0	33.0	25.6	Medium
MALAPPURAM	Changaramkulam [6585]	KAREKKAT TEMPLE	81.0	6.0	25.0	50.0	61.7	High
MALAPPURAM	Changaramkulam [6585]	KARUNAKARAN KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	KATTUPARAMBA	81.0	6.0	26.0	49.0	60.5	High
MALAPPURAM	Changaramkulam [6585]	KILIYANKUNNU	81.0	5.0	29.0	47.0	58.0	High
MALAPPURAM	Changaramkulam [6585]	KOCHIRIKUND KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	KODAKATTUKUNNU	81.0	0.0	27.3	53.7	66.3	High
MALAPPURAM	Changaramkulam [6585]	KOLANCHERY PADAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	KOLOTHU PADAM KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	KOOLAN KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	KOOLAN MOOPPILAKKAD MASJID	81.0	0.0	28.3	52.7	65.1	High
MALAPPURAM	Changaramkulam [6585]	KPR COMPLEX	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Changaramkulam [6585]	KRISHNA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	KUDUMBASREE	81.0	0.0	44.0	37.0	45.7	Medium
MALAPPURAM	Changaramkulam [6585]	KUNJO ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	KUPPIVELLAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	KURIKKAD	81.0	0.0	12.3	68.7	84.8	Very High
MALAPPURAM	Changaramkulam [6585]	KUZHAPULLI	81.0	5.0	35.0	41.0	50.6	High
MALAPPURAM	Changaramkulam [6585]	L P S THARIYAM	81.0	0.0	25.2	55.8	68.9	High
MALAPPURAM	Changaramkulam [6585]	MAKKALI	81.0	3.0	32.3	45.7	56.4	High
MALAPPURAM	Changaramkulam [6585]	MAMANIPPADI	129.0	0.0	53.4	75.6	58.6	High
MALAPPURAM	Changaramkulam [6585]	MANAKADAVU	81.0	5.0	18.0	58.0	71.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Changaramkulam [6585]	MANAPADY	81.0	0.0	34.0	47.0	58.0	High
MALAPPURAM	Changaramkulam [6585]	MANCHADI	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Changaramkulam [6585]	MANGLODHAYAM	81.0	0.0	9.0	72.0	88.9	Very High
MALAPPURAM	Changaramkulam [6585]	MANTHADAM	81.0	0.0	54.2	26.8	33.1	Medium
MALAPPURAM	Changaramkulam [6585]	MARATH	81.0	0.0	11.3	69.7	86.0	Very High
MALAPPURAM	Changaramkulam [6585]	MATTAM	129.0	3.0	13.0	113.0	87.6	Very High
MALAPPURAM	Changaramkulam [6585]	MERIBA	81.0	0.0	27.9	53.1	65.6	High
MALAPPURAM	Changaramkulam [6585]	MG NAIR	129.0	0.0	17.0	112.0	86.8	Very High
MALAPPURAM	Changaramkulam [6585]	MIDCOFF	81.0	0.0	45.0	36.0	44.4	Medium
MALAPPURAM	Changaramkulam [6585]	MOOCHIKADAVU KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	MOSCO	81.0	3.0	30.8	47.2	58.3	High
MALAPPURAM	Changaramkulam [6585]	MOTHER	81.0	0.0	9.7	71.3	88.0	Very High
MALAPPURAM	Changaramkulam [6585]	MUKKILAPEEDIKA	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Changaramkulam [6585]	MUTHOOR	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Changaramkulam [6585]	MUTHUKAD PALLY	81.0	0.0	16.9	64.1	79.1	Very High
MALAPPURAM	Changaramkulam [6585]	MV PUMP	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	N M WOOD	81.0	0.0	19.6	61.4	75.8	Very High
MALAPPURAM	Changaramkulam [6585]	NANNAMMUKKU	129.0	0.0	56.0	73.0	56.6	High
MALAPPURAM	Changaramkulam [6585]	NARANIPUZHA	121.0	0.0	31.3	89.7	74.1	High
MALAPPURAM	Changaramkulam [6585]	NARANIPUZHA BRIDEGE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	NARANIPUZHA THEKKUMURI	129.0	6.3	59.9	62.8	48.7	Medium
MALAPPURAM	Changaramkulam [6585]	NASNAZ	129.0	0.0	26.0	103.0	79.8	Very High
MALAPPURAM	Changaramkulam [6585]	NEELA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	NEELA-160	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	NILAMPATHI	81.0	5.0	13.0	63.0	77.8	Very High
MALAPPURAM	Changaramkulam [6585]	PADINJATTUMMURI	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Changaramkulam [6585]	PAKARAVOOR	129.0	0.0	72.0	57.0	44.2	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Changaramkulam [6585]	PALLIKARA LP SCHOOL	129.0	0.0	44.3	84.7	65.7	High
MALAPPURAM	Changaramkulam [6585]	PALLIKKARA THEKKUMURII	81.0	3.0	8.0	70.0	86.4	Very High
MALAPPURAM	Changaramkulam [6585]	PANCHAYATH COMPLEX	129.0	0.0	8.2	120.8	93.7	Very High
MALAPPURAM	Changaramkulam [6585]	PANTHAMKUNNU	81.0	0.0	21.0	60.0	74.1	High
MALAPPURAM	Changaramkulam [6585]	PANTHA VOOR LI	129.0	5.0	37.2	86.8	67.3	High
MALAPPURAM	Changaramkulam [6585]	PAPER GLASS-100	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	PARAKKAL	129.0	3.0	37.3	88.7	68.8	High
MALAPPURAM	Changaramkulam [6585]	PATTERY	129.0	0.0	45.6	83.4	64.7	High
MALAPPURAM	Changaramkulam [6585]	PERMUKKU ROAD	81.0	5.0	19.3	56.7	70.0	High
MALAPPURAM	Changaramkulam [6585]	PERUMBAL	81.0	8.0	43.0	30.0	37.0	Medium
MALAPPURAM	Changaramkulam [6585]	PERUMUKKU	81.0	2.0	50.3	28.7	35.4	Medium
MALAPPURAM	Changaramkulam [6585]	PIDAVANNURE	81.0	9.0	16.0	56.0	69.1	High
MALAPPURAM	Changaramkulam [6585]	POLICE STATION	202.0	0.0	140.0	62.0	30.7	Medium
MALAPPURAM	Changaramkulam [6585]	POOCHAPPADY	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Changaramkulam [6585]	POST OFFICE	81.0	0.0	29.3	51.7	63.8	High
MALAPPURAM	Changaramkulam [6585]	PULINCHODU	129.0	3.0	39.2	86.8	67.3	High
MALAPPURAM	Changaramkulam [6585]	PULLOONIYIL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	PUNJAB NATONAL BANK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	PUNNAKKAL	81.0	0.0	50.5	30.5	37.7	Medium
MALAPPURAM	Changaramkulam [6585]	PUTHUMANAKADAVU KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	RGGVY-100	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Changaramkulam [6585]	S R B	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	SABANA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	SABEENA	129.0	0.0	54.0	75.0	58.1	High
MALAPPURAM	Changaramkulam [6585]	SAINABA MILL	81.0	0.0	75.3	5.7	7.0	Very Low
MALAPPURAM	Changaramkulam [6585]	SANA	81.0	0.0	4.8	76.2	94.1	Very High
MALAPPURAM	Changaramkulam [6585]	SANJAY	81.0	0.0	13.0	68.0	84.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Changaramkulam [6585]	SIVA TEMBLE	81.0	0.0	39.6	41.4	51.1	High
MALAPPURAM	Changaramkulam [6585]	SRAYIKADAV	81.0	0.0	90.0	0.0	0.0	Very Low
MALAPPURAM	Changaramkulam [6585]	TACHANKADU	81.0	0.0	45.2	35.8	44.2	Medium
MALAPPURAM	Changaramkulam [6585]	TATA MOTORS	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	THACHUPARAMBU	81.0	0.0	80.3	0.7	0.9	Very Low
MALAPPURAM	Changaramkulam [6585]	THALAPPIL	202.0	0.0	34.0	168.0	83.2	Very High
MALAPPURAM	Changaramkulam [6585]	THARIYAM JAWAN	81.0	0.0	26.0	55.0	67.9	High
MALAPPURAM	Changaramkulam [6585]	THARIYAM PANCHAYATHPADI	81.0	10.0	36.0	35.0	43.2	Medium
MALAPPURAM	Changaramkulam [6585]	THATTANPADY	81.0	0.0	48.4	32.6	40.2	Medium
MALAPPURAM	Changaramkulam [6585]	THEKKEMUKKU	129.0	0.0	54.0	75.0	58.1	High
MALAPPURAM	Changaramkulam [6585]	THEKKUM THAZHAM	81.0	9.6	44.0	27.4	33.8	Medium
MALAPPURAM	Changaramkulam [6585]	THENGILAPALLI	81.0	0.0	42.0	39.0	48.1	Medium
MALAPPURAM	Changaramkulam [6585]	THENGILAPPADAM	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Changaramkulam [6585]	TIPPUNAGAR	129.0	5.0	40.0	84.0	65.1	High
MALAPPURAM	Changaramkulam [6585]	TUBE WELL	81.0	0.0	60.0	21.0	25.9	Medium
MALAPPURAM	Changaramkulam [6585]	UDINIPARAMBA	129.0	0.0	20.1	108.9	84.4	Very High
MALAPPURAM	Changaramkulam [6585]	VADAKKUMMURI	129.0	0.0	11.0	118.0	91.5	Very High
MALAPPURAM	Changaramkulam [6585]	VAKKATTE AMBALAM	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Changaramkulam [6585]	VAKKATTUPARAMBU	81.0	8.6	43.3	29.1	36.0	Medium
MALAPPURAM	Changaramkulam [6585]	VAKKETH MILL	129.0	8.0	65.5	55.5	43.0	Medium
MALAPPURAM	Changaramkulam [6585]	VARIYARMOOLA	81.0	0.0	27.0	54.0	66.7	High
MALAPPURAM	Changaramkulam [6585]	VATTATHOOR	129.0	0.0	60.0	69.0	53.5	High
MALAPPURAM	Changaramkulam [6585]	VELATTU AMBALAM	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Changaramkulam [6585]	SEMBUZH KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	VVK AUDITORIUM	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Changaramkulam [6585]	WHITE ROSE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Changaramkulam [6585]	YOUTH FUL	81.0	0.0	14.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chattiparamba [6708]	ABH ROAD	81.0	0.0	35.0	46.0	56.8	High
MALAPPURAM	Chattiparamba [6708]	AKKAPARAMBA	81.0	0.0	45.5	35.5	43.8	Medium
MALAPPURAM	Chattiparamba [6708]	AKKAPARAMBA MADRASSA	81.0	0.0	37.0	44.0	54.3	High
MALAPPURAM	Chattiparamba [6708]	AKKAPARAMBA WATER TANK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	ALPATTAKULAMBA	129.0	0.0	27.5	101.5	78.7	Very High
MALAPPURAM	Chattiparamba [6708]	ALPATTAKULAMBA PALLI	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Chattiparamba [6708]	AMBALAPALLIYALI	81.0	0.0	21.0	60.0	74.1	High
MALAPPURAM	Chattiparamba [6708]	AMBALATHARA	81.0	10.0	41.0	30.0	37.0	Medium
MALAPPURAM	Chattiparamba [6708]	ARAKKALPADI	81.0	0.0	26.0	55.0	67.9	High
MALAPPURAM	Chattiparamba [6708]	AYANIKUTHU CHALIL	81.0	0.0	26.0	55.0	67.9	High
MALAPPURAM	Chattiparamba [6708]	BAPCO 2 MILL	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	BAPCO CHANJAL	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	BRANCH MADRASSA	81.0	2.0	15.0	64.0	79.0	Very High
MALAPPURAM	Chattiparamba [6708]	BRANTHAN KAVU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	CAPITAL MALL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	CHALAD	81.0	0.0	9.7	71.3	88.0	Very High
MALAPPURAM	Chattiparamba [6708]	CHANJAL	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Chattiparamba [6708]	CHANJAL RUBBER	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Chattiparamba [6708]	CHAPPANANGADI KAIRALI	81.0	5.0	36.0	40.0	49.4	Medium
MALAPPURAM	Chattiparamba [6708]	CHAPPANANGADI KOORIYAD ROAD	129.0	5.0	40.8	83.2	64.5	High
MALAPPURAM	Chattiparamba [6708]	CHAPPANANGADI PANCHAYATH	81.0	0.0	59.1	21.9	27.0	Medium
MALAPPURAM	Chattiparamba [6708]	CHATTIPARAMBA MANTHI	129.0	0.0	40.0	89.0	69.0	High
MALAPPURAM	Chattiparamba [6708]	CHATTIPARAMBA MARKET	81.0	0.0	35.0	46.0	56.8	High
MALAPPURAM	Chattiparamba [6708]	CHATTIPARAMBA MRPL	81.0	0.0	12.0	69.0	85.2	Very High
MALAPPURAM	Chattiparamba [6708]	CHATTIPARAMBA PUMP	81.0	5.0	23.0	53.0	65.4	High
MALAPPURAM	Chattiparamba [6708]	CHATTIPARAMBA TOWN	129.0	0.0	10.0	119.0	92.2	Very High
MALAPPURAM	Chattiparamba [6708]	CHERUKULAMBA EAST	81.0	0.0	59.0	22.0	27.2	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chattiparamba [6708]	CHERUKULAMBA WEST	81.0	0.0	79.0	2.0	2.5	Very Low
MALAPPURAM	Chattiparamba [6708]	CHOONUR CHIRAKKAL	81.0	0.0	37.0	44.0	54.3	High
MALAPPURAM	Chattiparamba [6708]	CHORAKKAVU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	CLASSIC INTERLOCK	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	CM FOODS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	DEVALAPPADY	81.0	0.0	28.8	52.2	64.4	High
MALAPPURAM	Chattiparamba [6708]	DHANYA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	EAST KODUR	202.0	3.0	170.8	28.1	13.9	Low
MALAPPURAM	Chattiparamba [6708]	EAST KODUR PHC	81.0	0.0	80.9	0.1	0.2	Very Low
MALAPPURAM	Chattiparamba [6708]	EDATTUPARA	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Chattiparamba [6708]	EDUCARE HOSTEL	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	EXCEL OIL	129.0	0.0	7.0	122.0	94.6	Very High
MALAPPURAM	Chattiparamba [6708]	FIBA MILL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	HITECH 1	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	HITECH 2	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	HOB PACK	129.0	0.0	80.0	49.0	38.0	Medium
MALAPPURAM	Chattiparamba [6708]	HOB TECH MARAVATTAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	INDUSTRIAL ESTATE	202.0	3.0	37.0	162.0	80.2	Very High
MALAPPURAM	Chattiparamba [6708]	KACHADIPPARA	81.0	0.0	26.3	54.7	67.5	High
MALAPPURAM	Chattiparamba [6708]	KADARAM	81.0	2.0	43.0	36.0	44.4	Medium
MALAPPURAM	Chattiparamba [6708]	KALAPPA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	KAMCO 2	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	KAMCO-1	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	KARIMBANANOKKU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	KATTUNGALCHOLA	129.0	0.0	13.5	115.5	89.5	Very High
MALAPPURAM	Chattiparamba [6708]	KIZHAKKETHALA	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Chattiparamba [6708]	KLAKKUMPURAM	81.0	0.0	42.0	39.0	48.1	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chattiparamba [6708]	KODUR CO-OPERATIVE BANK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	KOLKALAM	81.0	0.0	52.7	28.3	34.9	Medium
MALAPPURAM	Chattiparamba [6708]	KOLKALAM TOWER CHERUPARAMBA	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Chattiparamba [6708]	KOTTAPPURAM	81.0	0.0	19.7	61.3	75.6	Very High
MALAPPURAM	Chattiparamba [6708]	KUNHALAN	81.0	0.0	12.0	69.0	85.2	Very High
MALAPPURAM	Chattiparamba [6708]	KUNNAMKUTTY	81.0	3.0	18.0	60.0	74.1	High
MALAPPURAM	Chattiparamba [6708]	KURUKUNDU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	KURUPPUMPADI	129.0	18.0	37.3	73.7	57.1	High
MALAPPURAM	Chattiparamba [6708]	LAKSHAM VEEDU COLONY	81.0	3.0	19.1	58.9	72.7	High
MALAPPURAM	Chattiparamba [6708]	MALAYIL CH FOODS	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	MALAYIL CHOLASSERI FOODS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	MALAYIL NO 1 FOOD CITY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	MALAYIL NO 2 FOOD CITY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	MALAYIL NO 3 FOOD PARK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	MANNAZHI	81.0	0.0	26.0	55.0	67.9	High
MALAPPURAM	Chattiparamba [6708]	MARAVATTAM AYURVEDIC PHARMACY	324.0	0.0	0.0	324.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	MEA	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Chattiparamba [6708]	MELEPARAMBU	81.0	0.0	32.9	48.1	59.4	High
MALAPPURAM	Chattiparamba [6708]	MIYA FOOD	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	MOULANA	81.0	0.0	29.0	52.0	64.2	High
MALAPPURAM	Chattiparamba [6708]	MUNDAKKOD	81.0	3.0	39.0	39.0	48.1	Medium
MALAPPURAM	Chattiparamba [6708]	MUNDAKKOD TOWER	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Chattiparamba [6708]	MUNDAKKOD VALIYAPARAMBA	81.0	5.0	25.0	51.0	63.0	High
MALAPPURAM	Chattiparamba [6708]	MUNDAKKOD WATER TANK	81.0	13.0	24.0	44.0	54.3	High
MALAPPURAM	Chattiparamba [6708]	MUNDIYANTHARA	81.0	20.0	19.0	42.0	51.9	High
MALAPPURAM	Chattiparamba [6708]	MUNDIYANTHARA SHARJAH	81.0	0.0	18.0	63.0	77.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chattiparamba [6708]	NAIRPADI	81.0	0.0	59.3	21.7	26.8	Medium
MALAPPURAM	Chattiparamba [6708]	NARIYANKUNNU	81.0	0.0	12.0	69.0	85.2	Very High
MALAPPURAM	Chattiparamba [6708]	NAYADIKUNNU	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Chattiparamba [6708]	NEETTICHIRA	81.0	5.0	28.0	48.0	59.3	High
MALAPPURAM	Chattiparamba [6708]	NELLOLI NIRAPPIL	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Chattiparamba [6708]	NELLOLIPARAMBA	81.0	0.0	40.0	41.0	50.6	High
MALAPPURAM	Chattiparamba [6708]	NERUPARAMBA	81.0	0.0	60.2	20.8	25.6	Medium
MALAPPURAM	Chattiparamba [6708]	NEX FIBRE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	NJATTUKETTI	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Chattiparamba [6708]	NJVALAKKUNDU	81.0	5.0	8.0	68.0	84.0	Very High
MALAPPURAM	Chattiparamba [6708]	OTTATHARA	129.0	3.0	27.3	98.7	76.5	Very High
MALAPPURAM	Chattiparamba [6708]	PANTHODI MILL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	PAPER PLATE	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Chattiparamba [6708]	PAPPAYI	81.0	5.0	0.0	76.0	93.8	Very High
MALAPPURAM	Chattiparamba [6708]	PARANKIMOOCHIKKAL	202.0	0.0	13.0	189.0	93.6	Very High
MALAPPURAM	Chattiparamba [6708]	PARANKIMOOCHIKKAL JAWAN	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	PARANKIMOOCHIKKAL RAJANPADI	81.0	5.0	6.5	69.5	85.8	Very High
MALAPPURAM	Chattiparamba [6708]	PARANKIMOOCHIKKAL TOWER	81.0	0.0	17.8	63.2	78.0	Very High
MALAPPURAM	Chattiparamba [6708]	PARAYARANGADI	81.0	0.0	77.9	3.1	3.8	Very Low
MALAPPURAM	Chattiparamba [6708]	PARENGAL COLONY	81.0	5.0	41.0	35.0	43.2	Medium
MALAPPURAM	Chattiparamba [6708]	PATHAYAKKALLU	129.0	0.0	48.0	81.0	62.8	High
MALAPPURAM	Chattiparamba [6708]	PATTUPARA	81.0	2.0	19.0	60.0	74.1	High
MALAPPURAM	Chattiparamba [6708]	PAZHAMKULAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	PETTA	81.0	4.5	26.0	50.5	62.3	High
MALAPPURAM	Chattiparamba [6708]	PONNARAMPALLIYALI	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Chattiparamba [6708]	POOKKADU	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Chattiparamba [6708]	POOKKADU RGGVY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chattiparamba [6708]	POORAPARAMBA	81.0	0.0	64.7	16.3	20.1	Low
MALAPPURAM	Chattiparamba [6708]	PULIYATTUKULAM	81.0	0.0	29.0	52.0	64.2	High
MALAPPURAM	Chattiparamba [6708]	RABEEHULLA	81.0	0.0	60.0	21.0	25.9	Medium
MALAPPURAM	Chattiparamba [6708]	RAYIPARAMBU	81.0	8.0	0.0	73.0	90.1	Very High
MALAPPURAM	Chattiparamba [6708]	SANA TOWER KURUPPUMPADI	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	SANTHIGRAMAM	81.0	0.0	10.0	71.0	87.6	Very High
MALAPPURAM	Chattiparamba [6708]	SCHOOL PARAMBA	81.0	0.0	42.0	39.0	48.1	Medium
MALAPPURAM	Chattiparamba [6708]	SEAOUS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	SHAMSUDHEEN OLAKARA	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Chattiparamba [6708]	TELEPHONE EXCHANGE	129.0	0.0	27.0	102.0	79.1	Very High
MALAPPURAM	Chattiparamba [6708]	THANIKKAL	81.0	5.0	52.3	23.7	29.3	Medium
MALAPPURAM	Chattiparamba [6708]	THANIKKAL SHAPPINPADI	81.0	3.0	52.2	25.8	31.9	Medium
MALAPPURAM	Chattiparamba [6708]	THANNEERPARAMB	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	THEKKEKARA COLONY	81.0	5.0	24.5	51.5	63.6	High
MALAPPURAM	Chattiparamba [6708]	THEKKUMKULAMBA	81.0	0.0	39.0	42.0	51.9	High
MALAPPURAM	Chattiparamba [6708]	THOTTAPPAYA	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Chattiparamba [6708]	TIPTOP 1	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	TIPTOP 2	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	VALIYAD	129.0	5.0	37.0	87.0	67.4	High
MALAPPURAM	Chattiparamba [6708]	VALIYAD AUDITORIUM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	VATTALUR CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chattiparamba [6708]	VATTALUR MELKULAMBA	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Chattiparamba [6708]	VATTALUR TUBEWELL	81.0	0.0	54.8	26.2	32.3	Medium
MALAPPURAM	Chattiparamba [6708]	VATTAPARAMBA	81.0	5.0	22.0	54.0	66.7	High
MALAPPURAM	Chattiparamba [6708]	VATTAPARAMBA MICHABHOOMI	81.0	0.0	36.3	44.7	55.1	High
MALAPPURAM	Chattiparamba [6708]	VATTAPARAMBA TOWN	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Chattiparamba [6708]	VK METALS CHANJAL	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chattiparamba [6708]	VL SUPER MARKET	81.0	30.0	49.0	2.0	2.5	Very Low
MALAPPURAM	Chelari [6577]	A T K PARUTHIKKODE	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chelari [6577]	ADATTU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	ADIYODI ROAD	81.0	0.0	46.0	35.0	43.2	Medium
MALAPPURAM	Chelari [6577]	AL - AMEEN	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	AL-ZAIM COLDSTORAGE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	ALBA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	ALIVE	81.0	5.0	15.0	61.0	75.3	Very High
MALAPPURAM	Chelari [6577]	ALLAN TAPIOCA	81.0	0.0	33.0	48.0	59.3	High
MALAPPURAM	Chelari [6577]	ALPHINE	324.0	0.0	0.0	324.0	100.0	Very High
MALAPPURAM	Chelari [6577]	ALUMINIUM	81.0	0.0	42.7	38.3	47.3	Medium
MALAPPURAM	Chelari [6577]	ALUNGAL	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Chelari [6577]	AMBALAPPADI	81.0	0.0	62.0	19.0	23.5	Low
MALAPPURAM	Chelari [6577]	AMBALAVALAVU	81.0	0.0	23.5	57.5	71.0	High
MALAPPURAM	Chelari [6577]	AMINA BRICKS	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Chelari [6577]	ANKAPPARAMBA	81.0	5.0	41.9	34.1	42.1	Medium
MALAPPURAM	Chelari [6577]	AREEPARAMBU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	AYYAPPANKAVU	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Chelari [6577]	BHM PARUTHIKKODE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	CASTLE BRICKS PARUTHIKKODE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	CHACKALAKKAL PACKAGE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	CHALIYIL	81.0	0.0	7.0	74.0	91.4	Very High
MALAPPURAM	Chelari [6577]	CHANDRA SANTHI	129.0	0.0	10.9	118.0	91.5	Very High
MALAPPURAM	Chelari [6577]	CHAPPA PARA	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Chelari [6577]	CHATHRATHODI	81.0	0.0	79.0	2.0	2.5	Very Low
MALAPPURAM	Chelari [6577]	CHEENADATH COLONY	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Chelari [6577]	CHELARI SHOPPING COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chelari [6577]	CHELLOTUPARAMBE	81.0	3.0	13.0	65.0	80.2	Very High
MALAPPURAM	Chelari [6577]	CHENAKKAL	81.0	6.5	49.0	25.5	31.5	Medium
MALAPPURAM	Chelari [6577]	CHENAKKANDI	81.0	5.0	21.0	55.0	67.9	High
MALAPPURAM	Chelari [6577]	CHETTIERMAD PUMP	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Chelari [6577]	CHETTIYARMADU	81.0	0.0	41.8	39.2	48.5	Medium
MALAPPURAM	Chelari [6577]	CHOICE FAN	81.0	0.0	34.0	47.0	58.0	High
MALAPPURAM	Chelari [6577]	CHOLAKKARAMADU	81.0	3.0	20.0	58.0	71.6	High
MALAPPURAM	Chelari [6577]	CK NAGER	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Chelari [6577]	DEEPTHI	81.0	5.0	62.4	13.6	16.8	Low
MALAPPURAM	Chelari [6577]	DEVATHIYAL TOWER	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Chelari [6577]	DEVATHIYAL TOWN	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Chelari [6577]	DIGI PACK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	DMS HOSPITAL	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chelari [6577]	DUBAI TOWER	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chelari [6577]	EASY PACK U K C	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chelari [6577]	ELAMPILASERI-2	81.0	12.0	18.0	51.0	63.0	High
MALAPPURAM	Chelari [6577]	ELAMPILASSERI SCHOOL	81.0	0.0	81.0	0.0	0.0	Very Low
MALAPPURAM	Chelari [6577]	ENGINEERING COLLEGE	129.0	13.0	88.0	28.0	21.7	Low
MALAPPURAM	Chelari [6577]	EVERGREEN APARTMENT	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chelari [6577]	FAROOKHABAD	81.0	0.0	26.0	55.0	67.9	High
MALAPPURAM	Chelari [6577]	FORMOSA	202.0	5.0	17.0	180.0	89.1	Very High
MALAPPURAM	Chelari [6577]	FORZZA	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chelari [6577]	FRAGNOSS CHAPPALS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	GURUMANDHIRAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	INDUS TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	JAWANS NAGAR	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Chelari [6577]	JRS RESTAURENT	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chelari [6577]	K W A	81.0	5.0	24.0	52.0	64.2	High
MALAPPURAM	Chelari [6577]	KADAKKATTUPARA	81.0	5.0	45.0	31.0	38.3	Medium
MALAPPURAM	Chelari [6577]	KAITHON	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KAKKANCHERI TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KAKKATHADAM	129.0	3.0	88.3	37.7	29.2	Medium
MALAPPURAM	Chelari [6577]	KANDAAYIPPADAM	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Chelari [6577]	KANIVU	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Chelari [6577]	KARIGAMKULAM	81.0	0.0	14.2	66.8	82.4	Very High
MALAPPURAM	Chelari [6577]	KARUVANDI	81.0	10.0	14.0	57.0	70.4	High
MALAPPURAM	Chelari [6577]	KELASSAM THODI	81.0	0.0	46.0	35.0	43.2	Medium
MALAPPURAM	Chelari [6577]	KIFRA MALABAR GOLD	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KINFRA NEW-IT SDF TFR	648.0	75.0	0.0	573.0	88.4	Very High
MALAPPURAM	Chelari [6577]	KINFRA-CAWIN ELETRIK	405.0	0.0	35.0	370.0	91.4	Very High
MALAPPURAM	Chelari [6577]	KINFRA-FOSTER BREAD	405.0	0.0	0.0	405.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KINFRA-IT-HIGH RISE BUILDING	510.0	0.0	0.0	510.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KINFRA-JOY	405.0	0.0	0.0	405.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KINFRA-MEBRAN	405.0	0.0	0.0	405.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KINFRA-PARK CENTRE	405.0	0.0	0.0	405.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KINFRA-POLY FLEX	405.0	0.0	0.0	405.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KINFRA-SATHYA SAI	405.0	0.0	0.0	405.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KINRFA W-T-P	405.0	0.0	0.0	405.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KINRFA-COCHIN BAKERY	405.0	0.0	25.0	380.0	93.8	Very High
MALAPPURAM	Chelari [6577]	KODASERIPOTTA	81.0	0.0	56.0	25.0	30.9	Medium
MALAPPURAM	Chelari [6577]	KOHINOOR	129.0	3.0	37.9	88.1	68.3	High
MALAPPURAM	Chelari [6577]	KOHINOOR TEMPLE	81.0	3.0	52.2	25.8	31.8	Medium
MALAPPURAM	Chelari [6577]	KOLAKKATUCHALY	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Chelari [6577]	KOLAKKUTH	81.0	3.0	9.0	69.0	85.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chelari [6577]	KOMARAPPADI	129.0	0.0	127.6	1.4	1.1	Very Low
MALAPPURAM	Chelari [6577]	KOONOLMADU	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Chelari [6577]	KOONOLMADU HC	81.0	0.0	28.5	52.5	64.8	High
MALAPPURAM	Chelari [6577]	KOTHERI	81.0	2.0	34.2	44.8	55.3	High
MALAPPURAM	Chelari [6577]	KOYAPPA	81.0	3.0	39.0	39.0	48.1	Medium
MALAPPURAM	Chelari [6577]	KOYAPPA TEMPLE	81.0	0.0	80.4	0.6	0.7	Very Low
MALAPPURAM	Chelari [6577]	KOZHIPARAMBATHMAD	81.0	0.0	54.0	27.0	33.3	Medium
MALAPPURAM	Chelari [6577]	KOZHISSEIRIMADU	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Chelari [6577]	KR FOODS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	KUDUKKIYIL MADU	81.0	5.0	27.7	48.3	59.6	High
MALAPPURAM	Chelari [6577]	KUTTILAPARAMBE	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Chelari [6577]	LAKSHAMVEEDU	81.0	0.0	41.0	40.0	49.4	Medium
MALAPPURAM	Chelari [6577]	LAMIRA	202.0	3.0	13.0	186.0	92.1	Very High
MALAPPURAM	Chelari [6577]	MAILANCHIVALAVU	202.0	10.0	65.2	126.8	62.8	High
MALAPPURAM	Chelari [6577]	MANAKKATTU TEMPLE	81.0	0.0	22.9	58.1	71.8	High
MALAPPURAM	Chelari [6577]	MANEEKASHA	81.0	6.0	27.0	48.0	59.3	High
MALAPPURAM	Chelari [6577]	MELERIKKAVU	81.0	0.0	40.0	41.0	50.6	High
MALAPPURAM	Chelari [6577]	MENGOLIMADU	81.0	5.0	28.0	48.0	59.3	High
MALAPPURAM	Chelari [6577]	MMAP CHELARI	129.0	0.0	25.0	104.0	80.6	Very High
MALAPPURAM	Chelari [6577]	MOSCOPARA	81.0	0.0	41.0	40.0	49.4	Medium
MALAPPURAM	Chelari [6577]	MUDHRA	81.0	10.0	54.5	16.5	20.4	Low
MALAPPURAM	Chelari [6577]	NCC	81.0	0.0	32.0	49.0	60.5	High
MALAPPURAM	Chelari [6577]	NEDUNGOTTURMADU	81.0	0.0	39.3	41.7	51.5	High
MALAPPURAM	Chelari [6577]	NEEROLPALAM SOUTH	81.0	3.0	41.7	36.3	44.8	Medium
MALAPPURAM	Chelari [6577]	NEEROLPALAM TOWN	129.0	0.0	21.0	108.0	83.7	Very High
MALAPPURAM	Chelari [6577]	NETHAJI ROAD	81.0	2.5	78.4	0.1	0.1	Very Low
MALAPPURAM	Chelari [6577]	NHAI	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chelari [6577]	OFFICE-KSEB CHELARI	20.0	0.0	4.0	16.0	80.0	Very High
MALAPPURAM	Chelari [6577]	OLIPURAM-15	81.0	5.0	19.0	57.0	70.4	High
MALAPPURAM	Chelari [6577]	ORLANDO CITY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	OTTAKKALLU	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Chelari [6577]	PADATTALUNGAL	81.0	0.0	21.2	59.8	73.8	High
MALAPPURAM	Chelari [6577]	PAINGOTTOOR	81.0	6.0	61.6	13.4	16.5	Low
MALAPPURAM	Chelari [6577]	PAINGOTTOOR STADIUM	81.0	10.0	53.5	17.5	21.7	Low
MALAPPURAM	Chelari [6577]	PANAMBRA	129.0	5.0	66.0	58.0	44.9	Medium
MALAPPURAM	Chelari [6577]	PANAYAPPURAM	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Chelari [6577]	PARAMBATH KAVU	81.0	3.0	14.0	64.0	79.0	Very High
MALAPPURAM	Chelari [6577]	PARAMBILPEEDIKA	129.0	3.0	66.7	59.3	46.0	Medium
MALAPPURAM	Chelari [6577]	PARAMBILPEEDIKA BSNL	81.0	10.0	27.0	44.0	54.3	High
MALAPPURAM	Chelari [6577]	PARUTHIKKODE	81.0	3.0	6.0	72.0	88.9	Very High
MALAPPURAM	Chelari [6577]	PERUVALLOOR WOOD	81.0	0.0	17.1	63.9	78.9	Very High
MALAPPURAM	Chelari [6577]	PERUVALLOOR TILES	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Chelari [6577]	PEVUNGAL	81.0	5.0	16.2	59.8	73.8	High
MALAPPURAM	Chelari [6577]	PLEGER CHAPPALS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	POOTHAMKUTTI	81.0	0.0	54.8	26.2	32.3	Medium
MALAPPURAM	Chelari [6577]	PREMA	81.0	0.0	44.0	37.0	45.7	Medium
MALAPPURAM	Chelari [6577]	PUTHOOR PALLIKKAL	129.0	21.6	68.0	39.4	30.5	Medium
MALAPPURAM	Chelari [6577]	QUICK SMART WASH	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	ROTTIPEEDIKA	81.0	5.0	33.0	43.0	53.1	High
MALAPPURAM	Chelari [6577]	S I E I CHELARI	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Chelari [6577]	S-I E-I CHELARI	81.0	10.0	27.0	44.0	54.3	High
MALAPPURAM	Chelari [6577]	SAFIYACHAPPALS	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Chelari [6577]	SAMASTHA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	SANKARAMADU	81.0	0.0	11.0	70.0	86.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chelari [6577]	SANTHI NAGAR	81.0	3.0	69.0	9.0	11.1	Low
MALAPPURAM	Chelari [6577]	SATHYAPURAM	81.0	8.0	43.9	29.1	35.9	Medium
MALAPPURAM	Chelari [6577]	SBT	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Chelari [6577]	STANDARD BACKERY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	THADATHIL COLONEY	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Chelari [6577]	THANAL	129.0	0.0	47.0	82.0	63.6	High
MALAPPURAM	Chelari [6577]	THATTASSERIMADU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	THOTTUNGAL KANDY	81.0	0.0	64.0	17.0	21.0	Low
MALAPPURAM	Chelari [6577]	UKC	81.0	0.0	27.8	53.2	65.7	High
MALAPPURAM	Chelari [6577]	VADAKKEEL MADU	81.0	3.6	49.0	28.4	35.1	Medium
MALAPPURAM	Chelari [6577]	VARAPPARA	81.0	5.0	52.0	24.0	29.6	Medium
MALAPPURAM	Chelari [6577]	VARICHAL	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Chelari [6577]	VATTAPPARAMB	81.0	0.0	33.8	47.2	58.3	High
MALAPPURAM	Chelari [6577]	VENNAYOOR	81.0	0.0	41.0	40.0	49.4	Medium
MALAPPURAM	Chelari [6577]	VENNAYOOR MUSCOT PACKING	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Chelari [6577]	VOLENT CHAPPALS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chelari [6577]	VYKKATHUPADAM	81.0	10.0	32.5	38.5	47.5	Medium
MALAPPURAM	Chelari [6577]	YATHEEMKHANA	81.0	3.0	52.0	26.1	32.2	Medium
MALAPPURAM	Chungathara [6713]	4 CENT KAVUMPADAM NAGAR	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	A ONE FEEDS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	ALBA RICE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	ALIYAN BAZAR	129.0	11.0	87.0	31.0	24.0	Low
MALAPPURAM	Chungathara [6713]	AMBALAKUNNU	202.0	0.0	21.2	180.8	89.5	Very High
MALAPPURAM	Chungathara [6713]	AMBALAPOIL KADAVU	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	AMBALAPOIL POOCHAKUTH	20.0	0.0	3.0	17.0	85.0	Very High
MALAPPURAM	Chungathara [6713]	AMBEDKER	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Chungathara [6713]	ANDIKUNNU	129.0	8.0	60.1	60.9	47.2	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chungathara [6713]	BENNYKUNNU	81.0	3.0	43.2	34.8	43.0	Medium
MALAPPURAM	Chungathara [6713]	CHAKKUTTI IRRIGATION	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	CHATHANPUTHUVAI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	CHEERAKUZH TOWN	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Chungathara [6713]	CHORAKANDY PHC	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	CHORAKKANDI	81.0	0.0	22.5	58.5	72.2	High
MALAPPURAM	Chungathara [6713]	CHUNGATHARA COMMUNITY HALL	255.0	5.0	86.6	163.4	64.1	High
MALAPPURAM	Chungathara [6713]	CHUNGATHARA EXCHANGE	129.0	0.0	5.0	124.0	96.1	Very High
MALAPPURAM	Chungathara [6713]	CHUNGATHARA PALLIPPADI	202.0	0.0	52.4	149.6	74.1	High
MALAPPURAM	Chungathara [6713]	CHUNGATHARA SERVICE BANK	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	EDAMALA	129.0	0.0	51.0	78.0	60.5	High
MALAPPURAM	Chungathara [6713]	FARM-IRRIGATION	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	FOREST NURSERY	51.0	0.0	0.0	51.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	IDEAMUKKU	81.0	0.0	68.9	12.1	14.9	Low
MALAPPURAM	Chungathara [6713]	KADUVAKKUZHY LI-1	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	KADUVAKKUZHY LI-2	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	KAIPPINI KAVALA	81.0	3.0	28.0	50.0	61.7	High
MALAPPURAM	Chungathara [6713]	KAIPPINY KADAVU	129.0	3.0	17.0	109.0	84.5	Very High
MALAPPURAM	Chungathara [6713]	KALIKADAVU	81.0	13.0	35.0	33.0	40.7	Medium
MALAPPURAM	Chungathara [6713]	KARINKORAMANNA	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Chungathara [6713]	KATTICHIRA	81.0	13.0	34.0	34.0	42.0	Medium
MALAPPURAM	Chungathara [6713]	KAVALAMKODE	20.0	0.0	5.0	15.0	75.0	Very High
MALAPPURAM	Chungathara [6713]	KAVALAMKODE LI	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Chungathara [6713]	KODEERI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	KOLMPADAM	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Chungathara [6713]	KONNAMANNA	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Chungathara [6713]	KONNAMANNA SOCIETY	81.0	3.0	24.0	54.0	66.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chungathara [6713]	KOOTTAPPADI	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Chungathara [6713]	KOTTAMALA	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	KOTTAMALA MUNDAPADAM	20.0	0.0	3.0	17.0	85.0	Very High
MALAPPURAM	Chungathara [6713]	KOTTEPADAM HOSPITAL	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Chungathara [6713]	KOTTEPADAM KULAM	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Chungathara [6713]	KOTTEPPADAM-VARAKKODE	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Chungathara [6713]	KTDC	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	KUNJAAN PADI	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Chungathara [6713]	KUNNATH	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Chungathara [6713]	KUNNATHUPOTTY	81.0	3.0	30.0	48.0	59.3	High
MALAPPURAM	Chungathara [6713]	KUNNATHUPOTTY KADAVU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	KUTTIMUNDA	81.0	10.0	33.1	37.9	46.8	Medium
MALAPPURAM	Chungathara [6713]	KUTTIMUNDA KALAM JUNCTION	81.0	11.0	28.0	42.0	51.9	High
MALAPPURAM	Chungathara [6713]	MAMPOIL CHC ROAD	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Chungathara [6713]	MAMPOIL TOWN	81.0	0.0	41.8	39.2	48.4	Medium
MALAPPURAM	Chungathara [6713]	MANALI	81.0	3.0	19.0	59.0	72.8	High
MALAPPURAM	Chungathara [6713]	MANALIKURISU	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Chungathara [6713]	MANALY LI	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	MANGODE	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Chungathara [6713]	MANNATHI TEMPLE-AMBALAPOIL	81.0	9.0	8.0	64.0	79.0	Very High
MALAPPURAM	Chungathara [6713]	MATHA SCHOOL KUNNU	81.0	3.0	9.0	69.0	85.2	Very High
MALAPPURAM	Chungathara [6713]	MOHANLAL DP TR AMBALAPOIL	20.0	0.0	3.0	17.0	85.0	Very High
MALAPPURAM	Chungathara [6713]	MULANTHALA	81.0	3.0	20.0	58.0	71.6	High
MALAPPURAM	Chungathara [6713]	MUNDAPPADAM	81.0	4.0	30.0	47.0	58.0	High
MALAPPURAM	Chungathara [6713]	MUPPALIPOTTY	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Chungathara [6713]	MUPPINI L I	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	MUTTIKADAVU	81.0	0.0	9.0	72.0	88.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chungathara [6713]	MUTTIKADAVU COTTAGE	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Chungathara [6713]	MUTTIKADAVU FARM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	MUTTIKADAVU FARM OFFICE	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Chungathara [6713]	MYLADAMPOTTY	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Chungathara [6713]	NARAYAMPOIL	81.0	3.0	5.0	73.0	90.1	Very High
MALAPPURAM	Chungathara [6713]	NEELANJI	81.0	0.0	37.0	44.0	54.3	High
MALAPPURAM	Chungathara [6713]	NELLIPOIL	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Chungathara [6713]	PADINJATTUMPADAM	81.0	0.0	6.2	74.8	92.4	Very High
MALAPPURAM	Chungathara [6713]	PALAYAKKODE	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Chungathara [6713]	PALLIKUTH TOWN	81.0	0.0	33.0	48.0	59.3	High
MALAPPURAM	Chungathara [6713]	PALUNDA ESTATE	81.0	0.0	29.0	52.0	64.2	High
MALAPPURAM	Chungathara [6713]	PALUNDA TOWN	81.0	8.0	58.9	14.1	17.4	Low
MALAPPURAM	Chungathara [6713]	PANAMANNA	81.0	3.0	0.0	78.0	96.3	Very High
MALAPPURAM	Chungathara [6713]	PANAMANNA CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	PARTYKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Chungathara [6713]	PARTYKUNNU NAGAR	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	PATHIRIPPADAM	81.0	6.0	0.0	75.0	92.6	Very High
MALAPPURAM	Chungathara [6713]	PATHIRIPPADAM TOWN	81.0	14.0	43.0	24.0	29.6	Medium
MALAPPURAM	Chungathara [6713]	PERUMBILAD	81.0	5.0	15.0	61.0	75.3	Very High
MALAPPURAM	Chungathara [6713]	PERUMBILAD NAGAR	51.0	0.0	10.0	41.0	80.4	Very High
MALAPPURAM	Chungathara [6713]	PERUMPOILKUNNU	81.0	16.0	51.0	14.0	17.3	Low
MALAPPURAM	Chungathara [6713]	PERUMPOILKUNNU PAPPADAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	POOCHAKKUTH	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Chungathara [6713]	POOKOTTUMANNA	81.0	5.0	33.0	43.0	53.1	High
MALAPPURAM	Chungathara [6713]	POOKOTTUMANNA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	POOVATHIKADAVU LI	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	POOVATHIKKADAVU	81.0	3.0	16.0	62.0	76.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Chungathara [6713]	PULIMUNDA	81.0	8.0	46.0	27.0	33.3	Medium
MALAPPURAM	Chungathara [6713]	PUNNA COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	RAMACHAMPADAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Chungathara [6713]	THALANJI	81.0	3.0	40.0	38.0	46.9	Medium
MALAPPURAM	Chungathara [6713]	VALAYANPADI KATTICHIRA	81.0	0.0	11.5	69.5	85.8	Very High
MALAPPURAM	Edakkara [6544]	4 CENT COLONY PALEMAD	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Edakkara [6544]	A T V MENONPOTTY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	ABMS FOOD RICE KALASAGAR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	AC ELAVUMTHITTA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	ALI SQUARE	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	AMBALAM ROAD	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	ANGADIYIL COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	ARNNADAMPADAM	129.0	0.0	52.0	77.0	59.7	High
MALAPPURAM	Edakkara [6544]	ASHOKA BAR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	ATV MUSLIYARANGADY	129.0	3.0	23.0	103.0	79.8	Very High
MALAPPURAM	Edakkara [6544]	AYSHA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	AZIYA WEDDING CASTLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	BANGLAVIN KUNNU	81.0	3.0	24.0	54.0	66.7	High
MALAPPURAM	Edakkara [6544]	BARBER MUKKU	129.0	3.0	51.0	75.0	58.1	High
MALAPPURAM	Edakkara [6544]	BEAUTY MARK GOLD	81.0	3.0	47.0	31.0	38.3	Medium
MALAPPURAM	Edakkara [6544]	BEIROOT	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	BEVERAGE	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Edakkara [6544]	BHAGAVATHIMUNDA	81.0	0.0	14.3	66.7	82.3	Very High
MALAPPURAM	Edakkara [6544]	CHEMMANNUR GOLD	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	CHURULI	81.0	0.0	34.5	46.5	57.4	High
MALAPPURAM	Edakkara [6544]	CITY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	DOCTOR DIAGNOSTIC CENTRE	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edakkara [6544]	DUBAI MALL	202.0	0.0	9.9	192.1	95.1	Very High
MALAPPURAM	Edakkara [6544]	EDAKKARA BUYPASS	81.0	3.0	39.2	38.8	47.9	Medium
MALAPPURAM	Edakkara [6544]	EDAKKARA EXCHANGE	129.0	0.0	66.0	63.0	48.8	Medium
MALAPPURAM	Edakkara [6544]	EDAKKARA KURISHU	81.0	5.0	53.2	22.8	28.1	Medium
MALAPPURAM	Edakkara [6544]	EDAKKARA NEW BUS STAND	129.0	0.0	25.0	104.0	80.6	Very High
MALAPPURAM	Edakkara [6544]	EDAKKARA PALAM	129.0	8.0	25.3	95.7	74.2	High
MALAPPURAM	Edakkara [6544]	EDAKKARA PANCHAYATH COMPLEX	129.0	0.0	10.0	119.0	92.2	Very High
MALAPPURAM	Edakkara [6544]	ERANAD HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	ERATTAYAMKULAM	51.0	0.0	10.0	41.0	80.4	Very High
MALAPPURAM	Edakkara [6544]	GANDHI PRATHIMA	202.0	0.0	19.2	182.8	90.5	Very High
MALAPPURAM	Edakkara [6544]	GRACE TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	ILLIKKAD	81.0	3.0	23.0	55.0	67.9	High
MALAPPURAM	Edakkara [6544]	KAKKAPARATHA	81.0	11.0	27.0	43.0	53.1	High
MALAPPURAM	Edakkara [6544]	KALASAGAR PRESTIGE HUT	129.0	20.0	86.0	23.0	17.8	Low
MALAPPURAM	Edakkara [6544]	KAPPUNDA	81.0	11.0	42.0	28.0	34.6	Medium
MALAPPURAM	Edakkara [6544]	KARUNECHI	81.0	9.0	40.0	32.0	39.5	Medium
MALAPPURAM	Edakkara [6544]	KARUNECHI CHURCH	81.0	0.0	21.0	60.0	74.1	High
MALAPPURAM	Edakkara [6544]	KARUNECHI LF	81.0	0.0	26.3	54.7	67.5	High
MALAPPURAM	Edakkara [6544]	KATTADI L-I	129.0	0.0	5.0	124.0	96.1	Very High
MALAPPURAM	Edakkara [6544]	KATTICHIRA	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Edakkara [6544]	KORIPADI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	KOWKKAD	81.0	5.0	11.3	64.7	79.9	Very High
MALAPPURAM	Edakkara [6544]	KPM MALL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	KUNNUMMALPOTTY	81.0	3.0	38.0	40.0	49.4	Medium
MALAPPURAM	Edakkara [6544]	MANAKKAD	81.0	3.0	46.4	31.6	39.0	Medium
MALAPPURAM	Edakkara [6544]	MAYFAIR WOODS MUPPINI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edakkara [6544]	MENON POTTY	81.0	10.0	55.4	15.6	19.3	Low
MALAPPURAM	Edakkara [6544]	METRO BAZAR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	MILLUMPADI	129.0	0.0	79.0	50.0	38.8	Medium
MALAPPURAM	Edakkara [6544]	MOLLAPADI ATV PHARMA	81.0	3.0	6.0	72.0	88.9	Very High
MALAPPURAM	Edakkara [6544]	MUPPINI	129.0	0.0	19.5	109.5	84.9	Very High
MALAPPURAM	Edakkara [6544]	MUPPINI COLONY	81.0	0.0	33.8	47.2	58.3	High
MALAPPURAM	Edakkara [6544]	MURINGAMUNDA SCHOOLPADI	81.0	0.0	19.4	61.6	76.0	Very High
MALAPPURAM	Edakkara [6544]	MUSLIYARANGADI-1	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	NALLAMTHANNI	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Edakkara [6544]	NALLAMTHANNI AMBALAM ROAD	81.0	3.0	14.0	64.0	79.0	Very High
MALAPPURAM	Edakkara [6544]	NAROKAVU	81.0	21.0	23.2	36.8	45.4	Medium
MALAPPURAM	Edakkara [6544]	NAROKAVU CHURCH	81.0	0.0	9.0	72.0	88.9	Very High
MALAPPURAM	Edakkara [6544]	ONAKKAMANNA	81.0	8.0	20.4	52.6	64.9	High
MALAPPURAM	Edakkara [6544]	ONNAMPADI	81.0	3.0	25.4	52.6	64.9	High
MALAPPURAM	Edakkara [6544]	PALATHINGAL JUMA MASJID	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	PALEMAD AMBALAM	81.0	0.0	59.7	21.3	26.3	Medium
MALAPPURAM	Edakkara [6544]	PALEMAD POTTY	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Edakkara [6544]	PALEMAD SCHOOL PADI	81.0	13.0	39.0	29.0	35.8	Medium
MALAPPURAM	Edakkara [6544]	PALLIPPADY	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Edakkara [6544]	PAPPACHAN PADI	81.0	5.0	21.4	54.6	67.4	High
MALAPPURAM	Edakkara [6544]	PARLY	81.0	0.0	41.0	40.0	49.4	Medium
MALAPPURAM	Edakkara [6544]	PATHIRIPADAM SCHOOL	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Edakkara [6544]	PAYIMPADAM	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Edakkara [6544]	POTTANTHARIPPA	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Edakkara [6544]	PRESTIGE SOUK	81.0	0.0	25.6	55.4	68.4	High
MALAPPURAM	Edakkara [6544]	RELIANCE RETAIL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	ROYAL TOWER	129.0	0.0	10.0	119.0	92.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edakkara [6544]	S MALL EDAKKARA PALAM	324.0	0.0	0.0	324.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	SAMIKUNNU	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Edakkara [6544]	SANKARAMKULAM	81.0	27.0	52.3	1.7	2.1	Very Low
MALAPPURAM	Edakkara [6544]	SBI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	TATA MOTORS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edakkara [6544]	THAMBURANKUNNU	81.0	7.0	34.3	39.7	49.0	Medium
MALAPPURAM	Edakkara [6544]	THANALGRAMAM	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Edakkara [6544]	THANDUPARAPADI	81.0	0.0	37.3	43.7	54.0	High
MALAPPURAM	Edakkara [6544]	THANNIKADAVU NO-1	81.0	0.0	59.1	21.9	27.0	Medium
MALAPPURAM	Edakkara [6544]	THEYYETHUMPADAM	81.0	0.0	9.0	72.0	88.9	Very High
MALAPPURAM	Edakkara [6544]	THONIKKAI	81.0	8.0	41.0	32.0	39.5	Medium
MALAPPURAM	Edakkara [6544]	UNICHANDAM	81.0	3.0	8.4	69.6	85.9	Very High
MALAPPURAM	Edakkara [6544]	UNICHANDAM FOREST	81.0	3.0	0.0	78.0	96.3	Very High
MALAPPURAM	Edakkara [6544]	UTHIRAKULAM	81.0	8.0	17.4	55.6	68.6	High
MALAPPURAM	Edakkara [6544]	VELLARAMKUNNU	81.0	10.0	28.0	43.0	53.1	High
MALAPPURAM	Edakkara [6544]	WEST PERUMKULAM	129.0	0.0	32.4	96.6	74.9	High
MALAPPURAM	Edappal [6584]	A M TOWER	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Edappal [6584]	AIWA TOWER	129.0	5.0	5.0	119.0	92.2	Very High
MALAPPURAM	Edappal [6584]	AMBROZIA	405.0	0.0	18.0	387.0	95.6	Very High
MALAPPURAM	Edappal [6584]	AMSAKACHERY	129.0	0.0	34.9	94.1	72.9	High
MALAPPURAM	Edappal [6584]	AYILAKAD	129.0	11.0	118.0	0.0	0.0	Very Low
MALAPPURAM	Edappal [6584]	AYILAKKAD SCHOOL-100 KVA	81.0	5.0	30.0	46.0	56.8	High
MALAPPURAM	Edappal [6584]	AYYAPPANKAVU	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Edappal [6584]	B S N L	129.0	0.0	27.5	101.5	78.7	Very High
MALAPPURAM	Edappal [6584]	BAYAN COMPLEX-ZARA GOLD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	BLOCK OFFICE	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Edappal [6584]	C K TOWER	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edappal [6584]	CHAKKANATH	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Edappal [6584]	CHAMRAMANAM	129.0	13.0	63.6	52.4	40.6	Medium
MALAPPURAM	Edappal [6584]	CHANDAKUNNU	129.0	5.0	36.6	87.4	67.8	High
MALAPPURAM	Edappal [6584]	CHICKING	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Edappal [6584]	CHITTAZHIKUNNU	81.0	2.0	22.3	56.7	70.0	High
MALAPPURAM	Edappal [6584]	CHITTAZIKUNNU PALLI	81.0	5.0	30.3	45.7	56.4	High
MALAPPURAM	Edappal [6584]	CHOLAKUNNU	81.0	0.0	35.7	45.3	55.9	High
MALAPPURAM	Edappal [6584]	CHUNGAM NORTH	255.0	0.0	45.3	209.7	82.2	Very High
MALAPPURAM	Edappal [6584]	CHUNGAM WEST	202.0	4.0	27.0	171.0	84.7	Very High
MALAPPURAM	Edappal [6584]	CITY	81.0	0.0	48.0	33.0	40.7	Medium
MALAPPURAM	Edappal [6584]	COMPANY PADI	129.0	15.0	34.3	79.7	61.8	High
MALAPPURAM	Edappal [6584]	CRESCENT PLAZA	129.0	0.0	64.6	64.4	49.9	Medium
MALAPPURAM	Edappal [6584]	DAKSHINAMOORTHY	81.0	10.0	41.0	30.0	37.0	Medium
MALAPPURAM	Edappal [6584]	DHEEMA GOLD-INDOOR TFR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	DOWN TOWN ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	EDAPAL ANGADI	81.0	2.0	47.0	32.0	39.5	Medium
MALAPPURAM	Edappal [6584]	EDAPPAL HIGH SCHOOL	81.0	3.0	0.0	78.0	96.3	Very High
MALAPPURAM	Edappal [6584]	EDAPPAL HOSPITAL	129.0	20.0	16.8	92.2	71.5	High
MALAPPURAM	Edappal [6584]	EDAPPAL STEELS	255.0	0.0	24.5	230.5	90.4	Very High
MALAPPURAM	Edappal [6584]	EMIRATES MALL 400KVA LT INDOOR	324.0	0.0	0.0	324.0	100.0	Very High
MALAPPURAM	Edappal [6584]	ERUVAPRA PADAM	81.0	8.0	38.5	34.5	42.6	Medium
MALAPPURAM	Edappal [6584]	ERUVAPRA PUMP HOUSE	81.0	0.0	14.1	66.9	82.6	Very High
MALAPPURAM	Edappal [6584]	ERUVAPRA TEMPLE	81.0	8.0	34.3	38.7	47.8	Medium
MALAPPURAM	Edappal [6584]	ESTATE	81.0	0.0	13.3	67.7	83.6	Very High
MALAPPURAM	Edappal [6584]	GOKUL MATCHES	81.0	0.0	47.2	33.8	41.7	Medium
MALAPPURAM	Edappal [6584]	GOLDEN MOTORS	81.0	0.0	12.0	69.0	85.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edappal [6584]	GOLDEN TOWER INDOOR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	GOVINDA	129.0	0.0	107.8	21.2	16.4	Low
MALAPPURAM	Edappal [6584]	GOVINDA-INDOOR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	GOVT HOSPITAL EDAPPAL-100 KVA	81.0	5.0	16.0	60.0	74.1	High
MALAPPURAM	Edappal [6584]	HANUMANKAVU	81.0	3.0	23.0	55.0	67.9	High
MALAPPURAM	Edappal [6584]	KANNANCHIRA	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Edappal [6584]	KANNENKAYAL KOLE	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Edappal [6584]	KANTHALLOOR	81.0	3.0	9.0	69.0	85.2	Very High
MALAPPURAM	Edappal [6584]	KARIMBANAKKAL	81.0	0.0	71.4	9.6	11.9	Low
MALAPPURAM	Edappal [6584]	KHADEEJA CASTLE-INDOOR TFR	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Edappal [6584]	KOLATH MANA	81.0	0.0	34.7	46.3	57.1	High
MALAPPURAM	Edappal [6584]	KOLATH VIDYAPEEDOM	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Edappal [6584]	KOLATHU PALLI	81.0	0.0	64.7	16.3	20.1	Low
MALAPPURAM	Edappal [6584]	KOTHA KANDATH THAZHAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	KOTTAMUKU	81.0	11.3	57.0	12.7	15.7	Low
MALAPPURAM	Edappal [6584]	KOTTAPPURAM	129.0	0.0	17.3	111.7	86.6	Very High
MALAPPURAM	Edappal [6584]	KRISHIBHAVAN	81.0	5.0	55.0	21.0	25.9	Medium
MALAPPURAM	Edappal [6584]	KUNDAYAR	129.0	0.0	24.3	104.7	81.2	Very High
MALAPPURAM	Edappal [6584]	KUNDAYAR KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	KUTTIPPALA NSS	81.0	0.0	33.0	48.0	59.2	High
MALAPPURAM	Edappal [6584]	KUTTIPPALA VILLAGE	81.0	3.3	40.3	37.4	46.2	Medium
MALAPPURAM	Edappal [6584]	LT AL MADEENA-USS	129.0	0.0	8.7	120.3	93.3	Very High
MALAPPURAM	Edappal [6584]	LT AMANA MALL- USS	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Edappal [6584]	LT DUBAI MALL -INDOOR TFR	255.0	0.0	0.0	255.0	100.0	Very High
MALAPPURAM	Edappal [6584]	LT VIVA PALACE USS	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Edappal [6584]	LT-EMIRATES MALL-USS	324.0	0.0	0.0	324.0	100.0	Very High
MALAPPURAM	Edappal [6584]	M H SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edappal [6584]	MADAYAPARAMBU	81.0	3.0	69.0	9.0	11.1	Low
MALAPPURAM	Edappal [6584]	MADAYI KOLE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	MAHILASAMAJAM	129.0	0.0	14.0	115.0	89.1	Very High
MALAPPURAM	Edappal [6584]	MALABAR CABLE KANTHALLOOR	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Edappal [6584]	MALAKURATHIKKAV-100KVA	81.0	0.0	78.4	2.6	3.2	Very Low
MALAPPURAM	Edappal [6584]	MANALIYARKAVU	81.0	0.0	20.6	60.4	74.6	High
MALAPPURAM	Edappal [6584]	MANATH KAVU	81.0	0.0	35.3	45.7	56.4	High
MALAPPURAM	Edappal [6584]	MANJAKKATTU	81.0	0.0	10.3	70.7	87.3	Very High
MALAPPURAM	Edappal [6584]	MANOOR KAYAL	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Edappal [6584]	MLA PADY	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Edappal [6584]	MOOKAMBIKA	129.0	11.0	78.3	39.7	30.8	Medium
MALAPPURAM	Edappal [6584]	NADUVATTAM	202.0	0.0	52.3	149.7	74.1	High
MALAPPURAM	Edappal [6584]	NELLISSERY IHRD	81.0	5.0	11.0	65.0	80.2	Very High
MALAPPURAM	Edappal [6584]	NELLISSERY JUNCTION	81.0	0.0	55.0	26.0	32.1	Medium
MALAPPURAM	Edappal [6584]	NIRAMAYA HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	NIRAMAYA USS	255.0	0.0	0.0	255.0	100.0	Very High
MALAPPURAM	Edappal [6584]	NOVA GOLD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	OLAMBU	129.0	0.0	46.3	82.7	64.1	High
MALAPPURAM	Edappal [6584]	OLD P AND T	129.0	3.0	22.0	104.0	80.6	Very High
MALAPPURAM	Edappal [6584]	OPPUS MALL INDOOR	255.0	0.0	0.0	255.0	100.0	Very High
MALAPPURAM	Edappal [6584]	OVUPALAM	81.0	0.0	27.0	54.0	66.7	High
MALAPPURAM	Edappal [6584]	PADINJATTUMURI	81.0	3.0	19.0	59.0	72.8	High
MALAPPURAM	Edappal [6584]	PALEKKAT	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	PERUMPARAMBA	129.0	18.0	56.3	54.7	42.4	Medium
MALAPPURAM	Edappal [6584]	PILAKKAL PALLI	81.0	0.0	27.0	54.0	66.7	High
MALAPPURAM	Edappal [6584]	POLPAKARA	129.0	0.0	46.0	83.0	64.3	High
MALAPPURAM	Edappal [6584]	POLPAKARA M G	81.0	0.0	11.0	70.0	86.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edappal [6584]	PONKUNNU	129.0	3.0	37.0	89.0	69.0	High
MALAPPURAM	Edappal [6584]	PONNAZHICKARA	81.0	0.0	43.3	37.7	46.5	Medium
MALAPPURAM	Edappal [6584]	POOKARATHARA KINAR	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Edappal [6584]	POOKARATHARA SCHOOL-160 KVA	129.0	0.0	95.3	33.7	26.1	Medium
MALAPPURAM	Edappal [6584]	POOKARATHARA-250 KVA	202.0	3.0	62.0	137.0	67.8	High
MALAPPURAM	Edappal [6584]	POROOKARA TEMPLE	129.0	0.0	45.3	83.7	64.9	High
MALAPPURAM	Edappal [6584]	PORUKKARA SCHOOL	81.0	3.0	22.9	55.1	68.0	High
MALAPPURAM	Edappal [6584]	POTTUR	81.0	0.0	48.4	32.6	40.3	Medium
MALAPPURAM	Edappal [6584]	PREMIER LAB	129.0	0.0	43.4	85.6	66.3	High
MALAPPURAM	Edappal [6584]	PROYAL-INDOOR TFR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	PULIKAD	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Edappal [6584]	PULINCHODE	129.0	3.0	52.3	73.7	57.1	High
MALAPPURAM	Edappal [6584]	PULIYARAKUNNU	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Edappal [6584]	PURAMUNDEKKAD	81.0	0.0	40.3	40.7	50.2	High
MALAPPURAM	Edappal [6584]	R V C	202.0	3.0	56.0	143.0	70.8	High
MALAPPURAM	Edappal [6584]	RAYHAN	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Edappal [6584]	RELIANCE TRENDS	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Edappal [6584]	SAPARIYA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	SARADA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	SAYOOJ BAR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	SHALIMAR	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Edappal [6584]	SOUBAGYA	81.0	0.0	40.0	41.0	50.6	High
MALAPPURAM	Edappal [6584]	SPEX INDIA	129.0	15.0	56.5	57.5	44.6	Medium
MALAPPURAM	Edappal [6584]	SREEVALSAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	SUKAPURAM	81.0	5.0	45.6	30.4	37.5	Medium
MALAPPURAM	Edappal [6584]	SURYA INDUSTRIAL-NADUVATTAM	129.0	0.0	50.0	79.0	61.2	High
MALAPPURAM	Edappal [6584]	TATA MOTORS	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edappal [6584]	TATA MOTORS PALLI-100 KVA	81.0	0.0	32.0	49.0	60.5	High
MALAPPURAM	Edappal [6584]	THALAMUNDA	81.0	3.0	33.3	44.7	55.2	High
MALAPPURAM	Edappal [6584]	THATTANPADI	129.0	0.0	58.0	71.0	55.0	High
MALAPPURAM	Edappal [6584]	THRIVENI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	THUYYAM UP SCHOOL	81.0	0.0	7.0	74.0	91.4	Very High
MALAPPURAM	Edappal [6584]	THYKKAD	81.0	8.0	38.0	35.0	43.2	Medium
MALAPPURAM	Edappal [6584]	UDINIKKARA	81.0	0.0	77.5	3.5	4.3	Very Low
MALAPPURAM	Edappal [6584]	UDIYANNUR	81.0	5.0	33.3	42.7	52.7	High
MALAPPURAM	Edappal [6584]	UNIKKATTUPADY	81.0	0.0	39.3	41.7	51.5	High
MALAPPURAM	Edappal [6584]	UNITED MALL	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Edappal [6584]	USHUS	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Edappal [6584]	V ONE MIO	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edappal [6584]	VADASSERY	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Edappal [6584]	VALIYADU	202.0	6.2	59.0	136.8	67.7	High
MALAPPURAM	Edappal [6584]	VALYAD GLP SCHOOL	81.0	5.0	32.0	44.0	54.3	High
MALAPPURAM	Edappal [6584]	VARSHA-160 KVA	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Edappal [6584]	VATTAMKULAM CENTRE	202.0	5.0	72.7	124.3	61.5	High
MALAPPURAM	Edappal [6584]	VATTAMKULAM PANCHAYATH	129.0	0.0	27.0	102.0	79.1	Very High
MALAPPURAM	Edappal [6584]	VAYANASALA-100 KVA	81.0	0.0	41.8	39.2	48.4	Medium
MALAPPURAM	Edappal [6584]	VEDAPURAM	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Edappal [6584]	VENGINIKARA	81.0	3.0	57.4	20.6	25.4	Medium
MALAPPURAM	Edappal [6584]	VKM FORT	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Edappal [6584]	VYDYARMOOLA	81.0	0.0	51.0	30.0	37.0	Medium
MALAPPURAM	Edappal [6584]	VYDYARPADI	81.0	20.0	41.3	19.7	24.3	Low
MALAPPURAM	Edarikode [6558]	ABDURAHMAN ROAD	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Edarikode [6558]	ADRUSSERY	129.0	0.0	23.0	106.0	82.2	Very High
MALAPPURAM	Edarikode [6558]	AJFAN	324.0	0.0	0.0	324.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edarikode [6558]	AMBALAKULAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edarikode [6558]	AMBALAVATTAM	129.0	10.0	67.2	51.8	40.1	Medium
MALAPPURAM	Edarikode [6558]	AREEKKAL	81.0	3.0	3.0	75.0	92.6	Very High
MALAPPURAM	Edarikode [6558]	AVH	81.0	5.0	26.0	50.0	61.7	High
MALAPPURAM	Edarikode [6558]	BISMI CONNECT	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Edarikode [6558]	CHANGUVETTY	129.0	10.0	38.7	80.3	62.2	High
MALAPPURAM	Edarikode [6558]	CHENAPPARAMBU	129.0	5.0	42.2	81.8	63.4	High
MALAPPURAM	Edarikode [6558]	CHERUSSOLA	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Edarikode [6558]	CHETTIYANKINAR	129.0	28.0	98.6	2.4	1.8	Very Low
MALAPPURAM	Edarikode [6558]	CHINAKKAL PALLI	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Edarikode [6558]	CHIRAKKAL	81.0	0.0	42.0	39.0	48.1	Medium
MALAPPURAM	Edarikode [6558]	CHOLAMADU	81.0	0.0	39.8	41.2	50.8	High
MALAPPURAM	Edarikode [6558]	CHUDALAPPARA	129.0	5.0	38.0	86.0	66.7	High
MALAPPURAM	Edarikode [6558]	CITY	81.0	8.0	42.0	31.0	38.3	Medium
MALAPPURAM	Edarikode [6558]	CLASSY FURNITURE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edarikode [6558]	DARUL AMEN APPARTMENT	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Edarikode [6558]	DISPENSARY	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Edarikode [6558]	DOPA	129.0	0.0	25.8	103.2	80.0	Very High
MALAPPURAM	Edarikode [6558]	EDARIKODE NH	81.0	0.0	44.0	37.0	45.7	Medium
MALAPPURAM	Edarikode [6558]	EDARIKODE TOWN	202.0	5.0	80.5	116.5	57.7	High
MALAPPURAM	Edarikode [6558]	ESTATE PADI	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Edarikode [6558]	GRIPPO POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edarikode [6558]	GYATHI TOWER	162.0	0.0	0.0	162.0	100.0	Very High
MALAPPURAM	Edarikode [6558]	HARISON MEDICAL CENTRE	129.0	0.0	43.5	85.5	66.3	High
MALAPPURAM	Edarikode [6558]	HIDAYATH NAGAR	81.0	5.0	28.3	47.7	58.9	High
MALAPPURAM	Edarikode [6558]	ICE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edarikode [6558]	JALANIDHI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Edarikode [6558]	KADENGATHOTTY	81.0	3.3	30.2	47.5	58.6	High
MALAPPURAM	Edarikode [6558]	KAKKATHADAM	81.0	0.0	13.3	67.7	83.6	Very High
MALAPPURAM	Edarikode [6558]	KALATHINGALMADU	81.0	5.0	21.9	54.1	66.8	High
MALAPPURAM	Edarikode [6558]	KALLIKKAL VALAPPIL	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Edarikode [6558]	KALLUVETTUPARA	81.0	3.0	31.5	46.5	57.4	High
MALAPPURAM	Edarikode [6558]	KANJIKKUZHINGARA	81.0	0.0	50.0	31.0	38.3	Medium
MALAPPURAM	Edarikode [6558]	KANNATHAPPADI	81.0	0.0	11.3	69.7	86.0	Very High
MALAPPURAM	Edarikode [6558]	KARATTANGADI	129.0	0.0	66.0	63.0	48.8	Medium
MALAPPURAM	Edarikode [6558]	KARINGAPPARA	129.0	0.0	44.0	85.0	65.9	High
MALAPPURAM	Edarikode [6558]	KAZHUNGILAPPADI	129.0	8.0	46.0	75.0	58.1	High
MALAPPURAM	Edarikode [6558]	KELAMKULAM	81.0	0.0	11.1	69.9	86.3	Very High
MALAPPURAM	Edarikode [6558]	KIZHAKKINITHARA	81.0	0.0	22.6	58.5	72.2	High
MALAPPURAM	Edarikode [6558]	KLARI SOUTH	81.0	10.0	50.7	20.3	25.0	Medium
MALAPPURAM	Edarikode [6558]	KLARIPPALLI	81.0	5.0	24.4	51.6	63.7	High
MALAPPURAM	Edarikode [6558]	KOZHICHENA WOOD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Edarikode [6558]	KR BAKERY	81.0	5.0	15.3	60.7	74.9	High
MALAPPURAM	Edarikode [6558]	KULAMBIL PARA	81.0	5.0	21.0	55.0	67.9	High
MALAPPURAM	Edarikode [6558]	KUNJICHENA	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Edarikode [6558]	KUNNATHIYIL	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Edarikode [6558]	KURUKA	129.0	10.0	59.4	59.6	46.2	Medium
MALAPPURAM	Edarikode [6558]	KUTTATTUPARA	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Edarikode [6558]	KUTTIPPALA	81.0	8.0	39.0	34.0	42.0	Medium
MALAPPURAM	Edarikode [6558]	KUTTYALANGADI	81.0	10.0	55.0	16.0	19.8	Low
MALAPPURAM	Kadalundi [6632]	A P ROAD	129.0	0.0	94.2	34.8	27.0	Medium
MALAPPURAM	Kadalundi [6632]	ABAD II	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	ABAD NO1	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	ALAIJA	202.0	0.0	10.0	192.0	95.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Kadalundi [6632]	ALUNGAL	129.0	0.0	48.8	80.2	62.2	High
MALAPPURAM	Kadalundi [6632]	ANJOOM RESIDENCE	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Kadalundi [6632]	AVOKI	129.0	0.0	47.0	82.0	63.6	High
MALAPPURAM	Kadalundi [6632]	AYISHA	129.0	0.0	39.0	90.0	69.8	High
MALAPPURAM	Kadalundi [6632]	AYYAMBAKKI	81.0	0.0	30.0	51.0	63.0	High
MALAPPURAM	Kadalundi [6632]	AYYAPPANKAVU	81.0	0.0	33.5	47.5	58.7	High
MALAPPURAM	Kadalundi [6632]	BANU RUBBER	81.0	0.0	27.3	53.7	66.3	High
MALAPPURAM	Kadalundi [6632]	BHAJANAMADOM	81.0	0.0	46.8	34.2	42.2	Medium
MALAPPURAM	Kadalundi [6632]	CHALIPARAMBU	129.0	10.0	67.5	51.5	39.9	Medium
MALAPPURAM	Kadalundi [6632]	CHALIPARMBA COLONY	81.0	0.0	29.8	51.2	63.2	High
MALAPPURAM	Kadalundi [6632]	CHALIYAM BEACH	202.0	0.0	28.0	174.0	86.1	Very High
MALAPPURAM	Kadalundi [6632]	CHALIYAM MARKET	202.0	0.0	83.8	118.2	58.5	High
MALAPPURAM	Kadalundi [6632]	CHALIYAM VATTATH	202.0	5.0	92.0	105.0	52.0	High
MALAPPURAM	Kadalundi [6632]	CHALIYAPADAM	81.0	0.0	30.5	50.5	62.3	High
MALAPPURAM	Kadalundi [6632]	CHEERANTHODI	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Kadalundi [6632]	CHELEMBRA TELE EXCHANGE	81.0	4.4	13.2	63.3	78.2	Very High
MALAPPURAM	Kadalundi [6632]	CHELOOPADAM PALLY	81.0	0.0	32.0	49.0	60.5	High
MALAPPURAM	Kadalundi [6632]	CHELOOR PADAM	129.0	0.0	67.5	61.5	47.7	Medium
MALAPPURAM	Kadalundi [6632]	CHEMBAITHODE	81.0	0.0	27.1	53.9	66.6	High
MALAPPURAM	Kadalundi [6632]	CHITHRA CINEPLEX	81.0	0.0	50.0	31.0	38.3	Medium
MALAPPURAM	Kadalundi [6632]	CICO	81.0	0.0	32.0	49.0	60.5	High
MALAPPURAM	Kadalundi [6632]	COIR SOCIETY	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Kadalundi [6632]	EDACHIRA	202.0	3.0	62.0	137.0	67.8	High
MALAPPURAM	Kadalundi [6632]	EDAKAZHIKADAVE	81.0	0.0	26.0	55.0	67.9	High
MALAPPURAM	Kadalundi [6632]	ENNAKATTU PALLI	81.0	5.0	40.5	35.5	43.9	Medium
MALAPPURAM	Kadalundi [6632]	FERRY	81.0	5.0	49.1	26.9	33.1	Medium
MALAPPURAM	Kadalundi [6632]	FISHERIS	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Kadalundi [6632]	GULF ROAD	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Kadalundi [6632]	IMATE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	IND ESTATE CALVARI HILL	405.0	6.0	96.8	302.2	74.6	High
MALAPPURAM	Kadalundi [6632]	JARAM CHALIYAM	129.0	0.0	47.0	82.0	63.6	High
MALAPPURAM	Kadalundi [6632]	JAZ ICE PLANT	129.0	20.0	5.0	104.0	80.6	Very High
MALAPPURAM	Kadalundi [6632]	KADALUNDI	202.0	0.0	51.0	151.0	74.8	High
MALAPPURAM	Kadalundi [6632]	KADALUNDI EAST	129.0	0.0	21.0	108.0	83.7	Very High
MALAPPURAM	Kadalundi [6632]	KADALUNDI KADAVU	81.0	0.0	53.0	28.0	34.6	Medium
MALAPPURAM	Kadalundi [6632]	KADALUNDI MARKET	81.0	15.0	63.0	3.0	3.7	Very Low
MALAPPURAM	Kadalundi [6632]	KADALUNDI TELE EXCHANGE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	KADALUNDI WEST	81.0	0.0	54.7	26.3	32.4	Medium
MALAPPURAM	Kadalundi [6632]	KADUKKA BAZAR	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Kadalundi [6632]	KAITHA VALAPPIL	202.0	0.0	12.0	190.0	94.1	Very High
MALAPPURAM	Kadalundi [6632]	KALLAMPARA	202.0	3.0	63.0	136.0	67.3	High
MALAPPURAM	Kadalundi [6632]	KALLUVALAPPU	129.0	10.0	30.0	89.0	69.0	High
MALAPPURAM	Kadalundi [6632]	KAPPALANGADI	81.0	0.0	63.0	18.1	22.3	Low
MALAPPURAM	Kadalundi [6632]	KARAKALI	129.0	0.0	73.8	55.2	42.8	Medium
MALAPPURAM	Kadalundi [6632]	KAYANIPADAM	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Kadalundi [6632]	KEEZHKODE	81.0	0.0	31.1	49.9	61.5	High
MALAPPURAM	Kadalundi [6632]	KIZHAKKUMBAD	81.0	0.0	39.0	42.0	51.9	High
MALAPPURAM	Kadalundi [6632]	KODAPPURAMTHODE	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Kadalundi [6632]	KONATH	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Kadalundi [6632]	KONATHKUZHI	81.0	45.0	32.3	3.7	4.6	Very Low
MALAPPURAM	Kadalundi [6632]	KOONOOR VALAVU	129.0	0.0	51.0	78.0	60.5	High
MALAPPURAM	Kadalundi [6632]	KOTTAKKADAVU	81.0	0.0	9.0	72.0	88.9	Very High
MALAPPURAM	Kadalundi [6632]	KUNNATHU PADI	129.0	0.0	43.0	86.0	66.7	High
MALAPPURAM	Kadalundi [6632]	KUTTIPALA	129.0	0.0	14.5	114.5	88.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Kadalundi [6632]	LAKSHMI	202.0	0.0	72.0	130.0	64.4	High
MALAPPURAM	Kadalundi [6632]	LIGHT HOUSE	129.0	0.0	11.0	118.0	91.5	Very High
MALAPPURAM	Kadalundi [6632]	LOVELYCORNER	129.0	6.0	39.0	84.0	65.1	High
MALAPPURAM	Kadalundi [6632]	M I E NALLUR	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	M I E SREEPURI ROAD	81.0	0.0	42.1	38.9	48.0	Medium
MALAPPURAM	Kadalundi [6632]	MALAYIL THAZHAM	129.0	5.0	34.8	89.2	69.1	High
MALAPPURAM	Kadalundi [6632]	MANGATTUKULAM	81.0	3.0	44.2	33.8	41.7	Medium
MALAPPURAM	Kadalundi [6632]	MANNUR RAIL	129.0	0.0	69.0	60.0	46.5	Medium
MALAPPURAM	Kadalundi [6632]	MANNUR TEMPLE	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Kadalundi [6632]	MANNUR VALAVU	129.0	0.0	24.0	105.0	81.4	Very High
MALAPPURAM	Kadalundi [6632]	MARVA RUBBER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	MORBIDO	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	MUKKATH KADAVE	81.0	4.6	43.3	33.1	40.9	Medium
MALAPPURAM	Kadalundi [6632]	MURUKALLINGAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	NAZA PLASTIC	129.0	3.0	14.0	112.0	86.8	Very High
MALAPPURAM	Kadalundi [6632]	NIKHIL PLASTIC	129.0	3.0	29.0	97.0	75.2	Very High
MALAPPURAM	Kadalundi [6632]	OLD BANK	129.0	0.0	50.0	79.0	61.2	High
MALAPPURAM	Kadalundi [6632]	PADIKKALTHAZHAM	81.0	3.1	9.0	68.9	85.0	Very High
MALAPPURAM	Kadalundi [6632]	PALAKKATHAZHAM	81.0	5.0	35.0	41.0	50.6	High
MALAPPURAM	Kadalundi [6632]	PANAYAPURAM	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Kadalundi [6632]	PANCHAYATH OFFICE	81.0	0.0	39.0	42.0	51.9	High
MALAPPURAM	Kadalundi [6632]	PARAVANCHERI PADAM	81.0	0.0	33.0	48.0	59.3	High
MALAPPURAM	Kadalundi [6632]	PARAYIL	129.0	0.0	61.7	67.3	52.1	High
MALAPPURAM	Kadalundi [6632]	PAZHANCHANNUR TEMPLE	81.0	5.0	23.2	52.8	65.2	High
MALAPPURAM	Kadalundi [6632]	PEDIYATTUKUNNU	81.0	16.0	22.3	42.7	52.7	High
MALAPPURAM	Kadalundi [6632]	PERUMUGHAM ANGADI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	PERUNNEERI	81.0	0.0	23.3	57.7	71.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Kadalundi [6632]	PERUNTHODI PADAM	129.0	6.6	21.9	100.5	77.9	Very High
MALAPPURAM	Kadalundi [6632]	PHARMACY COLLEGE CHELEMBRA	81.0	5.0	32.0	44.0	54.3	High
MALAPPURAM	Kadalundi [6632]	POOCHERIKUNNU	129.0	3.0	55.8	70.2	54.5	High
MALAPPURAM	Kadalundi [6632]	PROBHODHINI	81.0	0.0	28.0	53.0	65.4	High
MALAPPURAM	Kadalundi [6632]	PULLIPARAMBU ANGADI	129.0	9.6	88.9	30.5	23.6	Low
MALAPPURAM	Kadalundi [6632]	PULLIPARAMBU SCHOOL	129.0	10.0	28.0	91.0	70.5	High
MALAPPURAM	Kadalundi [6632]	SHIFA HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	SRANKUPADI	129.0	0.0	14.0	115.0	89.1	Very High
MALAPPURAM	Kadalundi [6632]	T M H HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	TENERIPARA	129.0	0.0	28.8	100.2	77.7	Very High
MALAPPURAM	Kadalundi [6632]	THAIKKADAPPURAM	129.0	0.0	13.3	115.7	89.7	Very High
MALAPPURAM	Kadalundi [6632]	THANNEERCHAL	129.0	3.0	61.0	65.0	50.4	High
MALAPPURAM	Kadalundi [6632]	THIRUTHI	81.0	3.0	39.0	39.0	48.1	Medium
MALAPPURAM	Kadalundi [6632]	UNITED POLYMERS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Kadalundi [6632]	VADAKKUMBAD RAIL	81.0	0.0	25.5	55.5	68.5	High
MALAPPURAM	Kadalundi [6632]	VADAKKUMPAD	81.0	0.0	15.6	65.4	80.7	Very High
MALAPPURAM	Kadalundi [6632]	VAKKADAVE	129.0	0.0	127.5	1.5	1.2	Very Low
MALAPPURAM	Kadalundi [6632]	VALIYAL	81.0	0.0	44.0	37.0	45.6	Medium
MALAPPURAM	Kadalundi [6632]	VATTAPARAMB	129.0	13.0	116.0	0.0	0.0	Very Low
MALAPPURAM	Kadalundi [6632]	VKC FOOT GEAR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	AALAPPARA	81.0	0.0	30.3	50.7	62.6	High
MALAPPURAM	Keezhuparamba [6707]	ALINCHODE	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Keezhuparamba [6707]	ALUMKANDI	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Keezhuparamba [6707]	ANAKALLU	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Keezhuparamba [6707]	ANVAR NAGAR KUNIYIL	129.0	0.0	44.0	85.0	65.9	High
MALAPPURAM	Keezhuparamba [6707]	ASYA PADI	81.0	5.0	23.0	53.0	65.4	High
MALAPPURAM	Keezhuparamba [6707]	ATHADI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Keezhuparamba [6707]	AYALAKKODE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	BEEMAN KUZHI	81.0	0.0	31.0	50.0	61.7	High
MALAPPURAM	Keezhuparamba [6707]	BRICKWAY CRYSTAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	CHAGIRI	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Keezhuparamba [6707]	CHAIRANGADU	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Keezhuparamba [6707]	CHEKKUNNE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	CHEMBRAMMAL	81.0	3.0	11.3	66.7	82.3	Very High
MALAPPURAM	Keezhuparamba [6707]	CHERUPUZHA	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Keezhuparamba [6707]	CHOOlattipara	129.0	0.0	9.0	120.0	93.0	Very High
MALAPPURAM	Keezhuparamba [6707]	DEVASWAMKAD	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Keezhuparamba [6707]	EAST VADAKKUM MURI	81.0	3.0	47.0	31.0	38.3	Medium
MALAPPURAM	Keezhuparamba [6707]	EDAKKANDIPOTTA	129.0	0.0	28.3	100.7	78.1	Very High
MALAPPURAM	Keezhuparamba [6707]	EDAKKATTU PARAMBA TOWER	81.0	3.0	0.0	78.0	96.3	Very High
MALAPPURAM	Keezhuparamba [6707]	EDAKKATTUPARAMBA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	EDASSERIKADAVU	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Keezhuparamba [6707]	ENTHROTH	129.0	0.0	6.3	122.7	95.1	Very High
MALAPPURAM	Keezhuparamba [6707]	ENVIRA MURINHAD	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	JALJEEVAN KWA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	JAPAN PADI	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KALAKKAPARA	51.0	0.0	0.0	51.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KALAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KALAPPARA HATCHERY	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KALLARATTIKKAL	129.0	0.0	42.3	86.7	67.2	High
MALAPPURAM	Keezhuparamba [6707]	KALLINGAL	81.0	0.0	20.8	60.2	74.3	High
MALAPPURAM	Keezhuparamba [6707]	KALLINGAL PETROLEUM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KANHIRALA	129.0	0.0	62.6	66.4	51.4	High
MALAPPURAM	Keezhuparamba [6707]	KANNAMPALLI LIFT-IRRIGATION	81.0	0.0	19.0	62.0	76.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Keezhuparamba [6707]	KARATHODE	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Keezhuparamba [6707]	KATTADI POYIL	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Keezhuparamba [6707]	KEEZHUPARAMBA	81.0	5.0	38.3	37.7	46.5	Medium
MALAPPURAM	Keezhuparamba [6707]	KINARADAPPAN	129.0	5.0	63.0	61.0	47.3	Medium
MALAPPURAM	Keezhuparamba [6707]	KINATTINKANDY	129.0	10.0	27.5	91.5	70.9	High
MALAPPURAM	Keezhuparamba [6707]	KODINHIPPARAMBU	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Keezhuparamba [6707]	KODUMPUZHA	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KONOORKANDI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KONOORKANDI CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KOORANKALLU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KOOTTAPOOVATHI	81.0	0.0	33.0	48.0	59.3	High
MALAPPURAM	Keezhuparamba [6707]	KOTHUPARA	81.0	0.0	23.2	57.8	71.4	High
MALAPPURAM	Keezhuparamba [6707]	KOTTUPURAM	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Keezhuparamba [6707]	KT TOWER	162.0	0.0	0.0	162.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KUNHANPADI	81.0	0.0	4.0	77.0	95.1	Very High
MALAPPURAM	Keezhuparamba [6707]	KUNIYIL	202.0	0.0	38.0	164.0	81.2	Very High
MALAPPURAM	Keezhuparamba [6707]	KUNIYIL CHOLA	81.0	0.0	52.3	28.7	35.4	Medium
MALAPPURAM	Keezhuparamba [6707]	KURIKKALAMPAD	81.0	0.0	21.0	60.0	74.1	High
MALAPPURAM	Keezhuparamba [6707]	KURISHUPALLI JUNCTION	81.0	0.0	9.0	72.0	88.9	Very High
MALAPPURAM	Keezhuparamba [6707]	KUTOOLI TOWER	81.0	0.0	26.3	54.7	67.5	High
MALAPPURAM	Keezhuparamba [6707]	KUTTOOLI	81.0	0.0	35.5	45.5	56.2	High
MALAPPURAM	Keezhuparamba [6707]	KUTTOOLI PRESS	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	KUZHINAKKI PALAM	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Keezhuparamba [6707]	KVR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	MA CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	MAANITHODIKA	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Keezhuparamba [6707]	MADAMBI	81.0	0.0	32.4	48.6	60.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Keezhuparamba [6707]	MARATHODU-2	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	MEDARANHI	81.0	0.0	9.0	72.0	88.9	Very High
MALAPPURAM	Keezhuparamba [6707]	MELEPARAMBU TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	MOORKANADU TOWER	129.0	0.0	13.0	116.0	89.9	Very High
MALAPPURAM	Keezhuparamba [6707]	MURINJAMAD	81.0	5.0	15.0	61.0	75.3	Very High
MALAPPURAM	Keezhuparamba [6707]	NELLERIKUNNU	81.0	5.0	21.0	55.0	67.9	High
MALAPPURAM	Keezhuparamba [6707]	NELLIYAYI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	ODAKAYAM	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Keezhuparamba [6707]	ODAKAYAM TOWER	81.0	0.0	3.1	77.8	96.1	Very High
MALAPPURAM	Keezhuparamba [6707]	OTHUPALLIPURAYI	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Keezhuparamba [6707]	PALLIKKUNNU	81.0	0.0	73.5	7.5	9.3	Very Low
MALAPPURAM	Keezhuparamba [6707]	PALLITHAZHAM TKM	81.0	0.0	81.0	0.0	0.0	Very Low
MALAPPURAM	Keezhuparamba [6707]	PALOTH	202.0	0.0	14.0	188.0	93.1	Very High
MALAPPURAM	Keezhuparamba [6707]	PAMPANKAVU	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	PANAMPILAVU	81.0	3.0	11.0	67.0	82.7	Very High
MALAPPURAM	Keezhuparamba [6707]	PANNIYANMALA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	PANTHALANGADI	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Keezhuparamba [6707]	PARAKKAD	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Keezhuparamba [6707]	PARAPPACHAL	81.0	5.0	57.7	18.3	22.6	Low
MALAPPURAM	Keezhuparamba [6707]	PAROTTICHAL	81.0	0.0	12.0	69.0	85.2	Very High
MALAPPURAM	Keezhuparamba [6707]	PATHANAPURAM	202.0	5.0	30.0	167.0	82.7	Very High
MALAPPURAM	Keezhuparamba [6707]	PATHANAPURAM MADRASSA	81.0	3.0	25.0	53.0	65.4	High
MALAPPURAM	Keezhuparamba [6707]	PATHANAPURAM TYRE	81.0	0.0	11.3	69.7	86.0	Very High
MALAPPURAM	Keezhuparamba [6707]	PAVANNA	129.0	0.0	36.0	93.0	72.1	High
MALAPPURAM	Keezhuparamba [6707]	PAVANNA JALANIDHI	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	PAYAMPARAMBA	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Keezhuparamba [6707]	PEEDIKAPARAMB	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Keezhuparamba [6707]	PERINGADAVU KUNIYIL	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Keezhuparamba [6707]	PILAKKAL	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	POOVATHIKKAL	81.0	5.0	22.0	54.0	66.7	High
MALAPPURAM	Keezhuparamba [6707]	POOVATHIKKAL TOWER	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Keezhuparamba [6707]	POOVATHIKKANDI	129.0	4.4	55.0	69.6	54.0	High
MALAPPURAM	Keezhuparamba [6707]	PULINKUNNU	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Keezhuparamba [6707]	QUALITY TYRES	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	RABEEH MANTHI PATHANAPURAM	51.0	0.0	0.0	51.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	RAMANKULAM	81.0	0.0	22.0	59.0	72.8	High
MALAPPURAM	Keezhuparamba [6707]	SANTHINAGAR	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Keezhuparamba [6707]	THACHAMPARAMB	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Keezhuparamba [6707]	THACHANNA	129.0	0.0	11.5	117.5	91.1	Very High
MALAPPURAM	Keezhuparamba [6707]	THADAPARAMBA	81.0	0.0	13.3	67.7	83.6	Very High
MALAPPURAM	Keezhuparamba [6707]	THEKKINCHUVADE	129.0	3.0	41.3	84.7	65.7	High
MALAPPURAM	Keezhuparamba [6707]	THEKKUMCHUVAD CRESHE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	THEKU MURI	81.0	10.0	37.0	34.0	42.0	Medium
MALAPPURAM	Keezhuparamba [6707]	THENARUVI	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	THENCHERY	81.0	0.0	7.4	73.6	90.9	Very High
MALAPPURAM	Keezhuparamba [6707]	THERATTA GROUND	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Keezhuparamba [6707]	THERATTAMMAL	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Keezhuparamba [6707]	THIRUMANGALAM	81.0	0.0	41.0	40.0	49.4	Medium
MALAPPURAM	Keezhuparamba [6707]	THIRUTHI	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Keezhuparamba [6707]	THIRUTHI KOPRA	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	THOTTUMUKKAM	81.0	0.0	37.0	44.0	54.3	High
MALAPPURAM	Keezhuparamba [6707]	THOTTUMUKKAM CRUSHER	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Keezhuparamba [6707]	THOTTUMUKKAM EXANGE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	VADAKKUMMURI	129.0	0.0	53.0	76.0	58.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Keezhuparamba [6707]	VADAKKUMMURI TYRE	129.0	0.0	16.0	113.0	87.6	Very High
MALAPPURAM	Keezhuparamba [6707]	VALAPPRA	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Keezhuparamba [6707]	VANNILAPARAMBA	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Keezhuparamba [6707]	VERUPALAM	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Keezhuparamba [6707]	VETILAPARA CHC	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	VETILAPPARA SCHOOL	81.0	0.0	24.3	56.7	70.0	High
MALAPPURAM	Keezhuparamba [6707]	VEZHAKODE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	VEZHAKODE CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Keezhuparamba [6707]	VILAKKUPARAMBA	81.0	3.0	16.3	61.7	76.2	Very High
MALAPPURAM	Keezhuparamba [6707]	WEST PATHANAPURAM	129.0	0.0	19.0	110.0	85.3	Very High
MALAPPURAM	Koombara [6805]	ACHANKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	ACHANKUNNU MINDAMADAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	ACHANKUNNU RESORT	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Koombara [6805]	ACHANKUNNU SATWA RESORT	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	AKAMPUZHA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	AKAMPUZHA BAPOOTYKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	AKAMPUZHA-PUMP HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	ALLI RUBBER ESTATE	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Koombara [6805]	ANAYOD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	ANAYODE MEDICENE	202.0	0.0	0.0	202.0	100.0	Very High
MALAPPURAM	Koombara [6805]	ANAYODE TOWN	81.0	3.0	12.0	66.0	81.5	Very High
MALAPPURAM	Koombara [6805]	BATHAMCHUVADU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	BEE RESORT AKAMPUZHA	129.0	0.0	5.0	124.0	96.1	Very High
MALAPPURAM	Koombara [6805]	BHOOTHAMKUZHI-1	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Koombara [6805]	BHOOTHAMKUZHI-2	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	CHEENKANNIPALI-KARIMBU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	CHULLIYAKAM	51.0	0.0	0.0	51.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Koombara [6805]	CHUNDATHUM POYIL	129.0	0.0	29.4	99.5	77.2	Very High
MALAPPURAM	Koombara [6805]	CHUNDATHUM POYIL KARIMBU	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Koombara [6805]	EV CHARGING STATION	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	HAYATH RESIDENCY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KAKKADAM POYIL TOWN	81.0	0.0	2.0	79.0	97.5	Very High
MALAPPURAM	Koombara [6805]	KAKKADAM POYIL-KUNNATH	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KAKKADAM POYIL-PULIMTHANAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KAKKADAMPOYIL HIGH SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KAKKADAMPOYIL PHC	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KALLAMPULLU-POOVARAMTHODE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KALLIPPARA CONCRETE ROAD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KALLIPPARA TOWN	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KALLIPPARA VAYAL AB JN	81.0	3.0	0.0	78.0	96.3	Very High
MALAPPURAM	Koombara [6805]	KALLIPPARA VAYAL ROAD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KALPINI EAST	81.0	0.0	22.7	58.3	71.9	High
MALAPPURAM	Koombara [6805]	KALPOOR VAYAL	81.0	0.0	32.0	49.0	60.5	High
MALAPPURAM	Koombara [6805]	KALPPINI THODE	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Koombara [6805]	KARIMBU JUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KARIMBU-KARIYATHAMKUNNEL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KARIMBU-NADUVAZHI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KARIMBU-NAVALLY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KARIMBU-PARK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KARIMKUTTY	81.0	0.0	37.5	43.5	53.7	High
MALAPPURAM	Koombara [6805]	KOLAPPARAKUNNU-BYPASS	81.0	0.0	28.0	53.0	65.4	High
MALAPPURAM	Koombara [6805]	KOODARANHI POST OFFICE	129.0	0.0	28.0	101.0	78.3	Very High
MALAPPURAM	Koombara [6805]	KOODARANHI TOWN	202.0	0.0	47.9	154.1	76.3	Very High
MALAPPURAM	Koombara [6805]	KOODARANHI-HSS	81.0	0.0	50.0	31.0	38.3	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Koombara [6805]	KOODARANJI RELIANCE	81.0	3.0	38.0	40.0	49.4	Medium
MALAPPURAM	Koombara [6805]	KOOMBARA TOWER	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Koombara [6805]	KOOMPARA EXCHANGE	81.0	0.0	9.0	72.0	88.9	Very High
MALAPPURAM	Koombara [6805]	KOOTTAKARA PUMPHOUSE	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Koombara [6805]	KOOTTAKKARA	81.0	0.0	41.1	39.9	49.3	Medium
MALAPPURAM	Koombara [6805]	KOTTARAPATTA-KALPOOR	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Koombara [6805]	KOVILAKATHUMKADAV	81.0	5.0	55.0	21.0	25.9	Medium
MALAPPURAM	Koombara [6805]	KULIRAMUTTY PUMP HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	KULIRAMUTTY TOWN	81.0	0.0	4.0	77.0	95.1	Very High
MALAPPURAM	Koombara [6805]	KUNTHAMCHARI	81.0	0.0	21.0	60.0	74.1	High
MALAPPURAM	Koombara [6805]	KURANGETHUMPARA	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Koombara [6805]	MALANADU CRUSHUR	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Koombara [6805]	MANJAKKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	MANKAYAM	81.0	0.0	16.8	64.2	79.3	Very High
MALAPPURAM	Koombara [6805]	MANKAYAM HEAVENCOOL	81.0	4.0	41.0	36.0	44.4	Medium
MALAPPURAM	Koombara [6805]	MANKAYAM-RUBBER	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Koombara [6805]	MARANCHATTI TOWER	81.0	3.0	19.3	58.7	72.5	High
MALAPPURAM	Koombara [6805]	MARANCHATTI TOWN	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Koombara [6805]	MAVOOR HAJIPADI-KALLIPPARA	20.0	0.0	0.0	20.0	100.0	Very High
MALAPPURAM	Koombara [6805]	MAZHUVANCHERY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	MEDAPPARA JN	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	MEDAPPARA RESORT	129.0	0.0	11.8	117.2	90.9	Very High
MALAPPURAM	Koombara [6805]	MEDAPPARA-UDUMBUPARA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	MELE PERUMBOOLA	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Koombara [6805]	MERIGIRI CRUSHER	129.0	0.0	8.0	121.0	93.8	Very High
MALAPPURAM	Koombara [6805]	MOONBAY RESORT	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	MUNDAMALA	81.0	22.0	36.5	22.5	27.8	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Koombara [6805]	MUTHUVAMBAI	81.0	3.0	9.0	69.0	85.2	Very High
MALAPPURAM	Koombara [6805]	MYSORE PATTI	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Koombara [6805]	NATIONAL COIR KALPATHI-KARIMK U	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	OOLIKKAL SHEP	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	OTTAPLAVU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	PAIKADAN MALA	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Koombara [6805]	PALLIKKUNNU NAYADAMPOYIL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	PANAKKACHAL	81.0	3.0	38.5	39.5	48.8	Medium
MALAPPURAM	Koombara [6805]	PATTOTH	81.0	0.0	39.0	42.0	51.9	High
MALAPPURAM	Koombara [6805]	PATTOTH-KV CRUSHER	129.0	0.0	31.3	97.7	75.8	Very High
MALAPPURAM	Koombara [6805]	PEDIKAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	PEEDIKAPARA-PUNNAKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	PEELIKKUNNU	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Koombara [6805]	PERUMPOOLA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	POOVARAMTHODE ANAKKALLUMPARA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	POOVARAMTHODE RESORT	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Koombara [6805]	POOVARANTHODE SHEP	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	POTTANPARA COLONY	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Koombara [6805]	PUNNAKADAV MATHA CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	PUNNAKADAVU	81.0	0.0	18.0	63.0	77.8	Very High
MALAPPURAM	Koombara [6805]	PUNNAKADAVU-MATHALI COREY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	PUSHPAGIRI	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Koombara [6805]	PUTHUKADU-MARANCHATTY	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Koombara [6805]	SRAMBI	51.0	0.0	0.0	51.0	100.0	Very High
MALAPPURAM	Koombara [6805]	SUNNYPADY	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Koombara [6805]	THADATHILPADY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Koombara [6805]	THALIYILLATHADAM	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Koombara [6805]	THANIKUNNU	51.0	0.0	0.0	51.0	100.0	Very High
MALAPPURAM	Koombara [6805]	THAZHE KAKKAD TOWN	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Koombara [6805]	THAZHE KOODARANJI	81.0	5.0	31.0	45.0	55.6	High
MALAPPURAM	Koombara [6805]	THAZHEKAKKADU COLONY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	THAZHEKAKKADU-PAMBINKAVU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	THEKKINKADU	81.0	5.0	0.0	76.0	93.8	Very High
MALAPPURAM	Koombara [6805]	THENARUVI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	THENARUVI RESORT	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Koombara [6805]	THENARUVI-PANAMTHOTTEM	51.0	0.0	0.0	51.0	100.0	Very High
MALAPPURAM	Koombara [6805]	THOTTAKKAD	81.0	3.0	0.0	78.0	96.3	Very High
MALAPPURAM	Koombara [6805]	THOTTUMUKKAM CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Koombara [6805]	URUMI	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Koombara [6805]	URUMI-SUBSTATION-AUX	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Koombara [6805]	VAZHIKADAVU-KULIRAMUTTY	81.0	0.0	25.4	55.6	68.6	High
MALAPPURAM	Koombara [6805]	VEETTIPPARA	81.0	0.0	43.0	38.0	46.9	Medium
MALAPPURAM	Koombara [6805]	VEETTIPPARA CRUSHER	129.0	0.0	6.0	123.0	95.3	Very High
MALAPPURAM	Pannikkode [6777]	ADAMPADI	81.0	0.0	24.5	56.5	69.7	High
MALAPPURAM	Pannikkode [6777]	ADHADIKUNNU	81.0	0.0	29.9	51.1	63.1	High
MALAPPURAM	Pannikkode [6777]	AMBALAPATTA	81.0	5.0	5.0	71.0	87.7	Very High
MALAPPURAM	Pannikkode [6777]	AQUATICA FISH PAZHAMPARAMBA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	ATHANI INDUSTRY	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	BSNL-CHERUVADI	81.0	0.0	32.1	48.9	60.4	High
MALAPPURAM	Pannikkode [6777]	CARE FOUNDATION	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Pannikkode [6777]	CASINO	81.0	6.0	11.0	64.0	79.0	Very High
MALAPPURAM	Pannikkode [6777]	CHAKKALANKUNN	81.0	3.0	3.0	75.0	92.6	Very High
MALAPPURAM	Pannikkode [6777]	CHALAKKAL	81.0	0.0	60.0	21.0	25.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Pannikkode [6777]	CHALIL PARA	81.0	0.0	7.0	74.0	91.4	Very High
MALAPPURAM	Pannikkode [6777]	CHATHANPARAMBA	81.0	5.0	24.0	52.0	64.2	High
MALAPPURAM	Pannikkode [6777]	CHC KODIYATHUR	81.0	0.0	44.4	36.6	45.2	Medium
MALAPPURAM	Pannikkode [6777]	CHEEPANKUZH	81.0	0.0	21.0	60.0	74.1	High
MALAPPURAM	Pannikkode [6777]	CHEEPANKUZH AYURVEDA	81.0	0.0	37.7	43.3	53.4	High
MALAPPURAM	Pannikkode [6777]	CHELAPPURAM	81.0	0.0	45.7	35.3	43.5	Medium
MALAPPURAM	Pannikkode [6777]	CHERUVADI KADAVU	81.0	0.0	11.4	69.6	85.9	Very High
MALAPPURAM	Pannikkode [6777]	CHERUVADY TOWN	81.0	0.0	56.0	25.0	30.9	Medium
MALAPPURAM	Pannikkode [6777]	CHITTARIPILAKKAL	129.0	3.0	24.0	102.0	79.1	Very High
MALAPPURAM	Pannikkode [6777]	CHULLIKAPARAMBA	129.0	5.0	35.1	88.9	68.9	High
MALAPPURAM	Pannikkode [6777]	CHULLIKAPARAMBA BANK	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	CHULLIKKAPARAMBU TOWN	81.0	15.0	33.0	33.0	40.7	Medium
MALAPPURAM	Pannikkode [6777]	COCONUT OIL MILL	81.0	6.0	43.3	31.7	39.1	Medium
MALAPPURAM	Pannikkode [6777]	COMTRUST	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	EDAVAZHIKADAVU	81.0	4.0	15.0	62.0	76.5	Very High
MALAPPURAM	Pannikkode [6777]	ERANJIMAVU	81.0	0.0	37.7	43.3	53.5	High
MALAPPURAM	Pannikkode [6777]	ERANJIPARAMBA	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Pannikkode [6777]	GOTHAMBU ROAD	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Pannikkode [6777]	GREEN OFFSET	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	GREEN VALLEY	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	GROUP OFFSET	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	HASANATH	81.0	0.0	14.9	66.1	81.7	Very High
MALAPPURAM	Pannikkode [6777]	J-M CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	JIO FUEL KARUTHAPARAMBA	202.0	0.0	50.0	152.0	75.2	Very High
MALAPPURAM	Pannikkode [6777]	KAKKAD MALIYEKKAL	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Pannikkode [6777]	KAKKAD TOWN	81.0	0.0	30.5	50.5	62.4	High
MALAPPURAM	Pannikkode [6777]	KAKKADAN KUNNU	81.0	3.0	44.1	33.9	41.8	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Pannikkode [6777]	KAMBALATH	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Pannikkode [6777]	KANDANGAL	129.0	0.0	50.1	78.9	61.1	High
MALAPPURAM	Pannikkode [6777]	KANNAMPARAMBA	81.0	4.0	6.0	71.0	87.7	Very High
MALAPPURAM	Pannikkode [6777]	KARAKUTTY	81.0	0.0	52.4	28.6	35.3	Medium
MALAPPURAM	Pannikkode [6777]	KARALIPARAMBA	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Pannikkode [6777]	KARATTU	81.0	3.0	73.6	4.4	5.4	Very Low
MALAPPURAM	Pannikkode [6777]	KARATTU VAYAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	KARUTHAPARAMBA	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Pannikkode [6777]	KAVILADA	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Pannikkode [6777]	KODIYATHOOR BANK-ERANJIMAVU	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	KODIYATHOOR TOWN	129.0	8.0	64.0	57.0	44.2	Medium
MALAPPURAM	Pannikkode [6777]	KOOLIMADU AREEKARA	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Pannikkode [6777]	KOOLIMADU TOWN	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Pannikkode [6777]	KOOLIMADU-IDEA	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Pannikkode [6777]	KOOLIMADU-KWA	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Pannikkode [6777]	KOTHANAPARAMBA	81.0	0.0	56.4	24.6	30.3	Medium
MALAPPURAM	Pannikkode [6777]	KOTHEYAMCHAL	129.0	17.0	59.5	52.5	40.7	Medium
MALAPPURAM	Pannikkode [6777]	KSEB OFFICE	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	KT PRESS NELLIKAPARAMBA	129.0	0.0	0.0	129.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	KULANGARA	81.0	0.0	12.9	68.1	84.1	Very High
MALAPPURAM	Pannikkode [6777]	KUNNATHPALLI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	KUNNUMMAL	81.0	0.0	72.0	9.0	11.1	Low
MALAPPURAM	Pannikkode [6777]	KURUVADENGAL	81.0	0.0	27.4	53.6	66.2	High
MALAPPURAM	Pannikkode [6777]	KUTTIKATTU KUNNU	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Pannikkode [6777]	LOVE SHORE	81.0	0.0	23.4	57.5	71.0	High
MALAPPURAM	Pannikkode [6777]	MARVA CRUSHER-TKM	81.0	5.0	4.3	71.7	88.5	Very High
MALAPPURAM	Pannikkode [6777]	MATTUMURI	81.0	10.0	33.0	38.0	46.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Pannikkode [6777]	MAVAYI TOWER	129.0	3.0	21.0	105.0	81.4	Very High
MALAPPURAM	Pannikkode [6777]	MOHRA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	MOLIKAVU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	MUNNUR	129.0	3.0	25.3	100.7	78.1	Very High
MALAPPURAM	Pannikkode [6777]	MUTHODE	81.0	0.0	16.0	65.0	80.2	Very High
MALAPPURAM	Pannikkode [6777]	NADAKKAL	81.0	3.0	39.1	38.9	48.0	Medium
MALAPPURAM	Pannikkode [6777]	NELLIKAPARAMBA	129.0	0.0	36.8	92.2	71.4	High
MALAPPURAM	Pannikkode [6777]	NELLIKAPARAMBA TOWN	81.0	0.0	69.7	11.3	13.9	Low
MALAPPURAM	Pannikkode [6777]	P H E D	81.0	5.0	47.0	29.0	35.8	Medium
MALAPPURAM	Pannikkode [6777]	PALAKUNNU-RGGVY	81.0	0.0	27.5	53.5	66.0	High
MALAPPURAM	Pannikkode [6777]	PALOTTUPARAMBA	129.0	3.0	24.0	102.0	79.0	Very High
MALAPPURAM	Pannikkode [6777]	PANNIKODE-1 TOWN	129.0	0.0	35.0	94.0	72.9	High
MALAPPURAM	Pannikkode [6777]	PANNIKODE-2	81.0	9.0	18.2	53.8	66.4	High
MALAPPURAM	Pannikkode [6777]	PARAYANGATTU FUEL KOOLIMADU	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	PAZHAMPARAMBA	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Pannikkode [6777]	PHC POTTAMMAL	81.0	2.0	13.0	66.0	81.5	Very High
MALAPPURAM	Pannikkode [6777]	PHC VODAFONE	81.0	0.0	19.0	62.0	76.5	Very High
MALAPPURAM	Pannikkode [6777]	PUTHIYANIDOM-2	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Pannikkode [6777]	SARKAR PARAMBA ROAD	129.0	0.0	49.0	80.0	62.0	High
MALAPPURAM	Pannikkode [6777]	SARKARPARAMBA-2	81.0	0.0	21.0	60.0	74.1	High
MALAPPURAM	Pannikkode [6777]	SOUTH KODIYATHOOR	129.0	5.0	28.0	96.0	74.4	High
MALAPPURAM	Pannikkode [6777]	THADAYI	81.0	0.0	13.2	67.8	83.7	Very High
MALAPPURAM	Pannikkode [6777]	THARAMMAL KADAVU	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Pannikkode [6777]	THEKKINCHUVADU	81.0	3.0	27.0	51.0	62.9	High
MALAPPURAM	Pannikkode [6777]	THENANGAPARAMBA	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Pannikkode [6777]	THONNICHAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	THRIKKALAYUR	81.0	0.0	31.7	49.3	60.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Pannikkode [6777]	UCHAKAVU-WOOD	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	VALILLAPUZHA	129.0	5.0	39.0	85.0	65.9	High
MALAPPURAM	Pannikkode [6777]	VALILLAPUZHA TOWN	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	VALIYAPARAMBA CRUSHER	81.0	0.0	43.3	37.7	46.6	Medium
MALAPPURAM	Pannikkode [6777]	VALIYAPARAMBA TOWN	81.0	0.0	27.4	53.5	66.1	High
MALAPPURAM	Pannikkode [6777]	VALIYAPARAMBU HATCHERY	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Pannikkode [6777]	VILAKKOTTIL	81.0	0.0	36.0	45.0	55.6	High
MALAPPURAM	Pannikkode [6777]	VYSYAMPURAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Pannikkode [6777]	WEST KODIYATHOOR	81.0	5.0	8.0	68.0	84.0	Very High
MALAPPURAM	Thazhecode [6710]	AALTHARA	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Thazhecode [6710]	AATTEERIPPARA	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Thazhecode [6710]	ADIYAPPURAM	81.0	18.0	55.0	8.0	9.9	Very Low
MALAPPURAM	Thazhecode [6710]	ALIPPARAMBA PHC	81.0	0.0	17.0	64.0	79.0	Very High
MALAPPURAM	Thazhecode [6710]	AMBALAMKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Thazhecode [6710]	AMBEDHKAR COLONY	81.0	0.0	6.3	74.7	92.2	Very High
MALAPPURAM	Thazhecode [6710]	AMMINIKKAD IOC	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	AMMINIKKAD KUNNUMMAL	129.0	6.0	76.0	47.0	36.4	Medium
MALAPPURAM	Thazhecode [6710]	ATHIKKAL BUS STOP	81.0	6.0	35.0	40.0	49.4	Medium
MALAPPURAM	Thazhecode [6710]	ATHIKKAL PALLI	81.0	20.0	59.9	1.1	1.4	Very Low
MALAPPURAM	Thazhecode [6710]	AURA SCHOOL	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Thazhecode [6710]	BIDATHI SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	BIDAVUMALA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	CHETHALLOOR BANK	81.0	0.0	80.7	0.3	0.4	Very Low
MALAPPURAM	Thazhecode [6710]	CHETTIYANGADI	81.0	0.0	37.0	44.0	54.3	High
MALAPPURAM	Thazhecode [6710]	CHORANDI	81.0	0.0	47.0	34.0	42.0	Medium
MALAPPURAM	Thazhecode [6710]	CHUDALAPPADI	81.0	0.0	18.3	62.7	77.4	Very High
MALAPPURAM	Thazhecode [6710]	DEEPALAYAM	81.0	0.0	78.3	2.7	3.3	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Thazhecode [6710]	EDAMANAPPADI	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Thazhecode [6710]	EDAYIKAL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	EMS NURSING COLLEGE	129.0	5.0	11.0	113.0	87.6	Very High
MALAPPURAM	Thazhecode [6710]	GHANDI NAGAR	81.0	0.0	5.0	76.0	93.8	Very High
MALAPPURAM	Thazhecode [6710]	HOMESTEAD	129.0	0.0	129.0	0.0	0.0	Very Low
MALAPPURAM	Thazhecode [6710]	HUTCH TOWER	81.0	0.0	81.0	0.0	0.0	Very Low
MALAPPURAM	Thazhecode [6710]	IQBAL WOOD	129.0	3.0	41.0	85.0	65.9	High
MALAPPURAM	Thazhecode [6710]	KALLUVETTY	81.0	0.0	91.6	0.0	0.0	Very Low
MALAPPURAM	Thazhecode [6710]	KANNATHY	81.0	0.0	25.0	56.0	69.1	High
MALAPPURAM	Thazhecode [6710]	KAPPUPARAMBA PALLI	81.0	5.0	76.0	0.0	0.0	Very Low
MALAPPURAM	Thazhecode [6710]	KAPPUPARAMBU	129.0	0.0	28.0	101.0	78.3	Very High
MALAPPURAM	Thazhecode [6710]	KARIMBANATHOTTAM	81.0	0.0	14.0	67.0	82.7	Very High
MALAPPURAM	Thazhecode [6710]	KARIMKALIKAVU	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Thazhecode [6710]	KARINGALLATHANI MADRASSA	81.0	0.0	9.0	72.0	88.9	Very High
MALAPPURAM	Thazhecode [6710]	KARINKALLATHANI HIGHWAY	81.0	0.0	18.5	62.5	77.2	Very High
MALAPPURAM	Thazhecode [6710]	KARINKALLATHANI PANCHAYATH	202.0	5.0	8.8	188.2	93.2	Very High
MALAPPURAM	Thazhecode [6710]	KARINKALLATHANI TOWN	129.0	0.0	10.0	119.0	92.2	Very High
MALAPPURAM	Thazhecode [6710]	KARINKALLATHANI YARAM	129.0	0.0	29.0	100.0	77.5	Very High
MALAPPURAM	Thazhecode [6710]	KATTEKKADU	81.0	3.0	11.0	67.0	82.7	Very High
MALAPPURAM	Thazhecode [6710]	KODAKKAPARAMBA JALANIDHI	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	KODAKKAPARAMBU	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Thazhecode [6710]	KOORIKUNDU PHC	81.0	10.0	30.0	41.0	50.6	High
MALAPPURAM	Thazhecode [6710]	KORAMKODE	129.0	5.0	19.0	105.0	81.4	Very High
MALAPPURAM	Thazhecode [6710]	KULATHILPEEDIKA	81.0	0.0	34.0	47.0	58.0	High
MALAPPURAM	Thazhecode [6710]	KUNNANATH	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Thazhecode [6710]	KUNNATHUVATTA	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Thazhecode [6710]	KUTTYPULY	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Thazhecode [6710]	MADAAMPARA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	MADAMBRA	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Thazhecode [6710]	MALANKADA	81.0	0.0	11.0	70.0	86.4	Very High
MALAPPURAM	Thazhecode [6710]	MANIKKYAPPARAMBA	81.0	0.0	8.0	73.0	90.1	Very High
MALAPPURAM	Thazhecode [6710]	MARAMBATTAKUNNU PALLI	81.0	9.0	68.1	3.9	4.8	Very Low
MALAPPURAM	Thazhecode [6710]	MARAMPATTAKUNNU	81.0	4.2	12.0	64.8	79.9	Very High
MALAPPURAM	Thazhecode [6710]	MARUTHALA	81.0	5.0	43.0	33.0	40.7	Medium
MALAPPURAM	Thazhecode [6710]	MARUTHANPARA	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Thazhecode [6710]	MATTARA	81.0	25.0	42.4	13.6	16.7	Low
MALAPPURAM	Thazhecode [6710]	MATTARA TOWER	81.0	35.0	35.5	10.5	12.9	Low
MALAPPURAM	Thazhecode [6710]	MEKKARAVU	81.0	0.0	72.0	9.0	11.1	Low
MALAPPURAM	Thazhecode [6710]	MELEKAPPUPARAMBU	81.0	0.0	38.0	43.0	53.1	High
MALAPPURAM	Thazhecode [6710]	MOLLAPPADI	81.0	5.0	26.0	50.0	61.7	High
MALAPPURAM	Thazhecode [6710]	MOLLAPPADI FARM	51.0	0.0	0.0	51.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	MUCHUNTHIMOOLA	81.0	0.0	45.0	36.0	44.4	Medium
MALAPPURAM	Thazhecode [6710]	MUKKILAPARAMBA	81.0	0.0	11.3	69.7	86.0	Very High
MALAPPURAM	Thazhecode [6710]	MUTHALAPPADAM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	MUTHIRAMANNA	81.0	5.0	23.3	52.7	65.1	High
MALAPPURAM	Thazhecode [6710]	MUTHIRAMANNA PHC	81.0	5.0	27.0	49.0	60.5	High
MALAPPURAM	Thazhecode [6710]	MUTHUKKUMPURAM	81.0	0.0	50.0	31.0	38.3	Medium
MALAPPURAM	Thazhecode [6710]	MUTHUKKUMPURAM MADRASSA	81.0	5.0	33.0	43.0	53.1	High
MALAPPURAM	Thazhecode [6710]	NADUVAPARAMBU	81.0	0.0	41.0	40.0	49.4	Medium
MALAPPURAM	Thazhecode [6710]	NADUVILATHANI	129.0	13.0	69.7	46.3	35.9	Medium
MALAPPURAM	Thazhecode [6710]	NECHYIL	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	ODAMALA	81.0	5.0	10.0	66.0	81.5	Very High
MALAPPURAM	Thazhecode [6710]	ODAMALAKKUNNU	81.0	5.0	20.0	56.0	69.1	High
MALAPPURAM	Thazhecode [6710]	ONGODE	81.0	0.0	14.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Thazhecode [6710]	PALLIKKULAM	81.0	0.0	38.0	43.0	53.1	High
MALAPPURAM	Thazhecode [6710]	PALLIKUNNU	129.0	0.0	47.0	82.0	63.6	High
MALAPPURAM	Thazhecode [6710]	PANAMBI	81.0	0.0	27.0	54.0	66.7	High
MALAPPURAM	Thazhecode [6710]	PANAMKURISSIKAVU	81.0	0.0	24.0	57.0	70.4	High
MALAPPURAM	Thazhecode [6710]	PAPPADAPADI	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Thazhecode [6710]	PARAKKANNI	81.0	10.0	36.0	35.0	43.2	Medium
MALAPPURAM	Thazhecode [6710]	PARIYAPURAM	81.0	0.0	23.0	58.0	71.6	High
MALAPPURAM	Thazhecode [6710]	PATHAIKKARA	129.0	5.0	35.0	89.0	69.0	High
MALAPPURAM	Thazhecode [6710]	PERUMBALAPARA	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	PILATHARA	81.0	0.0	10.0	71.0	87.7	Very High
MALAPPURAM	Thazhecode [6710]	PODEKADE	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Thazhecode [6710]	POOVATHANI	129.0	23.0	65.7	40.3	31.3	Medium
MALAPPURAM	Thazhecode [6710]	PULAPPA	81.0	0.0	3.0	78.0	96.3	Very High
MALAPPURAM	Thazhecode [6710]	PUTHOOR SHANTHI	81.0	0.0	6.0	75.0	92.6	Very High
MALAPPURAM	Thazhecode [6710]	PUTHOOR TOWN	81.0	0.0	20.0	61.0	75.3	Very High
MALAPPURAM	Thazhecode [6710]	SHALIMAR	81.0	15.0	59.0	7.0	8.6	Very Low
MALAPPURAM	Thazhecode [6710]	SHIFA CHETHALLUR	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	ST MARYS	129.0	10.0	19.0	100.0	77.5	Very High
MALAPPURAM	Thazhecode [6710]	SWAGATH	129.0	0.0	36.0	93.0	72.1	High
MALAPPURAM	Thazhecode [6710]	THAZHEKODE KSEB	81.0	5.0	62.5	13.5	16.7	Low
MALAPPURAM	Thazhecode [6710]	THAZHEKODE PALAM	129.0	0.0	45.0	84.0	65.1	High
MALAPPURAM	Thazhecode [6710]	THAZHEKODE PALLI	81.0	0.0	40.0	41.0	50.6	High
MALAPPURAM	Thazhecode [6710]	THAZHEMARUTHALA	81.0	0.0	13.0	68.0	84.0	Very High
MALAPPURAM	Thazhecode [6710]	THAZHEMATTARA	81.0	4.2	10.0	66.8	82.4	Very High
MALAPPURAM	Thazhecode [6710]	THUVVASSERI	81.0	10.0	5.0	66.0	81.5	Very High
MALAPPURAM	Thazhecode [6710]	UPPUMKAVU	129.0	11.0	51.0	67.0	51.9	High
MALAPPURAM	Thazhecode [6710]	VADAKKEKARA	129.0	11.0	108.6	9.4	7.3	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
MALAPPURAM	Thazhecode [6710]	VALAMKULAM	81.0	0.0	42.7	38.3	47.3	Medium
MALAPPURAM	Thazhecode [6710]	VALAMKULAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	VALIPPARA	81.0	5.0	16.0	60.0	74.1	High
MALAPPURAM	Thazhecode [6710]	VANITHA INDUSTRY	202.0	5.0	6.0	191.0	94.6	Very High
MALAPPURAM	Thazhecode [6710]	VATTAPARAMBA HC	81.0	5.0	15.0	61.0	75.3	Very High
MALAPPURAM	Thazhecode [6710]	VATTAPARAMBA PAKKATH	81.0	0.0	15.0	66.0	81.5	Very High
MALAPPURAM	Thazhecode [6710]	VAZHIIYILAPARA	81.0	5.0	31.0	45.0	55.6	High
MALAPPURAM	Thazhecode [6710]	VELINGOTTUKUNNU	81.0	0.0	7.0	74.0	91.4	Very High
MALAPPURAM	Thazhecode [6710]	VELLAPPARA	81.0	5.0	40.3	35.7	44.0	Medium
MALAPPURAM	Thazhecode [6710]	VENDAMOOLA	81.0	8.0	45.0	28.0	34.6	Medium
MALAPPURAM	Thazhecode [6710]	VM POULTRY FARM	81.0	0.0	0.0	81.0	100.0	Very High
MALAPPURAM	Thazhecode [6710]	ZAM ZAM POLIMER	81.0	0.0	5.0	76.0	93.8	Very High