

KSEB Renewable Energy Feasibility Report

Generated report · 2000 transformers across 1 districts. Balance % = (Balance Available ÷ 90% DTR Capacity) × 100.

District Summary

District	Transformers	Balance (kW)	Very High	High	Medium	Low	Very Low	Unknown
PATHANAMTHITTA	2000	148,777.7	1157	480	227	62	74	0
TOTAL	2000	148,777.7	1157	480	227	62	74	0

PATHANAMTHITTA — 2000 transformers

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Adoor [4609]	AATTINKARA	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Adoor [4609]	ABC	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Adoor [4609]	ADOOR CENTRAL	129.0	0.0	21.0	108.0	83.7	Very High
PATHANAMTHITTA	Adoor [4609]	ADOOR HS	81.0	0.0	37.0	44.0	54.3	High
PATHANAMTHITTA	Adoor [4609]	ADOOR MARKET	81.0	0.0	60.7	20.3	25.1	Medium
PATHANAMTHITTA	Adoor [4609]	AISHA ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	ALATHINAL	81.0	3.0	16.0	62.0	76.5	Very High
PATHANAMTHITTA	Adoor [4609]	ALPHA FLAT	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	ALUVILA	81.0	5.0	59.8	16.2	20.0	Low
PATHANAMTHITTA	Adoor [4609]	AMMAKANDAKARA	81.0	20.1	44.5	16.4	20.3	Low
PATHANAMTHITTA	Adoor [4609]	AMPADY FLAT	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	APPLIED SCIENCE ADOOR	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	APSARA LODGE	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	ATTAKODE	81.0	8.0	19.4	53.6	66.2	High
PATHANAMTHITTA	Adoor [4609]	AYYAPPAVILASAM	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Adoor [4609]	BEN GROUP	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	BEVCO	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	BHAVADASANMUKKU	81.0	5.0	24.0	52.0	64.2	High
PATHANAMTHITTA	Adoor [4609]	BINURAJAN	81.0	0.0	9.0	72.0	88.9	Very High
PATHANAMTHITTA	Adoor [4609]	BISMI DTR	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	CENTRAL BAZAR	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	CENTRAL PARK	129.0	0.0	10.0	119.0	92.2	Very High
PATHANAMTHITTA	Adoor [4609]	CHAKKIMUKKU	81.0	3.0	0.0	78.0	96.3	Very High
PATHANAMTHITTA	Adoor [4609]	CHENNAMPALLY	129.0	3.0	125.9	0.1	0.1	Very Low
PATHANAMTHITTA	Adoor [4609]	CHENNAMPALLY VAYANASALA	129.0	8.0	85.3	35.7	27.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Adoor [4609]	CHETTIYAR PADI VEETIL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	CHICKING	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	CHITTANIMUKKU	81.0	0.0	6.3	74.7	92.2	Very High
PATHANAMTHITTA	Adoor [4609]	CHITTUNDAYIL	81.0	19.8	22.0	39.2	48.4	Medium
PATHANAMTHITTA	Adoor [4609]	CHOORAKODE H S	81.0	11.0	72.0	0.0	0.0	Very Low
PATHANAMTHITTA	Adoor [4609]	CHOORAKODU KALATHATTU	129.0	5.0	26.3	97.7	75.7	Very High
PATHANAMTHITTA	Adoor [4609]	CHOORAKODU PLASTIC	129.0	0.0	15.0	114.0	88.4	Very High
PATHANAMTHITTA	Adoor [4609]	CRYSTAL PLAZA	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	DELAVA	81.0	9.0	29.0	43.0	53.1	High
PATHANAMTHITTA	Adoor [4609]	DEVADANATHU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	DUMMY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	DUMMY-2	51.0	0.0	0.0	51.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	E-PASS TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	ESAF BANK	129.0	0.0	36.0	93.0	72.1	High
PATHANAMTHITTA	Adoor [4609]	EV VAYANASALA	81.0	5.0	74.5	1.5	1.9	Very Low
PATHANAMTHITTA	Adoor [4609]	EXCISE OFFICE	81.0	0.0	24.4	56.6	69.9	High
PATHANAMTHITTA	Adoor [4609]	FEDERAL BANK	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	FIRE STATION	129.0	0.0	35.7	93.3	72.3	High
PATHANAMTHITTA	Adoor [4609]	GALAXY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	GANDHINAGAR	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Adoor [4609]	GEETHAM	129.0	12.0	74.0	43.0	33.3	Medium
PATHANAMTHITTA	Adoor [4609]	GEORGE SONS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	GO EASY CHARGING	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	GOEC CHARGING STATION	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	HOLY ANGELS SCHOOL	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Adoor [4609]	HVDS 1	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	HVDS 10	12.0	0.0	0.0	12.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Adoor [4609]	HVDS 11	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	HVDS 12	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	HVDS 13	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	HVDS 14	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	HVDS 15	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	HVDS 2	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	HVDS 3	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	HVDS 7	12.0	0.0	8.0	4.0	33.3	Medium
PATHANAMTHITTA	Adoor [4609]	HVDS 8	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	IDBI BANK	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	IDUKKY READY MIX	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	INDUS MARUTHI	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Adoor [4609]	IOC	81.0	0.0	31.0	50.0	61.7	High
PATHANAMTHITTA	Adoor [4609]	JAYAPURAM	81.0	0.0	29.7	51.3	63.4	High
PATHANAMTHITTA	Adoor [4609]	KAIMALAPPARA	81.0	0.0	21.1	59.9	74.0	High
PATHANAMTHITTA	Adoor [4609]	KAITHAKKARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	KANJIRAPPARA	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Adoor [4609]	KANNAMPETTI	81.0	5.0	5.0	71.0	87.7	Very High
PATHANAMTHITTA	Adoor [4609]	KARIMPANNOOR	81.0	3.0	0.0	78.0	96.3	Very High
PATHANAMTHITTA	Adoor [4609]	KARUVATTA CANAL	81.0	5.0	32.0	44.0	54.3	High
PATHANAMTHITTA	Adoor [4609]	KARUVATTA FLAT	81.0	0.0	45.3	35.7	44.1	Medium
PATHANAMTHITTA	Adoor [4609]	KARUVATTA SOUTH	81.0	15.0	41.0	25.0	30.9	Medium
PATHANAMTHITTA	Adoor [4609]	KEERICKAL PADY	81.0	0.0	33.0	48.0	59.3	High
PATHANAMTHITTA	Adoor [4609]	KENCOSE	202.0	1.0	76.9	124.1	61.5	High
PATHANAMTHITTA	Adoor [4609]	KERALA	202.0	10.0	71.5	120.5	59.6	High
PATHANAMTHITTA	Adoor [4609]	KFC	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	KODAKKATHARA BY PASS	81.0	20.0	36.0	25.0	30.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Adoor [4609]	KONNAMANKARA	129.0	0.0	32.0	97.0	75.2	Very High
PATHANAMTHITTA	Adoor [4609]	KONNAMANKARA-2	81.0	12.0	64.8	4.2	5.2	Very Low
PATHANAMTHITTA	Adoor [4609]	KOSAKUZH	81.0	3.0	0.0	78.0	96.3	Very High
PATHANAMTHITTA	Adoor [4609]	KOTTAMUKAL	81.0	16.0	63.3	1.7	2.1	Very Low
PATHANAMTHITTA	Adoor [4609]	KOTTAPURAM	81.0	6.0	10.0	65.0	80.2	Very High
PATHANAMTHITTA	Adoor [4609]	KSRTC	129.0	5.0	6.0	118.0	91.5	Very High
PATHANAMTHITTA	Adoor [4609]	KTDC TOWER	81.0	13.0	46.4	21.6	26.7	Medium
PATHANAMTHITTA	Adoor [4609]	KUMBILUMVILA	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Adoor [4609]	KUNNATHUKARA	81.0	0.0	34.0	47.0	58.0	High
PATHANAMTHITTA	Adoor [4609]	KUNNATHUKARA NO-2	81.0	14.0	57.4	9.6	11.8	Low
PATHANAMTHITTA	Adoor [4609]	KUREKKATU PADY	81.0	20.0	53.1	7.9	9.8	Very Low
PATHANAMTHITTA	Adoor [4609]	KV ADOOR	81.0	0.0	27.0	54.0	66.7	High
PATHANAMTHITTA	Adoor [4609]	LALS RESIDENCY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	LE BEAUTE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	LIC	129.0	0.0	5.0	124.0	96.1	Very High
PATHANAMTHITTA	Adoor [4609]	MAHADEVA	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Adoor [4609]	MALABAR GOLD	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	MALAMEKARA	81.0	10.0	70.6	0.4	0.5	Very Low
PATHANAMTHITTA	Adoor [4609]	MANAKALA	129.0	8.0	41.0	80.0	62.0	High
PATHANAMTHITTA	Adoor [4609]	MANAKALA CHIRA	81.0	0.0	31.0	50.0	61.8	High
PATHANAMTHITTA	Adoor [4609]	MANAKALA ENGG COLLAGE	81.0	3.0	0.0	78.0	96.3	Very High
PATHANAMTHITTA	Adoor [4609]	MANAKALA POLYTECHNIC	129.0	0.0	48.7	80.3	62.2	High
PATHANAMTHITTA	Adoor [4609]	MANGARETHU PADI	81.0	3.0	5.0	73.0	90.1	Very High
PATHANAMTHITTA	Adoor [4609]	MANIYATHU BHAGOM	81.0	14.0	29.0	38.0	46.9	Medium
PATHANAMTHITTA	Adoor [4609]	MAR CRISOSTEM COLLEGE	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Adoor [4609]	MARIYAM PLAZA	129.0	0.0	3.0	126.0	97.7	Very High
PATHANAMTHITTA	Adoor [4609]	MAX	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Adoor [4609]	MELATHIL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	MELOOD	81.0	0.0	11.5	69.5	85.8	Very High
PATHANAMTHITTA	Adoor [4609]	MITHRAPURAM	81.0	0.0	80.7	0.3	0.3	Very Low
PATHANAMTHITTA	Adoor [4609]	MMDM ITC	81.0	0.0	38.0	43.0	53.1	High
PATHANAMTHITTA	Adoor [4609]	MOONNALAM	129.0	19.0	50.0	60.0	46.5	Medium
PATHANAMTHITTA	Adoor [4609]	MORE ADOOR	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	MULLAMTHANATHU PADI	81.0	16.0	52.6	12.4	15.3	Low
PATHANAMTHITTA	Adoor [4609]	MUNDAPPALLY	129.0	20.0	76.5	32.5	25.2	Medium
PATHANAMTHITTA	Adoor [4609]	MUTHOOT	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NADAM	129.0	0.0	35.0	94.0	72.9	High
PATHANAMTHITTA	Adoor [4609]	NAIR FLAT	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NALPATHINAIRAMPADI	81.0	0.0	46.0	35.0	43.2	Medium
PATHANAMTHITTA	Adoor [4609]	NAMBOORETHU PADI	81.0	3.0	20.0	58.0	71.6	High
PATHANAMTHITTA	Adoor [4609]	NANDILATHU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NAYANAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NEDUMKULANJI	129.0	25.0	102.7	1.3	1.0	Very Low
PATHANAMTHITTA	Adoor [4609]	NEDUMKULANJI SOCIETY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NEDUMKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NEEMA EMPORIUM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NELLIMUKAL CANAL	81.0	5.0	14.0	62.0	76.5	Very High
PATHANAMTHITTA	Adoor [4609]	NELLIMUKAL JUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NELLIMUKAL PUMP	81.0	0.0	22.5	58.5	72.2	High
PATHANAMTHITTA	Adoor [4609]	NEW LIC	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NEW PRIVATE BUS STAND	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	NIRAPPUKADAVU	81.0	3.0	53.0	25.0	30.9	Medium
PATHANAMTHITTA	Adoor [4609]	OMEGA	202.0	3.0	111.3	87.7	43.4	Medium
PATHANAMTHITTA	Adoor [4609]	OORILETHU PADI	81.0	3.0	0.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Adoor [4609]	ORCHID GARDEN VILLAS	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	P AND T	202.0	0.0	18.0	184.0	91.1	Very High
PATHANAMTHITTA	Adoor [4609]	P B ADOOR	81.0	0.0	50.3	30.7	37.9	Medium
PATHANAMTHITTA	Adoor [4609]	PALAZHY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	PAMPETTUKULAM	81.0	8.0	41.0	32.0	39.5	Medium
PATHANAMTHITTA	Adoor [4609]	PANDIKKUDY SCHOOL	81.0	10.0	25.0	46.0	56.8	High
PATHANAMTHITTA	Adoor [4609]	PANDIKUDI	129.0	4.0	76.6	48.4	37.5	Medium
PATHANAMTHITTA	Adoor [4609]	PANNIVIZHA TEMPLE	81.0	23.0	47.5	10.5	13.0	Low
PATHANAMTHITTA	Adoor [4609]	PANNIVIZHA VALIYAKULAM	81.0	0.0	17.3	63.7	78.6	Very High
PATHANAMTHITTA	Adoor [4609]	PARTHASARATHY-1	129.0	0.0	37.4	91.6	71.0	High
PATHANAMTHITTA	Adoor [4609]	PARTHASARATHY-2	81.0	3.0	0.0	78.0	96.3	Very High
PATHANAMTHITTA	Adoor [4609]	PASS	81.0	0.0	8.6	72.4	89.4	Very High
PATHANAMTHITTA	Adoor [4609]	PAZHAKULAM	81.0	5.0	54.9	21.1	26.1	Medium
PATHANAMTHITTA	Adoor [4609]	PAZHAKULAM CANAL	81.0	3.0	5.0	73.0	90.1	Very High
PATHANAMTHITTA	Adoor [4609]	PAZHAKULAM MOSQUE	81.0	0.0	23.0	58.0	71.6	High
PATHANAMTHITTA	Adoor [4609]	PAZHAVARICKAL	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	PERINGANADU MAHADEVAR	81.0	8.0	11.0	62.0	76.5	Very High
PATHANAMTHITTA	Adoor [4609]	PERINGANADU NO-1	81.0	3.0	13.0	65.0	80.2	Very High
PATHANAMTHITTA	Adoor [4609]	PLAVILATHARA	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Adoor [4609]	PML	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Adoor [4609]	POOVAMPALLI	81.0	15.0	33.4	32.6	40.2	Medium
PATHANAMTHITTA	Adoor [4609]	POOVANKUNNU	81.0	0.0	6.4	74.6	92.1	Very High
PATHANAMTHITTA	Adoor [4609]	POTHADY	81.0	28.0	45.9	7.1	8.8	Very Low
PATHANAMTHITTA	Adoor [4609]	PRECISES	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	PUTHENCHANTHA	81.0	0.0	22.5	58.5	72.2	High
PATHANAMTHITTA	Adoor [4609]	PWD	81.0	11.0	48.0	22.0	27.2	Medium
PATHANAMTHITTA	Adoor [4609]	R D OFFICE	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Adoor [4609]	RELIANT TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	REVENUE TOWER	405.0	0.0	51.0	354.0	87.4	Very High
PATHANAMTHITTA	Adoor [4609]	SEMINARY	81.0	7.2	13.0	60.8	75.0	Very High
PATHANAMTHITTA	Adoor [4609]	SHALOM	81.0	0.0	30.0	51.0	63.0	High
PATHANAMTHITTA	Adoor [4609]	SILENT VALLEY FLAT	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	SK FLAT	129.0	0.0	10.0	119.0	92.2	Very High
PATHANAMTHITTA	Adoor [4609]	SPJ TOWER	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	SREENAGAR	81.0	3.0	46.0	32.0	39.5	Medium
PATHANAMTHITTA	Adoor [4609]	SREENARAYANAPURAM TEMPLE	81.0	8.0	22.0	51.0	63.0	High
PATHANAMTHITTA	Adoor [4609]	SREENARAYANAPURAM-1	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Adoor [4609]	ST MARRYS SCAN	81.0	0.0	16.4	64.6	79.7	Very High
PATHANAMTHITTA	Adoor [4609]	SUB STATION T R	81.0	6.0	49.0	26.0	32.1	Medium
PATHANAMTHITTA	Adoor [4609]	SUBSTATION KAVU	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Adoor [4609]	SUNNY COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	TB ADOOR	129.0	3.0	22.0	104.0	80.6	Very High
PATHANAMTHITTA	Adoor [4609]	THARAYIL PADI	81.0	5.0	25.0	51.0	63.0	High
PATHANAMTHITTA	Adoor [4609]	THAZHATHUMON	81.0	16.0	32.0	33.0	40.7	Medium
PATHANAMTHITTA	Adoor [4609]	THENGUMTHAARA	81.0	10.0	69.2	1.8	2.2	Very Low
PATHANAMTHITTA	Adoor [4609]	THENGUVILA	81.0	11.0	26.0	44.0	54.3	High
PATHANAMTHITTA	Adoor [4609]	THUVAYOOR NORTH	81.0	10.0	18.5	52.5	64.8	High
PATHANAMTHITTA	Adoor [4609]	TRENDS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	UDHAYAGIRI	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Adoor [4609]	VADAKEDATHUKAVU PLASTIC	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	VAIDYARUPADI	81.0	3.0	60.0	18.0	22.2	Low
PATHANAMTHITTA	Adoor [4609]	VALLIKULAM	81.0	5.0	5.0	71.0	87.7	Very High
PATHANAMTHITTA	Adoor [4609]	VANJIMUKKU	129.0	6.0	68.0	55.0	42.6	Medium
PATHANAMTHITTA	Adoor [4609]	VATTATHARA PADI	81.0	0.0	28.2	52.8	65.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Adoor [4609]	VEERAPPALY VILLA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	VELLAKULANGARA	81.0	8.0	72.0	1.0	1.2	Very Low
PATHANAMTHITTA	Adoor [4609]	VELLAKULANGARA CANAN NAGAR	81.0	5.0	52.0	24.0	29.6	Medium
PATHANAMTHITTA	Adoor [4609]	VELLARAMKUNNU	81.0	26.0	11.0	44.0	54.3	High
PATHANAMTHITTA	Adoor [4609]	VILANILAM	81.0	0.0	27.0	54.0	66.7	High
PATHANAMTHITTA	Adoor [4609]	VINAYAKA	129.0	18.0	68.0	43.0	33.3	Medium
PATHANAMTHITTA	Adoor [4609]	VISWAKARMMA	81.0	0.0	27.0	54.0	66.7	High
PATHANAMTHITTA	Adoor [4609]	WYTEFORTICO CHARGING STATION	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Adoor [4609]	YAMUNA	81.0	5.0	57.8	18.2	22.5	Low
PATHANAMTHITTA	Adoor [4609]	ZEENATHU ICE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	AIKKAD	81.0	0.0	16.0	65.0	80.2	Very High
PATHANAMTHITTA	Aranmula [5535]	AIKKARA	129.0	0.0	39.0	90.0	69.8	High
PATHANAMTHITTA	Aranmula [5535]	ALTHARA	81.0	8.0	21.3	51.7	63.8	High
PATHANAMTHITTA	Aranmula [5535]	ALTHARA ALACODU	81.0	10.0	28.0	43.0	53.1	High
PATHANAMTHITTA	Aranmula [5535]	AMBADI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	ANANDHAVADY	129.0	5.0	8.0	116.0	89.9	Very High
PATHANAMTHITTA	Aranmula [5535]	ARANMULA KANIKKAVANCHI	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Aranmula [5535]	ARATTUPUZHA-MILL	129.0	3.0	64.2	61.8	47.9	Medium
PATHANAMTHITTA	Aranmula [5535]	ARATTUPUZHA-SCHOOL	81.0	0.0	29.7	51.3	63.3	High
PATHANAMTHITTA	Aranmula [5535]	ASHANKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	AYYANKOICKAL	129.0	0.0	18.0	111.0	86.0	Very High
PATHANAMTHITTA	Aranmula [5535]	B S N L	81.0	0.0	12.0	69.0	85.2	Very High
PATHANAMTHITTA	Aranmula [5535]	BHAGAVATHIPPADI	81.0	0.0	45.3	35.7	44.1	Medium
PATHANAMTHITTA	Aranmula [5535]	CHAKKITTAPADI JUNCTION	129.0	5.0	28.0	96.0	74.4	High
PATHANAMTHITTA	Aranmula [5535]	CHAKKITTAPPADY	81.0	10.0	8.0	63.0	77.8	Very High
PATHANAMTHITTA	Aranmula [5535]	CHANDRAPRA	81.0	0.0	17.5	63.5	78.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Aranmula [5535]	CHOOOLA	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Aranmula [5535]	CIVIL STATION	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	EDANATTIDAM	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Aranmula [5535]	ENGINEERING COLLEGE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	ERUMAKAD JUNCTION	81.0	6.0	21.0	54.0	66.7	High
PATHANAMTHITTA	Aranmula [5535]	ERUMAKAD POST OFFICE	81.0	3.0	3.0	75.0	92.6	Very High
PATHANAMTHITTA	Aranmula [5535]	GANAPATHY TEMPLE	81.0	3.0	41.0	37.0	45.7	Medium
PATHANAMTHITTA	Aranmula [5535]	GURUKKANKUNNU	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Aranmula [5535]	KACHERI PADY	81.0	8.0	28.0	45.0	55.6	High
PATHANAMTHITTA	Aranmula [5535]	KALARIKKODU	81.0	0.0	32.0	49.0	60.5	High
PATHANAMTHITTA	Aranmula [5535]	KANJIRAVELI AIRPORT	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Aranmula [5535]	KANJIRAVELI RATIONKADA	81.0	3.0	3.0	75.0	92.6	Very High
PATHANAMTHITTA	Aranmula [5535]	KANJIRAVELI TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Aranmula [5535]	KAVALAPLACKAL	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Aranmula [5535]	KAVUMPADY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Aranmula [5535]	KGS PETROL PUMP	129.0	0.0	10.0	119.0	92.2	Very High
PATHANAMTHITTA	Aranmula [5535]	KIDAGANOOR JUNCTION	81.0	0.0	31.3	49.7	61.4	High
PATHANAMTHITTA	Aranmula [5535]	KIDANGANOOR MARKET	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Aranmula [5535]	KIZHAKKENADA	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Aranmula [5535]	KOLLARICKAL	81.0	5.0	6.0	70.0	86.4	Very High
PATHANAMTHITTA	Aranmula [5535]	KONKULANJI	129.0	0.0	35.0	94.0	72.9	High
PATHANAMTHITTA	Aranmula [5535]	KOTTAIKKAKOM	129.0	0.0	51.0	78.0	60.5	High
PATHANAMTHITTA	Aranmula [5535]	KOZHIMALA	129.0	0.0	16.0	113.0	87.6	Very High
PATHANAMTHITTA	Aranmula [5535]	KOZHIMALA KARAYATH	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	KOZHIPPALAM	81.0	19.0	38.0	24.0	29.6	Medium
PATHANAMTHITTA	Aranmula [5535]	KULAMAPOZHY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	KULATHINKAL PADI	81.0	8.0	71.2	1.8	2.2	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Aranmula [5535]	KURICHIMUTTAM	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Aranmula [5535]	KURISINMOODU	81.0	0.0	5.3	75.7	93.5	Very High
PATHANAMTHITTA	Aranmula [5535]	KURUMTHAR	81.0	8.0	16.0	57.0	70.4	High
PATHANAMTHITTA	Aranmula [5535]	LAKA TEMPLE	81.0	9.0	43.5	28.4	35.1	Medium
PATHANAMTHITTA	Aranmula [5535]	MALAKARA ST THOMAS HOSPITAL	81.0	5.0	66.0	10.0	12.3	Low
PATHANAMTHITTA	Aranmula [5535]	MALAKKARA	129.0	0.0	25.0	104.0	80.6	Very High
PATHANAMTHITTA	Aranmula [5535]	MALAMUTTOM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	MANAKKUPPY	81.0	5.0	13.0	63.0	77.8	Very High
PATHANAMTHITTA	Aranmula [5535]	MANAKUPPY-ANGANAVADI	81.0	3.0	19.0	59.0	72.8	High
PATHANAMTHITTA	Aranmula [5535]	MANAPPALLY	129.0	6.0	13.0	110.0	85.3	Very High
PATHANAMTHITTA	Aranmula [5535]	MANAPPALLY JUNCTION	81.0	10.0	47.0	24.0	29.6	Medium
PATHANAMTHITTA	Aranmula [5535]	MANGATTUMoola	81.0	0.0	25.0	56.0	69.1	High
PATHANAMTHITTA	Aranmula [5535]	MARAMON	81.0	8.0	33.0	40.0	49.4	Medium
PATHANAMTHITTA	Aranmula [5535]	MAYALUMON	81.0	13.0	42.8	25.2	31.1	Medium
PATHANAMTHITTA	Aranmula [5535]	MEZHUVELI HARIJAN COLONY	81.0	0.0	39.2	41.8	51.5	High
PATHANAMTHITTA	Aranmula [5535]	MEZHUVELI-ALAKODU	129.0	0.0	20.0	109.0	84.5	Very High
PATHANAMTHITTA	Aranmula [5535]	MULAMTHADAM	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Aranmula [5535]	NALKALIKAL AIR PORT	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Aranmula [5535]	NALKKALIKAL	81.0	6.0	30.0	45.0	55.6	High
PATHANAMTHITTA	Aranmula [5535]	NEDIYAKALA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Aranmula [5535]	NEERVILAKAM-KANIKAVANCHI	81.0	0.0	36.0	45.0	55.6	High
PATHANAMTHITTA	Aranmula [5535]	NEERVILAKAM-SCHOOL	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Aranmula [5535]	NEERVILAKAM-TEMPLE	81.0	0.0	50.0	31.0	38.3	Medium
PATHANAMTHITTA	Aranmula [5535]	NSTC	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Aranmula [5535]	ONTHEKADU	81.0	0.0	16.0	65.0	80.2	Very High
PATHANAMTHITTA	Aranmula [5535]	OZHOORKADAVU	129.0	0.0	3.0	126.0	97.7	Very High
PATHANAMTHITTA	Aranmula [5535]	PADINJARENADA	81.0	0.0	10.0	71.0	87.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Aranmula [5535]	PALLIMUKKOM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	PALLIMUKKOM-TOWER	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Aranmula [5535]	PARAMBETH	81.0	3.0	6.0	72.0	88.9	Very High
PATHANAMTHITTA	Aranmula [5535]	PARAPPATTUPADI	81.0	16.0	42.0	23.0	28.4	Medium
PATHANAMTHITTA	Aranmula [5535]	PARUTHUPARA	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Aranmula [5535]	PERANGATIL CHURCH	81.0	8.0	3.0	70.0	86.4	Very High
PATHANAMTHITTA	Aranmula [5535]	PERANGATTIL COLONY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	PERAPPOOR	81.0	6.0	13.0	62.0	76.5	Very High
PATHANAMTHITTA	Aranmula [5535]	PULIKUNNUMALA VEERACHAKRAM	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Aranmula [5535]	PUNNAMALACHIRA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	PUNNATTUKUNNU	81.0	0.0	9.0	72.0	88.9	Very High
PATHANAMTHITTA	Aranmula [5535]	ROHINIPADI	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Aranmula [5535]	RWSS MALAKKARA	129.0	0.0	10.0	119.0	92.2	Very High
PATHANAMTHITTA	Aranmula [5535]	SATHRAM	81.0	0.0	16.0	65.0	80.2	Very High
PATHANAMTHITTA	Aranmula [5535]	SBI KIZHAKKENADA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	SREE VIDYA SAMITHI	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	THANNIKUNNU	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Aranmula [5535]	THARANGAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Aranmula [5535]	THARAYIL MUKKU	81.0	0.0	47.0	34.0	42.0	Medium
PATHANAMTHITTA	Aranmula [5535]	THOLA SCHOOL	81.0	0.0	50.0	31.0	38.3	Medium
PATHANAMTHITTA	Aranmula [5535]	THOTTAPUZHASSERY	129.0	5.0	19.0	105.0	81.4	Very High
PATHANAMTHITTA	Aranmula [5535]	THURUTHIMALA	81.0	0.0	9.0	72.0	88.9	Very High
PATHANAMTHITTA	Aranmula [5535]	THURUTHIMALA PUNJA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Aranmula [5535]	VALLANA	81.0	0.0	12.0	69.0	85.2	Very High
PATHANAMTHITTA	Aranmula [5535]	VAZHEPPADI	129.0	6.0	45.2	77.8	60.3	High
PATHANAMTHITTA	Aranmula [5535]	VAZHEPPADY LAKSHAMVEEDU	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Aranmula [5535]	VELLANGOOR	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Aranmula [5535]	VILAKKUMADAM	129.0	0.0	44.0	85.0	65.9	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	ALUMKAL PADY	81.0	0.0	4.3	76.7	94.7	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	AMPANICADU	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	AMPANICADU PALLIPADI	81.0	0.0	50.5	30.5	37.7	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	ARUVIKUZH	81.0	0.0	12.0	69.0	85.2	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	AYIROOR	202.0	0.0	30.7	171.3	84.8	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	AYIROOR LP SCHOOL	81.0	0.0	42.0	39.0	48.1	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	AYURVEDAM	81.0	3.0	5.0	73.0	90.1	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	BKM RESIDENCY	129.0	0.0	3.0	126.0	97.7	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	BONE MILL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHALAYIKKARA	81.0	5.1	36.0	39.9	49.3	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHALAYIKKARA MAIN ROAD	81.0	5.0	31.0	45.0	55.6	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHARALKUNNU	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHERUKOLPUZHA PALAM JN	81.0	0.0	32.0	49.0	60.5	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHETTIMUKKU	81.0	0.0	66.0	15.0	18.5	Low
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHETTIMUKKU BANK	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHIRA	81.0	0.0	80.8	0.2	0.2	Very Low
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHIRAPPURAM SNDP	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHIRAPURAM	81.0	5.0	3.0	73.0	90.1	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHIRAYIRAMBU YMCA	81.0	3.0	67.0	11.0	13.6	Low
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHOORANOLY	81.0	0.0	21.3	59.7	73.7	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHUVATTUPPARA	81.0	6.0	0.0	75.0	92.6	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	CHUZHIKUNNIPPADI	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	DR PRASANTH C JOHN	51.0	0.0	0.0	51.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	EARATTUPADI	81.0	5.0	35.9	40.1	49.5	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	EDAPPAVOOR	81.0	0.0	26.0	55.0	67.9	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	EDAPPAVOOR TEMPLE	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	ELAPPU	81.0	30.0	34.0	17.0	21.0	Low
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	ERAPPANTHOD	81.0	9.0	48.3	23.7	29.3	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	INDANADU	81.0	8.0	23.0	50.0	61.7	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	IVELIPADI	81.0	0.0	10.6	70.4	86.9	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KADAVEZHUMKALA	81.0	0.0	8.3	72.7	89.8	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KADAYAR	129.0	0.0	35.2	93.8	72.7	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KADAYAR DECOR	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KALAYIL PADY	81.0	0.0	11.3	69.7	86.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KALLIPPARA	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KANIYAMPADI	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KANJEETTUKARA PHC	81.0	3.0	39.0	39.0	48.1	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KANJEETUKARA	81.0	5.0	42.9	33.1	40.9	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KARINJOLATHUNDIL	81.0	0.0	19.2	61.8	76.2	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KATTAPPURAM PUMP HOUSE	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KAVUMUKKU	129.0	0.0	31.0	98.0	76.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KEEMADATHUPADI	81.0	0.0	33.0	48.0	59.3	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KOLABHAGOM	81.0	6.0	41.1	33.9	41.9	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KOODATHUMON	81.0	0.0	7.0	74.0	91.4	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KRISHI BHAVAN	81.0	3.0	35.0	43.0	53.1	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KUNNOKALI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	KURIANNOOR	81.0	0.0	56.5	24.5	30.2	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MALLOOR	129.0	0.0	5.0	124.0	96.1	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MANNAKKUZHY PUMP HOUSE	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MANNAKUZHY CHURCH	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MARAMKOLLI	81.0	8.0	25.0	48.0	59.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MARAMON	129.0	5.0	54.6	69.4	53.8	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MARAMON CONVENTION NAGAR	81.0	0.0	17.0	64.0	79.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MARUKARAPALAM	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MATHAPARA	81.0	5.0	17.0	59.0	72.8	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MATHIRAMPALLI	81.0	11.0	17.0	53.0	65.4	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MOOKKANNOOR	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MOOLACKAL PEEDIKA	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MUKKADA	81.0	3.0	6.0	72.0	88.9	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	MULAVOOR	81.0	4.0	31.0	46.0	56.8	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	NEDUMALA	81.0	0.0	40.0	41.0	50.6	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	NEDUMPRAYAR	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	NEELAMPLAVU	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	NEELAMPLAVU PUMP HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	NJUNNANTHARA	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	NJUZHOOOR	81.0	0.0	35.0	46.0	56.8	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	OCEANA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PANACHERRY	81.0	16.0	46.0	19.0	23.5	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PARUTHIMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PEKKAVUMKAL	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PERUMPARA	81.0	3.0	16.0	62.0	76.5	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PONMALA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PRAMADOM	81.0	0.0	30.0	51.0	63.0	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PRAMADOM PUMP HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PULIMUKKU	81.0	11.0	18.0	52.0	64.2	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PULIODIL	81.0	3.0	46.0	32.0	39.5	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PUTHEN SABARIMALA	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PUTHEZHAM	129.0	6.0	54.4	68.6	53.2	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PUTHIYAKAVU	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	PUTHIYAKAVU KIZHAKKENADA	81.0	3.0	36.1	41.9	51.7	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	THADIYOOR	202.0	0.0	25.0	177.0	87.6	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	THADIYOOR YMCA	129.0	0.0	22.0	107.0	82.9	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	THAYILLAM	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	THEKKUMKAL	81.0	5.0	14.0	62.0	76.5	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	THELLIYOOR KAAVU	81.0	3.0	3.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	THONIPPUZHA	81.0	0.0	37.0	44.0	54.3	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	THONIPUZHA CHAKKUTHARA	129.0	0.0	51.6	77.4	60.0	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	TROPICAL	81.0	5.0	44.0	32.0	39.5	Medium
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	UNIQUE PLAZA	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	VALAMPADY	81.0	0.0	23.0	58.0	71.6	High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	VENGALIL ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ayirur Kathakali Gramam [4608]	VETTIKADU	81.0	0.0	18.2	62.8	77.5	Very High
PATHANAMTHITTA	Changanachery [4636]	ABRAHAM-INFERTILITY	129.0	5.0	48.0	76.0	58.9	High
PATHANAMTHITTA	Changanachery [4636]	ACHAYANS	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	ADITHYA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	AJ REAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	AKSHARA NAGAR	129.0	3.0	65.2	60.8	47.1	Medium
PATHANAMTHITTA	Changanachery [4636]	AMBA	81.0	0.0	40.0	41.0	50.6	High
PATHANAMTHITTA	Changanachery [4636]	AMBADY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	AMMANKOVIL VATTAPPALLY	129.0	0.0	49.7	79.3	61.5	High
PATHANAMTHITTA	Changanachery [4636]	ANANDAPURAM	81.0	0.0	50.0	31.0	38.3	Medium
PATHANAMTHITTA	Changanachery [4636]	ANANDASRAMAM	129.0	8.0	57.3	63.7	49.4	Medium
PATHANAMTHITTA	Changanachery [4636]	ANCHUVILAKKU	81.0	5.0	14.0	62.0	76.5	Very High
PATHANAMTHITTA	Changanachery [4636]	ANDAVAN	129.0	15.0	44.0	70.0	54.3	High
PATHANAMTHITTA	Changanachery [4636]	ANGADI	129.0	20.4	108.0	0.6	0.5	Very Low
PATHANAMTHITTA	Changanachery [4636]	APSARA	202.0	0.0	25.0	177.0	87.6	Very High
PATHANAMTHITTA	Changanachery [4636]	ARAMANA KHADI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	ARIKKATHIL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Changanachery [4636]	ASSUMPTION COLLEGE	202.0	5.0	112.0	85.0	42.1	Medium
PATHANAMTHITTA	Changanachery [4636]	ATHAKUNNU	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Changanachery [4636]	ATTUVAKKARY-PARAL	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Changanachery [4636]	AVANI	81.0	23.0	21.0	37.0	45.7	Medium
PATHANAMTHITTA	Changanachery [4636]	BALIKA BHAVAN KUNNAKADU	129.0	0.0	11.0	118.0	91.5	Very High
PATHANAMTHITTA	Changanachery [4636]	BOTANICAL GARDEN	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Changanachery [4636]	BSNL PALATHRA	202.0	0.0	105.9	96.1	47.6	Medium
PATHANAMTHITTA	Changanachery [4636]	CANARA PAPER MILL ROAD	129.0	13.0	97.0	19.0	14.7	Low
PATHANAMTHITTA	Changanachery [4636]	CEENA	202.0	65.0	88.0	49.0	24.3	Low
PATHANAMTHITTA	Changanachery [4636]	CENTRAL JUNCTION	129.0	0.0	5.0	124.0	96.1	Very High
PATHANAMTHITTA	Changanachery [4636]	CHAITHANYA EV	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	CHAKKUPURAKKAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	CHANGANACHERRY CLUB	81.0	0.0	40.0	41.0	50.6	High
PATHANAMTHITTA	Changanachery [4636]	CHANGAZHIMUTTAM	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Changanachery [4636]	CHERUKARAKUNNU	81.0	0.0	24.0	57.0	70.3	High
PATHANAMTHITTA	Changanachery [4636]	CHETHIPUZHA KADAVU	202.0	8.0	88.3	105.7	52.3	High
PATHANAMTHITTA	Changanachery [4636]	CHETHIPUZHA PANCHAYATHU	202.0	9.0	91.1	101.9	50.5	High
PATHANAMTHITTA	Changanachery [4636]	CHOO LAPADY	202.0	0.0	99.5	102.5	50.8	High
PATHANAMTHITTA	Changanachery [4636]	CHRIST NAGAR	129.0	10.0	59.0	60.0	46.5	Medium
PATHANAMTHITTA	Changanachery [4636]	CHUDUKADU ANADASRAMAM	129.0	6.0	97.7	25.3	19.6	Low
PATHANAMTHITTA	Changanachery [4636]	COPTAC	81.0	0.0	54.9	26.1	32.2	Medium
PATHANAMTHITTA	Changanachery [4636]	DEVAMATHA CONVENT	129.0	0.0	67.0	62.0	48.1	Medium
PATHANAMTHITTA	Changanachery [4636]	DINE	202.0	70.0	88.0	44.0	21.8	Low
PATHANAMTHITTA	Changanachery [4636]	DIVISION OFFICE	202.0	0.0	20.0	182.0	90.1	Very High
PATHANAMTHITTA	Changanachery [4636]	EARA-PONGANAM	51.0	0.0	0.0	51.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	EAST WEST	129.0	5.0	28.0	96.0	74.4	High
PATHANAMTHITTA	Changanachery [4636]	EDIMANNIKKAL	129.0	0.0	37.4	91.6	71.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Changanachery [4636]	ELAMKUNNU CHURCH	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Changanachery [4636]	ELITE MANAKKACHIRA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	ELITE PALATHRA	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Changanachery [4636]	ELLUKUZHAY	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Changanachery [4636]	FALAHIIYA BYPASS	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Changanachery [4636]	FATHIMAPURAM OVER BRIDGE	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Changanachery [4636]	GENNXT FERTILITY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	GOLDEN TOWER	202.0	0.0	15.0	187.0	92.6	Very High
PATHANAMTHITTA	Changanachery [4636]	GREENVALLEY	81.0	5.0	8.0	68.0	84.0	Very High
PATHANAMTHITTA	Changanachery [4636]	HALLAPARA	129.0	15.0	69.9	44.1	34.2	Medium
PATHANAMTHITTA	Changanachery [4636]	HEAD POSTOFFICE	202.0	0.0	12.0	190.0	94.1	Very High
PATHANAMTHITTA	Changanachery [4636]	HIDAYATHU	129.0	8.0	53.0	68.0	52.7	High
PATHANAMTHITTA	Changanachery [4636]	HOSPITAL	202.0	0.0	61.0	141.0	69.8	High
PATHANAMTHITTA	Changanachery [4636]	HOUSING BOARD	129.0	10.0	106.0	13.0	10.1	Low
PATHANAMTHITTA	Changanachery [4636]	ICICI KAVALAM	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	IDBI BANK	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	INDUS MOTORS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	INDUSIND BANK	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KADAMPADAM-EAST	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KADAMTHOTTU TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KAKKAMTHODU	129.0	15.0	62.3	51.7	40.1	Medium
PATHANAMTHITTA	Changanachery [4636]	KAKKATTUKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KALARIKAL TOWER	81.0	5.0	27.0	49.0	60.5	High
PATHANAMTHITTA	Changanachery [4636]	KALKULATHUKAVU	81.0	3.0	34.0	44.0	54.3	High
PATHANAMTHITTA	Changanachery [4636]	KANTHARI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KAPPUZHAKKERY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KARTHIKA	81.0	0.0	27.0	54.0	66.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Changanachery [4636]	KATTAPPURAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KAVANADU BYPASS	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KAVIL TEMPLE	81.0	0.0	80.0	1.0	1.2	Very Low
PATHANAMTHITTA	Changanachery [4636]	KOCHERI	129.0	0.0	105.7	23.3	18.0	Low
PATHANAMTHITTA	Changanachery [4636]	KOHINOOR EVCS	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KOOTTUMMEL CHURCH	81.0	5.0	23.0	53.0	65.4	High
PATHANAMTHITTA	Changanachery [4636]	KOTTARAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KOYIPURAM SCHOOL	81.0	10.0	46.0	25.0	30.9	Medium
PATHANAMTHITTA	Changanachery [4636]	KTM COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	KULATHUNKAL TOWER	202.0	0.0	5.0	197.0	97.5	Very High
PATHANAMTHITTA	Changanachery [4636]	KUMARANKARY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Changanachery [4636]	KUNNAKKADU	129.0	5.0	10.0	114.0	88.4	Very High
PATHANAMTHITTA	Changanachery [4636]	KUTTAMPEROOR	202.0	2.0	50.0	150.0	74.3	High
PATHANAMTHITTA	Changanachery [4636]	KUTTISSERY KADAVU	129.0	0.0	17.7	111.3	86.3	Very High
PATHANAMTHITTA	Changanachery [4636]	KUZHICKARRY	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Changanachery [4636]	LAKSHMIPURAM PALACE	81.0	8.0	50.0	23.0	28.4	Medium
PATHANAMTHITTA	Changanachery [4636]	MADHUMoola	202.0	13.0	187.8	1.2	0.6	Very Low
PATHANAMTHITTA	Changanachery [4636]	MALEKUNNU	81.0	5.0	8.0	68.0	84.0	Very High
PATHANAMTHITTA	Changanachery [4636]	MALEPARAMPU	129.0	0.0	84.0	45.0	34.9	Medium
PATHANAMTHITTA	Changanachery [4636]	MALI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	MANAKKACHIRA	129.0	0.0	4.0	125.0	96.9	Very High
PATHANAMTHITTA	Changanachery [4636]	MANAKKACHIRA SAW MILL	202.0	0.0	29.0	173.0	85.6	Very High
PATHANAMTHITTA	Changanachery [4636]	MANCHADIKKARA	81.0	0.0	12.0	69.0	85.2	Very High
PATHANAMTHITTA	Changanachery [4636]	MANCHERIKALAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	MANCHERIL PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	MANNAM NAGAR	129.0	0.0	60.8	68.2	52.9	High
PATHANAMTHITTA	Changanachery [4636]	MARATTUKULAM	255.0	0.0	15.0	240.0	94.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Changanachery [4636]	MARETTU TOWER ANNEX	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	MARRETTU TOWER	129.0	0.0	9.1	119.9	92.9	Very High
PATHANAMTHITTA	Changanachery [4636]	MARUTHI TOURIST HOME	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	MATTATHIL	202.0	13.0	51.0	138.0	68.3	High
PATHANAMTHITTA	Changanachery [4636]	MEENCHANTHA	129.0	0.0	31.0	98.0	76.0	Very High
PATHANAMTHITTA	Changanachery [4636]	MONI	51.0	0.0	0.0	51.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	MORE MADHUMoola	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	MORKULANGARA	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Changanachery [4636]	MORKULANGARA BYPASS	202.0	25.0	133.4	43.6	21.6	Low
PATHANAMTHITTA	Changanachery [4636]	MUKKADAN TOWER	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Changanachery [4636]	MULAKUPPADAM TOWER	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Changanachery [4636]	MUNICIPALITY	202.0	0.0	19.0	183.0	90.6	Very High
PATHANAMTHITTA	Changanachery [4636]	MUTHALAVACHIRA	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Changanachery [4636]	MYTHRI SADANAM	129.0	0.0	43.0	86.0	66.7	High
PATHANAMTHITTA	Changanachery [4636]	NEAR BY MART	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	NITHYA	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	NJATTUKALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	NSS COLLEGE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	NSS HEAD OFFICE	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Changanachery [4636]	NSS HOSTEL	129.0	10.0	45.0	74.0	57.4	High
PATHANAMTHITTA	Changanachery [4636]	NSS SHOPPING COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	ORTHODOX CHURCH	81.0	10.0	47.0	24.0	29.6	Medium
PATHANAMTHITTA	Changanachery [4636]	PALAKKULAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	PALAKUNNEL	202.0	5.0	41.0	156.0	77.2	Very High
PATHANAMTHITTA	Changanachery [4636]	PALATHARA SNDP	129.0	3.0	48.6	77.4	60.0	High
PATHANAMTHITTA	Changanachery [4636]	PANACHIKKAVU	129.0	3.0	48.0	78.0	60.5	High
PATHANAMTHITTA	Changanachery [4636]	PANDAKASALAKADAVU	405.0	13.0	59.0	333.0	82.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Changanachery [4636]	PARAKKAVETTY	202.0	5.0	146.0	51.0	25.3	Medium
PATHANAMTHITTA	Changanachery [4636]	PARAL CHURCH	81.0	5.0	5.0	71.0	87.7	Very High
PATHANAMTHITTA	Changanachery [4636]	PARAL SNDP	81.0	8.0	13.0	60.0	74.1	High
PATHANAMTHITTA	Changanachery [4636]	PARATTU TEMPLE	81.0	0.0	66.6	14.4	17.8	Low
PATHANAMTHITTA	Changanachery [4636]	PATTATHIMUKKU	129.0	13.0	115.0	1.0	0.8	Very Low
PATHANAMTHITTA	Changanachery [4636]	PATTITHANAM	129.0	0.0	24.0	105.0	81.4	Very High
PATHANAMTHITTA	Changanachery [4636]	PERUMPAZHAKADAVU	81.0	0.0	30.2	50.8	62.7	High
PATHANAMTHITTA	Changanachery [4636]	PERUNNA EAST	129.0	10.0	39.5	79.5	61.6	High
PATHANAMTHITTA	Changanachery [4636]	PERUNNA RED SQUARE	202.0	0.0	101.0	101.0	50.0	High
PATHANAMTHITTA	Changanachery [4636]	PERUNNA TEMPLE	81.0	5.0	46.4	29.6	36.6	Medium
PATHANAMTHITTA	Changanachery [4636]	PERUNNA WEST	202.0	14.0	64.0	124.0	61.4	High
PATHANAMTHITTA	Changanachery [4636]	PICHIMATTAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	PMJ EAST BLOCK	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	PMJ WEST BLOCK	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	POLICE QUARTERS	202.0	8.0	58.0	136.0	67.3	High
PATHANAMTHITTA	Changanachery [4636]	POLYPRINT	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	POOVATHAR	51.0	0.0	0.0	51.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	POPULAR	202.0	0.0	13.0	189.0	93.6	Very High
PATHANAMTHITTA	Changanachery [4636]	PORYANADI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	POTHODU	129.0	0.0	51.0	78.0	60.5	High
PATHANAMTHITTA	Changanachery [4636]	PP JOSE ROAD	202.0	0.0	20.0	182.0	90.1	Very High
PATHANAMTHITTA	Changanachery [4636]	QRS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	RAILWAY	202.0	0.0	26.0	176.0	87.1	Very High
PATHANAMTHITTA	Changanachery [4636]	RAILWAY BYPASS	81.0	0.0	31.0	50.0	61.7	High
PATHANAMTHITTA	Changanachery [4636]	RAILWAY STATION	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	RELIANCE	129.0	0.0	75.0	54.0	41.8	Medium
PATHANAMTHITTA	Changanachery [4636]	RELIANCE MALL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Changanachery [4636]	RELIANCE TRENDS	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	REVENUE TOWER	405.0	0.0	0.0	405.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	ROSHAN ARCADE	81.0	0.0	56.0	25.0	30.9	Medium
PATHANAMTHITTA	Changanachery [4636]	S B COLLEGE	202.0	3.0	54.9	144.1	71.3	High
PATHANAMTHITTA	Changanachery [4636]	SAAFA BYPASS	202.0	50.0	10.2	141.8	70.2	High
PATHANAMTHITTA	Changanachery [4636]	SAMBHUVANTHARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SANGEETHA	202.0	0.0	10.0	192.0	95.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SANJEEVANI HOSPITAL	81.0	53.0	28.0	0.0	0.0	Very Low
PATHANAMTHITTA	Changanachery [4636]	SASTHAVATTOM	129.0	5.0	82.5	41.5	32.2	Medium
PATHANAMTHITTA	Changanachery [4636]	SBHS	129.0	10.0	56.0	63.0	48.8	Medium
PATHANAMTHITTA	Changanachery [4636]	SBHS GROUND	81.0	13.0	65.0	3.0	3.7	Very Low
PATHANAMTHITTA	Changanachery [4636]	SBI KAVALAM	202.0	0.0	5.0	197.0	97.5	Very High
PATHANAMTHITTA	Changanachery [4636]	SEATON RUBBERS	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SECTION OFFICE	202.0	0.0	40.0	162.0	80.2	Very High
PATHANAMTHITTA	Changanachery [4636]	SHYNI	129.0	0.0	20.0	109.0	84.5	Very High
PATHANAMTHITTA	Changanachery [4636]	SILVI-ICE PLANT	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SKY LIGHT	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SNEHATHEERAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SOUPARNIKA BYPASS	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SOUPARNIKA PAREL	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SREEKRISHNA TEMPLE	129.0	26.0	87.0	16.0	12.4	Low
PATHANAMTHITTA	Changanachery [4636]	SREENIKETHAN GELLERIA	129.0	0.0	25.0	104.0	80.6	Very High
PATHANAMTHITTA	Changanachery [4636]	SREESANKARA HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SREESANKARA MARKET	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	ST JOSEPHS PRESS ANNEX	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	SURABHI AVANI	81.0	5.0	50.0	26.0	32.1	Medium
PATHANAMTHITTA	Changanachery [4636]	SURESH NURSING HOME	81.0	10.0	57.5	13.5	16.7	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Changanachery [4636]	SWAPNA	129.0	0.0	64.0	65.0	50.4	High
PATHANAMTHITTA	Changanachery [4636]	T B ROAD	202.0	0.0	92.0	110.0	54.5	High
PATHANAMTHITTA	Changanachery [4636]	TAMIZHU MANDRAM	81.0	5.0	21.0	55.0	67.9	High
PATHANAMTHITTA	Changanachery [4636]	TENSING	129.0	3.0	51.0	75.0	58.1	High
PATHANAMTHITTA	Changanachery [4636]	THAVALAPPARA	81.0	0.0	64.0	17.0	21.0	Low
PATHANAMTHITTA	Changanachery [4636]	THIRUMALA BYPASS	81.0	5.0	56.0	20.0	24.7	Low
PATHANAMTHITTA	Changanachery [4636]	TOWN GATE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	TOWN HALL	202.0	0.0	41.0	161.0	79.7	Very High
PATHANAMTHITTA	Changanachery [4636]	UDAYAGIRI	129.0	20.0	86.0	23.0	17.8	Low
PATHANAMTHITTA	Changanachery [4636]	UDHAYAGIRI HOSPITAL	81.0	0.0	60.0	21.0	25.9	Medium
PATHANAMTHITTA	Changanachery [4636]	URAVA COMPANY	81.0	10.0	0.0	71.0	87.7	Very High
PATHANAMTHITTA	Changanachery [4636]	URAVA ROAD	81.0	5.0	61.6	14.4	17.8	Low
PATHANAMTHITTA	Changanachery [4636]	VADAKKEKARA RAILWAYCROSS	81.0	0.0	30.2	50.8	62.7	High
PATHANAMTHITTA	Changanachery [4636]	VALLIKKAVU	81.0	0.0	80.6	0.4	0.5	Very Low
PATHANAMTHITTA	Changanachery [4636]	VANDIPPETTA MAIN	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Changanachery [4636]	VANI GROUND	129.0	23.0	70.0	36.0	27.9	Medium
PATHANAMTHITTA	Changanachery [4636]	VARIYATHUKULAM	129.0	15.0	79.1	34.9	27.0	Medium
PATHANAMTHITTA	Changanachery [4636]	VARRIER SAMAJAM	81.0	0.0	45.3	35.7	44.1	Medium
PATHANAMTHITTA	Changanachery [4636]	VAZHAPALLY GROUND	81.0	10.0	23.0	48.0	59.3	High
PATHANAMTHITTA	Changanachery [4636]	VAZHAPPALY TEMPLE	202.0	13.0	78.2	110.8	54.8	High
PATHANAMTHITTA	Changanachery [4636]	VEGITABLE MARKET	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Changanachery [4636]	VELANKUNNU	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Changanachery [4636]	VETTADY MOBILE TOWER	81.0	5.0	26.0	50.0	61.7	High
PATHANAMTHITTA	Changanachery [4636]	VETTADY SCHOOL	202.0	0.0	65.0	137.0	67.8	High
PATHANAMTHITTA	Changanachery [4636]	VETTADY TEMPLE	81.0	3.0	30.0	48.0	59.3	High
PATHANAMTHITTA	Changanachery [4636]	VETTITHURUTHU CHURCH	81.0	0.0	46.0	35.0	43.2	Medium
PATHANAMTHITTA	Changanachery [4636]	VETTITHURUTHU SNBP	81.0	0.0	24.0	57.0	70.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Changanachery [4636]	VEZHAKKADU	202.0	0.0	51.2	150.8	74.6	High
PATHANAMTHITTA	Changanachery [4636]	VIJAYANANDA	202.0	0.0	38.0	164.0	81.2	Very High
PATHANAMTHITTA	Changanachery [4636]	VIMCO	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Changanachery [4636]	WAREHOUSE	129.0	5.0	15.0	109.0	84.5	Very High
PATHANAMTHITTA	Changanachery [4636]	Y M S LODGE	81.0	0.0	38.0	43.0	53.1	High
PATHANAMTHITTA	Elavumthitta [4616]	AKAY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	AKKAYI	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Elavumthitta [4616]	ALUMKUTTY	81.0	3.0	17.0	61.0	75.3	Very High
PATHANAMTHITTA	Elavumthitta [4616]	ANAPPARA	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	ATHARAPPADU	81.0	6.0	0.0	75.0	92.6	Very High
PATHANAMTHITTA	Elavumthitta [4616]	ATHRAPPATT	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Elavumthitta [4616]	B-ED	81.0	0.0	23.0	58.0	71.6	High
PATHANAMTHITTA	Elavumthitta [4616]	BATHEL	81.0	3.0	0.0	78.0	96.3	Very High
PATHANAMTHITTA	Elavumthitta [4616]	BED COLLEGE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	BETHEL	81.0	8.0	30.0	43.0	53.1	High
PATHANAMTHITTA	Elavumthitta [4616]	BHAGAVATHYKKUNNU	81.0	3.0	31.2	46.8	57.8	High
PATHANAMTHITTA	Elavumthitta [4616]	BSNL ELANTHOOR	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Elavumthitta [4616]	C S-I	81.0	3.0	50.0	28.0	34.6	Medium
PATHANAMTHITTA	Elavumthitta [4616]	CHAKKALAMANNIL	81.0	8.0	3.0	70.0	86.4	Very High
PATHANAMTHITTA	Elavumthitta [4616]	CHAKKALAMANNIL CASHEW FACTORY	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Elavumthitta [4616]	CHAKKITTA	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Elavumthitta [4616]	HELLAKULANJI	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Elavumthitta [4616]	CHENNEERKKARA	81.0	5.0	0.0	76.0	93.8	Very High
PATHANAMTHITTA	Elavumthitta [4616]	CHIRACKAROTTU PADI	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Elavumthitta [4616]	CHIRAKAROTTU PADI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	CHURCHPADI	81.0	6.0	53.0	22.0	27.2	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Elavumthitta [4616]	CSI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	DINACHAKRA-OONNUKAL	81.0	5.0	10.0	66.0	81.5	Very High
PATHANAMTHITTA	Elavumthitta [4616]	EDAPARIYARAM	81.0	5.0	0.0	76.0	93.8	Very High
PATHANAMTHITTA	Elavumthitta [4616]	EDAPARIYARAM-HS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	EDAPPARIYARAM	81.0	3.0	27.0	51.0	63.0	High
PATHANAMTHITTA	Elavumthitta [4616]	EDAPPARIYARAM-2	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Elavumthitta [4616]	ELANTHOOR MARKET	81.0	0.0	25.1	55.9	69.0	High
PATHANAMTHITTA	Elavumthitta [4616]	ELANTHOOR-NEDUVELY	129.0	0.0	39.0	90.0	69.7	High
PATHANAMTHITTA	Elavumthitta [4616]	ELANTHUR NOBLE PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	ELAVUMTHITTA MARKET	129.0	0.0	51.0	78.0	60.5	High
PATHANAMTHITTA	Elavumthitta [4616]	FEDERAL BANK ELANTHOOR	81.0	0.0	32.0	49.0	60.5	High
PATHANAMTHITTA	Elavumthitta [4616]	HILLPARK	81.0	3.0	14.5	63.5	78.4	Very High
PATHANAMTHITTA	Elavumthitta [4616]	ITI	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Elavumthitta [4616]	J B	81.0	0.0	16.6	64.4	79.5	Very High
PATHANAMTHITTA	Elavumthitta [4616]	KACHIRA	81.0	0.0	26.2	54.8	67.6	High
PATHANAMTHITTA	Elavumthitta [4616]	KACHORAPADI	81.0	0.0	32.0	49.0	60.5	High
PATHANAMTHITTA	Elavumthitta [4616]	KAITHAKKADE	81.0	0.0	26.3	54.7	67.5	High
PATHANAMTHITTA	Elavumthitta [4616]	KAITHAVANA	81.0	5.0	51.0	25.0	30.9	Medium
PATHANAMTHITTA	Elavumthitta [4616]	KARACKATTUPADI	81.0	0.0	50.0	31.0	38.3	Medium
PATHANAMTHITTA	Elavumthitta [4616]	KHADHI ELANTHOOR	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Elavumthitta [4616]	KOLLAMPARA	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Elavumthitta [4616]	KOLLANTETHU PADI	81.0	0.0	26.0	55.0	67.9	High
PATHANAMTHITTA	Elavumthitta [4616]	KUZHICKATTIL PADI	81.0	3.0	21.0	57.0	70.4	High
PATHANAMTHITTA	Elavumthitta [4616]	MANIMALA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Elavumthitta [4616]	MELATHEMUKKU	81.0	5.0	56.3	19.7	24.3	Low
PATHANAMTHITTA	Elavumthitta [4616]	MEMURIYIL PLAZA-PRIVATE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	MUDACKANICKAL	81.0	5.0	34.0	42.0	51.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Elavumthitta [4616]	MUKKADA	129.0	25.0	87.9	16.1	12.5	Low
PATHANAMTHITTA	Elavumthitta [4616]	MULLOOR	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	MULLOOR	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	MUNJANATTU PADI	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Elavumthitta [4616]	MUTTATHUKONAM	81.0	5.0	48.3	27.7	34.2	Medium
PATHANAMTHITTA	Elavumthitta [4616]	MYLADUMPARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	NALLANIKKUNNU	81.0	0.0	23.7	57.3	70.8	High
PATHANAMTHITTA	Elavumthitta [4616]	NALLANIKKUNNU-KWA	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	NAMAKKUZHY	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Elavumthitta [4616]	NARANGATTUPADI	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Elavumthitta [4616]	NEDIYAKALA	81.0	5.0	41.0	35.0	43.2	Medium
PATHANAMTHITTA	Elavumthitta [4616]	NEDUMKULAM	81.0	0.0	39.0	42.0	51.9	High
PATHANAMTHITTA	Elavumthitta [4616]	NJUNNICKAL	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Elavumthitta [4616]	NURSING COLLEGE-100 KVA	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Elavumthitta [4616]	OONNUKAL	129.0	5.0	62.0	62.0	48.1	Medium
PATHANAMTHITTA	Elavumthitta [4616]	OONUKAL	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	PALACHUVADU	81.0	5.0	54.0	22.0	27.2	Medium
PATHANAMTHITTA	Elavumthitta [4616]	PANACKAL	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Elavumthitta [4616]	PARAIKKAL PADI	81.0	0.0	29.0	52.0	64.2	High
PATHANAMTHITTA	Elavumthitta [4616]	PATHAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	PATHAL-1	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Elavumthitta [4616]	POOKKODU	81.0	0.0	29.4	51.6	63.7	High
PATHANAMTHITTA	Elavumthitta [4616]	POOVANMALA	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Elavumthitta [4616]	PRAKKANAM	129.0	0.0	38.5	90.5	70.1	High
PATHANAMTHITTA	Elavumthitta [4616]	PULINTHITTA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	PULLAMALA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Elavumthitta [4616]	RAMANCHIRA	81.0	0.0	39.0	42.0	51.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Elavumthitta [4616]	SAHRIDAYAVEDI	81.0	3.0	3.0	75.0	92.6	Very High
PATHANAMTHITTA	Elavumthitta [4616]	SBI ELAVUMTHITTA	81.0	0.0	12.0	69.0	85.2	Very High
PATHANAMTHITTA	Elavumthitta [4616]	SNDP	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	SOUHRIDAYAVEDHI	81.0	0.0	17.0	64.0	79.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	TELEPHONE EXCHANGE	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Elavumthitta [4616]	THALATHAI PADI	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	THOZHUVZCODE	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Elavumthitta [4616]	THUNDITHEKKEMURUPE	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Elavumthitta [4616]	THUNDUCADU	81.0	0.0	44.3	36.7	45.3	Medium
PATHANAMTHITTA	Elavumthitta [4616]	TRIVENI	81.0	5.0	26.0	50.0	61.7	High
PATHANAMTHITTA	Elavumthitta [4616]	URBAN INN	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Elavumthitta [4616]	VADAKKEVILA	81.0	3.0	37.2	40.8	50.3	High
PATHANAMTHITTA	Elavumthitta [4616]	VALIYAVATTOM	81.0	0.0	35.0	46.0	56.8	High
PATHANAMTHITTA	Elavumthitta [4616]	VALIYAVATTOM HOSPITAL	81.0	8.0	29.0	44.0	54.3	High
PATHANAMTHITTA	Elavumthitta [4616]	VALUTHARA	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Enathu [4806]	AATTIRAPADY	81.0	10.0	52.0	19.0	23.5	Low
PATHANAMTHITTA	Enathu [4806]	ALTHARA	81.0	21.0	57.3	2.7	3.3	Very Low
PATHANAMTHITTA	Enathu [4806]	ARATTUPOZHA	81.0	3.0	23.0	55.0	67.9	High
PATHANAMTHITTA	Enathu [4806]	AYYANKOIKKAL	81.0	9.0	46.0	26.0	32.1	Medium
PATHANAMTHITTA	Enathu [4806]	BEDAM MUKKU	81.0	5.0	16.5	59.5	73.5	High
PATHANAMTHITTA	Enathu [4806]	BLOCKPADI	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Enathu [4806]	CAK TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Enathu [4806]	CHAITHANYA MARBLES	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Enathu [4806]	CHATHANNOOPUZHA	81.0	0.0	78.8	2.2	2.7	Very Low
PATHANAMTHITTA	Enathu [4806]	CHEEKKAN KALLU	81.0	3.0	10.0	68.0	84.0	Very High
PATHANAMTHITTA	Enathu [4806]	CHEMPAKASSERY	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Enathu [4806]	CHINNAKKADA	81.0	3.0	16.0	62.0	76.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Enathu [4806]	CHOORAKODU VAYANASALA	81.0	6.0	50.0	25.0	30.9	Medium
PATHANAMTHITTA	Enathu [4806]	DALAVA	81.0	0.0	39.9	41.1	50.8	High
PATHANAMTHITTA	Enathu [4806]	DALAVA SMARAKOM	81.0	0.0	29.0	52.0	64.2	High
PATHANAMTHITTA	Enathu [4806]	ELANGAMANGALAM C S I	81.0	4.0	24.0	53.0	65.4	High
PATHANAMTHITTA	Enathu [4806]	ELANGAMANGALAM KULANJIYIL	81.0	0.0	32.0	49.0	60.5	High
PATHANAMTHITTA	Enathu [4806]	ELANGAMANGALAM VAYAL	81.0	15.0	14.0	52.0	64.2	High
PATHANAMTHITTA	Enathu [4806]	ELANJIKODE	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Enathu [4806]	ENATHU BRIDGE	129.0	0.0	8.0	121.0	93.8	Very High
PATHANAMTHITTA	Enathu [4806]	ENATHU NORTHU	81.0	0.0	31.0	50.0	61.7	High
PATHANAMTHITTA	Enathu [4806]	ENATHU SUBSTATION	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Enathu [4806]	ENATHU TOWER	129.0	0.0	5.0	124.0	96.1	Very High
PATHANAMTHITTA	Enathu [4806]	ENATHU TOWN	202.0	10.0	23.1	168.8	83.6	Very High
PATHANAMTHITTA	Enathu [4806]	ENATHU UPS	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Enathu [4806]	GOEC EV STATION KILIVAYAL	129.0	0.0	25.0	104.0	80.6	Very High
PATHANAMTHITTA	Enathu [4806]	HUTCH TOWER	81.0	3.0	14.8	63.2	78.0	Very High
PATHANAMTHITTA	Enathu [4806]	KALAMALA	129.0	4.0	21.0	104.0	80.6	Very High
PATHANAMTHITTA	Enathu [4806]	KALAYIL	81.0	29.0	50.0	2.0	2.5	Very Low
PATHANAMTHITTA	Enathu [4806]	KALLUVILATAYHU	81.0	6.0	44.0	31.0	38.3	Medium
PATHANAMTHITTA	Enathu [4806]	KANJIRATHINMMOODU	81.0	0.0	40.0	41.0	50.6	High
PATHANAMTHITTA	Enathu [4806]	KANNAMKUNNIL	81.0	4.0	3.0	74.0	91.4	Very High
PATHANAMTHITTA	Enathu [4806]	KANNATTU KUNNU	81.0	16.8	32.0	32.2	39.8	Medium
PATHANAMTHITTA	Enathu [4806]	KANNIMALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Enathu [4806]	KAYARMUTTAM	81.0	3.0	10.0	68.0	84.0	Very High
PATHANAMTHITTA	Enathu [4806]	KEERATHIL	129.0	8.0	16.0	105.0	81.4	Very High
PATHANAMTHITTA	Enathu [4806]	KESARY JUNCTION	81.0	3.0	46.0	32.0	39.5	Medium
PATHANAMTHITTA	Enathu [4806]	KILIVAYAL COLLEGE	81.0	8.0	13.0	60.0	74.1	High
PATHANAMTHITTA	Enathu [4806]	KILIVAYAL MARKET	81.0	0.0	6.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Enathu [4806]	KIZHAKKUPURAM	81.0	5.0	32.0	44.0	54.3	High
PATHANAMTHITTA	Enathu [4806]	KIZHAKKUPURAM H S	81.0	6.0	16.0	59.0	72.8	High
PATHANAMTHITTA	Enathu [4806]	KOCHUVILAPADY	81.0	0.0	36.0	45.0	55.6	High
PATHANAMTHITTA	Enathu [4806]	KONNAMON	81.0	3.0	14.0	64.0	79.0	Very High
PATHANAMTHITTA	Enathu [4806]	KOONAMPALAVILA	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Enathu [4806]	MALANKAVU	81.0	3.0	3.0	75.0	92.6	Very High
PATHANAMTHITTA	Enathu [4806]	MAMPILA	129.0	0.0	41.0	88.0	68.2	High
PATHANAMTHITTA	Enathu [4806]	MANAPPURATHUPADY	129.0	14.0	20.0	95.0	73.6	High
PATHANAMTHITTA	Enathu [4806]	MANCHADI MUKKU	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Enathu [4806]	MANDACHANPARA	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Enathu [4806]	MANNADI MOSQUE	129.0	6.6	71.0	51.4	39.8	Medium
PATHANAMTHITTA	Enathu [4806]	MANNADY	202.0	7.0	99.0	96.0	47.5	Medium
PATHANAMTHITTA	Enathu [4806]	MANNADY MARKET	81.0	8.0	73.0	0.0	0.0	Very Low
PATHANAMTHITTA	Enathu [4806]	MANNADY RELIANCE	81.0	10.0	29.0	42.0	51.9	High
PATHANAMTHITTA	Enathu [4806]	MANNADY TEMPLE	81.0	3.0	30.0	48.0	59.3	High
PATHANAMTHITTA	Enathu [4806]	MANNADY WATER WORKS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Enathu [4806]	METHUKUMMEL CASHEW FACTORY	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Enathu [4806]	METHUKUMMEL JUNCTION	81.0	0.0	28.8	52.2	64.4	High
PATHANAMTHITTA	Enathu [4806]	METHUKUMMEL VAYAL	81.0	3.0	17.0	61.0	75.3	Very High
PATHANAMTHITTA	Enathu [4806]	MUDIPPURA	81.0	0.0	46.0	35.0	43.2	Medium
PATHANAMTHITTA	Enathu [4806]	MUDIPPURA H S	81.0	17.2	63.7	0.1	0.1	Very Low
PATHANAMTHITTA	Enathu [4806]	MULLAVELIL	81.0	3.0	31.0	47.0	58.0	High
PATHANAMTHITTA	Enathu [4806]	MULLOOR	81.0	0.0	12.0	69.0	85.2	Very High
PATHANAMTHITTA	Enathu [4806]	MYLADIKKAL	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Enathu [4806]	NADAKKAVU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Enathu [4806]	NADUVILEKARA	81.0	0.0	25.0	56.0	69.1	High
PATHANAMTHITTA	Enathu [4806]	NILAMEL	81.0	13.0	23.5	44.5	54.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Enathu [4806]	OORALATHIL	81.0	4.0	8.0	69.0	85.2	Very High
PATHANAMTHITTA	Enathu [4806]	PADANILAM	129.0	7.0	40.0	82.0	63.6	High
PATHANAMTHITTA	Enathu [4806]	PATTIYARA	81.0	8.0	21.0	52.0	64.2	High
PATHANAMTHITTA	Enathu [4806]	POLICE STATION	81.0	0.0	16.0	65.0	80.2	Very High
PATHANAMTHITTA	Enathu [4806]	PULIKKAVILA	20.0	0.0	14.4	5.6	27.8	Medium
PATHANAMTHITTA	Enathu [4806]	PULIMALA	81.0	3.0	11.0	67.0	82.7	Very High
PATHANAMTHITTA	Enathu [4806]	PUTHUSSEERIBHAGOM	129.0	0.0	34.4	94.7	73.4	High
PATHANAMTHITTA	Enathu [4806]	SCORPIO	81.0	3.0	8.0	70.0	86.4	Very High
PATHANAMTHITTA	Enathu [4806]	SNDP	81.0	5.0	22.0	54.0	66.7	High
PATHANAMTHITTA	Enathu [4806]	THATTARUPADY	81.0	6.0	51.2	23.8	29.4	Medium
PATHANAMTHITTA	Enathu [4806]	THATTARUPADY CASHEW	81.0	0.0	30.0	51.0	63.0	High
PATHANAMTHITTA	Enathu [4806]	THENGAMANMADAM	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Enathu [4806]	THUNDATHIL PADY	81.0	5.0	3.0	73.0	90.1	Very High
PATHANAMTHITTA	Enathu [4806]	VADAKKADATHUKAVU HS	129.0	0.0	35.0	94.0	72.9	High
PATHANAMTHITTA	Enathu [4806]	VADAKKEDATHUCAVU MARKET	81.0	5.0	57.0	19.0	23.5	Low
PATHANAMTHITTA	Enathu [4806]	VARIKKAPLAMMOODU	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Enathu [4806]	VARIKKAVELIL	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Enathu [4806]	VATTATHINAVILA	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Enathu [4806]	VAYALA	129.0	3.0	6.0	120.0	93.0	Very High
PATHANAMTHITTA	Enathu [4806]	VINAYAKA	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Enathu [4806]	YAMUNA MINI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	100PATHIKKAKKAVU	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	101POLICE STATION	81.0	0.0	30.0	51.0	63.0	High
PATHANAMTHITTA	Erumely [5637]	102PREMIER	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	103PROPOSE	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Erumely [5637]	105RELIANCE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	106SABARI HOMES	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Erumely [5637]	108SREENIPURAM	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	109ST MARY	81.0	0.0	30.3	50.7	62.6	High
PATHANAMTHITTA	Erumely [5637]	10ACRE MOOKKEMPETTY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	110ST THOMAS	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Erumely [5637]	111ST THOMAS SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	112TATA	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Erumely [5637]	113TECHNICAL SCHOOL	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	114THALAYINATHADAM	81.0	3.0	9.0	69.0	85.2	Very High
PATHANAMTHITTA	Erumely [5637]	115THAMPURAMKUNNU	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Erumely [5637]	116THAVALAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	117THIRUVALLUR SCHOOL	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	118THOOMKUZHIPPADY	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Erumely [5637]	119THULAPPALLY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	11ARAYANJILIMON	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Erumely [5637]	120THULAPPALLY BSNL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	121THUMARAMPARA	129.0	0.0	14.0	115.0	89.1	Very High
PATHANAMTHITTA	Erumely [5637]	122TOWER ALAPPATTU	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Erumely [5637]	123AMAKUNNU TOWER	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Erumely [5637]	124UMMIKKUPPA	81.0	5.0	8.0	68.0	84.0	Very High
PATHANAMTHITTA	Erumely [5637]	125VANDACKAL COLONY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	126VATTAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	127VAZHAKKALA	81.0	0.0	26.0	55.0	67.9	High
PATHANAMTHITTA	Erumely [5637]	128VELLANADI ESTATE	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	12ARUVACHAMKUZHY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	14ASSISI	129.0	5.0	43.0	81.0	62.8	High
PATHANAMTHITTA	Erumely [5637]	18AVE MARIA	81.0	0.0	17.0	64.0	79.0	Very High
PATHANAMTHITTA	Erumely [5637]	19AYYANMALA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Erumely [5637]	1AITHALAPPADY	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Erumely [5637]	20BSNL ERUMELY	81.0	5.0	47.3	28.7	35.4	Medium
PATHANAMTHITTA	Erumely [5637]	21CHARALA	129.0	16.0	82.0	31.0	24.0	Low
PATHANAMTHITTA	Erumely [5637]	23CHEMPAKAPPARA	81.0	3.0	47.0	31.0	38.3	Medium
PATHANAMTHITTA	Erumely [5637]	24CHERUVALLY ATTORAM	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Erumely [5637]	25EDAKADATHY	129.0	0.0	8.0	121.0	93.8	Very High
PATHANAMTHITTA	Erumely [5637]	26ELAPUMKAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	27ELIVALIKKARA	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Erumely [5637]	2ALAPPATTUPADY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	30ERUMELY NO-2	129.0	0.0	16.0	113.0	87.6	Very High
PATHANAMTHITTA	Erumely [5637]	32ERUTHUVAPUZHA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Erumely [5637]	33EZHUKUMON	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	34HIGH RANGE	81.0	3.0	8.0	70.0	86.4	Very High
PATHANAMTHITTA	Erumely [5637]	35 ACRE	81.0	8.0	35.0	38.0	46.9	Medium
PATHANAMTHITTA	Erumely [5637]	35TH ANGANVADI	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Erumely [5637]	36HOME GROWN	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	37IRUMBOONNIKKARA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	38IRUMPOONNIKKARA	81.0	3.0	8.5	69.5	85.8	Very High
PATHANAMTHITTA	Erumely [5637]	3ALUMINIUM	129.0	0.0	15.0	114.0	88.4	Very High
PATHANAMTHITTA	Erumely [5637]	40 ACRE	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Erumely [5637]	43KANAKAPALAM VODAFONE	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Erumely [5637]	44KANAKAPPALAM MTHS	129.0	0.0	30.0	99.0	76.7	Very High
PATHANAMTHITTA	Erumely [5637]	45KANAMALA B S N L	129.0	0.0	21.0	108.0	83.7	Very High
PATHANAMTHITTA	Erumely [5637]	46KANAMALA JUNCTION	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Erumely [5637]	47KANAMALA NORTH	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	48KANNIMALA PARAMADA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Erumely [5637]	49KANTHARIVALAVU	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Erumely [5637]	4TH MILE	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Erumely [5637]	50KARIMPINTHODU	81.0	0.0	46.0	35.0	43.2	Medium
PATHANAMTHITTA	Erumely [5637]	51KARINKALLUMMOOZHY	81.0	0.0	44.6	36.4	44.9	Medium
PATHANAMTHITTA	Erumely [5637]	52KARITHOD-25KVA	20.0	0.0	0.0	20.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	53KARITHODU	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Erumely [5637]	54KAVALAM PADI	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Erumely [5637]	55KAVUGUMKUZHY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	56KEERITHODU PLINTH	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	57KEERITHODU TOWER NO-1	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	59KISUMAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	5TH MILE	81.0	3.0	15.0	63.0	77.8	Very High
PATHANAMTHITTA	Erumely [5637]	60KOCHURAMAN ROAD	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Erumely [5637]	61KOCHUTHOTTAM	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	62KODITHOTTAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	63KODITHOTTAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	64KORATTY	129.0	3.0	25.7	100.3	77.7	Very High
PATHANAMTHITTA	Erumely [5637]	65KORATTY WATER WORKS	81.0	0.0	14.8	66.2	81.7	Very High
PATHANAMTHITTA	Erumely [5637]	67KOT ROAD PALLIPPADY	81.0	0.0	31.0	50.0	61.7	High
PATHANAMTHITTA	Erumely [5637]	68KURUVAMOOZHY	81.0	3.0	16.0	62.0	76.5	Very High
PATHANAMTHITTA	Erumely [5637]	69KURUVAMOOZHY PALLIPPADY	81.0	0.0	21.4	59.6	73.5	High
PATHANAMTHITTA	Erumely [5637]	6TH MILE	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Erumely [5637]	70KUTTAPPAIPPADY	81.0	0.0	40.0	41.0	50.6	High
PATHANAMTHITTA	Erumely [5637]	71MACKALKAVALA	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	72MANANGALLOR	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	73MANDIRAMPADI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	74MANIPUZHA	81.0	19.0	62.0	0.0	0.0	Very Low
PATHANAMTHITTA	Erumely [5637]	75MANJALARUVI	81.0	0.0	20.0	61.0	75.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Erumely [5637]	76MANJALARUVI TOWER	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	77MATTANNOORKKARA	81.0	3.0	14.0	64.0	79.0	Very High
PATHANAMTHITTA	Erumely [5637]	78MAZINN FOODS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	79MES COLLEGE	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Erumely [5637]	7AMAKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	80M E S K W A	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	81MOOKKANPETTY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	82MOOLAKKAYAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	83MUKKOOTTUTHARA	405.0	0.0	18.0	387.0	95.6	Very High
PATHANAMTHITTA	Erumely [5637]	84MUTTAPPALLY	81.0	5.0	0.0	76.0	93.8	Very High
PATHANAMTHITTA	Erumely [5637]	85NARANAMTHODE	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Erumely [5637]	86NEDUMKAVUVAYAL	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Erumely [5637]	87NEDUMKAVUVAYAL I T C	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Erumely [5637]	88NERCHAPPARA	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Erumely [5637]	89ORUMKALKADAVU PALAM	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Erumely [5637]	8AMBALAVALAVU	81.0	5.0	19.0	57.0	70.4	High
PATHANAMTHITTA	Erumely [5637]	90ORUMKALTHADAM	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Erumely [5637]	91PALAM ANGELVALLEY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	92PALLIPPADY ANGELVALLEY	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Erumely [5637]	93PALLIPPADY ARAYANJILIMON	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	94PALLIPPADY ELIVALIKKARA	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Erumely [5637]	95PANACHEPPARA	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Erumely [5637]	96PANACKAVAYAL	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Erumely [5637]	97PANAPILAVU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	99PANAPILAVU TOWER NO-2	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	9ARATTUKAYAM	81.0	3.0	4.0	74.0	91.4	Very High
PATHANAMTHITTA	Erumely [5637]	9TH COLONY EDAKADATHY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Erumely [5637]	ANNADANAMANDAPAM	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	ARUVICKAL MOOKKENPETTY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Erumely [5637]	AT ATTORAM EDAKADATHY	81.0	11.8	0.0	69.2	85.4	Very High
PATHANAMTHITTA	Erumely [5637]	CHEENIMARAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	EAST ELIVALIKKARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	EV BPCL	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	EV CHEMPATHUNKAL	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	EV IOCL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	HOSPITAL ASSISI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	HPCL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	KALAKETTY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	KALYANI	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	KAMBITHOTTAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	KEERITHODU TOWER NO-2	20.0	0.0	0.0	20.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	KK TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	KOT ROAD	51.0	0.0	14.0	37.0	72.5	High
PATHANAMTHITTA	Erumely [5637]	MARKET ERUMELY	129.0	0.0	52.0	77.0	59.7	High
PATHANAMTHITTA	Erumely [5637]	MATTANNORKARA VAYANASALA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Erumely [5637]	NO-1 ERUMELY	202.0	0.0	9.4	192.6	95.3	Very High
PATHANAMTHITTA	Erumely [5637]	NURSING COLLEGE ASSISSI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	PANAPILAVU TOWER NO-1	51.0	0.0	0.0	51.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	RANGE OFFICE	129.0	0.0	13.0	116.0	89.9	Very High
PATHANAMTHITTA	Erumely [5637]	SOUTH INDIAN BANK	129.0	5.0	25.0	99.0	76.7	Very High
PATHANAMTHITTA	Erumely [5637]	VAVAR SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Erumely [5637]	VICTORIA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	AKG COLONY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	ALAYILPADY	81.0	5.0	22.0	54.0	66.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Ezhamkulam [4611]	ALIAHA INDUSTRIES	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	AMBALATHARA	81.0	3.0	13.7	64.3	79.4	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	AMBALATHINALPADI	81.0	5.0	19.0	57.0	70.4	High
PATHANAMTHITTA	Ezhamkulam [4611]	AMRUTHA VIDYALAYAM	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Ezhamkulam [4611]	ANAMKOTTU	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Ezhamkulam [4611]	ANCHUMALA	81.0	0.0	14.3	66.7	82.3	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	ANCHUMURIKADA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	ARUKALICKAL	129.0	13.0	44.0	72.0	55.8	High
PATHANAMTHITTA	Ezhamkulam [4611]	AYANICKAMUKAL	81.0	3.0	14.0	64.0	79.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	BETHANIA	81.0	5.0	0.0	76.0	93.8	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	CARMAL CASHEW	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	CHAKKALAMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	CHALAYILMUKKU	81.0	0.0	11.3	69.7	86.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	CHAVARUPADY	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	CHAYALODU	81.0	3.0	30.0	48.0	59.3	High
PATHANAMTHITTA	Ezhamkulam [4611]	CHAYALODU CROSS	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	CHERUVA	81.0	8.0	36.3	36.7	45.3	Medium
PATHANAMTHITTA	Ezhamkulam [4611]	CHETTUKUZHYY	20.0	0.0	0.0	20.0	100.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	CHIRANICKAL	202.0	0.0	22.0	180.0	89.1	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	CHIRANIKKAL KWA	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	CHOORAKUNNIL	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	EETTIMOODU	81.0	8.0	14.0	59.0	72.8	High
PATHANAMTHITTA	Ezhamkulam [4611]	ELAMSOORANADU	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	EMSON	129.0	0.0	8.0	121.0	93.8	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	ERATHVAKUNNU	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	EZHAMKULAM	202.0	10.0	45.0	147.0	72.8	High
PATHANAMTHITTA	Ezhamkulam [4611]	EZHAMKULAM TEMPLE	81.0	0.0	27.0	54.0	66.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Ezhamkulam [4611]	GANDI SMARAKAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	GIRIDEVAN MALANADA	81.0	5.0	0.0	76.0	93.8	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	ISMAILPADI	81.0	0.0	34.0	47.0	58.0	High
PATHANAMTHITTA	Ezhamkulam [4611]	KAITHAPARAMBU	81.0	0.0	9.0	72.0	88.9	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	KALLETHU	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	KALLUMMUKAL	81.0	5.0	9.0	67.0	82.7	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	KALLUVILAPADY	81.0	3.0	39.0	39.0	48.1	Medium
PATHANAMTHITTA	Ezhamkulam [4611]	KANDATHIL	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Ezhamkulam [4611]	KANDATHIL BUILDING	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	KAPPIL	81.0	0.0	23.0	58.0	71.6	High
PATHANAMTHITTA	Ezhamkulam [4611]	KARACKAL	129.0	3.0	47.0	79.0	61.2	High
PATHANAMTHITTA	Ezhamkulam [4611]	KARINCHETIL	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	KAVANAL	81.0	5.0	14.0	62.0	76.5	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	KETTUNGALPADY	81.0	0.0	27.6	53.4	65.9	High
PATHANAMTHITTA	Ezhamkulam [4611]	KILIKKODE	129.0	11.0	17.0	101.0	78.3	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	KODIYATTU KAVU	81.0	8.0	31.0	42.0	51.9	High
PATHANAMTHITTA	Ezhamkulam [4611]	KODUMAN CATHOLIC	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Ezhamkulam [4611]	KODUMON CHIRA	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Kadambanad [4613]	4TH MILE	81.0	8.0	21.3	51.7	63.8	High
PATHANAMTHITTA	Kadambanad [4613]	7TH MILE	129.0	8.0	71.0	50.0	38.8	Medium
PATHANAMTHITTA	Kadambanad [4613]	AMBALATHUMBHAGAM	81.0	3.0	19.3	58.7	72.5	High
PATHANAMTHITTA	Kadambanad [4613]	AMPADI	81.0	5.0	20.3	55.7	68.8	High
PATHANAMTHITTA	Kadambanad [4613]	ANAMUKKU	81.0	0.0	43.3	37.7	46.6	Medium
PATHANAMTHITTA	Kadambanad [4613]	ANTHICHIRA	81.0	3.0	14.3	63.7	78.6	Very High
PATHANAMTHITTA	Kadambanad [4613]	ANTHICHIRA MARTHOMA CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	ARAYALAPPURAM	81.0	8.0	43.8	29.2	36.0	Medium
PATHANAMTHITTA	Kadambanad [4613]	ARAYALAPURAM GURUMANDIRAM	81.0	3.0	15.0	63.0	77.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Kadambanad [4613]	ATTUKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	BHARANIKAVU	81.0	3.0	12.0	66.0	81.5	Very High
PATHANAMTHITTA	Kadambanad [4613]	BHOOTHAKKUZHY	81.0	14.0	41.0	26.0	32.1	Medium
PATHANAMTHITTA	Kadambanad [4613]	C P MUKKU	81.0	8.0	39.0	34.0	42.0	Medium
PATHANAMTHITTA	Kadambanad [4613]	CANAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	CHEEKAKADAVU	129.0	14.0	25.8	89.2	69.1	High
PATHANAMTHITTA	Kadambanad [4613]	CHELOOR	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	CHETTIYARUMUKKU	81.0	5.0	58.0	18.0	22.2	Low
PATHANAMTHITTA	Kadambanad [4613]	CHILANKA	81.0	22.0	14.0	45.0	55.6	High
PATHANAMTHITTA	Kadambanad [4613]	CHUMADUTHANGI JN	81.0	0.0	80.0	1.0	1.2	Very Low
PATHANAMTHITTA	Kadambanad [4613]	DEEPAM LINE	81.0	3.0	12.0	66.0	81.5	Very High
PATHANAMTHITTA	Kadambanad [4613]	DEVAGIRI	81.0	10.0	15.0	56.0	69.1	High
PATHANAMTHITTA	Kadambanad [4613]	DURGA CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	EBANAZER	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Kadambanad [4613]	EDAKKAD MARKET	202.0	29.0	127.3	45.7	22.6	Low
PATHANAMTHITTA	Kadambanad [4613]	EDAKKAD UNNATHY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	EDAKKAD WATER WORKS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	EDAYANPALAM	81.0	3.0	9.0	69.0	85.2	Very High
PATHANAMTHITTA	Kadambanad [4613]	ELAVUM MOODU	81.0	0.0	20.3	60.7	74.9	High
PATHANAMTHITTA	Kadambanad [4613]	ELLUMVILA JN	81.0	0.0	19.4	61.6	76.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	ESQUIRE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	FEDERAL BANK	81.0	13.0	42.0	26.0	32.1	Medium
PATHANAMTHITTA	Kadambanad [4613]	GENESAVILASAM	81.0	8.0	3.0	70.0	86.4	Very High
PATHANAMTHITTA	Kadambanad [4613]	GOVINDAPURAM MARKET	81.0	5.0	60.8	15.2	18.8	Low
PATHANAMTHITTA	Kadambanad [4613]	IDIKKANDA	81.0	13.0	44.0	24.0	29.6	Medium
PATHANAMTHITTA	Kadambanad [4613]	IVILA	81.0	5.0	2.0	74.0	91.4	Very High
PATHANAMTHITTA	Kadambanad [4613]	JOTHIPURAM	81.0	0.0	19.0	62.0	76.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Kadambanad [4613]	KADAMPANAD	129.0	8.0	92.0	29.0	22.5	Low
PATHANAMTHITTA	Kadambanad [4613]	KADAMPANAD PUMP	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	KADAMPANADU EXCHANGE	81.0	8.0	23.0	50.0	61.7	High
PATHANAMTHITTA	Kadambanad [4613]	KAIRALI MUKKU	81.0	8.0	42.2	30.8	38.0	Medium
PATHANAMTHITTA	Kadambanad [4613]	KALATHIVILA	51.0	23.6	27.0	0.4	0.8	Very Low
PATHANAMTHITTA	Kadambanad [4613]	KALEELUMUKKU	81.0	11.0	12.0	58.0	71.6	High
PATHANAMTHITTA	Kadambanad [4613]	KALLAYKKATTU MUKKU	81.0	16.0	39.0	26.0	32.1	Medium
PATHANAMTHITTA	Kadambanad [4613]	KALLUKUZH	129.0	8.0	80.0	41.0	31.8	Medium
PATHANAMTHITTA	Kadambanad [4613]	KALLUMPURAM	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Kadambanad [4613]	KANIYAMKUZHY	81.0	3.0	19.3	58.7	72.5	High
PATHANAMTHITTA	Kadambanad [4613]	KANJIRAVILA	81.0	13.0	44.0	24.0	29.6	Medium
PATHANAMTHITTA	Kadambanad [4613]	KANNANBRICKS	81.0	0.0	12.3	68.7	84.8	Very High
PATHANAMTHITTA	Kadambanad [4613]	KARAMEL	81.0	5.0	5.0	71.0	87.7	Very High
PATHANAMTHITTA	Kadambanad [4613]	KARAYODI	81.0	0.0	32.0	49.0	60.5	High
PATHANAMTHITTA	Kadambanad [4613]	KARIMPARA	81.0	8.0	43.0	30.0	37.0	Medium
PATHANAMTHITTA	Kadambanad [4613]	KATTUTHAMVILA	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Kadambanad [4613]	KATTUVILA	81.0	17.0	9.0	55.0	67.9	High
PATHANAMTHITTA	Kadambanad [4613]	KEETTOOR KUNNUPURAM	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Kadambanad [4613]	KINARUMUKKU	81.0	8.0	19.0	54.0	66.7	High
PATHANAMTHITTA	Kadambanad [4613]	KOCHU KUNNU	81.0	8.0	36.0	37.0	45.7	Medium
PATHANAMTHITTA	Kadambanad [4613]	KOCHUPLAM MOODU	81.0	3.0	25.0	53.0	65.4	High
PATHANAMTHITTA	Kadambanad [4613]	KOKKANKAVU	81.0	3.0	10.0	68.0	84.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	KOLLARA	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Kadambanad [4613]	KOLLARA CRUSHER	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	KOLOORKUZH	20.0	0.0	6.0	14.0	70.0	High
PATHANAMTHITTA	Kadambanad [4613]	KUNDAVAN MALANADA	81.0	4.0	29.3	47.7	58.9	High
PATHANAMTHITTA	Kadambanad [4613]	KUNNATHOOR	202.0	8.0	13.0	181.0	89.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Kadambanad [4613]	KUNNATHOOR EXCHANGE	81.0	5.0	0.0	76.0	93.8	Very High
PATHANAMTHITTA	Kadambanad [4613]	KUNNUVILA	81.0	14.0	33.0	34.0	42.0	Medium
PATHANAMTHITTA	Kadambanad [4613]	KURUMPAKARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	KUTTICKAL	81.0	8.0	73.0	0.0	0.0	Very Low
PATHANAMTHITTA	Kadambanad [4613]	KUZHIALA	81.0	5.0	67.1	8.9	11.0	Low
PATHANAMTHITTA	Kadambanad [4613]	LINEX	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	MADATHIL	81.0	20.0	60.0	1.0	1.2	Very Low
PATHANAMTHITTA	Kadambanad [4613]	MAHADEVA	81.0	16.0	3.0	62.0	76.5	Very High
PATHANAMTHITTA	Kadambanad [4613]	MALAMKAVU	81.0	3.0	6.0	72.0	88.9	Very High
PATHANAMTHITTA	Kadambanad [4613]	MALANADA	81.0	6.3	35.3	39.4	48.6	Medium
PATHANAMTHITTA	Kadambanad [4613]	MANALUVILA	81.0	31.0	43.8	6.2	7.7	Very Low
PATHANAMTHITTA	Kadambanad [4613]	MANGAD	81.0	8.0	24.0	49.0	60.5	High
PATHANAMTHITTA	Kadambanad [4613]	MANGALASSERY	129.0	0.0	10.0	119.0	92.2	Very High
PATHANAMTHITTA	Kadambanad [4613]	MANIKKAMANGALAM	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Kadambanad [4613]	MANJALY	81.0	38.0	13.0	30.0	37.0	Medium
PATHANAMTHITTA	Kadambanad [4613]	MANNAROD	51.0	5.0	0.0	46.0	90.2	Very High
PATHANAMTHITTA	Kadambanad [4613]	MUDIPIAPPALLY ILLAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	MUKALETHUPADI	20.0	0.0	3.0	17.0	85.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	NADASALA	81.0	3.3	62.7	15.0	18.5	Low
PATHANAMTHITTA	Kadambanad [4613]	NAZARETH	81.0	12.0	43.0	26.0	32.1	Medium
PATHANAMTHITTA	Kadambanad [4613]	NEDIYAVILA	81.0	3.0	46.0	32.0	39.6	Medium
PATHANAMTHITTA	Kadambanad [4613]	NEDIYAVILA GURUMANDIRAM	81.0	10.0	18.0	53.0	65.4	High
PATHANAMTHITTA	Kadambanad [4613]	NEDUMKUNNU MALANADA	51.0	0.0	12.0	39.0	76.5	Very High
PATHANAMTHITTA	Kadambanad [4613]	NELLIMUKAL	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Kadambanad [4613]	NILACKAL	129.0	0.0	37.0	92.0	71.3	High
PATHANAMTHITTA	Kadambanad [4613]	OTTATHENGU	81.0	0.0	79.0	2.0	2.4	Very Low
PATHANAMTHITTA	Kadambanad [4613]	PADAKASSERY	81.0	14.0	3.0	64.0	79.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Kadambanad [4613]	PAKISTAN MUKKU	81.0	3.0	33.0	45.0	55.6	High
PATHANAMTHITTA	Kadambanad [4613]	PALLIPPADI	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Kadambanad [4613]	PANANTHOPPU	81.0	0.0	66.8	14.2	17.5	Low
PATHANAMTHITTA	Kadambanad [4613]	PANCHAVADY	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Kadambanad [4613]	PANDIMALAPPURAM	129.0	6.0	16.0	107.0	82.9	Very High
PATHANAMTHITTA	Kadambanad [4613]	PANDIMALAPPURAM SAMSKARIKANILA	81.0	5.0	10.0	66.0	81.5	Very High
PATHANAMTHITTA	Kadambanad [4613]	PARAMALA	81.0	0.0	17.0	64.0	79.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	PARAMALA CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	PHC	81.0	4.0	54.0	23.0	28.4	Medium
PATHANAMTHITTA	Kadambanad [4613]	PLATHARA TEMPLE	51.0	0.0	8.0	43.0	84.3	Very High
PATHANAMTHITTA	Kadambanad [4613]	POOJA CASHEW	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	PULLAMPALLY	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Kadambanad [4613]	PUNNAVILA	81.0	12.0	59.0	10.0	12.3	Low
PATHANAMTHITTA	Kadambanad [4613]	PUTHENAMBALAM TEMPLE	81.0	11.0	27.0	43.0	53.1	High
PATHANAMTHITTA	Kadambanad [4613]	RADIO MUKKU	81.0	8.3	3.0	69.7	86.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	SANGEETHA	81.0	8.0	13.0	60.0	74.1	High
PATHANAMTHITTA	Kadambanad [4613]	SASTHAM NADA	81.0	0.0	81.0	0.0	0.0	Very Low
PATHANAMTHITTA	Kadambanad [4613]	SIVAGIRI	81.0	16.0	65.0	0.0	0.0	Very Low
PATHANAMTHITTA	Kadambanad [4613]	TAVANOORKAVU	129.0	8.0	3.0	118.0	91.5	Very High
PATHANAMTHITTA	Kadambanad [4613]	THALAYAT	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Kadambanad [4613]	THAMPURAN FUELS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	THETTIVILA	81.0	29.0	48.0	4.0	4.9	Very Low
PATHANAMTHITTA	Kadambanad [4613]	THOLICKAL	81.0	11.0	21.0	49.0	60.5	High
PATHANAMTHITTA	Kadambanad [4613]	THOTTATHUMMURI	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Kadambanad [4613]	THRUKKANNAPURAM	81.0	3.0	22.0	56.0	69.1	High
PATHANAMTHITTA	Kadambanad [4613]	THUMPUMPARAM	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Kadambanad [4613]	THURUTHIKKARA	129.0	5.0	28.1	95.9	74.3	High
PATHANAMTHITTA	Kadambanad [4613]	THUVAYOOR	81.0	0.0	57.4	23.6	29.1	Medium
PATHANAMTHITTA	Kadambanad [4613]	THUVAYOOR PUMP	81.0	0.0	7.8	73.2	90.4	Very High
PATHANAMTHITTA	Kadambanad [4613]	UDAYANKAVU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	UDUMANMUKKU	81.0	16.0	35.3	29.7	36.7	Medium
PATHANAMTHITTA	Kadambanad [4613]	UNION ASSOCIATES	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Kadambanad [4613]	VAYAL	81.0	23.0	44.0	14.0	17.3	Low
PATHANAMTHITTA	Kadambanad [4613]	VAZHAVILA	81.0	3.0	22.0	56.0	69.1	High
PATHANAMTHITTA	Kadambanad [4613]	VELAMMOZHIKADAVU	81.0	3.0	7.0	71.0	87.7	Very High
PATHANAMTHITTA	Kadambanad [4613]	VEMBANADU	81.0	5.0	33.5	42.5	52.4	High
PATHANAMTHITTA	Karukachal [4641]	12TH MILE CHERKKOTTU NEW	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	12TH MILE NEW	81.0	32.0	49.0	0.0	0.0	Very Low
PATHANAMTHITTA	Karukachal [4641]	AFRICAPADY	81.0	0.0	36.0	45.0	55.6	High
PATHANAMTHITTA	Karukachal [4641]	ANCHANI C C NAGAR	81.0	0.0	23.0	58.0	71.6	High
PATHANAMTHITTA	Karukachal [4641]	ANCHANI CINEMAS	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	ANIYARAPPADY	129.0	0.0	44.0	85.0	65.9	High
PATHANAMTHITTA	Karukachal [4641]	ANNAKALLUGAL	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Karukachal [4641]	APAYAPPADY	129.0	6.0	64.0	59.0	45.7	Medium
PATHANAMTHITTA	Karukachal [4641]	ATTIPADY	81.0	3.0	25.0	53.0	65.4	High
PATHANAMTHITTA	Karukachal [4641]	BSNL KARUKACHAL	81.0	0.0	47.9	33.1	40.9	Medium
PATHANAMTHITTA	Karukachal [4641]	BUDHANAKUZHY	81.0	12.0	38.0	31.0	38.3	Medium
PATHANAMTHITTA	Karukachal [4641]	CAMEL FACTORY	202.0	3.0	36.3	162.7	80.5	Very High
PATHANAMTHITTA	Karukachal [4641]	CHAMPAKARA TEMPLE	81.0	8.0	54.0	19.0	23.5	Low
PATHANAMTHITTA	Karukachal [4641]	CHAMPAKKARA PALLIPPADY	81.0	0.0	38.0	43.0	53.1	High
PATHANAMTHITTA	Karukachal [4641]	CHELAKKOMPU	81.0	5.0	21.0	55.0	67.9	High
PATHANAMTHITTA	Karukachal [4641]	CHELAKOMPU POSTOFFICE	81.0	0.0	16.0	65.0	80.2	Very High
PATHANAMTHITTA	Karukachal [4641]	CHERUSERRYPADY	81.0	0.0	33.0	48.0	59.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Karukachal [4641]	CO-OPERATIVE BANK KANICHUKULAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	CVN SREERANGAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	DAIVAMPADY	202.0	8.0	49.0	145.0	71.8	High
PATHANAMTHITTA	Karukachal [4641]	ELAPPUNKAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	ERUMATHANAM KULAM	81.0	0.0	24.7	56.3	69.5	High
PATHANAMTHITTA	Karukachal [4641]	ERUPPICKAL	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Karukachal [4641]	EZHICKADU	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	EZHUMKALA	81.0	0.0	41.0	40.0	49.4	Medium
PATHANAMTHITTA	Karukachal [4641]	GREEN VALLEY MISAMPADY	129.0	6.0	64.0	59.0	45.7	Medium
PATHANAMTHITTA	Karukachal [4641]	IKULAM	81.0	0.0	17.1	63.9	78.9	Very High
PATHANAMTHITTA	Karukachal [4641]	J J GRANITES	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	KAIDACHIRA	81.0	5.0	20.0	56.0	69.1	High
PATHANAMTHITTA	Karukachal [4641]	KALAVARAPPEEDIKA	81.0	0.0	25.0	56.0	69.1	High
PATHANAMTHITTA	Karukachal [4641]	KALLOLY	81.0	5.0	13.0	63.0	77.8	Very High
PATHANAMTHITTA	Karukachal [4641]	KALLUNGALPADY	202.0	3.0	35.0	164.0	81.2	Very High
PATHANAMTHITTA	Karukachal [4641]	KANDATHIL BUILDING	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	KANICHAKULAM	81.0	13.0	32.0	36.0	44.4	Medium
PATHANAMTHITTA	Karukachal [4641]	KANIYANKUNNU	81.0	0.0	16.5	64.5	79.6	Very High
PATHANAMTHITTA	Karukachal [4641]	KANNAMKULAM	81.0	5.0	29.0	47.0	58.0	High
PATHANAMTHITTA	Karukachal [4641]	KARIKKAMALA-MACHIYANIPADY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	KARUKACHAL TOWN	202.0	3.0	48.0	151.0	74.8	High
PATHANAMTHITTA	Karukachal [4641]	KATTUVETTY	129.0	8.0	70.4	50.6	39.2	Medium
PATHANAMTHITTA	Karukachal [4641]	KAVALIMAVU-KOLLAMPARAMBU	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Karukachal [4641]	KAVUMKALPADY	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Karukachal [4641]	KOCHIKKALA	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Karukachal [4641]	KOOTHRAPALLY	129.0	11.0	35.5	82.5	63.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Karukachal [4641]	KULAGARAPADY	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Karukachal [4641]	KUMBIKKAPUZHA	81.0	0.0	29.0	52.0	64.2	High
PATHANAMTHITTA	Karukachal [4641]	KURUPPANKAVALA	81.0	3.0	32.0	46.0	56.8	High
PATHANAMTHITTA	Karukachal [4641]	LARA TOWER	129.0	0.0	14.7	114.3	88.6	Very High
PATHANAMTHITTA	Karukachal [4641]	MADATHINALCHIRA	81.0	10.0	28.5	42.5	52.5	High
PATHANAMTHITTA	Karukachal [4641]	MAKKOLLYPPADY	81.0	3.4	43.0	34.6	42.7	Medium
PATHANAMTHITTA	Karukachal [4641]	MAMPATHY	81.0	3.0	46.0	32.0	39.5	Medium
PATHANAMTHITTA	Karukachal [4641]	MAMUNDA	81.0	13.0	14.0	54.0	66.7	High
PATHANAMTHITTA	Karukachal [4641]	MANAKKARA	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Karukachal [4641]	MANIKULAM	81.0	8.0	64.0	9.0	11.1	Low
PATHANAMTHITTA	Karukachal [4641]	MANJAPPALLY	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	MANKUDIPPADY	81.0	11.0	50.0	20.0	24.7	Low
PATHANAMTHITTA	Karukachal [4641]	MANNANKAVALA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Karukachal [4641]	MANTHURUTHY	81.0	23.0	33.0	25.0	30.9	Medium
PATHANAMTHITTA	Karukachal [4641]	MANTHURUTHY-2	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Karukachal [4641]	MARIKKAL	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Karukachal [4641]	MAZHUVANADY	81.0	13.0	39.0	29.0	35.8	Medium
PATHANAMTHITTA	Karukachal [4641]	MERCY	129.0	0.0	71.0	58.0	45.0	Medium
PATHANAMTHITTA	Karukachal [4641]	MINI I E	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	MINI I E 500	405.0	3.0	3.0	399.0	98.5	Very High
PATHANAMTHITTA	Karukachal [4641]	MINI I E A	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	MODAYILPADY	81.0	3.0	19.0	59.0	72.8	High
PATHANAMTHITTA	Karukachal [4641]	MOUNT MIST	81.0	0.0	67.0	14.0	17.3	Low
PATHANAMTHITTA	Karukachal [4641]	MUTHIRAMALA	81.0	0.0	38.0	43.0	53.1	High
PATHANAMTHITTA	Karukachal [4641]	N S S	81.0	3.0	32.4	45.6	56.2	High
PATHANAMTHITTA	Karukachal [4641]	NADUKKEPPADY	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Karukachal [4641]	NALLOORPADAVU	81.0	0.0	17.0	64.0	79.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Karukachal [4641]	NAROLYPADY	81.0	0.0	29.0	52.0	64.2	High
PATHANAMTHITTA	Karukachal [4641]	NEDUGADAPALLY SCHOOL	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Karukachal [4641]	NEDUMKUNNAM CONVENT	81.0	0.0	55.3	25.7	31.7	Medium
PATHANAMTHITTA	Karukachal [4641]	NEDUMKUNNAM MARKET	81.0	5.0	50.3	25.7	31.7	Medium
PATHANAMTHITTA	Karukachal [4641]	NEDUMKUNNAM PANCHAYATH	81.0	8.0	11.0	62.0	76.5	Very High
PATHANAMTHITTA	Karukachal [4641]	NEDUMKUNNAM TOWN	129.0	5.0	25.0	99.0	76.7	Very High
PATHANAMTHITTA	Karukachal [4641]	NEDUMKUZHAY	81.0	3.0	3.0	75.0	92.6	Very High
PATHANAMTHITTA	Karukachal [4641]	NEDUNGADAPALLY KWA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	NEELAMPARA	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Karukachal [4641]	NETHALLOOR	81.0	3.0	29.0	49.0	60.5	High
PATHANAMTHITTA	Karukachal [4641]	NETHALLOOR KURISH	81.0	3.2	37.0	40.8	50.4	High
PATHANAMTHITTA	Karukachal [4641]	NILAMPODINJA	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Karukachal [4641]	OFFICE	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Karukachal [4641]	P L C FACTORY	129.0	11.0	42.3	75.7	58.7	High
PATHANAMTHITTA	Karukachal [4641]	PACHILAMACKEL	81.0	8.0	10.0	63.0	77.8	Very High
PATHANAMTHITTA	Karukachal [4641]	PALLIPPADY	202.0	0.0	88.0	114.0	56.4	High
PATHANAMTHITTA	Karukachal [4641]	PANACHICKAPPEEDIKA	129.0	5.0	30.0	94.0	72.9	High
PATHANAMTHITTA	Karukachal [4641]	PARACKEL	81.0	5.0	24.0	52.0	64.2	High
PATHANAMTHITTA	Karukachal [4641]	PATHALIL	81.0	3.0	20.0	58.0	71.6	High
PATHANAMTHITTA	Karukachal [4641]	PATHIKKEL KAVALA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Karukachal [4641]	PEKKAVU	81.0	5.0	7.0	69.0	85.2	Very High
PATHANAMTHITTA	Karukachal [4641]	PLACHICKAL	81.0	3.0	8.0	70.0	86.4	Very High
PATHANAMTHITTA	Karukachal [4641]	POOVANPARAPADY	81.0	6.0	38.0	37.0	45.6	Medium
PATHANAMTHITTA	Karukachal [4641]	PUNNAVELI	81.0	5.0	17.0	59.0	72.8	High
PATHANAMTHITTA	Karukachal [4641]	PUTHIYAPARAMBU	81.0	3.0	34.0	44.0	54.3	High
PATHANAMTHITTA	Karukachal [4641]	PUTHOORAM PADY	81.0	0.0	21.0	60.0	74.0	High
PATHANAMTHITTA	Karukachal [4641]	PUTHUPALLY PADAVU	81.0	0.0	14.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Karukachal [4641]	RELIANCE TRENDS	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	SANTHIPURAM	81.0	0.0	37.0	44.0	54.3	High
PATHANAMTHITTA	Karukachal [4641]	SREEBHADRA	81.0	3.0	19.0	59.0	72.8	High
PATHANAMTHITTA	Karukachal [4641]	SREEBHADRA TOWER	81.0	0.0	5.4	75.6	93.3	Very High
PATHANAMTHITTA	Karukachal [4641]	SREENIKETHAN	129.0	20.0	20.0	89.0	69.0	High
PATHANAMTHITTA	Karukachal [4641]	STAR LINE	81.0	5.0	11.0	65.0	80.2	Very High
PATHANAMTHITTA	Karukachal [4641]	THAIPARAMBU	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Karukachal [4641]	THAKDIYAL	81.0	10.0	24.0	47.0	58.0	High
PATHANAMTHITTA	Karukachal [4641]	THAREPPADY	81.0	8.4	23.0	49.6	61.2	High
PATHANAMTHITTA	Karukachal [4641]	THENGOLY	81.0	8.0	36.0	37.0	45.6	Medium
PATHANAMTHITTA	Karukachal [4641]	THIRUMMU	129.0	5.0	73.0	51.0	39.5	Medium
PATHANAMTHITTA	Karukachal [4641]	THOMMACHERY	81.0	3.0	35.0	43.0	53.1	High
PATHANAMTHITTA	Karukachal [4641]	THURUTHIKKADU	81.0	3.1	31.0	46.9	58.0	High
PATHANAMTHITTA	Karukachal [4641]	ULLATUKAVU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Karukachal [4641]	UMPIDY	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Karukachal [4641]	UMPIDY POST OFFICE	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Karukachal [4641]	UNNIPADY	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Karukachal [4641]	VATTAKAVU	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Karukachal [4641]	VATTAPARA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Karukachal [4641]	VELIYAM	81.0	13.0	28.0	40.0	49.4	Medium
PATHANAMTHITTA	Karukachal [4641]	VELLAPALLY	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Karukachal [4641]	VETTAMALA	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Karukachal [4641]	VETTIKKAVUMKAL	81.0	0.0	68.0	13.0	16.0	Low
PATHANAMTHITTA	Manimala [4642]	16 CENT TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	8TH MILE	129.0	0.0	32.0	97.0	75.2	Very High
PATHANAMTHITTA	Manimala [4642]	ADAMATTOM	81.0	0.0	26.0	55.0	67.9	High
PATHANAMTHITTA	Manimala [4642]	ALAPRAKKADU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Manimala [4642]	ALAYAMKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	ALTHARA	81.0	3.0	13.0	65.0	80.2	Very High
PATHANAMTHITTA	Manimala [4642]	AMALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	ANJILIMOODU	81.0	5.0	19.0	57.0	70.4	High
PATHANAMTHITTA	Manimala [4642]	B S N L	81.0	0.0	33.0	48.0	59.3	High
PATHANAMTHITTA	Manimala [4642]	BALAVADI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	CCM	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Manimala [4642]	CHARALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	CHARUVELI	81.0	3.0	9.0	69.0	85.2	Very High
PATHANAMTHITTA	Manimala [4642]	CHAVUTTADIPARA	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Manimala [4642]	CHERUVALLY	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Manimala [4642]	CHOVALLY	81.0	0.0	15.7	65.3	80.6	Very High
PATHANAMTHITTA	Manimala [4642]	CHURCH	81.0	10.0	27.0	44.0	54.3	High
PATHANAMTHITTA	Manimala [4642]	EDAMANNEPADI	81.0	8.0	3.0	70.0	86.4	Very High
PATHANAMTHITTA	Manimala [4642]	ERATHUVADAKARA	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Manimala [4642]	ESTATE LAYAM	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	ESTATE MOSQUE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	IOCL PUMP	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	K S E B	81.0	3.0	46.3	31.7	39.1	Medium
PATHANAMTHITTA	Manimala [4642]	KADUMARUTHI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	KAILATHUKAVALA	81.0	3.0	6.0	72.0	88.9	Very High
PATHANAMTHITTA	Manimala [4642]	KARAYOGAMPADY	81.0	5.0	8.0	68.0	84.0	Very High
PATHANAMTHITTA	Manimala [4642]	KARIKKATTOOR CTR	81.0	5.0	19.0	57.0	70.4	High
PATHANAMTHITTA	Manimala [4642]	KARIKKATTOOR TOWN	81.0	10.0	13.0	58.0	71.6	High
PATHANAMTHITTA	Manimala [4642]	KARIMPANAKULAM	81.0	0.0	30.6	50.4	62.2	High
PATHANAMTHITTA	Manimala [4642]	KOCHUMINI	81.0	0.0	30.0	51.0	63.0	High
PATHANAMTHITTA	Manimala [4642]	KOLEDAM	81.0	10.0	36.3	34.7	42.8	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Manimala [4642]	KONNAKKULAM	81.0	9.0	8.0	64.0	79.0	Very High
PATHANAMTHITTA	Manimala [4642]	KOOVAKAVU	81.0	3.0	11.0	67.0	82.7	Very High
PATHANAMTHITTA	Manimala [4642]	KOTHALAPPADI	81.0	0.0	31.0	50.0	61.7	High
PATHANAMTHITTA	Manimala [4642]	KOTHALAPPADY TOWER	81.0	3.0	7.0	71.0	87.7	Very High
PATHANAMTHITTA	Manimala [4642]	KOTTUKAPPALLY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	KOTTUKAPPALLY TOWER	81.0	5.0	27.0	49.0	60.5	High
PATHANAMTHITTA	Manimala [4642]	KUNNELPADY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Manimala [4642]	MANIMALA TOWN	202.0	0.0	45.8	156.2	77.3	Very High
PATHANAMTHITTA	Manimala [4642]	MANIMALAKKAVU TEMPLE	81.0	0.0	17.8	63.2	78.0	Very High
PATHANAMTHITTA	Manimala [4642]	MANNANANI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	MAROORKADAVU KWA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	MAROORKKADAVU	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Manimala [4642]	MAROTTICHUVADU	81.0	10.0	16.0	55.0	67.9	High
PATHANAMTHITTA	Manimala [4642]	MELEKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	MIDAS	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Manimala [4642]	MILMA	81.0	0.0	12.0	69.0	85.2	Very High
PATHANAMTHITTA	Manimala [4642]	MINI INDUSTRY 500	405.0	0.0	0.0	405.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	MINI-INDUSTRY SHADE	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	MOOLEPLAVU	81.0	3.0	13.0	65.0	80.2	Very High
PATHANAMTHITTA	Manimala [4642]	MOONGANI	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Manimala [4642]	MUKKADA	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Manimala [4642]	MUKKADA TOWER	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Manimala [4642]	NELLITHANAM	81.0	3.0	10.0	68.0	84.0	Very High
PATHANAMTHITTA	Manimala [4642]	NJAVARAPA	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manimala [4642]	PADIYARA	81.0	3.0	8.0	70.0	86.4	Very High
PATHANAMTHITTA	Manimala [4642]	PANACKAPPATHAL	81.0	3.0	19.0	59.0	72.8	High
PATHANAMTHITTA	Manimala [4642]	PARAKKADU	81.0	5.0	6.0	70.0	86.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Manimala [4642]	PAVATTICKAL	81.0	8.0	3.0	70.0	86.4	Very High
PATHANAMTHITTA	Manimala [4642]	PERUNNAKKAVALA	81.0	0.0	34.0	47.0	58.0	High
PATHANAMTHITTA	Manimala [4642]	PONTHENPUZHA	81.0	0.0	17.0	64.0	79.0	Very High
PATHANAMTHITTA	Manimala [4642]	PONTHENPUZHA K W A	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	PONTHENPUZHA TOWER	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Manimala [4642]	POOKANAMPOIKA	81.0	9.0	24.0	48.0	59.2	High
PATHANAMTHITTA	Manimala [4642]	POONIKAVU	81.0	0.0	8.3	72.7	89.8	Very High
PATHANAMTHITTA	Manimala [4642]	POONIKKAVU TOWER	81.0	8.0	11.0	62.0	76.5	Very High
PATHANAMTHITTA	Manimala [4642]	POOTHAKUZH	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	POOVATHOLI	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Manimala [4642]	POOVATHOLI SCHOOL	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Manimala [4642]	PULICHAMACKAL	81.0	0.0	6.4	74.6	92.0	Very High
PATHANAMTHITTA	Manimala [4642]	PULIKKALLU	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Manimala [4642]	PULIKKANPARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	PUTHENPEEDIKA	81.0	3.0	0.0	78.0	96.3	Very High
PATHANAMTHITTA	Manimala [4642]	SOBHANA CLUB	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Manimala [4642]	SUSHALAYAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	THALACHIRA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	THANNIKKUZHI	81.0	0.0	35.0	46.0	56.8	High
PATHANAMTHITTA	Manimala [4642]	THAYYIL	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Manimala [4642]	THEERADESHAM	81.0	0.0	22.8	58.2	71.9	High
PATHANAMTHITTA	Manimala [4642]	THEKKUMMOODU TOWER	81.0	0.0	6.1	74.9	92.5	Very High
PATHANAMTHITTA	Manimala [4642]	THONIPARA	81.0	8.0	16.0	57.0	70.4	High
PATHANAMTHITTA	Manimala [4642]	VAIDYASALAPADI	81.0	6.0	6.0	69.0	85.2	Very High
PATHANAMTHITTA	Manimala [4642]	VARUKUNNU	81.0	5.0	19.0	57.0	70.4	High
PATHANAMTHITTA	Manimala [4642]	VATTUKUNNAMALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manimala [4642]	VATTUKUNNAMALA TOWER	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Manipuzha [4620]	AKG	81.0	6.1	14.0	60.9	75.2	Very High
PATHANAMTHITTA	Manipuzha [4620]	AKLAMON	81.0	5.0	27.0	49.0	60.5	High
PATHANAMTHITTA	Manipuzha [4620]	ALUMTHURUTHI	81.0	8.0	24.2	48.8	60.2	High
PATHANAMTHITTA	Manipuzha [4620]	AMBILY	81.0	5.0	63.5	12.5	15.5	Low
PATHANAMTHITTA	Manipuzha [4620]	AMICHAKARY	129.0	0.0	3.0	126.0	97.7	Very High
PATHANAMTHITTA	Manipuzha [4620]	ANC	81.0	5.0	26.0	50.0	61.7	High
PATHANAMTHITTA	Manipuzha [4620]	ANCHALKUTTY	81.0	5.0	28.4	47.6	58.7	High
PATHANAMTHITTA	Manipuzha [4620]	ANCHUPARA	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Manipuzha [4620]	ARUPARAYIL PADY	81.0	3.0	17.0	61.0	75.3	Very High
PATHANAMTHITTA	Manipuzha [4620]	ASARIPARAMBILKADAVU	81.0	0.0	17.0	64.0	79.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	ATTUMALI	81.0	0.0	7.0	74.0	91.4	Very High
PATHANAMTHITTA	Manipuzha [4620]	AYYANAVELI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	AZHIYIDATHUCHIRA	81.0	18.0	61.2	1.8	2.2	Very Low
PATHANAMTHITTA	Manipuzha [4620]	BAZAR KADAVU	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	BLESSON ETTIKALAYIL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	BRAHMASWAM MADOM	81.0	7.0	32.0	42.0	51.9	High
PATHANAMTHITTA	Manipuzha [4620]	CHAKRASALA KADAVU	81.0	3.0	26.0	52.0	64.2	High
PATHANAMTHITTA	Manipuzha [4620]	CHALAKKUZHI	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	CHAPPEL KAVUMBHAGAM	81.0	8.0	29.0	44.0	54.3	High
PATHANAMTHITTA	Manipuzha [4620]	CHATHANKERY EXCHANGE	81.0	10.0	23.0	48.0	59.3	High
PATHANAMTHITTA	Manipuzha [4620]	CHATHANKERY KADAVU	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	CHATHANKERY LI	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	CHATHANKERY TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	CHERIPARAMPU	81.0	26.0	49.0	6.0	7.4	Very Low
PATHANAMTHITTA	Manipuzha [4620]	CHERUPPERY	81.0	0.0	16.0	65.0	80.2	Very High
PATHANAMTHITTA	Manipuzha [4620]	CHIRAYILPADI	81.0	6.3	6.0	68.7	84.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	CHOLOMAN MANA	81.0	3.0	20.0	58.0	71.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Manipuzha [4620]	CHOONDARA	81.0	8.0	25.0	48.0	59.3	High
PATHANAMTHITTA	Manipuzha [4620]	CHORATHIL PADY	81.0	0.0	13.7	67.3	83.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	CHOTHIYAKADAVU	81.0	0.0	23.0	58.0	71.6	High
PATHANAMTHITTA	Manipuzha [4620]	CMS MANAK	81.0	6.0	22.3	52.7	65.1	High
PATHANAMTHITTA	Manipuzha [4620]	CONCORD	81.0	0.0	4.0	77.0	95.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	COORIOS	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	COSMOS	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	EBENEZER	81.0	0.0	21.0	60.0	74.1	High
PATHANAMTHITTA	Manipuzha [4620]	EMPLOYMENT	202.0	0.0	51.0	151.0	74.8	High
PATHANAMTHITTA	Manipuzha [4620]	GANAPATHIPURAM	81.0	9.0	28.7	43.3	53.4	High
PATHANAMTHITTA	Manipuzha [4620]	GOVINDANKULANGARA	81.0	0.0	36.0	45.0	55.6	High
PATHANAMTHITTA	Manipuzha [4620]	HANUMAN	81.0	3.0	21.0	57.0	70.4	High
PATHANAMTHITTA	Manipuzha [4620]	ILAYIDATHUMADOM	81.0	5.0	10.7	65.3	80.6	Very High
PATHANAMTHITTA	Manipuzha [4620]	IMMANUEL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	IYRAMPALLY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Manipuzha [4620]	JANASEVA	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Manipuzha [4620]	KADAYANTHRA	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	KAIPUZHAKAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	KALAKKADAVU	81.0	5.0	43.0	33.0	40.7	Medium
PATHANAMTHITTA	Manipuzha [4620]	KALLUMKAL	81.0	5.0	20.0	56.0	69.1	High
PATHANAMTHITTA	Manipuzha [4620]	KALLUMKALCHURCH	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	KALLUNKAL AGRO	81.0	0.0	13.5	67.5	83.4	Very High
PATHANAMTHITTA	Manipuzha [4620]	KALLUPURACKAL	81.0	5.0	13.0	63.0	77.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	KANEKATTU PADI	81.0	3.0	26.5	51.5	63.6	High
PATHANAMTHITTA	Manipuzha [4620]	KARAKKAL LIBRARY	81.0	4.0	16.0	61.0	75.3	Very High
PATHANAMTHITTA	Manipuzha [4620]	KARAKKAL-1	81.0	17.0	35.8	28.2	34.8	Medium
PATHANAMTHITTA	Manipuzha [4620]	KARAKKAL-2	81.0	8.0	27.0	46.0	56.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Manipuzha [4620]	KARANASSERY	81.0	4.0	18.0	59.0	72.8	High
PATHANAMTHITTA	Manipuzha [4620]	KARATHRA	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Manipuzha [4620]	KARGIL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	KATTAPURAM	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	KATTILKUNNIL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	KATTOOKKARA	81.0	24.0	56.0	1.0	1.2	Very Low
PATHANAMTHITTA	Manipuzha [4620]	KAVUMBHAGAM	129.0	0.0	15.0	114.0	88.4	Very High
PATHANAMTHITTA	Manipuzha [4620]	KAYAPPURAM	129.0	4.2	33.0	91.8	71.2	High
PATHANAMTHITTA	Manipuzha [4620]	KAZHUPPIL	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	KILANNAPARAMBU	81.0	0.0	26.7	54.3	67.1	High
PATHANAMTHITTA	Manipuzha [4620]	KIZHAKKUMMURI	81.0	20.0	24.0	37.0	45.7	Medium
PATHANAMTHITTA	Manipuzha [4620]	KNANAYA CHURCH	81.0	8.0	18.0	55.0	67.9	High
PATHANAMTHITTA	Manipuzha [4620]	KOCHARIMUKKAM	81.0	6.0	22.0	53.0	65.4	High
PATHANAMTHITTA	Manipuzha [4620]	KONTHAMBAKKACHIRA	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Manipuzha [4620]	KOTHAPALLI	81.0	0.0	29.0	52.0	64.2	High
PATHANAMTHITTA	Manipuzha [4620]	KRISHIBHAVAN	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	KRISHNAPADAM	81.0	5.0	3.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	KURACHAL	81.0	0.0	31.0	50.0	61.7	High
PATHANAMTHITTA	Manipuzha [4620]	KURICHI	81.0	5.0	30.0	46.0	56.8	High
PATHANAMTHITTA	Manipuzha [4620]	KUTTUMMEL	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	KUZHIVELIPURAM	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Manipuzha [4620]	LAKSHMINARAYANA	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Manipuzha [4620]	MADANASSERIKADAVU	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Manipuzha [4620]	MALANKARA	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	MALAYATHRA	81.0	16.0	46.3	18.7	23.1	Low
PATHANAMTHITTA	Manipuzha [4620]	MALI	81.0	5.0	52.0	24.0	29.6	Medium
PATHANAMTHITTA	Manipuzha [4620]	MAMMOOTIL PADI	81.0	8.0	5.0	68.0	84.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Manipuzha [4620]	MANAK	81.0	0.0	39.3	41.7	51.5	High
PATHANAMTHITTA	Manipuzha [4620]	MANALELPALAM	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Manipuzha [4620]	MANIPUZHA	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Manipuzha [4620]	MANNAMKARACHIRA	129.0	6.0	19.0	104.0	80.6	Very High
PATHANAMTHITTA	Manipuzha [4620]	MARUTHI-POPULAR	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	MEPRAL	129.0	0.0	25.0	104.0	80.6	Very High
PATHANAMTHITTA	Manipuzha [4620]	MGM	81.0	5.0	35.6	40.4	49.8	Medium
PATHANAMTHITTA	Manipuzha [4620]	MULAMOODU	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	MUTHOOR	81.0	0.0	31.0	50.0	61.7	High
PATHANAMTHITTA	Manipuzha [4620]	MUTHOOR CHURCH	81.0	8.0	46.0	27.0	33.3	Medium
PATHANAMTHITTA	Manipuzha [4620]	MUTHOOR MFGC	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	MUTHOOR TABERNACLE	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	MUTTU CHIRA	81.0	5.0	13.0	63.0	77.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	NALOONNI PADI	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Manipuzha [4620]	NEDUMPRAM LI	81.0	13.2	21.3	46.5	57.4	High
PATHANAMTHITTA	Manipuzha [4620]	OLIVE	255.0	3.0	0.0	252.0	98.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	OTTAPHESE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	OTTATHENGU	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Manipuzha [4620]	PADAVINAKOM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	PAIKANDOM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	PANACHIMOOTIL KADAVU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	PANAMOOTIL PADY	81.0	0.0	13.2	67.8	83.7	Very High
PATHANAMTHITTA	Manipuzha [4620]	PAROOR PADY	81.0	0.0	9.3	71.7	88.5	Very High
PATHANAMTHITTA	Manipuzha [4620]	PARUTHIKKALPADI	81.0	0.0	27.0	54.0	66.7	High
PATHANAMTHITTA	Manipuzha [4620]	PATHANATTIL CHIRA	81.0	12.6	48.3	20.2	24.9	Low
PATHANAMTHITTA	Manipuzha [4620]	PATTATHICHIRA	81.0	0.0	26.0	55.0	67.9	High
PATHANAMTHITTA	Manipuzha [4620]	PERINGARA PANCHAYATH	81.0	8.0	25.0	48.0	59.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Manipuzha [4620]	PERINGARA-PMV	81.0	3.0	14.0	64.0	79.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	PERINGOL	81.0	6.3	50.0	24.7	30.5	Medium
PATHANAMTHITTA	Manipuzha [4620]	PERUMPALAM	81.0	0.0	44.0	37.0	45.7	Medium
PATHANAMTHITTA	Manipuzha [4620]	PERUMTHURUTHY	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	PODIYADI BEVERAGE	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Manipuzha [4620]	PODIYADI POST OFFICE	129.0	3.0	31.7	94.3	73.1	High
PATHANAMTHITTA	Manipuzha [4620]	PODIYADI SBI	129.0	0.0	41.0	88.0	68.2	High
PATHANAMTHITTA	Manipuzha [4620]	PODIYADI SBT	129.0	0.0	3.0	126.0	97.7	Very High
PATHANAMTHITTA	Manipuzha [4620]	PODIYADI SNDP	81.0	10.0	34.0	37.0	45.7	Medium
PATHANAMTHITTA	Manipuzha [4620]	POORNIMA	81.0	0.0	59.0	22.0	27.2	Medium
PATHANAMTHITTA	Manipuzha [4620]	POTHIRIKKALPADY	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Manipuzha [4620]	PULIKEEZHU	202.0	0.0	41.0	161.0	79.7	Very High
PATHANAMTHITTA	Manipuzha [4620]	PULIKEEZHU HOMEIO	81.0	3.0	8.0	70.0	86.4	Very High
PATHANAMTHITTA	Manipuzha [4620]	PULLATTU KALUNGU	81.0	8.0	6.7	66.3	81.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	PURACKAL PALAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	PURAYATTU	81.0	0.0	53.0	28.0	34.6	Medium
PATHANAMTHITTA	Manipuzha [4620]	RDO	81.0	10.0	35.0	36.0	44.4	Medium
PATHANAMTHITTA	Manipuzha [4620]	ROADUKADAVU	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	SAWMILL NEDUMPURAM	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Manipuzha [4620]	SBT MARKET	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Manipuzha [4620]	SREENARAYANA	81.0	0.0	80.0	1.0	1.2	Very Low
PATHANAMTHITTA	Manipuzha [4620]	SREEVALLABHA	202.0	5.0	33.7	163.3	80.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	ST JOHNS	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	ST MARYS	129.0	0.0	10.0	119.0	92.2	Very High
PATHANAMTHITTA	Manipuzha [4620]	SUNDAY SCHOOL	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Manipuzha [4620]	SWAMIPALAM	81.0	5.0	42.0	34.0	42.0	Medium
PATHANAMTHITTA	Manipuzha [4620]	THAMARAL	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Manipuzha [4620]	THAMARAL CSI CHURCH	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	THANANGADU	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Manipuzha [4620]	THARAVADU	81.0	0.0	18.7	62.3	77.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	THATTUPURACKAL	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	THEKKENADA	81.0	10.0	46.0	25.0	30.9	Medium
PATHANAMTHITTA	Manipuzha [4620]	THIRUVATTA	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Manipuzha [4620]	THONIPALAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	THOTTANISSERY	81.0	0.0	17.5	63.5	78.4	Very High
PATHANAMTHITTA	Manipuzha [4620]	THOTTODIPADI	81.0	0.0	26.0	55.0	67.9	High
PATHANAMTHITTA	Manipuzha [4620]	THRIKKEL	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Manipuzha [4620]	UNDAPLAVU	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Manipuzha [4620]	UNDAPLAVU BEVERAGE	81.0	3.0	39.2	38.8	47.9	Medium
PATHANAMTHITTA	Manipuzha [4620]	UTHRAMEL	81.0	8.0	19.0	54.0	66.7	High
PATHANAMTHITTA	Manipuzha [4620]	VADAKKENADA	81.0	6.0	7.8	67.2	82.9	Very High
PATHANAMTHITTA	Manipuzha [4620]	VADASSERI	81.0	3.0	8.0	70.0	86.4	Very High
PATHANAMTHITTA	Manipuzha [4620]	VAIKKATHILLAM	81.0	0.0	8.2	72.8	89.9	Very High
PATHANAMTHITTA	Manipuzha [4620]	VAIKKATHILLAM BRIDGE	81.0	8.0	28.0	45.0	55.6	High
PATHANAMTHITTA	Manipuzha [4620]	VALLABHASSERY	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Manipuzha [4620]	VENGAL	129.0	0.0	23.8	105.2	81.6	Very High
PATHANAMTHITTA	Manipuzha [4620]	VENGAL ALUMINIUM	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	VENGAL BRIDGE	81.0	5.0	3.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	VENGAL ERUKARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Manipuzha [4620]	VENGAL SNDP	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Manipuzha [4620]	VENPALA LI	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Manipuzha [4620]	VENPALA NO2	81.0	5.0	13.0	63.0	77.8	Very High
PATHANAMTHITTA	Manipuzha [4620]	VENPALA RATION SHOP	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Manipuzha [4620]	VILOPPALLY	81.0	9.0	8.0	64.0	79.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Pathanapuram [4595]	ADAMCODE	81.0	3.0	35.0	43.0	53.1	High
PATHANAMTHITTA	Pathanapuram [4595]	AL-AMEEN	81.0	3.0	11.3	66.7	82.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	ALUVILA	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	AMMANAMCODE	81.0	3.0	27.0	51.0	63.0	High
PATHANAMTHITTA	Pathanapuram [4595]	ANAKUZHYY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	ANAKUZHYY WEST	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Pathanapuram [4595]	ANTONYS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	ARAFA	81.0	3.0	41.3	36.7	45.3	Medium
PATHANAMTHITTA	Pathanapuram [4595]	ARUVITHARA	81.0	0.0	11.3	69.7	86.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	ASHABHAVAN	81.0	0.0	23.0	58.0	71.6	High
PATHANAMTHITTA	Pathanapuram [4595]	ASWINI HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	ATTINPURA	81.0	5.0	8.0	68.0	84.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	BALAVADY	81.0	5.0	38.0	38.0	46.9	Medium
PATHANAMTHITTA	Pathanapuram [4595]	BANK OF BARODA	20.0	0.0	0.0	20.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	BDS SQUARE	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	CHAPPRA	81.0	0.0	16.5	64.5	79.7	Very High
PATHANAMTHITTA	Pathanapuram [4595]	CHELAVANNOOR	81.0	0.0	29.5	51.5	63.6	High
PATHANAMTHITTA	Pathanapuram [4595]	CHELLAPPALLY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	CHEMMAMPALAM	81.0	3.0	8.0	70.0	86.4	Very High
PATHANAMTHITTA	Pathanapuram [4595]	CHENGILATH	81.0	3.0	55.0	23.0	28.4	Medium
PATHANAMTHITTA	Pathanapuram [4595]	CHENNAMKARA	81.0	10.0	18.0	53.0	65.4	High
PATHANAMTHITTA	Pathanapuram [4595]	CHITHALVETTY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	EDATHARA	202.0	0.0	24.0	178.0	88.1	Very High
PATHANAMTHITTA	Pathanapuram [4595]	EDATHARA MOSQUE	81.0	3.0	18.0	60.0	74.1	High
PATHANAMTHITTA	Pathanapuram [4595]	EDATHARA-HSS	81.0	0.0	21.3	59.7	73.7	High
PATHANAMTHITTA	Pathanapuram [4595]	ERAPPANTHODU	81.0	0.0	70.3	10.7	13.2	Low
PATHANAMTHITTA	Pathanapuram [4595]	FATHIMA TOWER	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Pathanapuram [4595]	FEDERAL BANK	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	FINIX PLASTIC	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	GANDHI BHAVAN	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	GO EC SALEMPURAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	GOVT HOSPITAL	129.0	0.0	14.0	115.0	89.1	Very High
PATHANAMTHITTA	Pathanapuram [4595]	GOVT HOSPITAL TOWER	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Pathanapuram [4595]	HIGHSCHOOL	129.0	0.0	31.0	98.0	76.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	IDINJAHKUZHY	81.0	0.0	17.0	64.0	79.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	IOC KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	JANATHA	81.0	0.0	27.7	53.3	65.8	High
PATHANAMTHITTA	Pathanapuram [4595]	KAILASAM	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KALLAMUTTAM	81.0	6.4	30.0	44.6	55.1	High
PATHANAMTHITTA	Pathanapuram [4595]	KALLUMKADAVU	202.0	0.0	3.0	199.0	98.5	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KALLUMKADAVU IDEA	81.0	0.0	27.0	54.0	66.7	High
PATHANAMTHITTA	Pathanapuram [4595]	KAMUKUMCHERY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KANCHODU MARUTHIMANGALAM	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KANJOTTU MALA	81.0	0.0	35.3	45.7	56.4	High
PATHANAMTHITTA	Pathanapuram [4595]	KARAMOODU	81.0	10.0	42.4	28.6	35.4	Medium
PATHANAMTHITTA	Pathanapuram [4595]	KARIMBALOOR	81.0	3.0	17.0	61.0	75.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KARISANAMKODU	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KAVALA	81.0	3.0	55.3	22.7	28.0	Medium
PATHANAMTHITTA	Pathanapuram [4595]	KAVALA TEMPLE	81.0	7.4	5.0	68.6	84.7	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KOTTANTHARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KOTTAVILA	51.0	0.0	0.0	51.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KUMBICAL	81.0	5.0	8.3	67.7	83.6	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KUMBICAL CANAL	81.0	0.0	7.0	74.0	91.4	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KUNDAYAM INDUSTRIAL ESTATE	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Pathanapuram [4595]	KUNDAYAM PALLI	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KUNDAYAM-TEMPLE	81.0	5.0	29.0	47.0	58.0	High
PATHANAMTHITTA	Pathanapuram [4595]	KUNNELPADY	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Pathanapuram [4595]	KUTTIMOOTTIL KADAVU	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	LAZER PALLY	81.0	0.0	55.0	26.0	32.1	Medium
PATHANAMTHITTA	Pathanapuram [4595]	LEKSHMIPURAM	81.0	6.0	66.9	8.1	10.0	Low
PATHANAMTHITTA	Pathanapuram [4595]	LENZKART	51.0	0.0	0.0	51.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MADATHIL TEMPLE	81.0	28.8	43.3	8.9	11.0	Low
PATHANAMTHITTA	Pathanapuram [4595]	MALANKAVU	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MALoor IDEA	81.0	3.3	8.0	69.7	86.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MALoor SHAPPUMUKKU	81.0	5.0	21.0	55.0	67.9	High
PATHANAMTHITTA	Pathanapuram [4595]	MANCHALLOOR KAVU	81.0	3.0	15.0	63.0	77.8	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MANCHALLOOR PALAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MANCODE	81.0	0.0	9.0	72.0	88.9	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MANJAKKALA	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MANJALLOOR	129.0	13.0	41.4	74.7	57.9	High
PATHANAMTHITTA	Pathanapuram [4595]	MARKET	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MARUTHIVILA	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MATHA	81.0	0.0	22.1	58.9	72.7	High
PATHANAMTHITTA	Pathanapuram [4595]	MAVANAL	202.0	0.0	5.0	197.0	97.5	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MOOLAKADA	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Pathanapuram [4595]	MOORTHICAVU	81.0	0.0	12.3	68.7	84.8	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MOOZHI	81.0	0.0	29.9	51.1	63.1	High
PATHANAMTHITTA	Pathanapuram [4595]	MOUNT TABOUR COMPLEX	81.0	5.0	24.0	52.0	64.2	High
PATHANAMTHITTA	Pathanapuram [4595]	MUKKAMTHODE	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Pathanapuram [4595]	MULLOORNIRAPPU	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Pathanapuram [4595]	MUTHUKKUZHI	81.0	19.0	61.1	0.9	1.1	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Pathanapuram [4595]	NEDUMPARAMPU	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Pathanapuram [4595]	OXYGEN	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	P AND T	81.0	0.0	73.2	7.8	9.6	Very Low
PATHANAMTHITTA	Pathanapuram [4595]	PACHAYATH COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PADAM	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PADAM PADAYANIPPARA	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PADAM-GURUMANDIRAM	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PALAMOODU	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PALLIMUKKU	81.0	3.0	37.0	41.0	50.6	High
PATHANAMTHITTA	Pathanapuram [4595]	PALLIMUKKU-TATA	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PANAMPATTA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PANCHAYATH MALL	405.0	0.0	0.0	405.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PANCHAYATH OFFICE	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PARAKKADAVU	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PARUTHIMALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PATHIRICKAL NSS	81.0	0.0	17.0	64.0	79.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PAZHANJIKADAVU	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PAZHANJIKADAVU STEEL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PERUMTHALLOOR	81.0	3.0	6.0	72.0	88.9	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PIDAVOOR-BLOCK	81.0	6.0	54.3	20.7	25.6	Medium
PATHANAMTHITTA	Pathanapuram [4595]	POOMKULANJI	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	PUNCHIRIMUKKU	81.0	13.0	21.0	47.0	58.0	High
PATHANAMTHITTA	Pathanapuram [4595]	PUTHALATH	81.0	11.0	20.0	50.0	61.7	High
PATHANAMTHITTA	Pathanapuram [4595]	PUTHUVAL CHURCH	81.0	0.0	34.0	47.0	58.0	High
PATHANAMTHITTA	Pathanapuram [4595]	PUTHUVAL-AMAL	81.0	0.0	25.0	56.0	69.1	High
PATHANAMTHITTA	Pathanapuram [4595]	PUTHUVAL-TOWER	81.0	5.0	14.0	62.0	76.5	Very High
PATHANAMTHITTA	Pathanapuram [4595]	S B-I	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Pathanapuram [4595]	SALVATION ARMY	202.0	3.0	41.0	158.0	78.2	Very High
PATHANAMTHITTA	Pathanapuram [4595]	SATHYAN MUKKU	81.0	5.0	74.4	1.6	2.0	Very Low
PATHANAMTHITTA	Pathanapuram [4595]	SAYANNA	129.0	0.0	28.0	101.0	78.3	Very High
PATHANAMTHITTA	Pathanapuram [4595]	SEEMA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	SOCIETY	129.0	0.0	5.2	123.8	96.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	SONAVE ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	ST JOSEPH	81.0	0.0	50.0	31.0	38.3	Medium
PATHANAMTHITTA	Pathanapuram [4595]	ST MARYS	81.0	0.0	31.4	49.6	61.3	High
PATHANAMTHITTA	Pathanapuram [4595]	STARCO PIPES	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	SUBSTATION	129.0	0.0	34.0	95.0	73.6	High
PATHANAMTHITTA	Pathanapuram [4595]	SWAMY	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Pathanapuram [4595]	THACHENS	81.0	0.0	15.8	65.2	80.5	Very High
PATHANAMTHITTA	Pathanapuram [4595]	THEKKEDATHU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	THEKKEKKARA MUKKU	81.0	11.0	22.0	48.0	59.3	High
PATHANAMTHITTA	Pathanapuram [4595]	THETTIKKUZH	81.0	0.0	44.0	37.0	45.7	Medium
PATHANAMTHITTA	Pathanapuram [4595]	THEVALAKKARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	THIDY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	THOPPIL	81.0	0.0	24.4	56.6	69.8	High
PATHANAMTHITTA	Pathanapuram [4595]	THRISSUR TILES	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	TILE FACTORY	81.0	0.0	15.0	66.0	81.5	Very High
PATHANAMTHITTA	Pathanapuram [4595]	TOWN	202.0	0.0	10.0	192.0	95.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	TREANDS	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	UDAYANCHIRA	81.0	0.0	19.0	62.0	76.5	Very High
PATHANAMTHITTA	Pathanapuram [4595]	VATTAKKAVU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	VAZHAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	VAZHATHOTTAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Pathanapuram [4595]	VAZHIKKINAR	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thengamom-Pallickal [4663]	AARATTUKULAM	81.0	14.1	57.0	9.9	12.3	Low
PATHANAMTHITTA	Thengamom-Pallickal [4663]	AARKKAKUZH	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	ADAIPADU	81.0	0.0	28.3	52.7	65.1	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	ALUMMOODU	81.0	16.0	26.0	39.0	48.1	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	ALUMMOODU VANCHI	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	AMMUMMAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	AVICHAKULAM	81.0	6.0	14.0	61.0	75.3	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	AVICHAKULAM ANGANAVADI	81.0	3.0	3.0	75.0	92.6	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	BEST VENEERS	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	BEST WOOD	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	BHARATHI INFRATEL	81.0	5.0	6.0	70.0	86.4	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	BUDHANAGAR	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CASHEW FACTORY	81.0	8.0	16.0	57.0	70.4	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHAKKANCHIRA MALA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHALA	81.0	6.0	16.0	59.0	72.8	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHALUTHUNDIL	81.0	3.0	19.0	59.0	72.8	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHAROORAYYATHU	81.0	3.0	8.0	70.0	86.4	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHATHAKULAM	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHENAMPUTHUR	81.0	11.0	24.0	46.0	56.8	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHENATTUSSERY	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHENGZHATHU CRUSHER	129.0	0.0	5.0	124.0	96.1	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHENGILATHU	81.0	6.0	21.0	54.0	66.7	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHERUKUNNAM	81.0	6.0	43.0	32.0	39.5	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	CHIRAKKONICHIRA	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	EDAKKADAVUKULAM	81.0	6.0	35.0	40.0	49.4	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	EHC	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	ELAMPALLIL	81.0	5.0	14.0	62.0	76.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thengamom-Pallickal [4663]	ELANJIMOODU	81.0	3.0	11.0	67.0	82.7	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	ENIYIL	81.0	9.0	13.0	59.0	72.8	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	GANAPATHY	81.0	3.0	15.0	63.0	77.8	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	GANESHAVILASOM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	GENGA BRICKS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	GIRIPURAM	81.0	13.0	54.0	14.0	17.3	Low
PATHANAMTHITTA	Thengamom-Pallickal [4663]	GREEN TECH SOLUTION	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KAITHACKAL	129.0	18.0	69.0	42.0	32.6	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KANDALASWAMY	81.0	23.0	27.0	31.0	38.3	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KANJIRAM KADAV NO-1	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KANJIRAM KADAVU NO-2	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KARINTHARUVILA	81.0	0.0	12.0	69.0	85.2	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KOCHUTHARA	81.0	6.0	14.0	61.0	75.3	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KOLAMALA	81.0	10.0	24.0	47.0	58.0	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KOLLAYICKAL	129.0	5.0	33.0	91.0	70.5	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KONATHUPALLY	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KULAMULLATHIL	81.0	5.0	49.5	26.5	32.7	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KUNJALUMMODU	81.0	3.0	18.0	60.0	74.1	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KUNNIRADAM	81.0	5.0	6.0	70.0	86.4	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	KUTTIYIL	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	MADAPLETH	81.0	5.0	38.0	38.0	46.9	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	MANGALETHU	51.0	0.0	16.0	35.0	68.6	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	MAROOR TEMPLE	81.0	22.0	38.0	21.0	25.9	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	MAYAKODE	81.0	3.0	6.3	71.7	88.5	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	MELOOD WEST	81.0	3.0	3.0	75.0	92.6	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	MOTHIRACHULLI	81.0	11.0	11.0	59.0	72.8	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	MOTHIRACHULLI LEKSHAMVEEDU	81.0	3.0	5.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thengamom-Pallickal [4663]	MUNDAPALLI SCHOOL	81.0	3.0	68.3	9.7	12.0	Low
PATHANAMTHITTA	Thengamom-Pallickal [4663]	MUNNATTUKARA	81.0	32.0	22.0	27.0	33.3	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	NELLIMUKAL ELA	129.0	3.0	39.0	87.0	67.4	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	OLICKAL	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	OTTUPARAMPU	81.0	5.0	47.0	29.0	35.8	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	PACHAKKADU	81.0	22.0	55.3	3.7	4.6	Very Low
PATHANAMTHITTA	Thengamom-Pallickal [4663]	PALLICKAL	81.0	3.0	21.0	57.0	70.4	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	PAPPADI KUNNU	81.0	0.0	12.0	69.0	85.2	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	PARAKOOTAM	81.0	0.0	22.0	59.0	72.8	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	PAYYANALLORE	81.0	21.0	32.0	28.0	34.6	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	POOMOODU	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	POST OFFICE	81.0	27.0	54.0	0.0	0.0	Very Low
PATHANAMTHITTA	Thengamom-Pallickal [4663]	PRIYADARSHINI	81.0	19.0	40.8	21.2	26.1	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	PULLIPARA	81.0	0.0	18.0	63.0	77.8	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	PUNNAKODE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	RELIANCE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	TECHNIBS ENGINEERING	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	TELEPHONE EXCHANGE	81.0	8.0	8.0	65.0	80.2	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	THENGAMOM	81.0	28.0	16.0	37.0	45.7	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	THENGINAL	81.0	13.0	8.0	60.0	74.1	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	THENNAPARAMBIL	51.0	3.0	11.0	37.0	72.5	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	THOTTUVA	81.0	6.0	12.3	62.7	77.4	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	UDICKAL KULAM	81.0	5.0	20.0	56.0	69.1	High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	ULLOORMUKAL	81.0	6.8	11.0	63.2	78.0	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	VAZHUVELI PADI	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Thengamom-Pallickal [4663]	VELLLACHIRA	81.0	6.0	39.0	36.0	44.4	Medium
PATHANAMTHITTA	Thengamom-Pallickal [4663]	VETERINARY	81.0	5.0	43.0	33.0	40.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thengamom-Pallickal [4663]	WATER WORKS	81.0	5.0	20.0	56.0	69.1	High
PATHANAMTHITTA	Thiruvalla [4617]	A V S	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ABAD RAMANCHIRA	324.0	0.0	10.0	314.0	96.9	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ADAKKAKULAM	81.0	13.0	45.0	23.0	28.4	Medium
PATHANAMTHITTA	Thiruvalla [4617]	AISWARYA BEVERAGES	81.0	0.0	50.0	31.0	38.3	Medium
PATHANAMTHITTA	Thiruvalla [4617]	AKHIL TIMBERS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ALAMPARAMPIL ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ALLAHABAD BANK	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ALPHA ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ALPINE KUTTAPPUZHA	162.0	0.0	0.0	162.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	AMBEDKAR	81.0	3.0	36.5	41.5	51.3	High
PATHANAMTHITTA	Thiruvalla [4617]	AMMATHANCHIRA	81.0	6.0	43.8	31.2	38.5	Medium
PATHANAMTHITTA	Thiruvalla [4617]	ANJILIMOODU	81.0	13.0	61.7	6.3	7.8	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	ANNAVATTOM	81.0	5.0	29.0	47.0	58.0	High
PATHANAMTHITTA	Thiruvalla [4617]	ASHOK	81.0	0.0	30.0	51.0	63.0	High
PATHANAMTHITTA	Thiruvalla [4617]	ASHOKA HOTEL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ASWATHI BHAVAN	81.0	8.0	41.7	31.3	38.6	Medium
PATHANAMTHITTA	Thiruvalla [4617]	ATHAKADU	81.0	5.0	22.6	53.4	65.9	High
PATHANAMTHITTA	Thiruvalla [4617]	ATHAKADU VILLA	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ATTINKARA	81.0	0.0	35.0	46.0	56.8	High
PATHANAMTHITTA	Thiruvalla [4617]	AUGUSTA COMMERCIAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	AVS SERINE KUTTAPPUZHA	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	AXIS BANK	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	B TECH ELIM	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	B TECH KALLOOR	405.0	0.0	32.0	373.0	92.1	Very High
PATHANAMTHITTA	Thiruvalla [4617]	B TECH LIVING STAR	405.0	0.0	0.0	405.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	B TECH MANJADI	202.0	0.0	0.0	202.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thiruvalla [4617]	B TECH TOWN STAR	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	B-TECH	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	B-TECH TOWN STAR	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	BENITT HOMES	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	BETHANY ARAMANA	81.0	11.0	68.6	1.4	1.7	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	BETHELPADI	81.0	3.0	56.1	21.9	27.0	Medium
PATHANAMTHITTA	Thiruvalla [4617]	BHIMA	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	BIBLE COLLEGE PAIPPAD	81.0	10.0	38.4	32.6	40.3	Medium
PATHANAMTHITTA	Thiruvalla [4617]	BOAT KADAVU	81.0	0.0	39.9	41.1	50.8	High
PATHANAMTHITTA	Thiruvalla [4617]	BTEC KODUMULETH THEEPPANY	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	C V P PARLIAMENT SQUARE	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	CASTLE BROOK HOMESTAY	81.0	0.0	30.0	51.0	63.0	High
PATHANAMTHITTA	Thiruvalla [4617]	CHANDRIMA	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	CHATHAMALA	81.0	14.0	66.2	0.8	1.0	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	CHEMPOLIMUKKU	129.0	5.0	80.0	44.0	34.1	Medium
PATHANAMTHITTA	Thiruvalla [4617]	CHILANKA	129.0	8.0	65.0	56.0	43.4	Medium
PATHANAMTHITTA	Thiruvalla [4617]	CHIRAPPADU	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Thiruvalla [4617]	CHOORAKUNNATH	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Thiruvalla [4617]	CHUMATHRA MASJID	81.0	5.0	24.0	52.0	64.2	High
PATHANAMTHITTA	Thiruvalla [4617]	CHUMATHRA SHAPPUPADY	81.0	3.0	19.0	59.0	72.8	High
PATHANAMTHITTA	Thiruvalla [4617]	CHUMATHRA SUBSTATION	81.0	9.0	64.0	8.0	9.9	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	CHUMATHRA TEMPLE	81.0	0.0	78.7	2.3	2.9	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	CITIZEN BRIDGE	81.0	0.0	6.0	75.0	92.6	Very High
PATHANAMTHITTA	Thiruvalla [4617]	CLUB 7	81.0	3.0	0.0	78.0	96.3	Very High
PATHANAMTHITTA	Thiruvalla [4617]	COLLEGE CANTEEN	81.0	5.0	45.0	31.0	38.3	Medium
PATHANAMTHITTA	Thiruvalla [4617]	CREMATORIUM	81.0	9.0	22.0	50.0	61.7	High
PATHANAMTHITTA	Thiruvalla [4617]	CVP ANNEX A	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thiruvalla [4617]	CVP X JN	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Thiruvalla [4617]	CVP-CITYTWOER	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	DD FIAT THUKALASSERY	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	DEEPA JUNCTION	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Thiruvalla [4617]	DEEPA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	DEO OFFICE	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Thiruvalla [4617]	DIAMOND PLAZA	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	DOCTORS TOWER	607.0	0.0	0.0	607.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	EAST THUKALASSERY	202.0	6.0	139.0	57.0	28.2	Medium
PATHANAMTHITTA	Thiruvalla [4617]	EZHUVANTHANAM	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	FUSION CENTRE MUTHOOR	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	GAS GODOWN	81.0	0.0	25.0	56.0	69.1	High
PATHANAMTHITTA	Thiruvalla [4617]	HERITAGE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	HOMEIO URAVACKAL	81.0	5.0	35.0	41.0	50.6	High
PATHANAMTHITTA	Thiruvalla [4617]	HVDS OXYGEN	12.0	0.0	15.0	0.0	0.0	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	HVDS TOWN BAKERY	12.0	0.0	0.0	12.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	IKKADU	81.0	3.0	65.0	13.0	16.0	Low
PATHANAMTHITTA	Thiruvalla [4617]	IKKARA TOWER	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	IKKARAPARAMB	81.0	3.0	46.8	31.2	38.5	Medium
PATHANAMTHITTA	Thiruvalla [4617]	INTERNATIONAL	81.0	0.0	26.0	55.0	67.9	High
PATHANAMTHITTA	Thiruvalla [4617]	INTERNATIONAL ARCAD	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	INTERNATIONAL GARDEN	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ITALIA-2	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ITALIA-3	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	ITTALIA-1	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	JOECEES	129.0	0.0	64.3	64.7	50.2	High
PATHANAMTHITTA	Thiruvalla [4617]	JP NAGAR	81.0	0.0	35.4	45.6	56.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thiruvalla [4617]	JP NAGAR FLAT	81.0	3.0	37.4	40.6	50.2	High
PATHANAMTHITTA	Thiruvalla [4617]	JP NAGAR PARK	81.0	0.0	8.2	72.8	89.9	Very High
PATHANAMTHITTA	Thiruvalla [4617]	JR ARCADE MADAMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KAAZHCHA KUTTAPUZHA	607.0	0.0	0.0	607.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KALLOORPADY	81.0	10.0	18.0	53.0	65.4	High
PATHANAMTHITTA	Thiruvalla [4617]	KANNAMKOTTAL	81.0	6.0	56.0	19.0	23.5	Low
PATHANAMTHITTA	Thiruvalla [4617]	KANNANATTUKULAM	81.0	5.0	19.3	56.7	70.0	High
PATHANAMTHITTA	Thiruvalla [4617]	KANNOTHUKADAVU	81.0	0.0	78.0	3.0	3.7	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	KARICODE TEMPLE	81.0	18.0	38.0	25.0	30.9	Medium
PATHANAMTHITTA	Thiruvalla [4617]	KARIPPAKUZHY	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KARMILARAM	129.0	0.0	114.0	15.0	11.6	Low
PATHANAMTHITTA	Thiruvalla [4617]	KATTOKARA AALU	81.0	3.0	31.0	47.0	58.0	High
PATHANAMTHITTA	Thiruvalla [4617]	KATTOOKKARA	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KAVERI	81.0	0.0	43.0	38.0	46.9	Medium
PATHANAMTHITTA	Thiruvalla [4617]	KEERTHI	129.0	0.0	21.0	108.0	83.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KEEZHADI	81.0	0.0	35.0	46.0	56.8	High
PATHANAMTHITTA	Thiruvalla [4617]	KGA MONSOON HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KINGANAMCHIRA	81.0	23.0	58.0	0.0	0.0	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	KIZHAKKEN MUTHOOR	129.0	13.0	111.7	4.3	3.3	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	KIZHAKKEN MUTHOOR CHRUCH	81.0	0.0	39.9	41.1	50.7	High
PATHANAMTHITTA	Thiruvalla [4617]	KOCHUPALLI JN	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KOLLAKUNNU	81.0	3.0	11.0	67.0	82.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KOTTATHODU	81.0	0.0	80.2	0.8	1.0	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	KOTTATHODU BRIDGE	51.0	0.0	0.0	51.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KP APPARTMENT	129.0	10.0	5.0	114.0	88.4	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KSRTC	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KSRTC SHOPPING COMPLEX	510.0	0.0	0.0	510.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thiruvalla [4617]	KULAKKADU	129.0	0.0	132.6	0.0	0.0	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	KULANGARA	129.0	0.0	47.7	81.3	63.0	High
PATHANAMTHITTA	Thiruvalla [4617]	KURISHUKAVALA	405.0	0.0	5.0	400.0	98.8	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KUTTAPUZHA	81.0	0.0	13.0	68.0	84.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KUTTAPUZHA BRIDGE	81.0	8.0	72.0	1.0	1.2	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	KUTTAPUZHA MATHILUNKAL	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KUTTENKERY	81.0	0.0	3.6	77.4	95.6	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KUZHICKATTU-ILLAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	KWA JALABHAVAN	81.0	0.0	55.0	26.0	32.1	Medium
PATHANAMTHITTA	Thiruvalla [4617]	MACHIPALLY	81.0	24.0	25.0	32.0	39.5	Medium
PATHANAMTHITTA	Thiruvalla [4617]	MADAMMUKKU	81.0	6.0	78.1	0.0	0.0	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	MAHALEKSHMI HOME	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	MANGO JUICE	81.0	0.0	80.3	0.7	0.9	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	MAREKATTU COMPLEX THURUMoola	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	MARIGIRI ARAMANA	81.0	0.0	65.0	16.0	19.8	Low
PATHANAMTHITTA	Thiruvalla [4617]	MARTHOMA COLLEGE	129.0	5.0	53.0	71.0	55.0	High
PATHANAMTHITTA	Thiruvalla [4617]	MARYGIRI COMPLEX	405.0	0.0	50.0	355.0	87.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	MATHILUNKAL	129.0	0.0	54.0	75.0	58.1	High
PATHANAMTHITTA	Thiruvalla [4617]	MAZHUVANGAD PAZHAYIDATHU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	MAZHUVANGADU	202.0	0.0	34.7	167.3	82.8	Very High
PATHANAMTHITTA	Thiruvalla [4617]	MEDICAL MISSION	81.0	5.0	49.0	27.0	33.3	Medium
PATHANAMTHITTA	Thiruvalla [4617]	MICROWAVE	81.0	3.0	17.0	61.0	75.3	Very High
PATHANAMTHITTA	Thiruvalla [4617]	MOHANALAYAM	81.0	8.0	48.2	24.8	30.6	Medium
PATHANAMTHITTA	Thiruvalla [4617]	MUKKANJIRAM	81.0	9.0	51.5	20.5	25.3	Medium
PATHANAMTHITTA	Thiruvalla [4617]	MUKKANJIRAM KPMS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	MULLELIPPALAM	81.0	7.2	21.7	52.1	64.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thiruvalla [4617]	MUNDUKOTTA	81.0	11.0	37.0	33.0	40.7	Medium
PATHANAMTHITTA	Thiruvalla [4617]	MUNDUKOTTA CROSS	81.0	15.0	43.9	22.1	27.3	Medium
PATHANAMTHITTA	Thiruvalla [4617]	MUTHOOR	202.0	0.0	40.3	161.7	80.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	MUTHOOR TEMPLE	81.0	3.0	52.0	26.0	32.1	Medium
PATHANAMTHITTA	Thiruvalla [4617]	MYLAMON	81.0	3.0	9.0	69.0	85.2	Very High
PATHANAMTHITTA	Thiruvalla [4617]	NANDILATH	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	NANKARAMALA	81.0	5.0	21.0	55.0	67.9	High
PATHANAMTHITTA	Thiruvalla [4617]	NEW HOSTEL	81.0	0.0	79.3	1.7	2.1	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	NJAKKUVALLY	129.0	0.0	18.0	111.0	86.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	NOEL CASA TVLA	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	NOEL ENLIVA	510.0	0.0	0.0	510.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	NOEL TUNES KIZHAKKAN MUTHOOR	648.0	0.0	66.6	581.4	89.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	OLIVE THIRUMOOLAPURAM	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PADAPPAD	129.0	14.0	119.8	0.0	0.0	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	PADATHU HOMES-100	81.0	0.0	8.0	73.0	90.1	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PAIPPAD MARKET	81.0	0.0	15.7	65.3	80.6	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PAIPPADU KAVALA	81.0	0.0	6.6	74.4	91.9	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PAIPPADU PARAYL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PAIPPADU SECTION OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PAIPPADU SHAPPUPADI	81.0	0.0	10.0	71.0	87.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PALAKOTTAL	81.0	7.0	3.0	71.0	87.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PANNIKANDOM PADI	81.0	3.0	75.5	2.5	3.1	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	PARACKAL MAZHUVANGADU	162.0	0.0	0.0	162.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PARANKALPADI	81.0	0.0	16.0	65.0	80.2	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PARATHRA	202.0	0.0	136.9	65.1	32.2	Medium
PATHANAMTHITTA	Thiruvalla [4617]	PARAYIL	81.0	7.0	72.0	2.0	2.4	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thiruvalla [4617]	PARIMAL TOWERS	202.0	0.0	15.0	187.0	92.6	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PARIYARATHU MALA	81.0	6.0	51.0	24.0	29.7	Medium
PATHANAMTHITTA	Thiruvalla [4617]	PARTY OFFICE	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PATTAPARAMPU	81.0	0.0	80.9	0.1	0.1	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	PAVANOOR COLONY	81.0	0.0	28.0	53.0	65.4	High
PATHANAMTHITTA	Thiruvalla [4617]	PAYIPPADU SECTION OFFICE	81.0	3.0	5.0	73.0	90.1	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PENSION KUNNU	81.0	3.0	5.0	73.0	90.1	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PERUMTHURUTHI	81.0	5.0	34.0	42.0	51.9	High
PATHANAMTHITTA	Thiruvalla [4617]	PODIPPARA	129.0	5.0	31.0	93.0	72.1	High
PATHANAMTHITTA	Thiruvalla [4617]	PRATHIBHA	81.0	5.0	5.0	71.0	87.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PULATHEEN-1	129.0	50.0	15.0	64.0	49.6	Medium
PATHANAMTHITTA	Thiruvalla [4617]	PULATHEEN-2	129.0	0.0	15.0	114.0	88.4	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PUSHPAGIRI	81.0	5.0	67.0	9.0	11.1	Low
PATHANAMTHITTA	Thiruvalla [4617]	PUTHAN KAVU TEMPLE	81.0	0.0	33.0	48.0	59.3	High
PATHANAMTHITTA	Thiruvalla [4617]	PUTHENPURACKAL BUILDING	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	PUTHUCHIRA	81.0	3.0	45.0	33.0	40.7	Medium
PATHANAMTHITTA	Thiruvalla [4617]	PUTHUCHIRA CHURCH	81.0	0.0	80.9	0.1	0.1	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	PUTHUVELY-100	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	RADCO	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	RAILWAY STATION	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	RAJAN	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	RAMANCHIRA-1	129.0	0.0	117.0	12.0	9.3	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	RAMANCHIRA-2	129.0	3.0	30.0	96.0	74.4	High
PATHANAMTHITTA	Thiruvalla [4617]	RAVI RAJ	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	REEFA	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	RELCON	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	RELCON MIDTOWN FLAT	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thiruvalla [4617]	RELIANCE	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Thiruvalla [4617]	REST HOUSE	81.0	0.0	9.0	72.0	88.9	Very High
PATHANAMTHITTA	Thiruvalla [4617]	REVENUE TOWER	405.0	0.0	0.0	405.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	S N D P MAZHUVANGAD	129.0	14.0	36.0	79.0	61.2	High
PATHANAMTHITTA	Thiruvalla [4617]	SANKARAMANGALAM FLAT	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SBT RAMANCHIRA	81.0	5.0	42.8	33.2	40.9	Medium
PATHANAMTHITTA	Thiruvalla [4617]	SCS SCHOOL	202.0	0.0	12.0	190.0	94.1	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SECTION OFFICE	81.0	3.0	0.0	78.0	96.3	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SHAPPU PADI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SHARON	81.0	0.0	80.5	0.5	0.6	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	SILVER CASTLE	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SILVER CASTLE APPARTMENT	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SILVER GARDEN	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SILVER NEST	324.0	0.0	0.0	324.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SKY HOTEL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SKY LINE COMMERCIAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SKYLINE AUGUSTA APARTMENTS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SKYLINE EDGE TOWER-2	405.0	0.0	0.0	405.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SKYLINE GDGE TOWER-1	405.0	0.0	0.0	405.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SKYLINE WINDMILL	1,012.0	0.0	130.0	882.0	87.2	Very High
PATHANAMTHITTA	Thiruvalla [4617]	SREENIVASA	81.0	3.0	23.0	55.0	67.9	High
PATHANAMTHITTA	Thiruvalla [4617]	ST GEORGE RAMANCHIRA	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	T K ROAD	405.0	0.0	5.0	400.0	98.8	Very High
PATHANAMTHITTA	Thiruvalla [4617]	T M J SHOPPING COMPLEX	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	THAZHAMON PLAZA RAMANCHIRA	81.0	0.0	25.0	56.0	69.1	High
PATHANAMTHITTA	Thiruvalla [4617]	THAZHAMPALLAM	81.0	0.0	17.0	64.0	79.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	THEEPANI SCHOOL	81.0	0.0	15.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thiruvalla [4617]	THILAK HOTEL	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	THIRST BEVERAGES	81.0	0.0	45.0	36.0	44.4	Medium
PATHANAMTHITTA	Thiruvalla [4617]	THIRUMOLAPURAM	202.0	14.0	68.0	120.0	59.4	High
PATHANAMTHITTA	Thiruvalla [4617]	THITTAPPALLY	81.0	0.0	80.8	0.2	0.3	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	THOPPILMALA	81.0	5.0	14.0	62.0	76.5	Very High
PATHANAMTHITTA	Thiruvalla [4617]	THOTTATHILPADY	81.0	3.0	18.0	60.0	74.1	High
PATHANAMTHITTA	Thiruvalla [4617]	THOTTAYIKKADAVU	81.0	13.0	67.1	0.9	1.1	Very Low
PATHANAMTHITTA	Thiruvalla [4617]	THUKALASSERI-I	202.0	3.0	36.0	163.0	80.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	THURUTHIKADAVU	81.0	21.0	37.0	23.0	28.4	Medium
PATHANAMTHITTA	Thiruvalla [4617]	THURUTHMALA PARA	81.0	0.0	26.0	55.0	67.9	High
PATHANAMTHITTA	Thiruvalla [4617]	THYMALA	81.0	0.0	25.0	56.0	69.1	High
PATHANAMTHITTA	Thiruvalla [4617]	TOWN SCAPE SKYLINE	405.0	0.0	0.0	405.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	TRAVANCORE CLUB	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	TRICARE DIAGNOSTICS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	TROPICANA	202.0	0.0	5.0	197.0	97.5	Very High
PATHANAMTHITTA	Thiruvalla [4617]	TROPICANA SQUARE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	UK PERUMTHURUTHI	129.0	0.0	27.0	102.0	79.1	Very High
PATHANAMTHITTA	Thiruvalla [4617]	URAVACKAL	129.0	3.0	35.0	91.0	70.5	High
PATHANAMTHITTA	Thiruvalla [4617]	VAITADU	81.0	0.0	47.0	34.0	42.0	Medium
PATHANAMTHITTA	Thiruvalla [4617]	VAITADU VILLA	81.0	3.0	14.0	64.0	79.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	VALLUVANCHIRA	81.0	0.0	9.0	72.0	88.9	Very High
PATHANAMTHITTA	Thiruvalla [4617]	VARAPPALAM	81.0	14.0	43.2	23.8	29.4	Medium
PATHANAMTHITTA	Thiruvalla [4617]	VARIKKADU	81.0	0.0	70.3	10.7	13.1	Low
PATHANAMTHITTA	Thiruvalla [4617]	VATTACHUVADU	81.0	8.0	20.0	53.0	65.4	High
PATHANAMTHITTA	Thiruvalla [4617]	VELIYAMKADAV	129.0	3.0	27.0	99.0	76.7	Very High
PATHANAMTHITTA	Thiruvalla [4617]	VELLAPPALLI	129.0	5.0	44.9	79.1	61.3	High
PATHANAMTHITTA	Thiruvalla [4617]	VENGAL	129.0	0.0	35.0	94.0	72.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Thiruvalla [4617]	VETENARY	81.0	5.0	11.0	65.0	80.2	Very High
PATHANAMTHITTA	Thiruvalla [4617]	VETTERINARY HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Thiruvalla [4617]	VILLAGE OFFICE	81.0	0.0	34.0	47.0	58.0	High
PATHANAMTHITTA	Thiruvalla [4617]	VIRAMANAPADI	81.0	5.0	33.5	42.5	52.4	High
PATHANAMTHITTA	Thiruvalla [4617]	WEIGHBRIDGE	81.0	0.0	11.0	70.0	86.4	Very High
PATHANAMTHITTA	Thiruvalla [4617]	YMA	81.0	11.0	30.0	40.0	49.4	Medium
PATHANAMTHITTA	Thiruvalla [4617]	YMCA	129.0	5.0	51.1	72.9	56.5	High
PATHANAMTHITTA	Thiruvalla [4617]	YOGAKSHEMA	81.0	3.0	11.0	67.0	82.7	Very High
PATHANAMTHITTA	Venmony [5824]	AALMAVUMUKKU	81.0	3.0	56.2	21.8	26.9	Medium
PATHANAMTHITTA	Venmony [5824]	ALAKODU KASHAYAM HOSPITAL	81.0	3.0	32.0	46.0	56.8	High
PATHANAMTHITTA	Venmony [5824]	ALUMTHURUTHU	81.0	5.0	33.3	42.7	52.7	High
PATHANAMTHITTA	Venmony [5824]	ALUMTHURUTHU COLONY	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Venmony [5824]	AMBIMUKKU	81.0	3.0	42.0	36.0	44.4	Medium
PATHANAMTHITTA	Venmony [5824]	ARANTHAKKADU	81.0	3.0	22.0	56.0	69.1	High
PATHANAMTHITTA	Venmony [5824]	ARANTHAKKADU PUNCHA	51.0	0.0	5.0	46.0	90.2	Very High
PATHANAMTHITTA	Venmony [5824]	ASHRAMAPADI	81.0	12.0	69.0	0.0	0.0	Very Low
PATHANAMTHITTA	Venmony [5824]	CHAMAKKAVU	81.0	0.0	20.0	61.0	75.3	Very High
PATHANAMTHITTA	Venmony [5824]	CHAMMATHU MUKKU	129.0	4.0	18.0	107.0	82.9	Very High
PATHANAMTHITTA	Venmony [5824]	CHANGAMALA	81.0	13.0	28.0	40.0	49.4	Medium
PATHANAMTHITTA	Venmony [5824]	CHANGAMALA COLONY	81.0	3.0	9.0	69.0	85.2	Very High
PATHANAMTHITTA	Venmony [5824]	CHERIYALUMMOODU	81.0	7.5	69.0	4.5	5.6	Very Low
PATHANAMTHITTA	Venmony [5824]	CHERUMIKKADU	81.0	0.0	56.0	25.0	30.9	Medium
PATHANAMTHITTA	Venmony [5824]	CHERUVALLOOR TEMPLE	129.0	0.0	58.5	70.5	54.6	High
PATHANAMTHITTA	Venmony [5824]	CHUTTIMALA	81.0	12.0	6.0	63.0	77.8	Very High
PATHANAMTHITTA	Venmony [5824]	GRAMADEEPAM	81.0	0.0	13.8	67.2	83.0	Very High
PATHANAMTHITTA	Venmony [5824]	ILAVINCHUVADU	81.0	11.0	18.0	52.0	64.2	High
PATHANAMTHITTA	Venmony [5824]	ILLATHUMEPPURAM TOWER	81.0	0.0	16.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Venmony [5824]	JANATHA CO-OPERATIVE SOCIETY	202.0	0.0	0.0	202.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	JANATHAPRESS	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	KAKKADA	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Venmony [5824]	KAKKADA MOSQUE	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Venmony [5824]	KALLYATHRA	129.0	10.0	25.2	93.8	72.7	High
PATHANAMTHITTA	Venmony [5824]	KALLYATHRA SBI	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Venmony [5824]	KANNADI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	KOCHUMURIKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	KODUKULANJI	202.0	0.0	27.0	175.0	86.6	Very High
PATHANAMTHITTA	Venmony [5824]	KONDODY	81.0	3.0	76.8	1.2	1.5	Very Low
PATHANAMTHITTA	Venmony [5824]	KOZHUVALLOOR MODY	81.0	0.0	41.0	40.0	49.4	Medium
PATHANAMTHITTA	Venmony [5824]	KOZHUVALLOOR TEMPLE	81.0	10.0	10.3	60.6	74.9	High
PATHANAMTHITTA	Venmony [5824]	KUTHIRAVATTAM	81.0	0.0	26.3	54.7	67.5	High
PATHANAMTHITTA	Venmony [5824]	KUTTIMUKKU	81.0	3.0	33.3	44.7	55.2	High
PATHANAMTHITTA	Venmony [5824]	MAITHANAM	81.0	11.0	33.0	37.0	45.7	Medium
PATHANAMTHITTA	Venmony [5824]	MANATHARAPADI	81.0	5.0	3.0	73.0	90.1	Very High
PATHANAMTHITTA	Venmony [5824]	MARUTHUMOODU	202.0	8.0	108.9	85.1	42.1	Medium
PATHANAMTHITTA	Venmony [5824]	MATHAPPADI	81.0	0.0	14.0	67.0	82.7	Very High
PATHANAMTHITTA	Venmony [5824]	MICROWAVE	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	MULAMUKKU	81.0	3.0	18.3	59.7	73.7	High
PATHANAMTHITTA	Venmony [5824]	MULAMUKKU CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	MYKKALA	81.0	0.0	24.0	57.0	70.4	High
PATHANAMTHITTA	Venmony [5824]	NALLORKULAM	81.0	0.0	53.7	27.3	33.7	Medium
PATHANAMTHITTA	Venmony [5824]	NEDIYAKALA COLONY	81.0	3.0	3.0	75.0	92.6	Very High
PATHANAMTHITTA	Venmony [5824]	NEDUVARAM CODU	81.0	3.0	33.7	44.3	54.7	High
PATHANAMTHITTA	Venmony [5824]	NJAKKUMPURATHUPADY	81.0	3.0	11.0	67.0	82.7	Very High
PATHANAMTHITTA	Venmony [5824]	PALLIPPURAM	81.0	0.0	25.0	56.0	69.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Venmony [5824]	PAMBOOR	81.0	0.0	5.3	75.7	93.5	Very High
PATHANAMTHITTA	Venmony [5824]	PARACHANDA	81.0	3.0	38.0	40.0	49.4	Medium
PATHANAMTHITTA	Venmony [5824]	PARACHANDA TOWER	129.0	13.0	24.0	92.0	71.3	High
PATHANAMTHITTA	Venmony [5824]	PAZHAMCHIRA	81.0	4.4	14.0	62.6	77.3	Very High
PATHANAMTHITTA	Venmony [5824]	PAZHOOR	81.0	11.0	32.0	38.0	46.9	Medium
PATHANAMTHITTA	Venmony [5824]	PENNUKKARA MARTHOMA CHURCH	81.0	0.0	42.0	39.0	48.1	Medium
PATHANAMTHITTA	Venmony [5824]	PENNUKKARA TEMPLE	51.0	9.0	17.0	25.0	49.0	Medium
PATHANAMTHITTA	Venmony [5824]	POIKAMUKKU	81.0	0.0	36.0	45.0	55.6	High
PATHANAMTHITTA	Venmony [5824]	POWATHUPADY	81.0	0.0	33.3	47.7	58.9	High
PATHANAMTHITTA	Venmony [5824]	PULAKKADAVU	81.0	6.0	35.0	40.0	49.4	Medium
PATHANAMTHITTA	Venmony [5824]	PULIKKAPALAM	81.0	3.0	14.0	64.0	79.0	Very High
PATHANAMTHITTA	Venmony [5824]	PULIMALA	81.0	5.0	32.6	43.4	53.6	High
PATHANAMTHITTA	Venmony [5824]	PULOOPALLIPADY	81.0	5.0	28.0	48.0	59.3	High
PATHANAMTHITTA	Venmony [5824]	PUNTHALA CHURCH	81.0	3.0	31.0	47.0	58.0	High
PATHANAMTHITTA	Venmony [5824]	PUNTHALA LI STATION	129.0	0.0	0.0	129.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	PUNTHALATHAZHAM NSS	81.0	8.0	30.3	42.7	52.7	High
PATHANAMTHITTA	Venmony [5824]	SHALEM	81.0	0.0	24.2	56.8	70.1	High
PATHANAMTHITTA	Venmony [5824]	SHALEM SCHOOL	129.0	0.0	38.0	91.0	70.5	High
PATHANAMTHITTA	Venmony [5824]	SHAPPILPADY	81.0	6.0	23.3	51.7	63.8	High
PATHANAMTHITTA	Venmony [5824]	SUNRISE HOSPITAL	255.0	0.0	0.0	255.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	THADATHIL PADI	51.0	0.0	14.7	36.3	71.2	High
PATHANAMTHITTA	Venmony [5824]	THAZHATHAMPALAM	81.0	3.0	58.5	19.5	24.1	Low
PATHANAMTHITTA	Venmony [5824]	THEVANAMODI	81.0	8.0	54.8	18.2	22.5	Low
PATHANAMTHITTA	Venmony [5824]	THONDUTHARAKKAVU	81.0	0.0	30.0	51.0	63.0	High
PATHANAMTHITTA	Venmony [5824]	THRIKKANNAPURAM	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	THURUTHY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
PATHANAMTHITTA	Venmony [5824]	THYVILAMODI	81.0	4.0	12.7	64.3	79.4	Very High
PATHANAMTHITTA	Venmony [5824]	THYYILPPADI	81.0	0.0	0.0	81.0	100.0	Very High
PATHANAMTHITTA	Venmony [5824]	ULIYANTHARA	81.0	3.0	26.0	52.0	64.2	High
PATHANAMTHITTA	Venmony [5824]	ULIYANTHARA NSS	81.0	3.0	23.0	55.0	67.9	High
PATHANAMTHITTA	Venmony [5824]	VALAPUZHA	81.0	0.0	9.0	72.0	88.9	Very High
PATHANAMTHITTA	Venmony [5824]	VARAMPOOR	129.0	3.0	37.0	89.0	69.0	High
PATHANAMTHITTA	Venmony [5824]	VARAMPOOR RDO	81.0	8.0	24.0	49.0	60.5	High
PATHANAMTHITTA	Venmony [5824]	VAYALORAM	81.0	0.0	5.0	76.0	93.8	Very High
PATHANAMTHITTA	Venmony [5824]	VEDURETHU	81.0	0.0	3.0	78.0	96.3	Very High
PATHANAMTHITTA	Venmony [5824]	VETERINARY	81.0	8.0	66.7	6.3	7.8	Very Low