

KSEB Renewable Energy Feasibility Report

Generated report · 2000 transformers across 1 districts. Balance % = (Balance Available ÷ 90% DTR Capacity) × 100.

District Summary

District	Transformers	Balance (kW)	Very High	High	Medium	Low	Very Low	Unknown
THIRUVANANTHAPURAM	2000	176,444.3	1138	526	228	55	51	2
TOTAL	2000	176,444.3	1138	526	228	55	51	2

THIRUVANANTHAPURAM — 2000 transformers

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Amboori [4656]	AMBOORI SCHOOL	81.0	0.0	24.0	57.0	70.4	High
THIRUVANANTHAPURAM	Amboori [4656]	ANAKUZHI	81.0	3.0	0.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Amboori [4656]	ANAMUKHAM	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPURAM	Amboori [4656]	ARUVIKUZHAY	81.0	0.0	8.8	72.2	89.1	Very High
THIRUVANANTHAPURAM	Amboori [4656]	CHAKKAPPARA FOREST	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Amboori [4656]	CHEENIKALA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Amboori [4656]	CHELANTHIKUZHI	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Amboori [4656]	COMMUNIST MUKKU	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Amboori [4656]	DIAVAPURA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Amboori [4656]	EDAVACHAL	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Amboori [4656]	KAKKACITY	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Amboori [4656]	KALIVILAKAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Amboori [4656]	KANDANTHITTA	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Amboori [4656]	KANDANTHITTA MELEMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Amboori [4656]	KANJIMOODU	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Amboori [4656]	KANNANNOOR	81.0	0.0	18.1	62.9	77.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Amboori [4656]	KARIKKUZHI FOREST	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KASAROAD	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KOCHUVAYEL MUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KOMBAI KANI	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KONDAKETTY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KOOTTAAPPU	81.0	0.0	13.5	67.5	83.3	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KUDAPPANAMOODU	81.0	10.0	24.0	47.0	58.0	High
THIRUVANANTHAPU RAM	Amboori [4656]	KUDAPPANAMOODUMARKET	81.0	0.0	21.1	59.9	74.0	High
THIRUVANANTHAPU RAM	Amboori [4656]	KULAMAMKUZHY	81.0	0.0	3.3	77.7	95.9	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KUMBICHAL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KURANJIMAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KUTTAMALA ITC	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	KUZHİYAR	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	MAMPARA	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	MAYAM	121.0	0.0	3.5	117.5	97.1	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	MOONGODU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	MUTHUPOTTA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Amboori [4656]	NEDUMPULLYY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	NJAVARAKKAD	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	NJAVARIAL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	NULLIYODU	129.0	0.0	51.0	78.0	60.5	High
THIRUVANANTHAPU RAM	Amboori [4656]	PAMBARAMKAVU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	PANTHA	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	PANTHAPLAMOODU	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	PEREKKONAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	POOCHAMUKKU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	POOCHAMUKKU HOSPITAL	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	PURAVIMALA	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	PURAVIMALA FOREST	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	PURUTHIPARA	51.0	0.0	0.0	51.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	PUTTUKAL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	RAJAGIRI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	SOORAVAKANI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	THANTTANMUKKU	81.0	0.0	14.6	66.4	82.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Amboori [4656]	THATTANMUKKU COLONY	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	THEKKEPANTHA	81.0	0.0	7.0	74.0	91.4	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	THEKKUPARA	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	THUDIYAMKONAM	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	VAVODU	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	VAZHICHAL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	VAZHICHAL SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	VELLARIKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Amboori [4656]	VITTIYODE	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	ANANDESWARAM	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	ARIYAVILA	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	ARUKIL	81.0	6.0	11.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	ARYANAD BSNL	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	ARYANAD GANAPATHIYAM KOVIL	81.0	0.0	43.3	37.7	46.5	Medium
THIRUVANANTHAPU RAM	Aryanad [4652]	ARYANAD MARKET	81.0	0.0	22.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Aryanad [4652]	AYYANKALAMADAM	81.0	3.0	36.1	41.9	51.7	High
THIRUVANANTHAPU RAM	Aryanad [4652]	CHERUKULAM	81.0	6.0	32.7	42.3	52.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Aryanad [4652]	CHERUMANCHAL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	CHILENTHIKKAVU	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	CHONAMPARA	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	CHOOZHA	129.0	0.0	9.0	120.0	93.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	EANCHAPURI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	ELIMALA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	ERAVOOR	81.0	0.0	47.0	34.0	42.0	Medium
THIRUVANANTHAPURAM	Aryanad [4652]	ERAVOOR MARKET	81.0	0.0	15.0	66.0	81.5	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	ERAVOOR TOWER	81.0	0.0	4.0	77.0	95.1	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	ERUMAKUZH	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	HOUSING BOARD	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	IRINCHAL	129.0	0.0	30.0	99.0	76.7	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KACHERINADA	81.0	0.0	12.0	69.0	85.2	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KADAMANKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KADUKODE	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KAITHODE	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KALAMPARA	129.0	0.0	8.0	121.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Aryanad [4652]	KALLARATHOTAM	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KALLIYAL	81.0	0.0	4.0	77.0	95.1	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KALLODE	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPURAM	Aryanad [4652]	KALLUVARAMBU	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KANAKKUZHI	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPURAM	Aryanad [4652]	KANAKKUZHI CHURCH	129.0	0.0	17.0	112.0	86.8	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KANIYAMVILAKAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KANNANKARAMOOZHI	81.0	0.0	6.5	74.5	92.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KAPUKADU	81.0	3.0	0.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KARIMBHOTHAN PARA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KARIYODE	81.0	0.0	22.0	59.0	72.8	High
THIRUVANANTHAPURAM	Aryanad [4652]	KAVIYAKODE	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KOKKOTTELA NO-1	81.0	3.0	21.0	57.0	70.4	High
THIRUVANANTHAPURAM	Aryanad [4652]	KOKKOTTELA NO-2	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KOKKOTTELA TOWER	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KOMBIDI	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Aryanad [4652]	KOODARAM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Aryanad [4652]	KORANDIVILA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KOTTAKKAKAM	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KOTTOOR	129.0	0.0	12.5	116.5	90.3	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KOTTOOR BSNL	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KOTTOOR TOWER	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KSRTC ARYANAD	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KUNNATHERI	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KURUVIYODE	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KUTTICAL MARKET	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KUTTICAL MELEMUKKU	129.0	0.0	73.0	56.0	43.4	Medium
THIRUVANANTHAPU RAM	Aryanad [4652]	KUTTICAL NO-1	129.0	0.0	45.6	83.4	64.7	High
THIRUVANANTHAPU RAM	Aryanad [4652]	KUTTICAL NO-2	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	KUZHIAMKONAM	129.0	3.0	21.0	105.0	81.4	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	LOURDU MATHA	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MALAVILA	81.0	3.0	9.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MANCODU	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MANNAMKONAM	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Aryanad [4652]	MANTHIKALAM	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MARIAGIRI	129.0	0.0	13.0	116.0	89.9	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MARUTHUMOODU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MELECHIRA	81.0	0.0	35.4	45.6	56.4	High
THIRUVANANTHAPU RAM	Aryanad [4652]	MUKKALI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MUKKOTHIVAYAL	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MULAMOODU	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MUNDANI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	MYLAMOODU	81.0	5.0	3.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	NADUVILA	81.0	11.0	66.0	4.0	4.9	Very Low
THIRUVANANTHAPU RAM	Aryanad [4652]	PACHAKKADU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	PALAIKONAM	81.0	0.0	27.0	54.0	66.6	High
THIRUVANANTHAPU RAM	Aryanad [4652]	PALAM	129.0	0.0	42.8	86.2	66.8	High
THIRUVANANTHAPU RAM	Aryanad [4652]	PALLIVETTA	129.0	0.0	21.0	108.0	83.7	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	PANKAV	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	PARUTHIPPALLI NO-1	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	PATTANIPARA	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Aryanad [4652]	PENGAD	81.0	0.0	21.0	60.0	74.1	High
THIRUVANANTHAPU RAM	Aryanad [4652]	PODIYAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	PONNERAKONAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	POST OFFICE	129.0	3.0	48.2	77.8	60.3	High
THIRUVANANTHAPU RAM	Aryanad [4652]	POTHODE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	POTTENCHIRA NO-1	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	POTTENCHIRA NO-2	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	POTTUKAVU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	PUTHANMOODU	81.0	5.0	52.0	24.0	29.6	Medium
THIRUVANANTHAPU RAM	Aryanad [4652]	REST HOUSE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	SHAMBHUTHANGI COMPANY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	SUDHA FUELS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	THACHANCODE	81.0	6.0	12.0	63.0	77.8	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	THEMPAMOODE	81.0	10.0	16.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Aryanad [4652]	THOLOOR	129.0	10.0	47.8	71.2	55.2	High
THIRUVANANTHAPU RAM	Aryanad [4652]	THRIVENI	81.0	6.0	0.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	UPPANACHAMKALA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Aryanad [4652]	UTHARAMCODE	81.0	0.0	21.0	60.0	74.1	High
THIRUVANANTHAPU RAM	Aryanad [4652]	VALIPARA	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	VALIYAKALAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	VALIYAMALA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	VALLIMANGALAM	81.0	3.0	7.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	VAZHAPALLY	81.0	3.4	8.0	69.6	85.9	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	VLAVETTY	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Aryanad [4652]	VLAVILA	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	AL-SAFA	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	ALAMCODE	202.0	0.0	53.7	148.3	73.4	High
THIRUVANANTHAPU RAM	Attingal [4531]	ALAMCODE LPS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	ALAMCODE MOSQUE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	ALAMCODE PALLI	81.0	13.0	51.0	17.0	21.0	Low
THIRUVANANTHAPU RAM	Attingal [4531]	ALAMCODE THAIKAVU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	ALAMCODU HS	129.0	30.0	85.8	13.2	10.2	Low
THIRUVANANTHAPU RAM	Attingal [4531]	AMMACHANMUKKU	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	ANSAR SAW MILL	81.0	0.0	11.0	70.0	86.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Attingal [4531]	ARYAS	129.0	0.0	9.0	120.0	93.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	AWICS	81.0	23.0	48.0	10.0	12.3	Low
THIRUVANANTHAPU RAM	Attingal [4531]	AXIS BANK	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	AYYAMPALLY	129.0	16.0	72.8	40.2	31.2	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	BHASKAR COLONY	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	BHS	129.0	10.0	90.8	28.2	21.9	Low
THIRUVANANTHAPU RAM	Attingal [4531]	BHS GROUND	81.0	3.0	45.2	32.8	40.5	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	BISMI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	C S I SCHOOL	202.0	0.0	34.0	168.0	83.2	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	C S-I SCHOOL	202.0	0.0	23.4	178.6	88.4	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	CHAPATHUMUKKU NO-II	81.0	5.0	6.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	CHAPPATHUMUKKU	129.0	3.0	42.1	83.9	65.0	High
THIRUVANANTHAPU RAM	Attingal [4531]	CHATHANPARA	129.0	9.0	17.0	103.0	79.8	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	CHATHANPARA PUMP	81.0	5.0	31.0	45.0	55.6	High
THIRUVANANTHAPU RAM	Attingal [4531]	CHENCHERIKONAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	CHERUVALIKONAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	CHICKING	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Attingal [4531]	CHOOOLA COMPANY	81.0	6.0	15.0	60.0	74.1	High
THIRUVANANTHAPURAM	Attingal [4531]	CHLOORODU	129.0	16.0	39.0	74.0	57.4	High
THIRUVANANTHAPURAM	Attingal [4531]	COLLEGE ROAD	81.0	0.0	28.0	53.0	65.4	High
THIRUVANANTHAPURAM	Attingal [4531]	DENTAL HOSPITAL	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPURAM	Attingal [4531]	DIVISION OFFICE	81.0	25.0	44.3	11.7	14.5	Low
THIRUVANANTHAPURAM	Attingal [4531]	ENG COLLEGE	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	GHS	129.0	20.0	77.2	31.8	24.6	Low
THIRUVANANTHAPURAM	Attingal [4531]	GOVERNMENT COLLEGE	81.0	0.0	76.0	5.0	6.2	Very Low
THIRUVANANTHAPURAM	Attingal [4531]	GOWRI	81.0	8.0	51.9	21.1	26.1	Medium
THIRUVANANTHAPURAM	Attingal [4531]	GRAMOM	202.0	0.0	59.8	142.2	70.4	High
THIRUVANANTHAPURAM	Attingal [4531]	GURUNAGAPPANKAVU	129.0	0.0	51.0	78.0	60.5	High
THIRUVANANTHAPURAM	Attingal [4531]	HARISREE	81.0	5.0	12.5	63.5	78.5	Very High
THIRUVANANTHAPURAM	Attingal [4531]	HDFC BANK	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	HERCULES	129.0	0.0	67.5	61.5	47.7	Medium
THIRUVANANTHAPURAM	Attingal [4531]	HOMEO BSNL	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPURAM	Attingal [4531]	INDIRA TOWER	202.0	0.0	5.0	197.0	97.5	Very High
THIRUVANANTHAPURAM	Attingal [4531]	IOB	81.0	0.0	31.2	49.8	61.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Attingal [4531]	IOB NO-I	81.0	0.0	47.5	33.5	41.4	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	IRIS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	ITI NH	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Attingal [4531]	ITI ROAD	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	ITI- GODOWN	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	JYOTHISHALAYAM	81.0	0.0	21.6	59.4	73.4	High
THIRUVANANTHAPU RAM	Attingal [4531]	K S R T C GARRAGE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	KADUVAYIL	129.0	3.0	37.0	89.0	69.0	High
THIRUVANANTHAPU RAM	Attingal [4531]	KALLAMVILA	81.0	9.3	32.0	39.6	49.0	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	KALLOORKONAM	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	KARICHAYIL	81.0	0.0	53.0	28.0	34.6	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	KATCHERY	202.0	20.0	12.9	169.1	83.7	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	KATTUMPURAM	129.0	3.0	8.0	118.0	91.5	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	KATTUMPURAM SOCIETY	81.0	9.0	62.0	10.0	12.3	Low
THIRUVANANTHAPU RAM	Attingal [4531]	KAVUNADA	129.0	3.0	35.5	90.5	70.2	High
THIRUVANANTHAPU RAM	Attingal [4531]	KEEZHATTINGAL	129.0	0.0	69.8	59.2	45.9	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	KFC	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Attingal [4531]	KIDUTHATTU TEMPLE	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	KOCHUVILA	129.0	0.0	110.0	19.0	14.8	Low
THIRUVANANTHAPU RAM	Attingal [4531]	KODUMON	129.0	0.0	23.8	105.2	81.6	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	KOLLAMPUZHA	202.0	0.0	14.2	187.8	92.9	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	KOLLAMPUZHA SAW MILL	81.0	0.0	22.8	58.2	71.8	High
THIRUVANANTHAPU RAM	Attingal [4531]	KOLLAYILTHOPPU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	KOTTIYODU	129.0	3.0	56.4	69.7	54.0	High
THIRUVANANTHAPU RAM	Attingal [4531]	KTCT	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	KUDAVOORKONAM	81.0	10.0	36.5	34.5	42.6	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	KUDAVOORKONAM HS	81.0	0.0	28.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Attingal [4531]	KUNNUVARAM	81.0	8.0	43.0	30.0	37.0	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	KURUP LINE	81.0	13.0	45.0	23.0	28.4	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	KUTHIRALAYAM	202.0	8.0	60.5	133.5	66.1	High
THIRUVANANTHAPU RAM	Attingal [4531]	KUZHIMUKKU	129.0	12.0	53.0	64.0	49.6	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	LMS	202.0	24.0	59.1	118.9	58.9	High
THIRUVANANTHAPU RAM	Attingal [4531]	LOVE DALE SCHOOL	129.0	8.0	49.8	71.2	55.2	High
THIRUVANANTHAPU RAM	Attingal [4531]	M M MALL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Attingal [4531]	M R	202.0	17.0	86.5	98.5	48.8	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	MAKS COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	MAMOODU	81.0	5.0	22.5	53.5	66.1	High
THIRUVANANTHAPU RAM	Attingal [4531]	MANKATTUMoola	81.0	13.0	37.0	31.0	38.3	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	MANNOORBAGHAM PALLI	81.0	8.0	30.3	42.7	52.7	High
THIRUVANANTHAPU RAM	Attingal [4531]	MANNOORBHAGAM	81.0	4.0	12.3	64.7	79.9	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	MCFC	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	MELATTINGAL	81.0	0.0	23.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Attingal [4531]	METRO	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	MEVARKAL	81.0	7.0	12.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	MINI CIVIL STATION	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	MOON STAR	129.0	18.0	71.3	39.7	30.7	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	MUKKUTHODU	81.0	8.0	16.4	56.6	69.9	High
THIRUVANANTHAPU RAM	Attingal [4531]	MULLASSERIKUNNU	81.0	0.0	3.3	77.7	96.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	MUNICIPALITY	202.0	5.0	27.0	170.0	84.2	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	MUNJINADU	81.0	0.0	35.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Attingal [4531]	NJARAKKATTUVILA	129.0	5.0	8.0	116.0	89.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Attingal [4531]	PACHAMKULAM	81.0	3.0	34.2	43.8	54.1	High
THIRUVANANTHAPU RAM	Attingal [4531]	PALAMKONAM	129.0	0.0	89.3	39.7	30.8	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	PALLIMUKKU	129.0	17.0	40.7	71.3	55.2	High
THIRUVANANTHAPU RAM	Attingal [4531]	PANAVELIPARAMPU	81.0	0.0	32.0	49.0	60.5	High
THIRUVANANTHAPU RAM	Attingal [4531]	PANAYATTUKONAM	20.0	0.0	6.0	14.0	70.0	High
THIRUVANANTHAPU RAM	Attingal [4531]	PANTHUKULAM	20.0	10.0	4.7	5.3	26.4	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	PARAKKULAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	PARANKIMAMVILA	81.0	20.4	32.0	28.6	35.3	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	PERANAM	81.0	0.0	55.0	26.0	32.1	Medium
THIRUVANANTHAPU RAM	Attingal [4531]	POOVANPARA	129.0	5.0	123.5	0.5	0.4	Very Low
THIRUVANANTHAPU RAM	Attingal [4531]	POOVANPARA BRIDGE	81.0	3.0	0.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	PRARTHANA	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	PULIKAL	129.0	0.0	8.0	121.0	93.8	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	PUTHUKUNNU TEMPLE	81.0	0.0	3.5	77.5	95.7	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	RADIOMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	RAMACHAMVILA	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Attingal [4531]	RAMNAGAR	81.0	2.2	78.5	0.3	0.3	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Attingal [4531]	RAVIVARMA LANE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	RELIANCE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	REST HOUSE	129.0	12.8	30.0	86.2	66.8	High
THIRUVANANTHAPURAM	Attingal [4531]	RICH	81.0	3.0	11.0	67.0	82.7	Very High
THIRUVANANTHAPURAM	Attingal [4531]	S R	405.0	5.0	50.8	349.2	86.2	Very High
THIRUVANANTHAPURAM	Attingal [4531]	S S PLAZA	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	SAMAD HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	SANTHITHEERAM	81.0	0.0	23.7	57.3	70.7	High
THIRUVANANTHAPURAM	Attingal [4531]	SASTHAMPADIKKAL	129.0	0.0	54.5	74.5	57.8	High
THIRUVANANTHAPURAM	Attingal [4531]	SATHRAMMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	SHAMS COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	SHINE COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	SUB DIVISION	129.0	0.0	4.3	124.7	96.7	Very High
THIRUVANANTHAPURAM	Attingal [4531]	SUBRAMANYAN TEMPLE	81.0	0.0	3.1	77.8	96.1	Very High
THIRUVANANTHAPURAM	Attingal [4531]	THENCHERIKONAM-RA	81.0	5.0	23.0	53.0	65.4	High
THIRUVANANTHAPURAM	Attingal [4531]	THENGILAZHIKAM	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Attingal [4531]	THENNOORKUNNATHU	81.0	3.0	26.0	52.0	64.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Attingal [4531]	THETTIMANVILA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	THINAVILA	129.0	0.0	40.0	89.0	69.0	High
THIRUVANANTHAPURAM	Attingal [4531]	THOPPICHANTHA	129.0	4.0	27.2	97.8	75.8	Very High
THIRUVANANTHAPURAM	Attingal [4531]	THOTTAKKADU	81.0	0.0	30.0	51.0	63.0	High
THIRUVANANTHAPURAM	Attingal [4531]	THOTTAVARAM	81.0	3.0	41.3	36.7	45.3	Medium
THIRUVANANTHAPURAM	Attingal [4531]	THOTTIKALLU	81.0	0.0	39.0	42.0	51.9	High
THIRUVANANTHAPURAM	Attingal [4531]	THULASI TEMPLE	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPURAM	Attingal [4531]	TOWN HALL	81.0	0.0	24.0	57.0	70.4	High
THIRUVANANTHAPURAM	Attingal [4531]	TOWN UPS	81.0	0.0	78.3	2.7	3.4	Very Low
THIRUVANANTHAPURAM	Attingal [4531]	TREASURY	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	VAICAVILA COLONY	81.0	0.0	9.4	71.6	88.3	Very High
THIRUVANANTHAPURAM	Attingal [4531]	VALIYAVILA	81.0	0.0	23.3	57.7	71.3	High
THIRUVANANTHAPURAM	Attingal [4531]	VAYALIKULAM	129.0	16.0	43.8	69.2	53.7	High
THIRUVANANTHAPURAM	Attingal [4531]	VAZHAPPALLY LANE	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Attingal [4531]	VEERALAM	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPURAM	Attingal [4531]	VELAMKONAM	81.0	6.0	47.4	27.6	34.0	Medium
THIRUVANANTHAPURAM	Attingal [4531]	VELARKUDY	202.0	15.0	80.8	106.2	52.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Attingal [4531]	VELLOORKONAM TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Attingal [4531]	VILAYILMOOLA	129.0	10.0	43.0	76.0	58.9	High
THIRUVANANTHAPU RAM	Attingal [4531]	VV CLINIC	202.0	5.0	46.0	151.0	74.8	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	18TH MILE KORANI	81.0	0.0	83.8	0.0	0.0	Very Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	A A PLASTIC	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	A K G	129.0	3.0	78.0	48.0	37.2	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	A S N BRICKS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	AA PLASTIC-II	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	AISWARYA NAGAR	81.0	11.0	46.6	23.4	28.8	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	AKSHAYA PLASTIC	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ALALLOOR	81.0	5.0	6.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ALAYILMUKKU	81.0	0.0	40.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	AMBALAMUKKU	81.0	8.0	50.9	22.1	27.3	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	AMUNTHIRATHU	129.0	10.0	21.2	97.8	75.8	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ARABIC COLLAGE	81.0	8.3	25.3	47.4	58.5	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ASANVILAKAM	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ASSEMBLY MUKKU	81.0	0.0	64.7	16.3	20.1	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ATHIRTHIMUKKU	81.0	9.0	52.3	19.7	24.3	Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	AVANAVANCHERY TEMPLE	255.0	8.0	73.1	173.9	68.2	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	AYILAM SOUTH	81.0	13.0	13.9	54.1	66.8	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	AYILAM TEMPLE	129.0	18.0	38.8	72.2	56.0	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	AYYANKALI	81.0	19.5	56.2	5.3	6.5	Very Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	BHAVANA CHEMPOOR	81.0	0.0	27.3	53.7	66.2	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	C S N	81.0	3.0	8.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	CHANNOORKADAVU	81.0	3.0	3.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	CHEMPOOR	129.0	3.0	70.0	56.0	43.4	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	CHEMPOOR LPS	81.0	5.0	42.0	34.0	42.0	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	CHENCHERY	81.0	10.0	30.7	40.3	49.7	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	CHITTATTINKARA PALLI	129.0	6.3	96.8	25.9	20.1	Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	CHOOOLA	81.0	3.0	39.0	39.0	48.1	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	COSMO GARDEN	81.0	3.0	45.4	32.6	40.3	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	EDAKKODU SOCIETY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	EDASSERY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	EDATHIMON	81.0	0.0	9.1	71.9	88.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ELAMPA HS	81.0	3.3	32.0	45.7	56.4	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ELAMPA PALAM	81.0	6.0	14.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ELAMPA THADAM	20.0	5.0	8.0	7.0	35.0	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	EV CHARGING STATION	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	GATE MUKKU	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	GRAMATHUMMUKKU	81.0	0.0	45.8	35.2	43.5	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	GUEST HOUSE	202.0	0.0	25.0	177.0	87.6	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	HARA	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	HERCULIS	129.0	0.0	10.2	118.8	92.1	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	HOSPITAL VALIYAKUNNU	129.0	5.0	28.0	96.0	74.4	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	INDUS	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	INTERNATIONAL SCHOOL	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	IOB	81.0	0.0	49.0	32.0	39.5	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KAIRALI NAGAR	81.0	5.0	17.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KALLINMOODU	81.0	8.0	23.0	50.0	61.7	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KARIKKUZHI	81.0	0.0	30.3	50.7	62.6	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KATTADIPOIKA	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KATTAYIL KONAM	81.0	0.0	33.5	47.5	58.7	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KATTUCHANTHA	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KIMS MOONNUMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KOCHALINMOODU	81.0	19.0	33.5	28.5	35.2	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KOLOOR STADIUM	81.0	0.0	15.6	65.4	80.7	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KORANI	129.0	5.0	34.0	90.0	69.8	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KUNNATHAMKONAM	81.0	3.0	19.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KURUMAMCODE	20.0	3.0	0.0	17.0	85.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	KUZHAVOORKONAM	81.0	0.0	7.0	74.0	91.4	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	LAKSHMI VILA	81.0	8.0	33.0	40.0	49.4	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MADAMOOZHY	81.0	10.6	31.0	39.5	48.7	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MAIVALLY ELAI	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MAMAM CLAY	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MAMAM S B I	81.0	15.0	5.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MAMOM MARKET	405.0	3.0	89.4	312.6	77.2	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MAMOM RELIANCE	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MANKATTUMoola	81.0	3.0	22.0	56.0	69.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MEHFIL	81.0	0.0	77.5	3.5	4.3	Very Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MELE ELAMPA	129.0	3.0	24.8	101.2	78.5	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MODEL BREAD	81.0	3.0	35.7	42.3	52.2	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MOHAJ	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MOONNUMUKKU	202.0	13.0	26.4	162.6	80.5	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	MURINGAMAN	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	NAKRAMCODE	129.0	11.0	44.3	73.7	57.1	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	NAZA TOWER	129.0	0.0	45.0	84.0	65.1	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	NEDUMPARAMPU	81.0	4.0	45.9	31.1	38.4	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	NEDUMPARAMPU GURUMANDIRAM	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	NELLIMOODU	81.0	8.0	8.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	NELLIVILA MUKKU	81.0	6.0	76.0	0.0	0.0	Very Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ONIVARAM	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	OORUPOIKA	202.0	0.0	82.4	119.6	59.2	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	PALAMOODU	81.0	0.0	88.0	0.0	0.0	Very Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	PALLIYARA	81.0	16.0	28.0	37.0	45.7	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	PARAYADI	81.0	0.0	41.0	40.0	49.4	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Avanavancherry [4532]	PARUTHI TEMPLE	129.0	0.0	62.8	66.2	51.3	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	PARUTHOOR	81.0	3.3	18.0	59.7	73.7	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	PARUTHOOR CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	PEROORKONAM	81.0	3.0	17.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	PLAVINMOODU	81.0	3.3	23.0	54.7	67.5	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	POIKAMUKKU	129.0	6.0	48.0	75.0	58.1	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	POINT MUKK	202.0	5.0	58.8	138.2	68.4	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	POOVANATHINMOODU	81.0	0.0	21.0	60.0	74.0	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	REGENCY MALL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ROMANA DISTILLERY	81.0	68.0	0.0	13.0	16.0	Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	ROYAL SODA	81.0	5.0	52.0	24.0	29.6	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	SAI GRAMOM	81.0	0.0	50.0	31.0	38.3	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	SANTHINAGAR	81.0	3.0	76.2	1.8	2.2	Very Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	SARATHI	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	SOCIETY CHEMPOOR	129.0	3.0	51.7	74.3	57.6	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	SREEPADAM	81.0	5.0	73.3	2.7	3.3	Very Low
THIRUVANANTHAPU RAM	Avanavancherry [4532]	STYLE UNION	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Avanavancherry [4532]	SUBSTATION	81.0	3.0	37.5	40.5	50.0	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	THACHOORKUNNU	81.0	3.0	19.3	58.7	72.5	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	THARANGINI	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	THAZHE ELAMPA	81.0	0.0	8.2	72.8	89.9	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	THEMBRAKONAM	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	THERIMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	TOLL JUNCTION	129.0	8.3	74.5	46.2	35.8	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	UMAHALL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	VALAKKADU	129.0	6.0	44.3	78.7	61.0	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	VALIYAKUNNU WS	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	VALIYAVILA	81.0	5.0	52.0	24.0	29.7	Medium
THIRUVANANTHAPU RAM	Avanavancherry [4532]	VARUVILAKOM	81.0	0.0	23.5	57.5	71.0	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	VASUDEVAPURAM	81.0	3.0	19.5	58.5	72.2	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	VAYANASALA	129.0	0.0	49.0	80.0	62.0	High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	VELANCODE PUMP HOUSE	81.0	3.0	15.0	63.0	77.8	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	VELLANIKKAL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Avanavancherry [4532]	WATER SUPPLY	405.0	3.0	36.0	366.0	90.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Balaramapuram [4542]	AGUSTAIR KOVIL	129.0	0.0	23.8	105.2	81.6	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	ALUVILA	81.0	0.0	59.5	21.5	26.5	Medium
THIRUVANANTHAPURAM	Balaramapuram [4542]	AMMANOORKKONAM	81.0	5.0	26.0	50.0	61.7	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	ANTHIYOOR	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	AYSWARYA GARDEN	81.0	3.0	30.0	48.0	59.3	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	AZHIPPIL	81.0	0.0	22.0	59.0	72.8	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	BALARAMAPURAM H S	81.0	0.0	34.4	46.6	57.5	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	BALARAMAPURAM NO-I	202.0	0.0	39.0	163.0	80.7	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	BALARAMAPURAM NO-II	202.0	0.0	95.0	107.0	53.0	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	BALARAMAPURAM NO-III	81.0	0.0	21.0	60.0	74.1	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	BHUMI HOMES	202.0	0.0	7.0	195.0	96.5	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	CHAMAVILA	129.0	0.0	35.4	93.6	72.5	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	CHANALPALAM THEMPAMUTTAM	81.0	0.0	37.0	44.0	54.3	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	CHARUVILA	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	CHEMMANNUKKUZH	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	CHITTIKKODU	81.0	0.0	7.0	74.0	91.4	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	CSI CHURCH IYTHIYOOR	0.0	0.0	0.0	0.0	-	Unknown

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Balaramapuram [4542]	CSI CHURCH-IYTHIYOOR ORIGINAL	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	DILEEP ROAD	81.0	0.0	21.4	59.6	73.5	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	DYE HOUSE	129.0	3.0	25.0	101.0	78.3	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	EDAKONAM THEMPAMUTTAM	81.0	0.0	12.0	69.0	85.2	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	EDUVA	129.0	4.0	48.9	76.1	59.0	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	FAKKIRGI	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	FEDERAL BANK	81.0	5.0	6.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	GANDHIGRAM	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	GEEM AUDITORIUM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	GURUDEVAN	81.0	5.0	0.0	76.0	93.8	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	HOUSING BOARD NO IV	0.0	0.0	15.0	0.0	-	Unknown
THIRUVANANTHAPURAM	Balaramapuram [4542]	HOUSING BOARD NO-I	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	HOUSING BOARD NO-II	202.0	0.0	39.0	163.0	80.7	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	HOUSING BOARD NO-III	202.0	0.0	3.0	199.0	98.5	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	HOUSING BOARD NO-IV	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KAIRALI GARDEN	81.0	0.0	68.0	13.0	16.0	Low
THIRUVANANTHAPURAM	Balaramapuram [4542]	KALLAMBALAM	202.0	0.0	17.0	185.0	91.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Balaramapuram [4542]	KATTU KULAM	81.0	3.0	11.0	67.0	82.7	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KAVINPURAM SOCIETY	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KAVUVILA	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KLPPADIYIL	81.0	0.0	34.7	46.3	57.1	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KODINADA	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KOODALLOOR	81.0	3.0	0.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KOORACHAN VILA	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KORANDI VILA	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KOTTAYAMMUKKU	81.0	3.0	12.0	66.0	81.5	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KOTTUKALKONAM SCHOOL	81.0	0.0	30.0	51.0	63.0	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KOZHODU	129.0	3.0	26.0	100.0	77.5	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KRISHNAPURAM SCHOOL	81.0	0.0	55.0	26.0	32.1	Medium
THIRUVANANTHAPURAM	Balaramapuram [4542]	KULANGARAKKONAM	81.0	3.0	8.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KULAVARAMBU	81.0	3.0	18.0	60.0	74.1	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	KUZHIVILASCHOOL	81.0	3.0	14.0	64.0	79.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MACHEL	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MACHEL STADIUM	81.0	0.0	34.0	47.0	58.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Balaramapuram [4542]	MADANKOVIL STREET	81.0	3.0	11.0	67.0	82.7	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MADANPARA	81.0	0.0	66.0	15.0	18.5	Low
THIRUVANANTHAPURAM	Balaramapuram [4542]	MALAVILA	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MALODE TEMPLE	129.0	0.0	17.0	112.0	86.8	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MANKALLIYOOR	129.0	0.0	21.0	108.0	83.7	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MARTHANDESWARAM	81.0	8.0	41.0	32.0	39.5	Medium
THIRUVANANTHAPURAM	Balaramapuram [4542]	METRO GARDEN	81.0	0.0	37.0	44.0	54.3	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MILLROSE	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MOOKAMBIKA	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MOTTAMOODU	202.0	0.0	13.0	189.0	93.6	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MUKKAMPALAMOODU NO-I	202.0	3.0	46.0	153.0	75.7	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MUKKAMPALAMOODU NO-II	81.0	0.0	33.0	48.0	59.2	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MUKKUNADA	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MULAKKALNADA	81.0	3.0	32.0	46.0	56.8	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MULAMOODU NO-II	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MULAMOODU-1	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	MUTHUVALLOORKONAM	81.0	0.0	18.0	63.0	77.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Balaramapuram [4542]	MYLAMOODU CHURCH	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	N C PURAM EDUVA	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	NADUKADU	129.0	3.0	45.0	81.0	62.8	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	NADUKKAD NSS	81.0	3.0	38.0	40.0	49.4	Medium
THIRUVANANTHAPURAM	Balaramapuram [4542]	NARUVAMOODU NO-1	129.0	0.0	68.8	60.2	46.7	Medium
THIRUVANANTHAPURAM	Balaramapuram [4542]	NARUVAMOODU-II	129.0	0.0	14.0	115.0	89.1	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	NAZARETH HOME SCHOOL NO-1	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	NAZARETH HOME SCHOOL NO-2	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	NEELANCHAL	81.0	3.0	9.0	69.0	85.2	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	NELLIVILA NO-I	202.0	0.0	35.3	166.7	82.5	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	NELLIVILA NO-II	129.0	3.0	22.5	103.5	80.2	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	NEW PANCHAYATH	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	OLIPPUNADA	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	ORION PLAZA	162.0	0.0	0.0	162.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	PANAYARAKKUNNU	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	PANAYARAKUNNU WATER TANK	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	PANAYATHERI	81.0	0.0	26.0	55.0	67.9	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Balaramapuram [4542]	PARAKUZHI COLONY	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	PARUTHICHAKONAM	202.0	0.0	19.0	183.0	90.6	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	PARUTHITHOPPU	129.0	9.0	24.0	96.0	74.4	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	PARVATHY HOSPITAL	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	PATHIRIYODE	81.0	3.0	8.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	PLAVOTTUTHOPPUKULAM	81.0	0.0	12.5	68.5	84.5	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	POOKAITHA	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	POOMCODE	81.0	5.0	36.5	39.5	48.7	Medium
THIRUVANANTHAPURAM	Balaramapuram [4542]	POOVADA	81.0	3.0	43.3	34.7	42.8	Medium
THIRUVANANTHAPURAM	Balaramapuram [4542]	PUTHRAKADU	81.0	3.0	18.0	60.0	74.1	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	QRS	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	R C STREET	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	RESSELPURAM NO-I	81.0	0.0	41.0	40.0	49.4	Medium
THIRUVANANTHAPURAM	Balaramapuram [4542]	RESSELPURAM NO-II	81.0	6.0	30.9	44.1	54.5	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	SBI TRANSFORMER	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	SULTHANA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	THALAYAL	129.0	0.0	29.0	100.0	77.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Balaramapuram [4542]	THALAYARUKONAM	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	THANNIKUZH	81.0	11.0	28.0	42.0	51.9	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	THANNIVILA	129.0	0.0	9.0	120.0	93.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	THEMPAMUTTOM	202.0	5.0	64.0	133.0	65.8	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	THENKARAKONAM	81.0	5.0	13.7	62.3	76.9	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	THITTAVELIKKARA	202.0	0.0	37.1	164.9	81.6	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	THUMBODE	81.0	0.0	35.3	45.7	56.4	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	V-CAST	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	VADAKKEVILA	81.0	0.0	41.0	40.0	49.4	Medium
THIRUVANANTHAPURAM	Balaramapuram [4542]	VALIYARATHALA	202.0	3.0	12.0	187.0	92.6	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	VANIGAR STREET	129.0	0.0	22.0	107.0	82.9	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	VELIKKOTTUKONAM	81.0	0.0	30.0	51.0	63.0	High
THIRUVANANTHAPURAM	Balaramapuram [4542]	VELLAPALLI CHANALKARA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	VELLAPALLY	81.0	3.0	11.0	67.0	82.7	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	VETTAMANGALAM	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	VILAYILMANA	81.0	5.0	10.0	66.0	81.5	Very High
THIRUVANANTHAPURAM	Balaramapuram [4542]	VILLIKULAM	81.0	0.0	32.4	48.6	60.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	AKSHARA VEEDHI	129.0	11.0	111.1	6.9	5.3	Very Low
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	ALAKKUKADAVU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	ALL SAINTS COLLEGE	202.0	11.0	127.0	64.0	31.7	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	ALL SAINTS JN	255.0	10.0	30.0	215.0	84.3	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	APPAN PILLA	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	ARAPPURAVILAKOM	81.0	8.0	17.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	AZEEM TOWER	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	BALANAGAR NO 1	202.0	0.0	2.0	200.0	99.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	BALANAGER NO 2	129.0	3.0	46.0	80.0	62.0	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	BHARATH PETROLEUM	202.0	9.0	23.0	170.0	84.2	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	BOAT CLUB	129.0	0.0	17.0	112.0	86.8	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	CHACKAI NO 1	405.0	5.0	67.3	332.7	82.1	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	CHACKAI NO2	129.0	0.0	84.0	45.0	34.9	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	CHOONDAKKUNNU	405.0	14.0	136.1	254.9	63.0	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	DEEDI	202.0	15.0	16.0	171.0	84.7	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	FACT	202.0	0.0	47.0	155.0	76.7	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	GANDHIMATHY SULPHATE	202.0	0.0	6.0	196.0	97.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	GURUSWAMY	81.0	0.0	40.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	GV RAJA	202.0	10.0	35.4	156.6	77.5	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	HIGH WAY	202.0	0.0	28.7	173.3	85.8	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	ICE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	IMA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	INTERNATIONAL	405.0	0.0	48.0	357.0	88.1	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	IOC	202.0	3.0	107.5	91.5	45.3	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KANNANTHURA	255.0	14.0	25.4	215.6	84.6	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KARALI NO 1	81.0	5.0	23.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KARALI-N0-II	81.0	5.0	22.3	53.7	66.3	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KARIKKAKAM WEST	129.0	5.0	50.8	73.2	56.8	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KARIKKAKOM LIBRARY	129.0	0.0	70.4	58.6	45.4	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KARIKKAKOM PUMP HOUSE	81.0	7.0	42.7	31.3	38.6	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KARIKKAKOM SCHOOL	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KARIKKAKOM TEMPLE	202.0	5.0	15.0	182.0	90.1	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KOCHUVELI MARKET	405.0	4.0	76.0	325.0	80.2	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KOCHUVELI TSUNAMI	81.0	0.0	37.0	44.0	54.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KSEB OFFICE	405.0	14.0	102.4	288.6	71.2	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	KSRTC SWIT EV 2	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT AEROPOLYS	255.0	0.0	5.0	250.0	98.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT AJAX	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT ALUMINIUM ALIED	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT ARC OILSEAL	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT AYISHA RUBBER	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT BEACON	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT CORAMANDAL CLAYS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT ELASTOTOPE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT FILATEX	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT INDOSHA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT KNR	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT KSRTC SWIFT	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT LOTUS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT LULU TENANT	1,620.0	0.0	0.0	1,620.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	LT METACARE	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT MSK WOODS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT NEST AGRO	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT ORANGE PRINTERS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT POWER LAUNDRY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT POWER PACK	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT PRASANTH RESIDENTIAL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT SATHYA LUBRICANTS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT SEASON TWO	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT SIVAVEL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT SSS RUBBER	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT TERMINAL PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT TRIVENI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	LT ZENCOIR	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	MADHAVAPURAM	202.0	8.0	60.4	133.6	66.1	High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	MADHURAM	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	MARBLE	202.0	15.0	159.9	27.1	13.4	Low
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	MINERVA PARAKKUDY	202.0	5.0	136.6	60.4	29.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	MOONAMANACKAL	129.0	3.0	40.5	85.5	66.3	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	MUDSUN	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	NH BYPASS	202.0	5.0	39.9	157.1	77.8	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	NIRMIDHI	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	OTTUPURA	81.0	0.0	47.5	33.5	41.3	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	PANCHAYATH KINAR	81.0	0.0	12.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	PONMUDI	405.0	0.0	75.0	330.0	81.5	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	POULTRY NO 1	405.0	10.0	170.2	224.8	55.5	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	POULTRY NO 2	255.0	8.0	170.4	76.6	30.0	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	POWERLINES	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	PRIYA RUBBER	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	PULLY MUDUKKU	405.0	0.0	203.0	202.0	49.9	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	PWD	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	R R LAUNDRY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	RAJEEV NAGAR	129.0	3.0	9.0	117.0	90.7	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	RVR	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	SABEENA	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	SATHEENDRA	202.0	52.0	77.0	73.0	36.1	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	SHANGHUMUGHAM NO 1	202.0	0.0	20.0	182.0	90.1	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	SHANGHUMUGHAM NO 2	202.0	0.0	40.0	162.0	80.2	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	SHANGHUMUGHAM TSUNAMI	129.0	3.0	42.0	84.0	65.1	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	SOUTH THUMBA	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	ST SEBASTIAN	81.0	8.0	31.0	42.0	51.9	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	ST SEBASTIAN NO 2	129.0	3.0	35.0	91.0	70.5	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	SV 43 - NO1	255.0	8.0	75.0	172.0	67.5	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	SV43 - NO2	81.0	0.0	14.3	66.7	82.3	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	THAZHASSERY	255.0	3.0	167.0	85.0	33.3	Medium
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	VALIAVELI CHURCH	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	VALIAVELI HEALTH CENTRE	202.0	13.0	34.7	154.3	76.4	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	VALIAVELI KURISHADI	202.0	0.0	28.0	174.0	86.1	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	VALIAVELI STADIUM	129.0	3.0	42.8	83.2	64.5	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	VALIAVELI TSUNAMI	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	VALIYAKULAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Beach Trivandrum [4513]	VAZHAVILA	202.0	0.0	71.8	130.2	64.5	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	VAZHAVILA PALAM	129.0	5.0	50.4	73.6	57.0	High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	VETTUKAD NO 1	405.0	11.0	161.1	232.9	57.5	High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	VETTUKAD NO 2	202.0	0.0	39.0	163.0	80.7	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	VETTUKAD TSUNAMI	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	VIDYAPEEDAM	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	WIRELESS	202.0	8.0	49.0	145.0	71.8	High
THIRUVANANTHAPURAM	Beach Trivandrum [4513]	WORLD MARKET	255.0	5.0	178.0	72.0	28.2	Medium
THIRUVANANTHAPURAM	Cantonment TVM [4506]	A R CAMP	202.0	0.0	107.0	95.0	47.0	Medium
THIRUVANANTHAPURAM	Cantonment TVM [4506]	AIRLINES	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Cantonment TVM [4506]	ANDOOR	129.0	0.0	10.0	119.0	92.3	Very High
THIRUVANANTHAPURAM	Cantonment TVM [4506]	ANVI TOWER	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Cantonment TVM [4506]	APOORVA CHAMBERS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Cantonment TVM [4506]	AROMA FLAT	510.0	0.0	0.0	510.0	100.0	Very High
THIRUVANANTHAPURAM	Cantonment TVM [4506]	ARTECH-SAMRUDHI	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Cantonment TVM [4506]	ASPINWALL	510.0	0.0	25.0	485.0	95.1	Very High
THIRUVANANTHAPURAM	Cantonment TVM [4506]	AYYANKALI HALL CSS	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPURAM	Cantonment TVM [4506]	AZAD	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	B CANTI	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	BAINS COURT	51.0	0.0	0.0	51.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	BAKERY NO-1	255.0	0.0	8.0	247.0	96.9	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	BAKERY NO-3	129.0	0.0	34.0	95.0	73.7	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	BARTON HILL	202.0	28.0	101.0	73.0	36.1	Medium
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	BELHAVEN GRAND	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	BHEEMA RESIDENCE	129.0	0.0	10.0	119.0	92.2	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	BHIMA URBAN GLORY	202.0	0.0	3.0	199.0	98.5	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	BOB PLAZA HDFC BANK	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	BRIGADIER LANE	202.0	5.0	75.8	121.2	60.0	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CANARA	202.0	0.0	5.0	197.0	97.5	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CANTONMENT-NO-1	202.0	0.0	34.0	168.0	83.2	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CANTONMENT-NO-2	202.0	0.0	74.0	128.0	63.4	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CAPITAL HEIGHTS	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CAPITOL TOWER	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CHAKRA	255.0	0.0	25.0	230.0	90.2	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CHANDRA	129.0	0.0	14.0	115.0	89.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CHANDRASEKARAN NAIR STADIUM	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CHARACHIRA	202.0	31.0	167.9	3.1	1.5	Very Low
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CHEMPAKA NAGAR	129.0	0.0	58.7	70.3	54.5	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CHINDHA	202.0	0.0	140.9	61.1	30.2	Medium
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CHITOR TOWER	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CHOICE HEIGHTS	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CITY SCHOOL	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CLIFF DALE	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CLIFF HOUSE-NO-1	202.0	4.0	96.0	102.0	50.5	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CLIFF HOUSE-NO-2	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CLOUD-9	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CORDIAL BHARATHI	510.0	0.0	0.0	510.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CORDIAL CORONA	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CORDIAL ESTATE VALENCODE	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CORDON KALYAN ROYAL	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	CORPORATION OUT	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	DEVASOM BOARD	202.0	9.0	147.5	45.5	22.5	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	DEW DROPS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	EVENING MARKET	202.0	5.0	136.7	60.4	29.9	Medium
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	GARDEN HEIGHTS	324.0	0.0	15.0	309.0	95.4	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	GREEN LANE	202.0	0.0	94.0	108.0	53.5	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	HEERA CRESENT	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	HEERA HIGH LIFE COMMERCIAL	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	HEERA HIGH LIFE RESIDENTIAL	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	K J K HOSPITAL	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	KADAYARA HOMEZ	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	KESTON RISE	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	KESTON TOWER	162.0	0.0	0.0	162.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	KOWDIAR HEAVEN	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	KOWDIAR HEIGHTS	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	KP TRANS	405.0	5.0	301.0	99.0	24.4	Low
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	KUNNUKUZHY	405.0	5.0	243.1	156.9	38.7	Medium
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	LABOUR COMPLEX	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	LAUREL PARK APARTMENT	129.0	0.0	13.0	116.0	89.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	LE-ROYALE	324.0	40.0	5.0	279.0	86.1	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	LEELAMMA MATHEW	129.0	0.0	25.0	104.0	80.6	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	LIBRARY	810.0	0.0	0.0	810.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	LMS-NO-1	202.0	5.0	38.0	159.0	78.7	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	LMS-NO-2	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	LMS-NO-3	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	LOGTECH	324.0	0.0	40.0	284.0	87.7	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	MAHARANI	405.0	0.0	38.0	367.0	90.6	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	MALANKARA	202.0	0.0	10.0	192.0	95.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	MERRIE PINK	162.0	0.0	0.0	162.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	MLCP-EV	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	MUTHOOT CAPITAL VIEW	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	MUTHOOT HOMEZ	324.0	0.0	50.0	274.0	84.6	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	NANDAVANAM	405.0	0.0	193.9	211.1	52.1	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	NANTHANCODE	405.0	9.0	201.8	194.2	48.0	Medium
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	NANTHANCODE-RBI QUARTERS	202.0	13.0	69.0	120.0	59.4	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	NEPTUNE	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	NETHAJI BOSS	129.0	5.0	30.0	94.0	72.9	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PALAYAM POLICE QUARTERS	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PALAYAM REHAB BLOCK	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PANAMOODU-NO-1	202.0	0.0	95.8	106.2	52.6	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PANAMOODU-NO-2	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PANDIT COLONY-NO-1	405.0	20.0	155.9	229.1	56.6	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PANDIT COLONY-NO-2	202.0	10.0	61.0	131.0	64.9	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PANKAJ TOWER	405.0	0.0	10.0	395.0	97.5	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PARK VIEW	255.0	0.0	20.0	235.0	92.2	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PEARL GARDEN	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PLAMOODU-NO-1	255.0	13.0	143.4	98.6	38.7	Medium
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PLAMOODU-NO-2	202.0	0.0	73.6	128.4	63.6	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PPD ANTHEM	510.0	0.0	0.0	510.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PRS GRACE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	PTC GRANDUER	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	QUEENS WAY	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	RBI OUT	202.0	0.0	53.5	148.5	73.5	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	REGENT COURT	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	RELCON	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	RELCON GREENLANE	162.0	0.0	0.0	162.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SAMARIYAS	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SANSKRIT	405.0	0.0	152.0	253.0	62.5	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SANSKRITI APARTMENT	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SAPHALYAMYAM COMPLEX-I	810.0	0.0	0.0	810.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SERENADE	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SERENE SQUARE	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SFS CAPITAL PARK	255.0	0.0	5.0	250.0	98.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SFS ONLY ONE	162.0	0.0	3.0	159.0	98.1	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SILVER OAK	202.0	10.0	166.2	25.8	12.8	Low
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SPENCER	324.0	0.0	0.0	324.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SREE DHANYA CASTLE	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SREEDHANYA VANTAGE POINT	510.0	0.0	0.0	510.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SREEPADMANABHA HEIGHTS	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	ST GEORGE CHURCH	324.0	0.0	0.0	324.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	STPI	255.0	0.0	30.0	225.0	88.2	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SUN ELITE	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SWARAJ BHAVAN	202.0	0.0	80.0	122.0	60.4	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	SYCOMORE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	THEKKUMMOODU	202.0	0.0	201.6	0.4	0.2	Very Low
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	TURBO PLUS PRECISE EYE HOSPITA	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	U I T	202.0	0.0	137.0	65.0	32.2	Medium
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	UNIVERSITY NO-1	202.0	0.0	41.4	160.6	79.5	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	UNIVERSITY NO-2	129.0	0.0	18.0	111.0	86.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	UTHRADAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	VALENCODE	405.0	3.0	113.3	288.6	71.3	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	VICTORIAN SQUARE	162.0	0.0	0.0	162.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	VIGILANCE	81.0	0.0	35.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	VIKAS BHAVAN	810.0	0.0	56.0	754.0	93.1	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	VIKAS BHAVAN HT-LT	510.0	0.0	50.0	460.0	90.2	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	VINTAGE VIEW	324.0	0.0	20.0	304.0	93.8	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	VYLOPPILLY	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	WEST CLIFF	202.0	19.0	113.5	69.5	34.4	Medium
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	WINDSOR MANSION	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Cantonment TVM [4506]	YMR	405.0	13.0	174.6	217.4	53.7	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	A P THOPPE	81.0	3.0	10.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	ADIKKALAM	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	ALAPPURAMKUNNU	81.0	0.0	16.7	64.3	79.3	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	ALAPPURAMKUNNU TOWER	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	ALTHARAMOODU	129.0	0.0	72.8	56.2	43.6	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	AMBEDKAR SCHOOL	81.0	3.0	27.8	50.2	62.0	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	AMBEDKER-ITC	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	ANJENGO COIR	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	AYOORVEDA HOSPITAL	81.0	0.0	35.4	45.6	56.4	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	AZHOOR GATE	81.0	3.0	6.0	72.0	88.9	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	AZHOOR HS	81.0	0.0	23.5	57.5	71.0	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	AZHOOR KADAVU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	AZHOOR TEMPLE	81.0	0.0	24.7	56.3	69.5	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	AZHOOR VILLAGE	81.0	0.0	15.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	BHAVANA JUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	BSNL-I	81.0	0.0	36.0	45.0	55.6	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	BSNL-II	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	BUS STAND NO-I	129.0	0.0	33.5	95.5	74.0	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	BUS STAND NO-II	81.0	0.0	73.2	7.8	9.6	Very Low
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	CANARA BANK	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	CHANDIRAM	81.0	8.0	47.0	26.0	32.1	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	CHEMBINMOOLA	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	CHERUVALLIMUKKU	129.0	0.0	19.0	110.0	85.3	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	CHITTARIKONAM	81.0	5.0	27.0	49.0	60.5	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	CHOVAZCHA PALLY	129.0	6.0	9.3	113.7	88.1	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	CHUMADUTHANGI	81.0	6.0	23.0	52.0	64.2	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	DECENTMUKKU	81.0	0.0	21.0	60.0	74.1	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	EDATHODE	81.0	3.0	16.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	ERATTAKALUNGU	20.0	0.0	6.0	14.0	69.9	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	GANAPATHY TEMPLE	81.0	5.0	36.8	39.2	48.4	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	GAS GODOWN	81.0	6.0	46.0	29.0	35.8	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	HOSPITAL-I	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	HOSPITAL-II	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	I O B	129.0	3.0	49.8	76.2	59.0	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KABARADY	81.0	0.0	23.3	57.7	71.2	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KADAKAM BRIDGE	81.0	0.0	26.4	54.6	67.4	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KADAKAM BUND	81.0	9.7	31.0	40.3	49.7	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KADAKAM MARKET	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KAILATHUKONAM	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KALIYIL PALAM	81.0	3.0	45.0	33.0	40.7	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KALLUPALAM	81.0	8.0	34.0	39.0	48.1	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KATTUMURAKKAL PALLY	81.0	3.0	44.0	34.0	42.0	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KATTUMURAKKAL ROAD	81.0	5.0	20.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KEELIMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KERAL	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KIZHUVILAM VILLAGE	81.0	3.0	27.0	51.0	63.0	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KOCHALUMMOODU	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KOLICHIRA	81.0	0.0	15.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KOLICHIRA THALAPP	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KOOTUM VATHILKAL	202.0	3.0	53.6	145.4	72.0	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KORATTAVILAKAM	81.0	0.0	62.3	18.7	23.1	Low
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KOTTAPURAM	81.0	6.0	23.0	52.0	64.2	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KUNNILKADA	81.0	8.0	17.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KUNNUMALA TEMPLE	81.0	0.0	13.3	67.7	83.6	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KURAKKADA	129.0	0.0	54.0	75.0	58.1	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KURAKKADA AMBEDKAR	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	KUTTIYATHUMUKKU	81.0	8.0	15.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	LESKA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	MAMAM NADA	81.0	13.0	59.3	8.7	10.7	Low
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	MANCHADIMOODU	129.0	3.0	47.5	78.5	60.9	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	MANCHADIMOODU GATE	81.0	0.0	25.5	55.5	68.5	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	MANCHADIMOODU-II	81.0	3.0	21.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	MARANGATTUKONAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	MASCUT HOUSE	81.0	0.0	42.3	38.7	47.8	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	MEEMPATTU	81.0	0.0	27.5	53.5	66.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	MEGHAMALL-INDOOR	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	MILLUMUKKU	81.0	0.0	40.0	41.0	50.6	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	MUDAPURAM	202.0	3.0	69.0	130.0	64.4	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	MUKTHIPHARMA	81.0	15.0	33.0	33.0	40.7	Medium
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	MULAYATHARAKAVU	129.0	11.0	49.0	69.0	53.5	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	MUTTAPPALAM	81.0	6.6	17.4	57.0	70.4	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	MUTTAPPALAM PODIYANMUKKU	129.0	8.0	58.4	62.6	48.5	Medium
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	MUTTAPPALAM SOCIETY	81.0	3.0	47.3	30.7	37.9	Medium
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	NAINAM KONAM	81.0	14.0	44.3	22.7	28.0	Medium
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	NAINAM KONAM ANGANAWADI	81.0	3.0	4.0	74.0	91.4	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	NAINAM KONAM MARKET	81.0	5.0	12.0	64.0	79.0	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	NAINAMKONAM ESTATE	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	NES BLOCK TRANSFORMER	81.0	0.0	23.5	57.5	71.0	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	NETHAJINAGAR	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	NEW RAJASTHAN	81.0	0.0	28.1	52.9	65.3	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	OTTAPLAMUKKU	81.0	0.0	80.7	0.3	0.4	Very Low
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	PADANILAM	81.0	0.0	31.3	49.7	61.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PALAKUNNU ROAD	81.0	10.0	47.7	23.3	28.7	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PALAKUNNU TEMPLE	202.0	3.6	102.2	96.2	47.6	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PANDAKASALA	81.0	10.0	19.0	52.0	64.2	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PANDAKASALA PALLI	81.0	0.0	10.8	70.2	86.6	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PANGAMALA KUNNU	81.0	10.0	24.0	47.0	58.0	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PANTHALAKODU	81.0	0.0	35.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PARAKKADU	81.0	16.0	11.0	54.0	66.7	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PARAYATHUKONAM	81.0	8.0	9.3	63.7	78.6	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PARAYATHUKONAM PALLY	81.0	11.0	38.0	32.0	39.5	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PERUMPATTAM	81.0	11.0	36.3	33.7	41.6	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PREM NAZIR	81.0	5.0	85.2	0.0	0.0	Very Low
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PUKAYILATHOPE	81.0	3.0	35.0	43.0	53.1	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PULIMOODU	81.0	3.0	27.1	50.9	62.9	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PULUNTHURUTHI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PURAVOOR	129.0	21.0	66.5	41.5	32.2	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PURAVOOR PALAM	81.0	5.0	52.0	24.0	29.6	Medium
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	PUTHUKKARI	81.0	11.0	53.5	16.5	20.4	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	PUTHUVEDU	81.0	0.0	45.0	36.0	44.4	Medium
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	SABHAVILA	81.0	30.0	48.1	2.9	3.6	Very Low
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	SANTHINAGAR	81.0	8.0	43.9	29.1	35.9	Medium
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	SARKARA GATE	81.0	3.0	16.0	62.0	76.5	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	SARKKARA TEMPLE	129.0	0.0	31.0	98.0	76.0	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	SARKKARA VILLAGE	202.0	3.0	81.2	117.8	58.3	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	SEEDFARM	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	SIVAKRISHNAPURAM	81.0	0.0	41.3	39.7	49.0	Medium
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	SUNAMI	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	SWAMIJI	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	TAMARAKULAM	81.0	11.0	50.4	19.6	24.1	Low
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	THENGUVILA TEMPLE	81.0	0.0	39.8	41.2	50.9	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	THENOORKONAM	81.0	8.0	38.0	35.0	43.2	Medium
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	THETTICHIRA	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	THITTAYILMUKKU	81.0	0.0	22.0	59.0	72.8	High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	THOTTAVARAM	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Chirayinkeezhu [4529]	TRIVENI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	VAKKATHUVILA	81.0	0.0	27.0	54.0	66.7	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	VALIYA ELA	81.0	3.0	14.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	VYDYANTE MUKKU	81.0	5.0	23.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Chirayinkeezhu [4529]	WATER WORKS	81.0	0.0	38.9	42.1	52.0	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	AANAD VAYAL	129.0	11.0	85.0	33.0	25.6	Medium
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ALAMUKKU	51.0	0.0	3.0	48.0	94.1	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	AMBEDKAR GRAMAM	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ANAD	81.0	0.0	35.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ANAD MANDAPAM	81.0	6.0	35.0	40.0	49.4	Medium
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ANAD PANCHAYATH	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ANCHAMKALLU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ARAMPALLY	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ARAMPALLY PUMP HOUSE	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ARIMKODU	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ATTINPURAM	81.0	3.0	10.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ATTINPURAM PUMPHOUSE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ATTUKAL AMBALAM	81.0	3.0	52.0	26.0	32.1	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ATTUKAL MILK	81.0	3.0	13.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	CHAKIRI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	CHANDRAMANGALAM	129.0	0.0	32.0	97.0	75.2	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	CHEKKONAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	CHERUVELI	81.0	3.0	39.0	39.0	48.1	Medium
THIRUVANANTHAPU RAM	Chullimanoor [4653]	CHULLALAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	CHULLALAM QUARY	81.0	0.0	18.0	63.0	77.8	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	CHULLIMANOOR	129.0	0.0	36.0	93.0	72.1	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	CISF	202.0	6.0	17.0	179.0	88.6	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	EARUMALA NO-2	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	ERUMALA NO-1	20.0	5.0	0.0	15.0	75.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	GANDHINAGAR	81.0	3.0	32.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	HEERA	81.0	5.0	3.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	IRYANADU	81.0	3.0	20.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	JEMS KALLIYODE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KALLADAKUNNU	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KALLIYODE	81.0	3.0	12.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KARIKUZHI	81.0	5.0	35.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KARIMKADA	81.0	5.0	22.0	54.0	66.7	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KARINKADA MINI	202.0	11.0	19.0	172.0	85.1	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KAZHAKKUNNU	202.0	3.0	34.5	164.5	81.4	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KHADIBOARD	81.0	4.0	28.4	48.5	59.9	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KOCHATTUKAL	81.0	5.0	35.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KOCHUPALODE	51.0	0.0	6.0	45.0	88.2	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KONGANAMKODU	81.0	6.0	0.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KOONANVENGA	81.0	5.0	46.7	29.3	36.2	Medium
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KOTHAKULANGARA	81.0	0.0	35.0	46.0	56.7	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	KUNDARAKUZH	81.0	5.0	35.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	MAHALEKSHMI NGAR	81.0	0.0	23.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	MALLABRAKONAM	129.0	3.0	18.0	108.0	83.7	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	MAMOODU	81.0	6.0	27.8	47.2	58.3	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	MANIYANKODE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	METHODU	81.0	3.0	32.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	MOOZHI	129.0	3.0	76.0	50.0	38.8	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chullimanoor [4653]	MOTTAKKAVU	81.0	3.0	23.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	MUKKUDIL	51.0	0.0	5.0	46.0	90.2	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	MULAMOODU	81.0	0.0	15.0	66.0	81.5	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	NAGACHERY	81.0	0.0	12.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	NALUMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	NEDUMBA	81.0	6.0	13.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	NELLIKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	NETTARAKONAM	81.0	3.0	25.5	52.5	64.8	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	OFFICE CHULLIMANOOR	81.0	0.0	95.0	0.0	0.0	Very Low
THIRUVANANTHAPU RAM	Chullimanoor [4653]	OORALIKONAM	81.0	3.0	29.0	49.0	60.5	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PANAVOOR	129.0	0.0	19.0	110.0	85.3	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PANAVOOR KRISHI BHAVAN	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PANAVOOR TEL EX	81.0	3.0	27.0	51.0	63.0	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PANAYAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PANAYAMCHERRY	51.0	3.0	17.0	31.0	60.8	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PANAYAMUTTOM NIRAPPIL	81.0	0.0	31.0	50.0	61.7	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PANDARAKONAM	81.0	19.0	48.6	13.4	16.5	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chullimanoor [4653]	POOVAKKADU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PULLAMALA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PUNAVAKUNNU	81.0	0.0	30.0	51.0	63.0	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	PUTHENPALAM	129.0	5.0	22.0	102.0	79.1	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	S N PURAM	129.0	3.0	19.1	106.9	82.9	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	SANTHI NAGAR	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	SIEMENS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	THALIKKAMUKAL	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	THEKKUMMOODU	81.0	0.0	36.5	44.5	55.0	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	THETTI MOODU	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	THOTTUMUKKU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	TOLL	81.0	3.0	75.7	2.3	2.8	Very Low
THIRUVANANTHAPU RAM	Chullimanoor [4653]	UNNUPALAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	UZHAPPAKONAM	81.0	0.0	79.0	2.0	2.5	Very Low
THIRUVANANTHAPU RAM	Chullimanoor [4653]	VADAKKEKONAM	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	VALKULAM	81.0	0.0	29.6	51.4	63.4	High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	VATTARATHALA	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Chullimanoor [4653]	VAYYAKKAV	81.0	0.0	8.0	73.0	90.2	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	VELLAMCHIRA	81.0	12.0	29.0	40.0	49.4	Medium
THIRUVANANTHAPU RAM	Chullimanoor [4653]	VELLAMKUDY	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	VELLARIKONAM	81.0	5.0	11.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	VENKITTAKKALA	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Chullimanoor [4653]	VETTAMPALLY	81.0	5.0	36.0	40.0	49.4	Medium
THIRUVANANTHAPU RAM	Edava [4526]	ANCHUMUKKU	81.0	0.0	18.0	63.0	77.8	Very High
THIRUVANANTHAPU RAM	Edava [4526]	ARATHANTAVILA	81.0	10.0	61.3	9.7	12.0	Low
THIRUVANANTHAPU RAM	Edava [4526]	ATHIVILA	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Edava [4526]	BHAJANAMADOM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Edava [4526]	CHIRAG TOWER	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Edava [4526]	CHIRAYIL	129.0	10.0	26.0	93.0	72.1	High
THIRUVANANTHAPU RAM	Edava [4526]	DECENTMUKKU	81.0	0.0	35.3	45.7	56.4	High
THIRUVANANTHAPU RAM	Edava [4526]	DREAMZ RESIDENCY	81.0	0.0	15.0	66.0	81.5	Very High
THIRUVANANTHAPU RAM	Edava [4526]	EDAVA GATE	129.0	0.0	37.0	92.0	71.3	High
THIRUVANANTHAPU RAM	Edava [4526]	EDAVA HS	81.0	25.4	55.0	0.6	0.7	Very Low
THIRUVANANTHAPU RAM	Edava [4526]	EDAVA PHC	81.0	0.0	16.6	64.4	79.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Edava [4526]	EDAVAKKULAM	81.0	0.0	8.5	72.5	89.5	Very High
THIRUVANANTHAPURAM	Edava [4526]	HEALTH CENTRE	129.0	0.0	4.0	125.0	96.9	Very High
THIRUVANANTHAPURAM	Edava [4526]	JAWAHAR SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Edava [4526]	KADIYATHI	81.0	3.0	11.0	67.0	82.7	Very High
THIRUVANANTHAPURAM	Edava [4526]	KAKKULAM	81.0	18.0	49.0	14.0	17.3	Low
THIRUVANANTHAPURAM	Edava [4526]	KALARIYIL	81.0	0.0	22.3	58.7	72.5	High
THIRUVANANTHAPURAM	Edava [4526]	KALLAZHY	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Edava [4526]	KANNAMBA	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Edava [4526]	KAPPIL BOAT CLUB	81.0	3.0	15.0	63.0	77.8	Very High
THIRUVANANTHAPURAM	Edava [4526]	KAPPIL H S	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPURAM	Edava [4526]	KAPPIL SNDP	81.0	10.0	27.7	43.3	53.4	High
THIRUVANANTHAPURAM	Edava [4526]	KARAMUKKU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Edava [4526]	KARIPPURAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Edava [4526]	KARUNILACODE	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Edava [4526]	KATTU VILA	81.0	3.0	23.0	55.0	67.9	High
THIRUVANANTHAPURAM	Edava [4526]	KUNJAN VILAKOM	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPURAM	Edava [4526]	KUNNUVILA	81.0	8.0	49.3	23.7	29.3	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Edava [4526]	KURUVILA	81.0	0.0	24.5	56.5	69.7	High
THIRUVANANTHAPU RAM	Edava [4526]	KUZHAIKKADU	81.0	3.0	52.0	26.0	32.1	Medium
THIRUVANANTHAPU RAM	Edava [4526]	MANKUZH	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Edava [4526]	MANTHRA TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Edava [4526]	MARAKKADA MUKKU	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Edava [4526]	MAVILA	202.0	3.0	77.6	121.4	60.1	High
THIRUVANANTHAPU RAM	Edava [4526]	MEKKULAM	81.0	0.0	28.1	52.9	65.3	High
THIRUVANANTHAPU RAM	Edava [4526]	MISKIN THERUVU	202.0	0.0	29.0	173.0	85.6	Very High
THIRUVANANTHAPU RAM	Edava [4526]	MOODILLA VILA	129.0	0.0	19.0	110.0	85.3	Very High
THIRUVANANTHAPU RAM	Edava [4526]	MOOLAKKADA	81.0	5.0	4.0	72.0	88.9	Very High
THIRUVANANTHAPU RAM	Edava [4526]	MUKKALAKKAL	81.0	3.0	27.0	51.0	62.9	High
THIRUVANANTHAPU RAM	Edava [4526]	N P VILA	81.0	10.0	22.7	48.3	59.6	High
THIRUVANANTHAPU RAM	Edava [4526]	NALUMUKKU	81.0	0.0	22.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Edava [4526]	NELLETTIL FERRY	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Edava [4526]	ODAYAM	202.0	0.0	13.0	189.0	93.6	Very High
THIRUVANANTHAPU RAM	Edava [4526]	ODAYAM BEACH	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Edava [4526]	ODAYAM MOSQUE	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Edava [4526]	OLIPPIL	81.0	0.0	9.5	71.5	88.2	Very High
THIRUVANANTHAPU RAM	Edava [4526]	PADIYIL	129.0	0.0	24.0	105.0	81.4	Very High
THIRUVANANTHAPU RAM	Edava [4526]	PALAKKAVU TEMPLE	81.0	14.0	50.0	17.0	21.0	Low
THIRUVANANTHAPU RAM	Edava [4526]	PANANINNAVILA	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Edava [4526]	PARAMBIL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Edava [4526]	PARAYIL	81.0	10.0	3.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Edava [4526]	PAYATTUVILA	81.0	13.0	23.0	45.0	55.6	High
THIRUVANANTHAPU RAM	Edava [4526]	PETHIRIMUKKU	81.0	0.0	13.0	68.0	83.9	Very High
THIRUVANANTHAPU RAM	Edava [4526]	POIKAYIL	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Edava [4526]	POTTAKKULAM	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Edava [4526]	PRESSMUKKU	81.0	0.0	35.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Edava [4526]	PULLANNICODE	81.0	3.0	21.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Edava [4526]	PUNNAKULAM	81.0	10.0	30.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Edava [4526]	PUNNAMOODU	81.0	5.0	28.3	47.7	58.9	High
THIRUVANANTHAPU RAM	Edava [4526]	PUTTIL TEMPLE	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Edava [4526]	SANGAM MUKKU	81.0	3.0	15.0	63.0	77.8	Very High
THIRUVANANTHAPU RAM	Edava [4526]	SBI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Edava [4526]	SREE EIGHT	81.0	0.0	35.0	46.0	56.8	High
THIRUVANANTHAPURAM	Edava [4526]	STADIUM	81.0	10.0	27.0	44.0	54.3	High
THIRUVANANTHAPURAM	Edava [4526]	THOTTINKARA	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Edava [4526]	THOTTUMMUGHAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Edava [4526]	THUSHARAMUKKU	81.0	13.0	13.0	55.0	67.9	High
THIRUVANANTHAPURAM	Edava [4526]	VENKULAM	202.0	10.0	54.3	137.7	68.2	High
THIRUVANANTHAPURAM	Edava [4526]	VENKULAM UPS	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Edava [4526]	VETTAKADA MARKET	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPURAM	Edava [4526]	VETTAKADA MOSQUE	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Edava [4526]	VILAKKULAM	81.0	3.0	21.0	57.0	70.4	High
THIRUVANANTHAPURAM	Edava [4526]	VILLAGE OFFICE	81.0	8.0	34.4	38.6	47.7	Medium
THIRUVANANTHAPURAM	Edava [4526]	WATER WORKS	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	ATTAKULANGARA	405.0	0.0	50.0	355.0	87.7	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	ATTUKAL SHOPPING COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	ATTUKAL SHOPPING COMPLEX OWN	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	BHAVANI TOWER HT-LT	162.0	0.0	0.0	162.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	BSNL_	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	BYPASS-I	202.0	0.0	5.0	197.0	97.5	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	BYPASS-I CSS	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	BYPASS-II	129.0	0.0	3.0	126.0	97.7	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	BYPASS-II CSS	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	BYPASS-III	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	CHALAI	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	CHEMBUPANIPPURA	405.0	4.0	43.0	358.0	88.4	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	FORT KOTHALAM	202.0	9.0	17.0	176.0	87.1	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	HEERACHAMBERS OWN	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	IRON BRIDGE	405.0	27.0	194.5	183.5	45.3	Medium
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	JM AVENUE	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	KAIRALI	129.0	10.0	51.0	68.0	52.7	High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	KARIMADOM	405.0	15.0	16.0	374.0	92.3	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	KARUPPETTIKADA	405.0	0.0	34.4	370.6	91.5	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	KARUPPETTIKADA CSS	405.0	0.0	14.8	390.2	96.3	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	KURIYATHI CSS	405.0	0.0	8.0	397.0	98.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	KURIYATHI-1	405.0	10.0	41.4	353.6	87.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	KURIYATHI-2	405.0	20.0	23.0	362.0	89.4	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	NANDINI GARDENS	202.0	10.0	78.3	113.7	56.3	High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PATTUVILAKAM CSS	202.0	0.0	51.8	150.2	74.3	High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PAZHAYASALA CSS	405.0	0.0	17.0	388.0	95.8	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	POWER HOUSE-1	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	POWER HOUSE-2	405.0	0.0	35.0	370.0	91.4	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	POYYANI	405.0	19.0	233.8	152.2	37.6	Medium
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PRASANTH NAGAR	255.0	0.0	13.0	242.0	94.9	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PRIYADARSINI	405.0	5.0	188.0	212.0	52.3	High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PUTHARIKANDAM NO-I	405.0	0.0	40.0	365.0	90.1	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PUTHARIKANDAM NO-II	129.0	0.0	15.9	113.1	87.7	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PUTHARIKANDAM NO-III	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PUTHARIKANDAM NO-IV	202.0	0.0	5.0	197.0	97.5	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PUTHARIKANDAM OWN	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PUTHEN STREET-1	202.0	0.0	66.0	136.0	67.3	High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PUTHEN STREET-II	81.0	11.0	63.0	7.0	8.6	Very Low
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	PUTHEN STREET-III	405.0	0.0	117.4	287.6	71.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	RAILWAY-1	405.0	0.0	51.3	353.7	87.3	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	RAILWAY-II	202.0	0.0	50.0	152.0	75.2	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	RAJADHANI NO-2 - KARIMPANAL	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	RAJADHANI-1	405.0	0.0	38.5	366.6	90.5	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	RAMANARMADOM	405.0	0.0	61.8	343.2	84.7	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	SABHAPATHI CSS	405.0	0.0	5.0	400.0	98.8	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	SILVER SAND CSS	405.0	0.0	6.0	399.0	98.5	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	SP BHAGYA	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	SREE PADMANABHA NO-I	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	SREE PADMANABHA NO-II	405.0	0.0	35.0	370.0	91.4	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	SREEBALA	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	SREEKANDESWARAM	405.0	11.0	125.2	268.8	66.4	High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	SWATHY NAGAR	255.0	0.0	90.0	165.0	64.7	High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	TAXI STAND	405.0	0.0	41.9	363.1	89.7	Very High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	TEXT BOOK NO-II OWN	129.0	0.0	60.0	69.0	53.5	High
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	TEXT BOOK-I	255.0	0.0	138.3	116.7	45.8	Medium
THIRUVANANTHAPURAM	Fort Trivandrum [4503]	THAVALODU	255.0	8.0	149.0	98.0	38.4	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	VIRAKUPURACOTTA	202.0	0.0	29.0	173.0	85.6	Very High
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	WEST NADA NO-I	202.0	3.0	134.2	64.8	32.1	Medium
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	WEST NADA NO-II	81.0	0.0	50.0	31.0	38.3	Medium
THIRUVANANTHAPU RAM	Fort Trivandrum [4503]	YAMUNA NAGER	405.0	25.0	142.0	238.0	58.8	High
THIRUVANANTHAPU RAM	Kachani [4691]	AYANICADU	81.0	6.0	19.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Kachani [4691]	CHAMAVILA	129.0	24.0	54.7	50.3	39.0	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	CHANICHALKKADAVU	81.0	3.0	50.0	28.0	34.6	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	CHEENIKKONAM GSI- PVT	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	CHEENIKONAM	202.0	5.0	138.5	58.5	29.0	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	CHEKKAKONAM	121.0	6.0	90.0	25.0	20.7	Low
THIRUVANANTHAPU RAM	Kachani [4691]	CHEKKALAMUKHAL	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	CHERIYAKONNI	129.0	6.0	20.0	103.0	79.8	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	CHERUPALODE	81.0	14.0	50.0	17.0	21.0	Low
THIRUVANANTHAPU RAM	Kachani [4691]	CHIRAKULAM	129.0	5.0	21.0	103.0	79.8	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	CORDIAL RISE -PVT	405.0	0.0	5.0	400.0	98.8	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	CORDONE - PVT	648.0	0.0	0.0	648.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	DARSAN LANE	129.0	16.0	79.0	34.0	26.4	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kachani [4691]	ERAYAN CODE	129.0	6.0	18.0	105.0	81.4	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	ERAYAN CODE ITC	129.0	6.0	33.0	90.0	69.8	High
THIRUVANANTHAPU RAM	Kachani [4691]	ERIKONAM	81.0	0.0	36.0	45.0	55.6	High
THIRUVANANTHAPU RAM	Kachani [4691]	HAMNET VILLA - PVT	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	IRUMBA	81.0	0.0	29.9	51.1	63.1	High
THIRUVANANTHAPU RAM	Kachani [4691]	JOSEPH LANE	129.0	33.0	81.5	14.5	11.2	Low
THIRUVANANTHAPU RAM	Kachani [4691]	KACHANI SCHOOL	129.0	4.0	76.0	49.0	38.0	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	KADAMBRAKUZHY	81.0	5.0	5.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	KADUVAKUZHY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	KALAGRAMAM	129.0	11.0	23.0	95.0	73.6	High
THIRUVANANTHAPU RAM	Kachani [4691]	KALATHUKAL	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	KARAKULAM 8 TH STONE	81.0	3.0	16.3	61.7	76.2	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	KARAKULAM PALAM	129.0	19.9	74.0	35.1	27.2	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	KAVADITHALAKAL	81.0	5.0	48.0	28.0	34.6	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	KAVUNADA	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	KELTRON KARAKULAM	81.0	0.0	26.5	54.5	67.3	High
THIRUVANANTHAPU RAM	Kachani [4691]	KIZHAKKELA	129.0	3.0	41.5	84.5	65.5	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kachani [4691]	KOCHUKARIKAKAM	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	KRISHI BHAVAN	129.0	13.0	89.0	27.0	20.9	Low
THIRUVANANTHAPU RAM	Kachani [4691]	KUNNATHUNADA	129.0	0.0	38.0	91.0	70.5	High
THIRUVANANTHAPU RAM	Kachani [4691]	KUNNOORSALA	202.0	11.0	101.7	89.3	44.2	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	MAADAVANA	129.0	0.0	24.8	104.2	80.8	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	MADATHU VILAKAM	202.0	0.0	72.7	129.3	64.0	High
THIRUVANANTHAPU RAM	Kachani [4691]	MANIKANTESWARAM	255.0	20.0	150.0	85.0	33.3	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	MARUTHANCODE	81.0	0.0	18.3	62.7	77.4	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	MILK SOCIETY	129.0	15.0	44.5	69.5	53.9	High
THIRUVANANTHAPU RAM	Kachani [4691]	MIR PRAKRITHI-PVT	405.0	0.0	28.0	377.0	93.1	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	MIR PVT	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	MIR-315 KVA-PVT	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	MUKKOLA	202.0	10.0	113.0	79.0	39.1	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	MYLAM	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	MYLAM GV RAJA- PVT	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	MYLOM LPS SCHOOL	81.0	0.0	12.1	68.9	85.1	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	NANUMALA	129.0	0.0	18.0	111.0	86.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kachani [4691]	NETTAYAM -OIL MILL	202.0	25.0	147.3	29.7	14.7	Low
THIRUVANANTHAPU RAM	Kachani [4691]	OONNAMPARA	81.0	3.0	21.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Kachani [4691]	PADAMANABHA NAGAR	81.0	8.0	66.0	7.0	8.6	Very Low
THIRUVANANTHAPU RAM	Kachani [4691]	PALAKUZH	81.0	3.0	39.0	39.0	48.1	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	PAMMATHALA	81.0	4.0	22.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Kachani [4691]	PANDIYODU	129.0	3.0	45.0	81.0	62.8	High
THIRUVANANTHAPU RAM	Kachani [4691]	PANNIKUZHICKARA	129.0	6.0	46.0	77.0	59.7	High
THIRUVANANTHAPU RAM	Kachani [4691]	PAZHAYATTINKARA	202.0	16.0	144.2	41.8	20.7	Low
THIRUVANANTHAPU RAM	Kachani [4691]	PEOPLES NAGAR	129.0	9.0	56.0	64.0	49.6	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	PIDAYANNOOR	81.0	8.0	24.0	49.0	60.5	High
THIRUVANANTHAPU RAM	Kachani [4691]	PRAKRTHI HEIGHTS	81.0	0.0	40.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Kachani [4691]	PULLIKKONAM	81.0	0.0	23.3	57.7	71.2	High
THIRUVANANTHAPU RAM	Kachani [4691]	ROCK GARDEN	81.0	5.0	69.9	6.1	7.6	Very Low
THIRUVANANTHAPU RAM	Kachani [4691]	ROSE GARDEN	129.0	3.0	124.2	1.8	1.4	Very Low
THIRUVANANTHAPU RAM	Kachani [4691]	SOUPARNIKA - PVT	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	SURESH LANE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	SWIMMING POOL	81.0	5.0	9.5	66.5	82.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kachani [4691]	THARATTA	202.0	12.0	111.5	78.5	38.8	Medium
THIRUVANANTHAPU RAM	Kachani [4691]	VATTAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	VAYANATTUKONAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kachani [4691]	VAZHAYILA	129.0	11.4	38.9	78.7	61.0	High
THIRUVANANTHAPU RAM	Kachani [4691]	VELUTHAMBI NAGAR	129.0	24.0	100.3	4.7	3.6	Very Low
THIRUVANANTHAPU RAM	Kachani [4691]	VETTIKONAM	129.0	9.0	42.5	77.5	60.1	High
THIRUVANANTHAPU RAM	Kachani [4691]	VR PURAM	81.0	3.0	19.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	AJI ICE FACTORY	129.0	5.0	5.0	119.0	92.2	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	ANATHALAVATTOM	202.0	0.0	21.0	181.0	89.6	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	ANJUTHENGU	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	ANJUTHENGU CHURCH	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	ANJUTHENGU FORT	129.0	0.0	22.0	107.0	82.9	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	ANJUTHENGU JUNCTION	129.0	0.0	10.0	119.0	92.2	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	ANJUTHENGU PANCHAYATH	81.0	5.0	30.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	APPOOPPAN NADA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	ASAN NAGAR	81.0	14.0	3.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	AYANTAVILA	81.0	0.0	22.0	59.0	72.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	BEACH ROAD	81.0	0.0	36.0	45.0	55.6	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	BHAJANAMADAM	81.0	3.0	0.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	BISMI ICE FACTORY	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	BSNL	129.0	3.0	88.5	37.5	29.1	Medium
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	CHAVADIMUKKU	81.0	0.0	19.2	61.8	76.3	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	CHIKKIVILA	81.0	3.0	45.6	32.4	40.0	Medium
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	DEVARU NADA	81.0	6.0	27.3	47.7	58.9	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	ELAPPURAM	81.0	5.0	22.0	54.0	66.7	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	FORT	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	GURUMANDIRAM	81.0	13.0	8.0	60.0	74.1	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	J R M ICE FACTORY	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	KANIYAKUDI	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	KAPALEESWARAM	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	KARUNTHUVAKADAVU	81.0	0.0	12.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	KAYIKKARA KADAVU	81.0	5.0	14.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	KEEZHATTINGAL	81.0	8.0	65.0	8.0	9.9	Very Low
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	KETTUPURA	81.0	0.0	20.0	61.0	75.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	KOLLAZHAKAM	81.0	20.0	6.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	KOVILTHOTTAM	81.0	3.0	13.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	KSEB KADAKKAVOOR	202.0	6.0	85.4	110.6	54.7	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MADAN NADA	81.0	5.0	8.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MADANKAVU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MAMPALLY	202.0	0.0	17.0	185.0	91.6	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MANKUZH	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MANNATHIMOOLA-I	129.0	3.0	24.0	102.0	79.1	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MANNATHIMOOLA-II	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MARODU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MARY ICE FACTORY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MEERAN KADAVU-II	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MEERANKADAVU-I	129.0	0.0	18.0	111.0	86.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MELKADAKKAVOOR-I	81.0	5.0	32.0	44.0	54.3	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MELKADAKKAVOOR-II	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MOOLAYIL THOTTAM-25 KVA	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	MUTHALAPOZH	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kadakkavoor [4528]	ONNAM PALAM	81.0	0.0	18.0	63.0	77.8	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	OORANKUDI	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	OOTTUPARAMBU	129.0	5.0	22.2	101.8	78.9	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	OTTALAPPURAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	PALLIMUKKU	81.0	0.0	32.0	49.0	60.5	High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	PARAYADI	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	PAZHANCHIRA	81.0	5.0	14.0	62.0	76.5	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	POLICE STATION	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	POOTHURA	81.0	3.0	6.0	72.0	88.9	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	PUTHENMANNU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	PUTTUKADA	81.0	9.0	19.0	53.0	65.4	High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	RAILWAY STATION	129.0	3.0	58.4	67.6	52.4	High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	SANKARAMTHAZHAM	81.0	0.0	45.2	35.8	44.2	Medium
THIRUVANANTHAPURAM	Kadakkavoor [4528]	SARASANAGAR	81.0	5.0	10.0	66.0	81.5	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	SINKARATHOPPU	81.0	0.0	12.0	69.0	85.2	Very High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	SNV	129.0	0.0	43.4	85.6	66.3	High
THIRUVANANTHAPURAM	Kadakkavoor [4528]	THAZHAMPALLY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	THEKKUMBHAGAM	129.0	0.0	14.0	115.0	89.1	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	THETTI MOOLA	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	THINAVILA	81.0	5.0	3.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	THINAVILA LPS	20.0	0.0	14.0	6.0	30.0	Medium
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	THINAVILA NO-1	129.0	0.0	29.0	100.0	77.5	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	THONIKKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	VADANAZHY	81.0	0.0	29.0	52.0	64.2	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	VELIMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	VELIVILAKAM	129.0	3.0	43.0	83.0	64.3	High
THIRUVANANTHAPU RAM	Kadakkavoor [4528]	VILLAGE	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	28 TH MILE NO 3	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	28 TH MILE NO I	129.0	17.0	101.0	11.0	8.5	Very Low
THIRUVANANTHAPU RAM	Kallambalam [4533]	28 TH MILE NO-II	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	ALUMKUNNU	81.0	0.0	18.0	63.0	77.8	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	AMBALATHINPANA	81.0	0.0	36.3	44.7	55.2	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	AMMANKONAM	81.0	0.0	56.8	24.2	29.9	Medium
THIRUVANANTHAPU RAM	Kallambalam [4533]	ANDIKONAM	81.0	3.0	15.8	62.2	76.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kallambalam [4533]	ANDIMOOLA	129.0	3.0	19.0	107.0	82.9	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	BISMILLA TOWER	81.0	0.0	24.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	CHITTAICODU	81.0	3.0	21.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	DECENTMUKKU	81.0	28.0	38.0	15.0	18.5	Low
THIRUVANANTHAPU RAM	Kallambalam [4533]	DOUBLOON	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	EDAMONNILA	81.0	8.0	16.7	56.3	69.5	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	EDAVOORKONAM	81.0	3.0	14.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	ERANIKONAM	81.0	0.0	56.0	25.0	30.9	Medium
THIRUVANANTHAPU RAM	Kallambalam [4533]	ETHUKKADU NO I	129.0	6.3	35.0	87.7	68.0	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	ETHUKKADU NO-II	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	GRANITE	129.0	0.0	21.5	107.5	83.3	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	GURMANDIRAM	81.0	8.0	14.1	58.9	72.7	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	GURUNAGAR	81.0	5.0	39.5	36.5	45.0	Medium
THIRUVANANTHAPU RAM	Kallambalam [4533]	HAMSAMUKKU	81.0	0.0	44.5	36.5	45.0	Medium
THIRUVANANTHAPU RAM	Kallambalam [4533]	HERCULIES MARUTHI SERVICE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	IRFAN INDOOR	255.0	0.0	0.0	255.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	J J AUDITORIUM	81.0	5.0	18.0	58.0	71.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kallambalam [4533]	JAS HEIGHTS	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	KADAMBATTUKONAM	81.0	2.0	10.3	68.7	84.8	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	KADAMBATTUKONAM ICE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	KADUVAYIL NO I	129.0	9.3	41.0	78.7	61.0	High
THIRUVANANTHAPURAM	Kallambalam [4533]	KADUVAYIL NO-II	81.0	0.0	43.3	37.7	46.5	Medium
THIRUVANANTHAPURAM	Kallambalam [4533]	KALATHOOR	81.0	10.0	31.0	40.0	49.4	Medium
THIRUVANANTHAPURAM	Kallambalam [4533]	KALLAMBALAM NO I	129.0	0.0	88.0	41.0	31.8	Medium
THIRUVANANTHAPURAM	Kallambalam [4533]	KALLAMBALAM NO-II	202.0	0.0	33.0	169.0	83.7	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	KALLAMBALAM NO-III	129.0	3.0	32.1	93.9	72.8	High
THIRUVANANTHAPURAM	Kallambalam [4533]	KALLUVILA	81.0	3.0	7.9	70.1	86.6	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	KANJIRATHINMOODU	81.0	0.0	24.0	57.0	70.4	High
THIRUVANANTHAPURAM	Kallambalam [4533]	KANNATTUKONAM	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	KARAVARAM	129.0	3.0	55.8	70.2	54.4	High
THIRUVANANTHAPURAM	Kallambalam [4533]	KOTTALAKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	KUMAR CASHEW	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	KUNDUMANKAVU	129.0	3.0	19.0	107.0	82.9	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	KUNDUMANKAVU ALTHARA	20.0	3.0	0.0	17.0	85.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kallambalam [4533]	KUNJUTHADAM	81.0	8.0	24.9	48.1	59.4	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	KUNNATHUVATHUKKAL	81.0	3.0	17.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	MANAMBOOR CHC	129.0	0.0	10.0	119.0	92.2	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	MANAMBOOR NO I	202.0	3.0	73.1	125.9	62.3	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	MANAMBOOR NO-II	81.0	3.0	52.0	26.0	32.1	Medium
THIRUVANANTHAPU RAM	Kallambalam [4533]	MANGALATHU	81.0	6.0	44.7	30.3	37.4	Medium
THIRUVANANTHAPU RAM	Kallambalam [4533]	MAVINMOODU NO I	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	MAVINMOODU NO-II	129.0	5.0	81.1	42.9	33.2	Medium
THIRUVANANTHAPU RAM	Kallambalam [4533]	MELEVILA	81.0	6.0	5.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	MENAPPARA	81.0	6.0	27.0	48.0	59.2	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	MOOZHIIYL	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	MULLARAMCODU	81.0	5.0	21.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	NAINAMKONAM	81.0	3.0	3.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	NALUCENT COLONY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	NAVAIKULAM H S	81.0	6.0	62.0	13.0	16.0	Low
THIRUVANANTHAPU RAM	Kallambalam [4533]	NAVAIKULAM KWA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	NELLICODU	129.0	11.0	74.5	43.5	33.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kallambalam [4533]	OTTOOR	129.0	0.0	16.0	113.0	87.6	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	OTTOOR TEMPLE	81.0	0.0	37.0	44.0	54.3	High
THIRUVANANTHAPURAM	Kallambalam [4533]	P H CENTRE	81.0	10.0	11.0	60.0	74.1	High
THIRUVANANTHAPURAM	Kallambalam [4533]	PANANTHARA	81.0	3.0	18.0	60.0	74.1	High
THIRUVANANTHAPURAM	Kallambalam [4533]	PANTHADIVILA	81.0	5.0	25.2	50.8	62.7	High
THIRUVANANTHAPURAM	Kallambalam [4533]	PARAKUNNU NO I	129.0	13.0	34.0	82.0	63.6	High
THIRUVANANTHAPURAM	Kallambalam [4533]	PARAKUNNU NO-II	81.0	3.0	26.7	51.3	63.3	High
THIRUVANANTHAPURAM	Kallambalam [4533]	PARIPPARA	81.0	3.0	21.0	57.0	70.4	High
THIRUVANANTHAPURAM	Kallambalam [4533]	PAVALLA KWA	81.0	0.0	44.3	36.7	45.3	Medium
THIRUVANANTHAPURAM	Kallambalam [4533]	PAVALLA PALLI	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	PAVALLA SAW MILL	81.0	0.0	17.8	63.2	78.0	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	PAVALLA SCHOOL	81.0	15.0	26.0	40.0	49.4	Medium
THIRUVANANTHAPURAM	Kallambalam [4533]	PENGUIN	81.0	11.0	44.2	25.8	31.8	Medium
THIRUVANANTHAPURAM	Kallambalam [4533]	PONGIL	81.0	6.0	41.8	33.2	41.0	Medium
THIRUVANANTHAPURAM	Kallambalam [4533]	PRESIDENT JN	129.0	5.0	42.2	81.8	63.4	High
THIRUVANANTHAPURAM	Kallambalam [4533]	PULLOORMUKKU	129.0	21.0	57.0	51.0	39.5	Medium
THIRUVANANTHAPURAM	Kallambalam [4533]	PULLURMUKKU SCHOOL	81.0	18.0	51.2	11.8	14.6	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kallambalam [4533]	PUTHENCODU	129.0	3.0	9.0	117.0	90.7	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	PUTHUSSERIMUKKU	129.0	0.0	22.0	107.0	82.9	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	SAMIYARKUNNU	81.0	3.0	13.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	SNEHA	129.0	8.0	117.9	3.1	2.4	Very Low
THIRUVANANTHAPU RAM	Kallambalam [4533]	THAMBURANNADA	81.0	0.0	23.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	THATTUPALAM PETROL PUMP	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	THOPPUVILA	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	THOTTIKKALLU	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	VADAKKEVAYAL	81.0	5.0	43.8	32.2	39.7	Medium
THIRUVANANTHAPU RAM	Kallambalam [4533]	VADAKOTTUKAVU	129.0	0.0	6.5	122.5	95.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	VAIRAMALA	81.0	5.0	36.5	39.5	48.8	Medium
THIRUVANANTHAPU RAM	Kallambalam [4533]	VALIYAVEETILKAVU	81.0	3.0	9.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	VANDITHADAM NO I	129.0	3.0	59.2	66.8	51.8	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	VANDITHADAM NO-II	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	VELLOORKONAM	129.0	8.0	41.0	80.0	62.0	High
THIRUVANANTHAPU RAM	Kallambalam [4533]	VELLOORKONAM CASHEW FACTORY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallambalam [4533]	VELLOORKONAMPALLI	81.0	0.0	22.0	59.0	72.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kallambalam [4533]	VETTIMONKONAM	81.0	3.0	23.0	55.0	67.9	High
THIRUVANANTHAPURAM	Kallambalam [4533]	VETTIMONKONAM COLONY	81.0	0.0	23.0	58.0	71.6	High
THIRUVANANTHAPURAM	Kallambalam [4533]	VETTIYARA SCHOOL	81.0	18.0	24.0	39.0	48.1	Medium
THIRUVANANTHAPURAM	Kallambalam [4533]	VEYILOOR NO I	129.0	0.0	8.0	121.0	93.8	Very High
THIRUVANANTHAPURAM	Kallambalam [4533]	VEYILOOR NO-II	81.0	8.0	31.0	42.0	51.9	High
THIRUVANANTHAPURAM	Kallambalam [4533]	VILANGARA	81.0	6.0	18.0	57.0	70.3	High
THIRUVANANTHAPURAM	Kallara [4557]	ALUMMOODU	81.0	6.0	20.0	55.0	67.9	High
THIRUVANANTHAPURAM	Kallara [4557]	AMBEDKAR COLONY	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Kallara [4557]	ARIVARIKUZHI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kallara [4557]	ARUVIPPURAM	81.0	0.0	12.0	69.0	85.2	Very High
THIRUVANANTHAPURAM	Kallara [4557]	AYIRAVALLI	81.0	3.0	31.8	46.2	57.0	High
THIRUVANANTHAPURAM	Kallara [4557]	AYIROOR	81.0	0.0	9.8	71.2	87.9	Very High
THIRUVANANTHAPURAM	Kallara [4557]	BHARATHANNOOR BSNL NEW	81.0	14.0	30.0	37.0	45.7	Medium
THIRUVANANTHAPURAM	Kallara [4557]	BHARATHANNOOR OLD BSNL	81.0	3.0	8.4	69.6	85.9	Very High
THIRUVANANTHAPURAM	Kallara [4557]	BHARATHANNOOR STADIUM	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPURAM	Kallara [4557]	BHARATHANNUR NO 1	129.0	10.0	18.0	101.0	78.3	Very High
THIRUVANANTHAPURAM	Kallara [4557]	BHARATHANNUR NO 11 MILK	81.0	6.0	37.0	38.0	46.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kallara [4557]	BHARATHANNUR TEMPLE	81.0	5.0	11.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	BHARATHANOOR KALUNGU	81.0	0.0	19.2	61.8	76.3	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	CHADAYAN MUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	CHAMAVILA	81.0	5.0	0.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	CHANTHAYILKKADU	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	CHEKKITTAMUKKU	81.0	10.0	71.0	0.0	0.0	Very Low
THIRUVANANTHAPU RAM	Kallara [4557]	CHERUVALAM	81.0	6.0	19.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Kallara [4557]	DARPPAVILA	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	ERULLOOR	81.0	6.0	31.0	44.0	54.3	High
THIRUVANANTHAPU RAM	Kallara [4557]	ETTIMUKKU	81.0	0.0	4.0	77.0	95.1	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	GOKULAM	129.0	0.0	8.0	121.0	93.8	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	GUARD STATION	81.0	0.0	24.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Kallara [4557]	ILANKAM	81.0	5.0	6.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	K T KUNNU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KADUVAKUZHICKARA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KALLARA BANK	81.0	0.0	12.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KALLARA BSNL	81.0	0.0	18.0	63.0	77.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kallara [4557]	KALLARA NO 1	202.0	11.0	48.0	143.0	70.8	High
THIRUVANANTHAPU RAM	Kallara [4557]	KALLARA PANCHAYATH	129.0	5.0	26.0	98.0	76.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KANCHINADA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KATHIRUVILA	81.0	19.0	40.0	22.0	27.2	Medium
THIRUVANANTHAPU RAM	Kallara [4557]	KATTUMPURAM	129.0	6.0	48.0	75.0	58.1	High
THIRUVANANTHAPU RAM	Kallara [4557]	KEEZHAR	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KOCHALUMMOODU	81.0	8.0	3.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KOCHULIYANCODE	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KOCHUVAYAL	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KOTTUR	81.0	3.0	24.0	54.0	66.7	High
THIRUVANANTHAPU RAM	Kallara [4557]	KURINCHILAKKADU	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KURINJILAKKADU MOSQUE	81.0	3.0	3.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	KURUMBAYAM	81.0	5.0	18.4	57.6	71.1	High
THIRUVANANTHAPU RAM	Kallara [4557]	KUTTIMOODU	129.0	0.0	59.4	69.6	54.0	High
THIRUVANANTHAPU RAM	Kallara [4557]	KUTTIMOODU SAW MILL	81.0	5.0	35.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Kallara [4557]	MADANNADA	81.0	6.0	41.3	33.7	41.6	Medium
THIRUVANANTHAPU RAM	Kallara [4557]	MADATHUVATHUKKAL	81.0	3.0	3.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kallara [4557]	MANACODU	81.0	11.0	18.0	52.0	64.2	High
THIRUVANANTHAPU RAM	Kallara [4557]	MANDIRAM MUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MANKUNDAYAM	81.0	3.0	6.0	72.0	88.9	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MARANADU	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MARUTHUMAN	202.0	0.0	45.0	157.0	77.7	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MAVUNINNA PACHA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MEETHOOR	81.0	8.0	18.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Kallara [4557]	MITHIRMALA SCHOOL	81.0	3.0	16.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MOOLAPEZH	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MOONNU MUKKU	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MOORTHIKKAVU	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MTM SCHOOL	81.0	4.0	19.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Kallara [4557]	MUDIPPURA	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Kallara [4557]	MULAMUKKU	81.0	0.0	10.3	70.7	87.3	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MULAYILKONAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	MUTHUVILA	129.0	3.0	45.0	81.0	62.8	High
THIRUVANANTHAPU RAM	Kallara [4557]	NEERAMANKADAVU	81.0	3.0	0.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kallara [4557]	NELLIDAPPARA	81.0	9.0	25.0	47.0	58.0	High
THIRUVANANTHAPU RAM	Kallara [4557]	NELLIKUNNU	81.0	5.0	12.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	OONNANPARA	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PACHAMUKKU	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PAKISTHANMUKKU	81.0	0.0	23.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Kallara [4557]	PALACHIRA	81.0	5.0	39.0	37.0	45.7	Medium
THIRUVANANTHAPU RAM	Kallara [4557]	PALKULAM	81.0	3.0	11.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PALLIMUKKU	81.0	3.0	46.4	31.6	39.0	Medium
THIRUVANANTHAPU RAM	Kallara [4557]	PALUVALLI	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PANGODE SCHOOL	81.0	6.0	17.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Kallara [4557]	PANGODE-POLICE STATION	81.0	0.0	6.4	74.6	92.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PANGODU NO 1	202.0	27.0	138.0	37.0	18.3	Low
THIRUVANANTHAPU RAM	Kallara [4557]	PANKAD	81.0	3.0	11.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PARAMUKAL	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PARAPPIL	81.0	3.0	6.0	72.0	88.9	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PARAPPIL SCHOOL	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PATHEKKAR	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kallara [4557]	PATTARA	81.0	9.0	55.0	17.0	21.0	Low
THIRUVANANTHAPU RAM	Kallara [4557]	PAZHAVILA BSNL	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PAZHAYA CHANTHA	81.0	29.0	35.0	17.0	21.0	Low
THIRUVANANTHAPU RAM	Kallara [4557]	PERAPPU	81.0	2.0	19.0	60.0	74.1	High
THIRUVANANTHAPU RAM	Kallara [4557]	PLACODE	129.0	11.3	32.7	85.0	65.9	High
THIRUVANANTHAPU RAM	Kallara [4557]	POLICEMUKKU	81.0	3.0	9.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	POTTIMUKKU	81.0	3.0	26.0	52.0	64.2	High
THIRUVANANTHAPU RAM	Kallara [4557]	PUCHEDIKKADU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PULIKKARA	81.0	0.0	11.5	69.5	85.8	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PULIPPARA	81.0	5.0	17.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Kallara [4557]	PULIPPARA MOSQUE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	PUTHUSSERY	81.0	10.0	27.0	44.0	54.3	High
THIRUVANANTHAPU RAM	Kallara [4557]	RIYAS PUTHAN PALLI	81.0	0.0	15.0	66.0	81.5	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	THACHONAM	81.0	0.0	34.0	47.0	58.0	High
THIRUVANANTHAPU RAM	Kallara [4557]	THANNICHAL	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	THANNIYAM	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	THARATTA	81.0	12.0	43.0	26.0	32.1	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kallara [4557]	THAZHEPANGODU	81.0	0.0	30.0	51.0	63.0	High
THIRUVANANTHAPU RAM	Kallara [4557]	THENGUMCODE	129.0	3.0	11.0	115.0	89.1	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	THENGUMCODE GP	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	THOTTUMPURAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	THOTUMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	THUMPODE	129.0	14.0	78.5	36.5	28.3	Medium
THIRUVANANTHAPU RAM	Kallara [4557]	UNNIMUKKU	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	V K POIKA	81.0	0.0	2.0	79.0	97.5	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	VALAKUZHIPACHA	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	VATTAPARA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kallara [4557]	VAZHATHOPPUPACHA	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	AMARIVILA	129.0	0.0	31.0	98.0	76.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	ANNOORKUZH	81.0	6.0	45.6	29.4	36.3	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	ATHIYARA	81.0	0.0	16.3	64.7	79.9	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	ATHMA BODHINI	81.0	10.0	17.6	53.4	65.9	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	AYANIMOOD	202.0	10.0	29.0	163.0	80.7	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	BHAGAVATHY NADA	129.0	6.0	64.2	58.8	45.6	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kalliyoor [4675]	BLIND SCHOOL	81.0	0.0	34.3	46.7	57.7	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	BSNL	81.0	0.0	7.7	73.3	90.5	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	BUNGLAW	129.0	8.0	54.5	66.5	51.6	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	CHANALKARA	129.0	10.0	33.3	85.7	66.4	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	CHENCODE	81.0	0.0	40.2	40.8	50.3	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	CHUDUKANDANVILA	81.0	5.0	55.1	20.9	25.8	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	EDUVA	81.0	10.0	22.3	48.7	60.1	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	ERATTAKULAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	GANAPATHI KOVIL	129.0	9.0	97.4	22.6	17.5	Low
THIRUVANANTHAPU RAM	Kalliyoor [4675]	GURUMANDIRAM VENNIYOOR	81.0	3.0	32.8	45.2	55.8	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	IRAL	129.0	8.3	58.5	62.2	48.2	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	ISKCON	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	JAIVATHOTTAM	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KAIRALI	81.0	8.0	25.4	47.6	58.7	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KAKKAMoola	129.0	4.0	50.7	74.3	57.6	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KAKKAMoola CSI CHURCH	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KALLIYOOR CSI CHURCH	81.0	0.0	67.0	14.0	17.3	Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KALLIYOOR POST OFFICE	81.0	9.0	56.5	15.5	19.1	Low
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KALLU VILA	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KALUNGUNADA	81.0	8.0	38.7	34.3	42.3	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KANIKKAKUTTY	81.0	11.0	36.3	33.7	41.6	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KANNAMKUZHY	129.0	0.0	3.3	125.7	97.4	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KAYALKARA	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KELESWARAM	202.0	15.0	51.3	135.7	67.2	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KIA	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KULANGARA	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KURUVIKKADU	129.0	17.0	46.6	65.4	50.7	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	KUZHIVILA	81.0	16.0	65.0	0.1	0.1	Very Low
THIRUVANANTHAPU RAM	Kalliyoor [4675]	MATHOORKONAM	81.0	10.0	39.8	31.2	38.5	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	MAVARATHALA	129.0	10.0	34.3	84.7	65.7	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	MAVUVILA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	MUDRALAYAM	81.0	0.0	15.7	65.3	80.6	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	MUGALOORMoola	81.0	8.0	65.2	7.8	9.7	Very Low
THIRUVANANTHAPU RAM	Kalliyoor [4675]	MUTHUKUZH	81.0	6.3	52.3	22.4	27.6	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kalliyoor [4675]	MUTHUVALOORKONAM	81.0	0.0	24.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	NEDINJIL	81.0	0.0	37.0	44.0	54.3	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	NELLIVILA	129.0	3.0	6.3	119.7	92.8	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	NELLIVILA NO II	81.0	3.0	0.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	NILAMA	129.0	11.0	86.4	31.6	24.5	Low
THIRUVANANTHAPU RAM	Kalliyoor [4675]	OOKODE	202.0	11.0	89.6	101.4	50.2	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PAKALLOOR	81.0	3.0	41.3	36.7	45.3	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PALARA KULAM	81.0	3.3	32.4	45.3	55.9	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PALLICHAL	202.0	0.0	64.7	137.3	68.0	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PALLICHAL KULAM	81.0	5.0	42.0	34.0	42.0	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PARAYILTHODU	81.0	3.0	28.0	50.0	61.7	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PAROORKUZH	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PATHRAVILAKOM	81.0	3.0	8.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PERINGAMALA NO II	129.0	5.0	15.0	109.0	84.5	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PERINGAMMALA NO 1	202.0	6.0	23.0	173.0	85.6	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	POOJAMUKKU	81.0	5.0	36.6	39.4	48.6	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PRAVACHAMBALAM	81.0	3.0	50.0	28.0	34.6	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PULLANNIMUKKU	202.0	15.1	41.5	145.4	72.0	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PUNNAMOODU	129.0	8.0	46.0	75.0	58.1	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	PUTHUVAL	81.0	5.0	32.7	43.3	53.5	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	RAJADHANI	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	RAKTHESWARI	81.0	8.0	20.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	S N R SASTHA	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	SASTHAN KOVIL	81.0	0.0	38.0	43.0	53.1	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	SHAMAVILA	81.0	15.0	28.0	38.0	46.9	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	SISUMANDIRAM	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	SIVALAYAKONAM	81.0	0.0	28.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	SREE NILAYAM	129.0	0.0	40.0	89.0	69.0	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	ST MARRYS CONVENT	81.0	0.0	39.8	41.2	50.9	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	STADIUM	129.0	0.0	18.6	110.4	85.6	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	STALIN	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	TATA LUXON	129.0	0.0	19.2	109.8	85.1	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	THERIKAVILA	81.0	3.0	16.4	61.6	76.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	THETTIVILA	129.0	0.0	14.3	114.7	88.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kalliyoor [4675]	THOTTINKARA	81.0	0.0	18.0	63.0	77.8	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	THUDALIVILA	81.0	3.0	49.3	28.7	35.4	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	V S AUDITORIUM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	VALLAMCODE	129.0	23.3	71.0	34.7	26.9	Medium
THIRUVANANTHAPU RAM	Kalliyoor [4675]	VARUVILA	81.0	0.0	37.0	44.0	54.3	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	VAWAMoola	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	VAYALIKADA	81.0	0.0	27.3	53.7	66.4	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	VAZHAVILA	129.0	6.6	97.5	24.9	19.3	Low
THIRUVANANTHAPU RAM	Kalliyoor [4675]	VEDIVECHANKOVIL	202.0	11.0	65.6	125.4	62.1	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	VEVILA	129.0	0.0	43.5	85.5	66.3	High
THIRUVANANTHAPU RAM	Kalliyoor [4675]	VODAFONE	81.0	0.0	35.7	45.3	56.0	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	ANTHIYoor	81.0	3.0	33.0	45.0	55.6	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	ARANGAMUGAL NO I	81.0	6.0	13.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	ARANGAMUGAL NO II	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	ARANGIL	81.0	5.0	23.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	ATHAZHAMANGALAM	129.0	3.0	0.0	126.0	97.7	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	AVANAKUZH	81.0	5.0	12.0	64.0	79.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kamukinkode [4868]	AVANAKUZH MANALUVILA	81.0	0.0	51.1	29.9	36.9	Medium
THIRUVANANTHAPU RAM	Kamukinkode [4868]	AYANIMOODU	81.0	3.0	34.0	44.0	54.3	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	BHASKAR NAGAR	129.0	0.0	11.0	118.0	91.5	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	CHEELANTHIMOODU	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	CHEMPANKULAM	81.0	4.0	13.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	CHITTACODE	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	CHUNDAVILAKAM	129.0	3.0	18.0	108.0	83.7	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	EDATHUMoola COLONY	81.0	3.0	6.4	71.6	88.3	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	ERUVAIKONAM	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KAMUKINKODE	202.0	3.0	68.0	131.0	64.9	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KANAVILA	81.0	8.0	34.0	39.0	48.1	Medium
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KANNARAVILA CHURCH	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KANNARAVILA NEW GREEN EVCS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KANNARAVILA NO I	129.0	0.0	48.0	81.0	62.8	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KANNARAVILA NO II	129.0	0.0	24.0	105.0	81.4	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KAVALAKULAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KAVITHA	81.0	10.0	66.0	5.0	6.2	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KOCHUPALLY	81.0	3.0	26.0	52.0	64.2	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KODANGAVILA	202.0	3.0	40.9	158.1	78.3	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KODIYANNOORKONAM CHURCH	81.0	3.0	20.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KODIYANNOORKONAM ITC	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KONNAMOODU	129.0	0.0	17.0	112.0	86.8	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KOTTIYAKOVIL	81.0	3.0	14.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KOTTMPARA	81.0	5.0	4.0	72.0	88.9	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KOZHODE	81.0	0.0	19.8	61.2	75.5	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	KUZHIPPALAM	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	MANALUVILA	81.0	3.0	32.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	MANCHIRA	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	MANNAKALLU NO I	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	MANNAKALLU NO II	81.0	0.0	18.0	63.0	77.8	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	MARAPPALAM	129.0	5.0	13.0	111.0	86.0	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	MARUTHAMCODE NO I	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	MARUTHAMCODE NO II	81.0	0.0	21.0	60.0	74.1	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	NANKARATHALA	81.0	0.0	14.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kamukinkode [4868]	OFFICE	81.0	6.0	31.9	43.1	53.2	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	OLATHANNI	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	OLATHANNI HOSPITAL	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	OLATHANNI OFFICE	81.0	0.0	46.0	35.0	43.2	Medium
THIRUVANANTHAPU RAM	Kamukinkode [4868]	ONAMCODE	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PACHIKKODE	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PALLITHOTTAM	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PARAMBUVILA	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PATHIRISSERI	81.0	3.0	24.0	54.0	66.7	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PERUMAKARA NO I	81.0	0.0	42.0	39.0	48.1	Medium
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PERUMAKKARA NO II	81.0	8.0	43.0	30.0	37.0	Medium
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PLANKALATHADAM	81.0	5.0	14.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PLAVILA -MARUTHI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PLAVILA NO 1	202.0	4.0	79.0	119.0	58.9	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	POOTHAMKODU	81.0	5.0	34.0	42.0	51.9	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PUNNARATHALA	81.0	0.0	22.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Kamukinkode [4868]	PUTHAMKULAM	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kamukinkode [4868]	PUTHICAL	81.0	0.0	80.5	0.5	0.6	Very Low
THIRUVANANTHAPURAM	Kamukinkode [4868]	RAMAPURAM SAW MILL	129.0	4.0	57.5	67.5	52.3	High
THIRUVANANTHAPURAM	Kamukinkode [4868]	RAMAPURAM TEMPLE	81.0	8.0	40.0	33.0	40.7	Medium
THIRUVANANTHAPURAM	Kamukinkode [4868]	SASTHAMTHALA	129.0	5.0	48.0	76.0	58.9	High
THIRUVANANTHAPURAM	Kamukinkode [4868]	THALAYARUTHANKULAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Kamukinkode [4868]	THANNIMOODU	129.0	0.0	56.0	73.0	56.6	High
THIRUVANANTHAPURAM	Kamukinkode [4868]	THITTACHAL TEMPLE	81.0	3.0	10.0	68.0	84.0	Very High
THIRUVANANTHAPURAM	Kamukinkode [4868]	VALIYAVILA	81.0	23.0	33.0	25.0	30.9	Medium
THIRUVANANTHAPURAM	Kamukinkode [4868]	VAZHIMUKKU	202.0	3.0	42.0	157.0	77.7	Very High
THIRUVANANTHAPURAM	Kamukinkode [4868]	VELLAKKUZHI	81.0	3.0	9.4	68.6	84.7	Very High
THIRUVANANTHAPURAM	Kamukinkode [4868]	VENPAKAL ELA	81.0	3.0	8.0	70.0	86.4	Very High
THIRUVANANTHAPURAM	Kamukinkode [4868]	VENPAKAL HOSPITAL	81.0	6.0	38.0	37.0	45.7	Medium
THIRUVANANTHAPURAM	Kamukinkode [4868]	VENPAKAL SCHOOL	81.0	0.0	27.0	54.0	66.7	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	A R	202.0	16.0	158.7	27.3	13.5	Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ALUMMOODU	202.0	0.0	39.0	163.0	80.7	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	AMBALLOOR	202.0	10.0	53.8	138.2	68.4	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	AMBALLOOR-BYPASS	129.0	0.0	28.0	101.0	78.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kaniyapuram [4522]	AMMAN COVIL	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ANAKAPILLA	202.0	16.0	33.0	153.0	75.7	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ANAKKAPPILLA KANAL	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ANDOOR KONAM HOSPITAL	81.0	7.0	74.0	0.0	0.0	Very Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ANDOORKONAM	202.0	6.0	106.4	89.6	44.3	Medium
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ANURPALLI	129.0	25.0	77.5	26.5	20.5	Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	APPOLO COLONY	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ARATUMUKU BEACH	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ARRATTUMUKKU JN	129.0	8.0	14.0	107.0	82.9	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	AUXILARY PTCDD SS	405.0	0.0	0.0	405.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	BISMI	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	BP NAGAR NO-I	20.0	0.0	10.0	10.0	50.0	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	BP NAGAR NO-II	20.0	0.0	5.0	15.0	75.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	C R P HOSPITAL-OUT DOOR	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CENTRAL SCHOOL	405.0	0.0	32.0	373.0	92.1	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CHANNANKARA	129.0	0.0	23.0	106.0	82.2	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CHANNANKARA-2-DURGA	81.0	6.0	72.0	3.0	3.7	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CHEENIPANA	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CHERAMANTHURUTH	129.0	3.0	24.0	102.0	79.1	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CONVENT NO-I	129.0	0.0	51.7	77.3	59.9	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CONVENT NO-II	81.0	3.0	43.0	35.0	43.2	Medium
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CRP NO 4 NEAR LINE AB QUARTERS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CRP NO-1 OFFICE	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CRP NO-2 CHAKKI MILL	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CRP NO-3-INSIDE APPOLO	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CRP NO-5 SEWAGE	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	CRP NO-6 SEWAGE QUARTERS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	DEEPTHI	129.0	0.0	12.0	117.0	90.7	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	DEVAMATHA	202.0	3.0	37.3	161.7	80.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	DLM	129.0	0.0	22.0	107.0	82.9	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	E V M	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	FATHIMA	81.0	0.0	80.3	0.7	0.9	Very Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	INDROYAL	129.0	3.0	28.7	97.3	75.4	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	JEMMYMUKU	129.0	5.0	32.0	92.0	71.3	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KADINAMKULAM	202.0	5.0	27.5	169.5	83.9	Very High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KALLINGARA	129.0	3.0	46.5	79.5	61.6	High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KALLUPALAM	81.0	0.0	33.0	48.0	59.3	High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KANDAL TEMPLE	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KANDAVILA	81.0	8.0	36.5	36.5	45.1	Medium
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KARICHARA	129.0	3.0	110.5	15.5	12.0	Low
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KARICHARA KADAV	81.0	3.0	25.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KOCHUKODUNGALLUR	81.0	0.0	38.7	42.3	52.2	High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KOTTARAMTHURUTHU	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	KUNNINAKOM	405.0	3.0	97.0	305.0	75.3	Very High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	MADANVILA	129.0	0.0	27.0	102.0	79.1	Very High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	MADANVILA-SCHOOL	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	MADANVILA-TEMPLE	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	MAITHANI	81.0	0.0	25.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	MALAMELPARAMPU	129.0	0.0	47.9	81.1	62.9	High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	MANAKKATTUVILAKAM	81.0	11.0	17.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	MANAPURAM	81.0	11.0	37.0	33.0	40.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kaniyapuram [4522]	MASTANMUKU	202.0	15.0	169.6	17.4	8.6	Very Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	MHS	129.0	8.0	76.3	44.7	34.7	Medium
THIRUVANANTHAPURAM	Kaniyapuram [4522]	MHS-II	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	MINI	202.0	0.0	45.0	157.0	77.7	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	MODAL SCHOOL	129.0	3.0	28.0	98.0	76.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	MUNDANCHIRA	81.0	0.0	40.2	40.8	50.3	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	MYVALLY	129.0	0.0	83.0	46.0	35.7	Medium
THIRUVANANTHAPURAM	Kaniyapuram [4522]	N C BROTHERS	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	NAMBIYARKULAM	129.0	0.0	129.0	0.0	0.0	Very Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	NAMBIYARKULAM RAILWAY	129.0	0.0	14.0	115.0	89.1	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	OLD INDIAN BANK	81.0	3.0	11.0	67.0	82.7	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	OTTAPANA	129.0	5.0	8.0	116.0	89.9	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PACHIRA	129.0	5.0	17.0	107.0	82.9	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PADIKAVILAKAM	129.0	0.0	3.0	126.0	97.7	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PADINJATTUMUKU	129.0	32.0	77.2	19.8	15.3	Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PADINJATTUMUKU-II	129.0	25.0	76.0	28.0	21.7	Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PALLINADA	129.0	19.0	109.9	0.1	0.1	Very Low

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PALLIPPURAM NO-1	129.0	0.0	13.0	116.0	89.9	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PALLIPURAM NO-2	81.0	0.0	23.2	57.8	71.4	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PALLIYAMPARAMPU	129.0	24.0	102.0	3.0	2.3	Very Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PANAVILAKAM	81.0	25.0	56.0	0.0	0.0	Very Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PARAMBIPALAM	129.0	19.0	90.9	19.1	14.8	Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PAZHANCHIRA	81.0	3.0	13.5	64.5	79.7	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PERUMATHURA NO-I	202.0	0.0	34.8	167.2	82.8	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PERUMATHURA NO-II-EDAPPALLY	129.0	0.0	3.5	125.5	97.3	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PERUMATHURA NO-III-MASJID	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PERUMATHURA PETROL PUMP	81.0	5.0	14.3	61.7	76.2	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	POURASAMATHY	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	POZHI BRIDGE	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PUTHANTHOP HOSPITAL	202.0	42.0	129.7	30.3	15.0	Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PUTHANTHOP-II CHURCH	129.0	3.0	51.9	74.1	57.4	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PUTHENTHOPPU-CANAL	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PUTHUKURICHY	129.0	0.0	19.0	110.0	85.3	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PUTHUKURICHY POST OFFICE	81.0	3.0	13.0	65.0	80.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Kaniyapuram [4522]	PUTHUVAL	202.0	0.0	35.0	167.0	82.7	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	RASI NAGAR	81.0	0.0	40.2	40.8	50.3	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	SANTHIPURAM CHURCH	81.0	0.0	4.0	77.0	95.1	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	SANTHIPURAM-II	129.0	0.0	25.0	104.0	80.6	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	SFS RHYTHM	1,012.0	0.0	20.0	992.0	98.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	SHIFA HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	SINGAPORE MUKKU	129.0	8.0	89.0	32.0	24.8	Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ST ANDREWS-1	81.0	3.0	16.0	62.0	76.5	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	ST ANDREWS-2	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	TELEPHONE EXCHANGE PKY	129.0	0.0	5.0	124.0	96.1	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	THAMARAKULAM	129.0	0.0	72.7	56.3	43.6	Medium
THIRUVANANTHAPURAM	Kaniyapuram [4522]	THAMARAKULAM-II	81.0	0.0	33.2	47.8	59.0	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	THAMARAKULAM-III	81.0	10.0	70.0	1.0	1.2	Very Low
THIRUVANANTHAPURAM	Kaniyapuram [4522]	THAZHAVILAKAM-2-RESORT	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	THAZHEVILAKOM	81.0	0.0	50.0	31.0	38.3	Medium
THIRUVANANTHAPURAM	Kaniyapuram [4522]	THEERAMAITHRI	129.0	0.0	39.0	90.0	69.8	High
THIRUVANANTHAPURAM	Kaniyapuram [4522]	THOTUMUKAM	81.0	0.0	35.5	45.5	56.2	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	THRIJOTHYPURAM	129.0	12.0	74.3	42.7	33.1	Medium
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	VADAKE PERUMATHURA-II-POZHI	202.0	0.0	13.0	189.0	93.6	Very High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	VADAKEPERUMATHURA	129.0	0.0	35.4	93.7	72.6	High
THIRUVANANTHAPU RAM	Kaniyapuram [4522]	VADAYILMUKKU	129.0	8.0	70.6	50.4	39.1	Medium
THIRUVANANTHAPU RAM	Madavoor [4536]	ALATHUKAVU	81.0	11.3	41.0	28.7	35.4	Medium
THIRUVANANTHAPU RAM	Madavoor [4536]	ALPHA SCHOOL	81.0	26.0	14.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Madavoor [4536]	AROOR	81.0	9.0	21.2	50.8	62.7	High
THIRUVANANTHAPU RAM	Madavoor [4536]	ARUKANJIRAM	81.0	8.0	11.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	AYITHALAKONAM	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	CHALAMKONAM	81.0	9.0	3.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	CHALAMKONAM KSHETHRAM	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	CHALIL	81.0	0.0	3.5	77.5	95.7	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	CHANGAYIL KONAM	81.0	3.0	3.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	CHANIKKAL	81.0	6.0	8.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	CHANNARUKONAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	CHAVARUPACHA	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	CHINDRANALLOOR	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Madavoor [4536]	CHIRATTAKUNNU	81.0	3.0	0.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	ELIKUNNAMMUKAL CASHEW FACTORY	81.0	8.0	10.0	63.0	77.8	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	ELIKUNNAMMUKAL PALLI	129.0	12.0	18.0	99.0	76.7	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	ENTHANOOR	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	K K JUNCTION	81.0	3.0	3.0	75.0	92.6	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	KAIPPALLIKONAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	KAITHODU	81.0	5.0	28.0	48.0	59.3	High
THIRUVANANTHAPURAM	Madavoor [4536]	KALATHRAMUKKU	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	KAPPAMVILA	81.0	5.0	41.0	35.0	43.2	Medium
THIRUVANANTHAPURAM	Madavoor [4536]	KAPPAMVILA JN	81.0	0.0	4.0	77.0	95.1	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	KAPPAMVILA VILLAGE	81.0	0.0	30.0	51.0	63.0	High
THIRUVANANTHAPURAM	Madavoor [4536]	KARAVAYIKKONAM	81.0	3.0	9.4	68.6	84.6	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	KARIMBUVILA THAIKKAVU	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	KARIMPUVILA	129.0	5.0	34.2	89.8	69.6	High
THIRUVANANTHAPURAM	Madavoor [4536]	KATTUCHANTHA	81.0	24.0	55.5	1.5	1.9	Very Low
THIRUVANANTHAPURAM	Madavoor [4536]	KATTUVALLIKKONAM	81.0	0.0	32.5	48.5	59.9	High
THIRUVANANTHAPURAM	Madavoor [4536]	KEEZHPEROOR	81.0	0.0	44.0	37.0	45.7	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Madavoor [4536]	KRISHNAN KUNNU	129.0	6.0	27.0	96.0	74.4	High
THIRUVANANTHAPU RAM	Madavoor [4536]	KUDAVOOR	81.0	6.0	0.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	KUDAVOOR PALLI	81.0	0.0	12.8	68.2	84.2	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	KURICHIYIL	81.0	13.0	25.3	42.7	52.7	High
THIRUVANANTHAPU RAM	Madavoor [4536]	LAKSHAMVEEDU	20.0	0.0	3.0	17.0	85.0	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	MADANTHAPACHA	129.0	0.0	90.0	39.0	30.2	Medium
THIRUVANANTHAPU RAM	Madavoor [4536]	MADAVOOR CASHEW	81.0	0.0	15.0	66.0	81.5	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	MADAVOOR MARKET	129.0	7.2	41.0	80.8	62.6	High
THIRUVANANTHAPU RAM	Madavoor [4536]	MADAVOOR PALLI	81.0	3.0	45.0	33.0	40.7	Medium
THIRUVANANTHAPU RAM	Madavoor [4536]	MANALAYAM	81.0	0.0	9.0	72.0	88.9	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	MANDAPA KUNNU	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	MANKONAM	81.0	5.0	32.0	44.0	54.3	High
THIRUVANANTHAPU RAM	Madavoor [4536]	MANKONAM VALAVIL	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	MAVUVILA	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	MICHABHOOMI I	20.0	0.0	2.0	18.0	90.0	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	MICHABHOOMI II	20.0	0.0	5.0	15.0	75.0	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	MULAKKALATHUKAVU	81.0	6.3	25.0	49.7	61.4	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Madavoor [4536]	MULAVANA	20.0	0.0	0.0	20.0	100.0	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	MUNNAMVILA	81.0	5.0	25.0	51.0	63.0	High
THIRUVANANTHAPURAM	Madavoor [4536]	NAAZ FOODS	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	OLIPURAM	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	OLOORKONAM	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	P H CENTER	81.0	0.0	37.5	43.5	53.7	High
THIRUVANANTHAPURAM	Madavoor [4536]	PADINJATTELA	81.0	18.0	40.0	23.0	28.4	Medium
THIRUVANANTHAPURAM	Madavoor [4536]	PANAPPAMKUNNU	81.0	0.0	19.0	62.0	76.5	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	PARAYIL	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	PARAYILKADA	81.0	0.0	22.0	59.0	72.8	High
THIRUVANANTHAPURAM	Madavoor [4536]	PAZHAYACHANTHA	81.0	0.0	44.4	36.6	45.1	Medium
THIRUVANANTHAPURAM	Madavoor [4536]	PONGANADU I	129.0	0.0	37.4	91.7	71.0	High
THIRUVANANTHAPURAM	Madavoor [4536]	PONGANADU I O C	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	PONGANADU UPS	81.0	11.0	18.0	52.0	64.2	High
THIRUVANANTHAPURAM	Madavoor [4536]	PRIYADERSINI	81.0	5.0	53.3	22.7	28.0	Medium
THIRUVANANTHAPURAM	Madavoor [4536]	PULIKKUZHI	81.0	5.0	30.1	45.9	56.7	High
THIRUVANANTHAPURAM	Madavoor [4536]	PULIYOORKONAM	81.0	5.0	17.0	59.0	72.8	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Madavoor [4536]	PULLIPPACHA	81.0	0.0	10.0	71.0	87.7	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	PUNNAVILA	81.0	5.0	15.0	61.0	75.3	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	PUTHUMANGALAM	81.0	5.0	70.0	6.0	7.4	Very Low
THIRUVANANTHAPURAM	Madavoor [4536]	SADAMMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	SEEMANTHAPURAM	81.0	5.0	24.0	52.0	64.2	High
THIRUVANANTHAPURAM	Madavoor [4536]	SEEMANTHAPURAM MARKET	81.0	5.0	10.0	66.0	81.5	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	THAKARAPARAMBU	81.0	0.0	18.8	62.2	76.8	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	THALAVILA	81.0	6.0	43.0	32.0	39.5	Medium
THIRUVANANTHAPURAM	Madavoor [4536]	THANKAKKALLU	81.0	4.0	11.0	66.0	81.5	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	THANNIMOODU	81.0	10.0	6.0	65.0	80.2	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	THEVAYIL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	THOPPIL	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	THOTTUVALLI	81.0	3.0	18.0	60.0	74.1	High
THIRUVANANTHAPURAM	Madavoor [4536]	THUMPODU	129.0	19.7	55.2	54.1	42.0	Medium
THIRUVANANTHAPURAM	Madavoor [4536]	ULLOORKONAM	81.0	3.0	27.0	51.0	63.0	High
THIRUVANANTHAPURAM	Madavoor [4536]	VALIYA KUNNU	81.0	3.0	0.0	78.0	96.3	Very High
THIRUVANANTHAPURAM	Madavoor [4536]	VARUVILAKAM	20.0	5.0	3.0	12.0	60.0	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Madavoor [4536]	VARYAVEEDU	81.0	15.0	11.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Madavoor [4536]	VAVACHERY	81.0	3.0	8.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	VAZHAMTHODU	81.0	3.0	19.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Madavoor [4536]	VENNICHIRA	202.0	5.0	14.0	183.0	90.6	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	VETTAKKATTUKONAM	81.0	5.0	19.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Madavoor [4536]	YAKSHIYAMBALAM	81.0	3.0	3.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Madavoor [4536]	YMA	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	AUDITORIUM	202.0	3.0	36.3	162.7	80.5	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	AYIRAVILLI	81.0	3.0	54.5	23.5	29.0	Medium
THIRUVANANTHAPU RAM	Paravoor [4576]	BSNL	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	BSNL NO-1	202.0	0.0	100.0	102.0	50.5	High
THIRUVANANTHAPU RAM	Paravoor [4576]	CHEENIVILA	81.0	4.0	25.0	52.0	64.2	High
THIRUVANANTHAPU RAM	Paravoor [4576]	CLAVARA	81.0	4.0	23.0	54.0	66.7	High
THIRUVANANTHAPU RAM	Paravoor [4576]	COURT	81.0	5.0	63.0	13.0	16.0	Low
THIRUVANANTHAPU RAM	Paravoor [4576]	DHAYABJI	81.0	3.0	35.0	43.0	53.1	High
THIRUVANANTHAPU RAM	Paravoor [4576]	FLOORCO	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	FRIENDS	81.0	0.0	18.3	62.7	77.4	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Paravoor [4576]	GALLERIA-1	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	I T C	81.0	8.0	28.0	45.0	55.6	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KALADARSHINI	81.0	7.0	11.0	63.0	77.8	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KALLAM KODI	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KALLAZHI	81.0	8.0	27.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KALLUM KUNNU	81.0	5.0	18.1	57.9	71.5	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KALLUM KUNNUTSUNAMI-I	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KALLUM KUNNUTSUNAMI-II	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KALLUMKUNNUCHURCH	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KALLUMPURAM	81.0	0.0	42.0	39.0	48.1	Medium
THIRUVANANTHAPU RAM	Paravoor [4576]	KAPPIL BOAT CLUB	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KAPPIL SNDP	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KARAKUZH	129.0	20.0	31.3	77.7	60.2	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KATTAKULAM	129.0	5.0	47.1	76.8	59.6	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KEDAS	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KIZHAKKADOM	81.0	3.0	16.0	62.0	76.5	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KOCHALUM MOODU	129.0	0.0	3.0	126.0	97.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Paravoor [4576]	KOLLARAZHIKOM MUKKU	81.0	3.0	21.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KONGAL	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KOONAYIL	81.0	0.0	34.0	47.0	58.0	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KOTAMOOLA TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	KOTTAMOOLA	81.0	0.0	34.0	47.0	58.0	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KUMITTY	81.0	3.0	19.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KURUP	81.0	5.0	25.0	51.0	63.0	High
THIRUVANANTHAPU RAM	Paravoor [4576]	KUTTUR	129.0	8.6	37.0	83.4	64.7	High
THIRUVANANTHAPU RAM	Paravoor [4576]	LOCAL	129.0	0.0	55.0	74.0	57.4	High
THIRUVANANTHAPU RAM	Paravoor [4576]	MALAKAYAL	81.0	3.0	25.3	52.7	65.1	High
THIRUVANANTHAPU RAM	Paravoor [4576]	MALAKKAYAL COLONY	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	MANCHADI MOODU	129.0	5.0	17.5	106.5	82.6	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	MANIYAN KULAM	81.0	0.0	17.7	63.3	78.1	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	MARKET	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	MAVIN MOODU	81.0	5.0	43.5	32.5	40.1	Medium
THIRUVANANTHAPU RAM	Paravoor [4576]	MENGANI	81.0	0.0	35.0	46.0	56.7	High
THIRUVANANTHAPU RAM	Paravoor [4576]	MLA	81.0	0.0	52.0	29.0	35.8	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Paravoor [4576]	MUGAL BEKERY	81.0	0.0	19.3	61.7	76.1	Very High
THIRUVANANTHAPURAM	Paravoor [4576]	MUNICIPAL SHOPPING COMPLEX	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPURAM	Paravoor [4576]	MUNNAZHIMUKKU	81.0	0.0	47.0	34.0	42.0	Medium
THIRUVANANTHAPURAM	Paravoor [4576]	MUTHALAKKULAM	81.0	0.0	29.0	52.0	64.2	High
THIRUVANANTHAPURAM	Paravoor [4576]	MYLAKKAL	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPURAM	Paravoor [4576]	NEDUNGOLAM	405.0	3.0	79.0	323.0	79.8	Very High
THIRUVANANTHAPURAM	Paravoor [4576]	NEDUNGOLAM HOSPITAL	81.0	0.0	18.0	63.0	77.8	Very High
THIRUVANANTHAPURAM	Paravoor [4576]	NEDUNGOLAM HS	81.0	10.0	42.0	29.0	35.8	Medium
THIRUVANANTHAPURAM	Paravoor [4576]	NERUKADAVU	81.0	10.0	6.0	65.0	80.2	Very High
THIRUVANANTHAPURAM	Paravoor [4576]	OLLAL	81.0	0.0	16.0	65.0	80.2	Very High
THIRUVANANTHAPURAM	Paravoor [4576]	OVER BRIDGE	129.0	14.0	54.0	61.0	47.3	Medium
THIRUVANANTHAPURAM	Paravoor [4576]	PADIPPURA	81.0	10.0	14.0	57.0	70.4	High
THIRUVANANTHAPURAM	Paravoor [4576]	PANA MOODU	81.0	0.0	11.3	69.7	86.0	Very High
THIRUVANANTHAPURAM	Paravoor [4576]	PANAYILKAVU	81.0	3.0	52.1	25.8	31.9	Medium
THIRUVANANTHAPURAM	Paravoor [4576]	PANDARAKKUZHI	81.0	3.0	18.0	60.0	74.1	High
THIRUVANANTHAPURAM	Paravoor [4576]	PANIKKAR MUKKU	81.0	5.0	43.2	32.8	40.4	Medium
THIRUVANANTHAPURAM	Paravoor [4576]	PANKUVILA	81.0	5.0	47.0	29.0	35.8	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Paravoor [4576]	PARAYIL KAVU	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	PAZHAYATHUMUKKU	81.0	5.0	39.0	37.0	45.7	Medium
THIRUVANANTHAPU RAM	Paravoor [4576]	POLICE STATION	129.0	3.0	76.7	49.3	38.2	Medium
THIRUVANANTHAPU RAM	Paravoor [4576]	POTTIKKAZHIYATHMOOLA	81.0	3.0	5.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	POZHIKARA	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	POZHIKKARACHEEP	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	PRASANA	129.0	0.0	33.0	96.0	74.4	High
THIRUVANANTHAPU RAM	Paravoor [4576]	PRAVASI	81.0	0.0	15.0	66.0	81.5	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	PUKKULAM TSUNAMI	202.0	0.0	0.0	202.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	PUNCHIRAKULAM	81.0	5.0	56.7	19.3	23.9	Low
THIRUVANANTHAPU RAM	Paravoor [4576]	PUNNAMUKKU	81.0	5.0	34.0	42.0	51.9	High
THIRUVANANTHAPU RAM	Paravoor [4576]	PUTHENVILA	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Paravoor [4576]	PUTHIYA KAVU	81.0	0.0	13.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	PUTTINGAL	81.0	6.0	19.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Paravoor [4576]	RATION KADA	81.0	0.0	31.3	49.7	61.3	High
THIRUVANANTHAPU RAM	Paravoor [4576]	READING ROOM KOONAYIL	129.0	3.0	60.4	65.6	50.8	High
THIRUVANANTHAPU RAM	Paravoor [4576]	RESOURT	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Paravoor [4576]	SAKTHY TEMPLE	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	SAMTHRIPTHI	81.0	3.0	25.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Paravoor [4576]	SASTHAMKOVIL	81.0	6.0	6.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	SBI	324.0	0.0	0.0	324.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	SIVA PARVATHI	81.0	8.0	26.0	47.0	58.0	High
THIRUVANANTHAPU RAM	Paravoor [4576]	SNCS	81.0	0.0	79.3	1.7	2.1	Very Low
THIRUVANANTHAPU RAM	Paravoor [4576]	SNVRC	129.0	0.0	0.0	129.0	100.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	SOCIETY	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	SOORYA	202.0	0.0	26.0	176.0	87.1	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	THAYYIL	81.0	0.0	49.6	31.4	38.8	Medium
THIRUVANANTHAPU RAM	Paravoor [4576]	THEKKUMBHAGAM HSS	81.0	3.0	48.0	30.0	37.0	Medium
THIRUVANANTHAPU RAM	Paravoor [4576]	TOWN SOUTH	81.0	0.0	35.9	45.1	55.6	High
THIRUVANANTHAPU RAM	Paravoor [4576]	VALIYAVELICHAM	81.0	3.0	3.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Paravoor [4576]	VARUKULAM	81.0	3.0	21.8	56.2	69.4	High
THIRUVANANTHAPU RAM	Paravoor [4576]	VINAYAKAR	129.0	5.0	36.0	88.0	68.2	High
THIRUVANANTHAPU RAM	Paravoor [4576]	YEKSHI KKAVU	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	AISWARYA SCHOOL	81.0	0.0	54.0	27.0	33.3	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Poothakulam [4671]	AISWARYA SCHOOL NO-2	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	AMARATHUMUKKU	81.0	0.0	40.0	41.0	50.6	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	ANGANWADI	81.0	5.0	68.0	8.0	9.9	Very Low
THIRUVANANTHAPU RAM	Poothakulam [4671]	BHAJANA MADAM	81.0	5.0	15.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	BHOOTHAKULAM H S	81.0	5.0	31.3	44.7	55.2	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	BLOCK MARAM	202.0	11.0	77.0	114.0	56.4	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	CHAKKAVILA	81.0	0.0	30.0	51.0	63.0	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	CHAMPANCHAL	81.0	3.0	9.0	69.0	85.2	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	CHARIPPURAM	81.0	5.0	18.0	58.0	71.6	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	CHIRAKKARA FLAG	81.0	0.0	11.0	70.0	86.4	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	CHIRAKKARA KAITHARY	129.0	15.0	49.0	65.0	50.4	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	CHIRAKKARA MARKET SOCIETY	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	CHIRAKKARA MILMA SOCIETY	81.0	0.0	8.0	73.0	90.1	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	CHIRAKKARATHAZHAM	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	CHIRRAKARA TEMPLE	81.0	0.0	41.0	40.0	49.4	Medium
THIRUVANANTHAPU RAM	Poothakulam [4671]	DECENT JUNCTION	81.0	3.0	34.0	44.0	54.3	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	DOCTERMUKKU	81.0	0.0	30.3	50.7	62.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Poothakulam [4671]	EAZHAMVILA	81.0	16.0	50.2	14.8	18.3	Low
THIRUVANANTHAPU RAM	Poothakulam [4671]	EDAPPANA	81.0	0.0	24.7	56.3	69.5	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	EDAYADI	81.0	5.0	50.1	25.9	32.0	Medium
THIRUVANANTHAPU RAM	Poothakulam [4671]	ELECTION MUKKU	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	EZHAMVILA VAYANASALA	81.0	0.0	14.0	67.0	82.7	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	GURUKULAM	81.0	0.0	21.0	60.0	74.1	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	GURUMANDIRAM	81.0	20.0	61.0	0.0	0.0	Very Low
THIRUVANANTHAPU RAM	Poothakulam [4671]	KALAKKODU BANK	81.0	14.0	37.9	29.1	35.9	Medium
THIRUVANANTHAPU RAM	Poothakulam [4671]	KALAKKODU NORTH	129.0	0.0	21.4	107.6	83.4	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	KALAKKODU PHC	81.0	5.0	53.0	23.0	28.4	Medium
THIRUVANANTHAPU RAM	Poothakulam [4671]	KALAKKODU SOUTH	81.0	0.0	28.0	53.0	65.4	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	KALUNGU	81.0	4.0	52.0	25.0	30.9	Medium
THIRUVANANTHAPU RAM	Poothakulam [4671]	KARADIMUKKU	81.0	0.0	60.0	21.0	25.9	Medium
THIRUVANANTHAPU RAM	Poothakulam [4671]	KATTIKADA	81.0	0.0	34.3	46.7	57.7	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	KAVERI PARK	81.0	0.0	0.0	81.0	100.0	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	KIZHAKKE VEEDU	81.0	3.0	30.0	48.0	59.3	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	KOONAMKULAM	81.0	0.0	19.0	62.0	76.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Poothakulam [4671]	KOTTUVAN KONAM	81.0	0.0	6.0	75.0	92.6	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	KOTTUVANKONAMCOLONY	81.0	0.0	13.6	67.4	83.2	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	KULANGARAKALA	81.0	0.0	21.2	59.8	73.8	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	MAKE UP JUN	81.0	0.0	35.0	46.0	56.8	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	MANDAPAMKUNNU	81.0	6.0	14.0	61.0	75.3	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	MAVILA	81.0	0.0	39.0	42.0	51.9	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	MINI STADIUM	81.0	0.0	22.0	59.0	72.8	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	MOOLAKKADA	81.0	8.0	71.4	1.6	1.9	Very Low
THIRUVANANTHAPU RAM	Poothakulam [4671]	MOOLAKKADA-1	81.0	2.0	13.0	66.0	81.5	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	MUKKADA	81.0	3.0	21.0	57.0	70.4	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	NELLETTIL-1	81.0	0.0	27.5	53.5	66.0	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	NELLETTIL-II	81.0	0.0	32.0	49.0	60.5	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	NJARODE	81.0	5.0	67.4	8.6	10.6	Low
THIRUVANANTHAPU RAM	Poothakulam [4671]	OONNINMOODU	81.0	5.0	29.5	46.5	57.4	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	OZHUKUPARA	129.0	6.0	23.0	100.0	77.5	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	PALOTTU KAVU	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	PARAVILA COLANY	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPU RAM	Poothakulam [4671]	PASUMENKARIKULAM	81.0	0.0	26.0	55.0	67.9	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	PATTAMBIL	81.0	5.0	20.0	56.0	69.1	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	PERUMKULAM	81.0	3.0	10.0	68.0	84.0	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	POOTHAKULAM EAST	81.0	0.0	36.0	45.0	55.6	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	POST OFFICE	81.0	8.0	47.3	25.7	31.7	Medium
THIRUVANANTHAPU RAM	Poothakulam [4671]	PUNNEKULAM	81.0	8.0	9.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	PUNNEKULAM MADAN NADA	81.0	0.0	17.0	64.0	79.0	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	PUTHANKULAM EAST	81.0	0.0	29.0	52.0	64.2	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	RAJAMILL	81.0	0.0	30.0	51.0	63.0	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	RAVANANPOIKA	81.0	0.0	28.1	52.9	65.3	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	SARADAMUKKU	81.0	0.0	31.0	50.0	61.7	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	SARAVANA	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	SPORTS CITY	162.0	3.0	50.0	109.0	67.3	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	THALAKULAM	81.0	3.0	36.0	42.0	51.9	High
THIRUVANANTHAPU RAM	Poothakulam [4671]	THENGUVILA	81.0	0.0	5.0	76.0	93.8	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	THONIPPARA	81.0	0.0	3.0	78.0	96.3	Very High
THIRUVANANTHAPU RAM	Poothakulam [4671]	VARURMUKKU	81.0	10.0	17.0	54.0	66.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
THIRUVANANTHAPURAM	Poothakulam [4671]	VARUVILA	81.0	0.0	22.0	59.0	72.8	High
THIRUVANANTHAPURAM	Poothakulam [4671]	VARUVILA N S S	81.0	3.0	28.0	50.0	61.7	High
THIRUVANANTHAPURAM	Poothakulam [4671]	VAYALKKARA	81.0	0.0	13.2	67.8	83.8	Very High
THIRUVANANTHAPURAM	Poothakulam [4671]	VAZHAVILA	81.0	0.0	18.0	63.0	77.8	Very High
THIRUVANANTHAPURAM	Poothakulam [4671]	VAZHAVILA-II	81.0	0.0	20.0	61.0	75.3	Very High
THIRUVANANTHAPURAM	Poothakulam [4671]	VELLAMUGHAM	81.0	0.0	18.0	63.0	77.8	Very High
THIRUVANANTHAPURAM	Poothakulam [4671]	VEPPALLINMOODU	81.0	8.0	34.1	38.9	48.0	Medium
THIRUVANANTHAPURAM	Poothakulam [4671]	VEPPINMOODU	81.0	5.0	26.0	50.0	61.7	High
THIRUVANANTHAPURAM	Poothakulam [4671]	VETTUTHODU	81.0	5.0	32.0	44.0	54.3	High
THIRUVANANTHAPURAM	Poothakulam [4671]	VETTUVILA	81.0	5.0	39.0	37.0	45.7	Medium
THIRUVANANTHAPURAM	Poothakulam [4671]	WATER FALL	81.0	5.0	44.9	31.1	38.4	Medium
THIRUVANANTHAPURAM	Poothakulam [4671]	YOUVAREKHA	81.0	0.0	26.9	54.1	66.8	High