

KSEB Renewable Energy Feasibility Report

Generated report · 2000 transformers across 1 districts. Balance % = (Balance Available ÷ 90% DTR Capacity) × 100.

District Summary

District	Transformers	Balance (kW)	Very High	High	Medium	Low	Very Low	Unknown
WAYANAD	2000	155,738.3	1802	154	32	5	7	0
TOTAL	2000	155,738.3	1802	154	32	5	7	0

WAYANAD — 2000 transformers

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Ambalavayal [6762]	AANDIKAVALA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	ADIVARAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	AMBALAVAYAL FARM	129.0	0.0	14.3	114.7	88.9	Very High
WAYANAD	Ambalavayal [6762]	AMBALAVAYAL TOWN	129.0	0.0	22.0	107.0	82.9	Very High
WAYANAD	Ambalavayal [6762]	AMBUKUTHI PATTIYAMBAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	AMBUKUTHY 4 CENT COLONY	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Ambalavayal [6762]	AMCO ONNEYAR	81.0	0.0	16.0	65.0	80.2	Very High
WAYANAD	Ambalavayal [6762]	ANAPPARA	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Ambalavayal [6762]	ANDOOR	81.0	0.0	21.7	59.3	73.2	High
WAYANAD	Ambalavayal [6762]	ANDOOR TOWER	81.0	0.0	10.7	70.3	86.8	Very High
WAYANAD	Ambalavayal [6762]	ANDOOR VALAVE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	ATHICHAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	ATHICHAL MILL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	AYIRAMKOLLY NO 1	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	AYIRAMKOLLY NO 2	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	B S N L AMBALAVAYAL	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	BAPPU ESTATE	81.0	0.0	6.5	74.5	92.0	Very High
WAYANAD	Ambalavayal [6762]	BUISCUIT FACTORY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	CHEENGAVALLAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	CHEENGERI	51.0	0.0	5.0	46.0	90.2	Very High
WAYANAD	Ambalavayal [6762]	CHEENIKKAMOOLA	51.0	0.0	3.0	48.0	94.1	Very High
WAYANAD	Ambalavayal [6762]	CHEEPRAM COLONY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	CHELLANCODE	81.0	0.0	17.0	64.0	79.0	Very High
WAYANAD	Ambalavayal [6762]	CHERUVAYAL	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	CHITHRAGIRI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Ambalavayal [6762]	CHOOORIMOOLA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	EDACKAL	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Ambalavayal [6762]	EDAKKAL CAVE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	EDAKKAL COLONY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	GAJASILA	81.0	0.0	7.3	73.7	91.0	Very High
WAYANAD	Ambalavayal [6762]	IRUTTARAKOLLY	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	KADALMAD	81.0	3.0	14.0	64.0	79.0	Very High
WAYANAD	Ambalavayal [6762]	KALIPARAMBA	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Ambalavayal [6762]	KALLERI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	KALLIKENI	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Ambalavayal [6762]	KAMBALAKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	KARADIPPARA	81.0	0.0	22.0	59.0	72.8	High
WAYANAD	Ambalavayal [6762]	KARAMKOLLY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	KARAPUZHA AQUARIUM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	KARIMKUTTY	81.0	3.0	13.0	65.0	80.2	Very High
WAYANAD	Ambalavayal [6762]	KARIMKUTTY RESORT	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	KARINGALODE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	KATTIKOLLY	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Ambalavayal [6762]	KOTTOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	KUMBALERI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	KUNDARA	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	KUPPAKOLLY	81.0	0.0	7.0	74.0	91.4	Very High
WAYANAD	Ambalavayal [6762]	KUTTIKAITHA	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Ambalavayal [6762]	KUZHIMALAM	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	KVK	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	LP SCHOOL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Ambalavayal [6762]	MALAMKOLLY	81.0	3.0	3.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Ambalavayal [6762]	MALIKA	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	MANJAPPARA	81.0	0.0	13.1	67.9	83.8	Very High
WAYANAD	Ambalavayal [6762]	MANKOMBU	81.0	0.0	20.0	61.0	75.3	Very High
WAYANAD	Ambalavayal [6762]	MANKUNNU	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Ambalavayal [6762]	MARINA MOTHER AND CHILD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	MARTIN	81.0	3.0	42.0	36.0	44.4	Medium
WAYANAD	Ambalavayal [6762]	MATTAPPARA	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	MEENMUTTY	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Ambalavayal [6762]	MENONMUKKU	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Ambalavayal [6762]	MOUNT AVENUE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	MOUNT XANADU RESORT	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	MULLOORKOLLY	81.0	5.0	0.0	76.0	93.8	Very High
WAYANAD	Ambalavayal [6762]	MUNNOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	MUSEUM	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	NAGATHANKUNNU	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Ambalavayal [6762]	NARIKUNDU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	NEELIMALA	81.0	3.0	21.0	57.0	70.4	High
WAYANAD	Ambalavayal [6762]	NEERCHAL	81.0	6.4	3.0	71.6	88.4	Very High
WAYANAD	Ambalavayal [6762]	NELLARA COLONEY	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Ambalavayal [6762]	NELLARACHAL	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Ambalavayal [6762]	ONNEYAR	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	OZHALAKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	PADIPARAMBA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	PAMPLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	PANGALERI	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	PAYIKOLLY	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Ambalavayal [6762]	POTHUKETTY	81.0	3.0	0.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Ambalavayal [6762]	POTTANKOLLY NO 1	51.0	0.0	27.0	24.0	47.1	Medium
WAYANAD	Ambalavayal [6762]	POTTANKOLLY NO 2	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	POTTANKOLLY NO 3	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	POTTANKOLLY NO 4	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	POTTANKOLLY NO 5	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Ambalavayal [6762]	POTTANKOLLY NO 6	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	POTTANKOLLY NO 7	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	POTTANKOLLY NO 8	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	POTTANKOLLY NO 9	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	PUTHUKKAD	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	RARS AMBALAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	RELIANCE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	REST HOUSE	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Ambalavayal [6762]	THATTIYAD RESORT	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	THATTIYADE	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Ambalavayal [6762]	THAZHE KUTTIKAITHA	20.0	0.0	5.0	15.0	75.0	Very High
WAYANAD	Ambalavayal [6762]	THEKKANKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	THOMATTUCHAL TOWN	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Ambalavayal [6762]	TOMYPLASTIC	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	TREATMENT PLANT	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	VADUVANCHAL TOWN	129.0	0.0	32.0	97.0	75.2	Very High
WAYANAD	Ambalavayal [6762]	VADUVANCHAL VALAVU	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Ambalavayal [6762]	VALIYAMoola	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	VATTACHOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	VELLACHATTAM	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Ambalavayal [6762]	VELLADA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	VELLERI	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Ambalavayal [6762]	VENGACHAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Ambalavayal [6762]	VISTHARA	81.0	50.0	0.0	31.0	38.3	Medium
WAYANAD	Ambalavayal [6762]	WAYANAD PALACE	129.0	0.0	8.0	121.0	93.8	Very High
WAYANAD	Ambalavayal [6762]	WILLOW RESORT ODAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Ambalavayal [6762]	WILSON ALUNGAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	33 KV STATION AUXILIARY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	ADALAIDE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	AFFAS HOTEL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	AKG	81.0	5.0	18.0	58.0	71.6	High
WAYANAD	Kalpetta [6586]	ALHINDH	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	AMBALAPADY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kalpetta [6586]	AMBEDKAR	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kalpetta [6586]	AMBILERY	129.0	5.0	29.0	95.0	73.6	High
WAYANAD	Kalpetta [6586]	AMMUS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	AMRUTHU	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	ANAPALAM	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	ANSAR COFEE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	AR CAMP	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	ATHIMOOLA	81.0	0.0	18.7	62.3	77.0	Very High
WAYANAD	Kalpetta [6586]	ATHIMOOLA TILES	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	AYURVEDA	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Kalpetta [6586]	BLOCK OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	BOT NEW STAND	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	BPCL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	BY PASS TP	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	BYE PASS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	CAPITAL MALL	162.0	0.0	0.0	162.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kalpetta [6586]	CHAMMUNDAM	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kalpetta [6586]	CHEMBRA	129.0	0.0	3.5	125.5	97.3	Very High
WAYANAD	Kalpetta [6586]	CHENAMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	CHERIYAPALLY	129.0	0.0	15.0	114.0	88.4	Very High
WAYANAD	Kalpetta [6586]	CHETTAN KUNNU	81.0	0.0	7.9	73.1	90.3	Very High
WAYANAD	Kalpetta [6586]	CHOLAPPURAM	81.0	4.0	9.0	68.0	84.0	Very High
WAYANAD	Kalpetta [6586]	CHOORIYATTA	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Kalpetta [6586]	CHUNDA PADY	81.0	0.0	6.4	74.6	92.1	Very High
WAYANAD	Kalpetta [6586]	CHUZALY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	CIVIL-I	129.0	0.0	15.0	114.0	88.4	Very High
WAYANAD	Kalpetta [6586]	CIVIL-II	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	CLINT STUDIO	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Kalpetta [6586]	COLLAGE HOSTAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	COLONY MUKKU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kalpetta [6586]	CRYSTAL RESIDENCY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	DEVI KAINATTY	129.0	0.0	32.0	97.0	75.2	Very High
WAYANAD	Kalpetta [6586]	DISTRIC PLANING OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	DISTRICT COURT	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	DM WIMS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	EDAGUNI	81.0	3.0	3.0	75.0	92.6	Very High
WAYANAD	Kalpetta [6586]	EDAGUNI VAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	EMILY	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Kalpetta [6586]	ERANJIVAYAL	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Kalpetta [6586]	EXODUS DENTAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	FALAH	81.0	0.0	58.4	22.6	27.9	Medium
WAYANAD	Kalpetta [6586]	FATHIMA	81.0	0.0	4.1	76.9	94.9	Very High
WAYANAD	Kalpetta [6586]	FRIENDS NAGAR	81.0	0.0	11.9	69.1	85.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kalpetta [6586]	GEETHAS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	GOODALAI BRIDGE	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Kalpetta [6586]	GOODALAYI KWA	129.0	0.0	10.0	119.0	92.2	Very High
WAYANAD	Kalpetta [6586]	GOODALLAI KUNNU	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	GOVERMENT COLLEGE	81.0	0.0	35.0	46.0	56.8	High
WAYANAD	Kalpetta [6586]	HARITHAGIRI	129.0	0.0	13.0	116.0	89.9	Very High
WAYANAD	Kalpetta [6586]	HILL TOWER	405.0	0.0	0.0	405.0	100.0	Very High
WAYANAD	Kalpetta [6586]	ICON RESIDENCY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	IMES TOWER	162.0	0.0	0.0	162.0	100.0	Very High
WAYANAD	Kalpetta [6586]	ITI	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Kalpetta [6586]	JILLABANK	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KAINATTY	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KALARIVEEDU	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Kalpetta [6586]	KALLAMKORY	129.0	0.0	24.0	105.0	81.4	Very High
WAYANAD	Kalpetta [6586]	KALLATT FLAT	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KALLATTU CHUHALI	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KALLYANAMANDHIRAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KALPETTA NO-I	129.0	0.0	5.0	124.0	96.1	Very High
WAYANAD	Kalpetta [6586]	KAMMADAM KUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KANNANKANDY	81.0	0.0	80.0	1.0	1.2	Very Low
WAYANAD	Kalpetta [6586]	KARADYMANNE	81.0	0.0	21.0	60.0	74.1	High
WAYANAD	Kalpetta [6586]	KARATTAPPADY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KENDRIYA VIDYALAYA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KJ HOSPITAL	324.0	0.0	0.0	324.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KODANCHERI KUNNU	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Kalpetta [6586]	KOKUZHI OLD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KOKUZHIMADAM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kalpetta [6586]	KOTTARAM AGRI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KOTTARAM APPARTMENT	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	KOTTAVAYAL	81.0	0.0	35.0	46.0	56.8	High
WAYANAD	Kalpetta [6586]	KSRTC	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Kalpetta [6586]	MADAKUNNU	51.0	0.0	5.0	46.0	90.2	Very High
WAYANAD	Kalpetta [6586]	MADIYOORKUNI	81.0	10.0	30.0	41.0	50.6	High
WAYANAD	Kalpetta [6586]	MAHAVEER MOVIE	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MAHAVEER WOOD	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MALABAR GOLD	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MALANAD COFEE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MAMBILICHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MANGALATH	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MANGAVAYAL	81.0	0.0	16.0	65.0	80.2	Very High
WAYANAD	Kalpetta [6586]	MANIYANKODE BANK	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Kalpetta [6586]	MANIYANKODE KALAM	81.0	0.0	6.0	75.0	92.5	Very High
WAYANAD	Kalpetta [6586]	MANIYANKODE TEMPLE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MANJALAMKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MARAVAYAL	81.0	3.0	30.0	48.0	59.3	High
WAYANAD	Kalpetta [6586]	MARKET	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MATHRBHOOMY	129.0	0.0	12.0	117.0	90.7	Very High
WAYANAD	Kalpetta [6586]	MENS HOSTEL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MESS HOUSE ROAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MICRO WAVE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MOORICAP	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Kalpetta [6586]	MOOVATTY KUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MOTHIRAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MS SWAMINATHAN	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kalpetta [6586]	MUNDERY	129.0	0.0	64.3	64.7	50.2	High
WAYANAD	Kalpetta [6586]	MUNDERY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MUNICIPAL PLANT	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	MYLADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	NEDUGODE	81.0	3.0	11.0	67.0	82.7	Very High
WAYANAD	Kalpetta [6586]	NEDUNILAM	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Kalpetta [6586]	NEDUNILAM TOWER	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Kalpetta [6586]	NJ COFFEE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	NMDC	405.0	0.0	0.0	405.0	100.0	Very High
WAYANAD	Kalpetta [6586]	ODATHODE PODAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	ONIVAYAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kalpetta [6586]	PANJAB	129.0	0.0	12.9	116.1	90.0	Very High
WAYANAD	Kalpetta [6586]	PANNIYORA	81.0	0.0	38.5	42.5	52.5	High
WAYANAD	Kalpetta [6586]	PEACE VILLAGE	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	PGR TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	PICARDO	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	PINANGODE PALLY	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Kalpetta [6586]	PINANGODE TOWN	81.0	0.0	55.8	25.2	31.1	Medium
WAYANAD	Kalpetta [6586]	PINANGODU MUKKU	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Kalpetta [6586]	PO BHAVAN	81.0	0.0	12.5	68.5	84.6	Very High
WAYANAD	Kalpetta [6586]	POLICE QURTERS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	PONNADA CRUSHER	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Kalpetta [6586]	PUHZAMUDI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kalpetta [6586]	PULIYARMALA	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Kalpetta [6586]	PULPPARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	PUTHIYA STAND	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	PUTHOORVAYAL	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kalpetta [6586]	PUTHUKUDIKUNNU UNNATHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	PUZHAKKAL	129.0	0.0	25.0	104.0	80.6	Very High
WAYANAD	Kalpetta [6586]	RATAKOLLY MALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	RATTAKOLLY	81.0	0.0	6.5	74.5	92.0	Very High
WAYANAD	Kalpetta [6586]	RED CHILLIES MADAKKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	REST HOUSE	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Kalpetta [6586]	ROYAL PLAZA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	SBI	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Kalpetta [6586]	SKMJ	81.0	0.0	21.0	60.0	74.1	High
WAYANAD	Kalpetta [6586]	SKY VIEW ARCADE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	SNEHANAGAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	SOORIYAMBAM COLONEY	81.0	0.0	18.0	63.0	77.8	Very High
WAYANAD	Kalpetta [6586]	SOORYA TOWER	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	SP OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	ST JOSEPH SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	TELEPHONE EXCHANGE	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kalpetta [6586]	THEVANA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	THONIKADAVE	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Kalpetta [6586]	THONIKADAVU TILES	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	THURKEY	81.0	0.0	27.4	53.6	66.2	High
WAYANAD	Kalpetta [6586]	TP TILES	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Kalpetta [6586]	VALAPPIL COMPLEX	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	VAVADI HEALTH CENTRE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	VAVDI CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	VEETTIYERI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	VELLAMPADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	VELLARAMKUNNU	129.0	0.0	9.9	119.1	92.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kalpetta [6586]	VENGAPALLY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kalpetta [6586]	VENGAPALLY WOOD	81.0	5.0	10.4	65.6	81.0	Very High
WAYANAD	Kalpetta [6586]	VETINERY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kalpetta [6586]	VIKAS NAGAR	81.0	0.0	24.8	56.2	69.3	High
WAYANAD	Kalpetta [6586]	VINAYAKA	51.0	0.0	9.0	42.0	82.4	Very High
WAYANAD	Kalpetta [6586]	WAREHOUSE	81.0	0.0	49.0	32.0	39.6	Medium
WAYANAD	Kalpetta [6586]	WINNERS PARK	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kalpetta [6586]	WOOD LAND	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	AMBALAKUNNU	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Kambalakkad [6718]	ANERY	129.0	0.0	12.0	117.0	90.7	Very High
WAYANAD	Kambalakkad [6718]	ARINJERMALA	81.0	0.0	17.0	64.0	79.0	Very High
WAYANAD	Kambalakkad [6718]	BADHIROORKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	CHEEKALLOOR	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Kambalakkad [6718]	CHEEKALLOOR HEALTH CENTER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	CHEENGADY	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Kambalakkad [6718]	CHEERATH	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	CHEMPAKAPATTA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	CHERUMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	CHITHRAMOOLA	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Kambalakkad [6718]	CHOUNDERY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	CHUNDAKARA	81.0	0.0	23.3	57.7	71.2	High
WAYANAD	Kambalakkad [6718]	CINIMALL KUNNU VELLARAMKUNNI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	EACHOME	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Kambalakkad [6718]	EERAMKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	ERUMATHARY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	FILSER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	HYPERCITY KAMBALAKKAD	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kambalakkad [6718]	JEEVANA	129.0	0.0	13.0	116.0	89.9	Very High
WAYANAD	Kambalakkad [6718]	KAMBALAKAD TOWN	129.0	3.0	7.7	118.3	91.7	Very High
WAYANAD	Kambalakkad [6718]	KAMBALAKKAD PUMB	129.0	0.0	21.0	108.0	83.7	Very High
WAYANAD	Kambalakkad [6718]	KAMBALAKKAD SBI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	KAMBALAKKAD SCHOOL	129.0	0.0	8.0	121.0	93.8	Very High
WAYANAD	Kambalakkad [6718]	KANIYAMBETTA	129.0	0.0	24.0	105.0	81.4	Very High
WAYANAD	Kambalakkad [6718]	KANIYAMBETTA B ED CENTRE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	KANIYAMBETTA SCHOOL	81.0	0.0	26.0	55.0	67.9	High
WAYANAD	Kambalakkad [6718]	KANNIYAMBETTA AYAPPA TEMBLE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	KARAKUNNU	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Kambalakkad [6718]	KARIMBADAKUNI	81.0	0.0	3.4	77.6	95.8	Very High
WAYANAD	Kambalakkad [6718]	KARIMKUTTY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kambalakkad [6718]	KARIMKUTTY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	KARINJAKUNNU	81.0	0.0	20.0	61.0	75.3	Very High
WAYANAD	Kambalakkad [6718]	KAVADAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	KELTRON VALAVU	129.0	0.0	29.0	100.0	77.5	Very High
WAYANAD	Kambalakkad [6718]	KOLIPETTA	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Kambalakkad [6718]	KOODOTHUMMEL	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Kambalakkad [6718]	KOTATHARA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Kambalakkad [6718]	KOTTATHARA LWSS	129.0	0.0	5.0	124.0	96.1	Very High
WAYANAD	Kambalakkad [6718]	KOTTAVAYAL	81.0	0.0	3.7	77.3	95.4	Very High
WAYANAD	Kambalakkad [6718]	KOZHINHJAGAD	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Kambalakkad [6718]	KUMBALAD	81.0	5.0	0.0	76.0	93.8	Very High
WAYANAD	Kambalakkad [6718]	KURUMBALALKOOTA	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	KWA TRANSFORMER KAMBALAKKAD	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Kambalakkad [6718]	MADAKIMALA	81.0	0.0	6.4	74.6	92.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kambalakkad [6718]	MADAKKI SAW MILL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	MADAKUNNU	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Kambalakkad [6718]	MALANKARA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kambalakkad [6718]	MARAVAYAL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Kambalakkad [6718]	MARVA WOOD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	MECHANA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	MILLUMUKKU	129.0	0.0	4.1	124.9	96.8	Very High
WAYANAD	Kambalakkad [6718]	MRS CHITRAMOOLA	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Kambalakkad [6718]	MUKRAMOOLA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kambalakkad [6718]	MURANIKKARA	129.0	0.0	44.3	84.7	65.6	High
WAYANAD	Kambalakkad [6718]	NARANGAMOOLA	81.0	0.0	33.0	48.0	59.3	High
WAYANAD	Kambalakkad [6718]	ONNAM MILE	129.0	0.0	23.0	106.0	82.2	Very High
WAYANAD	Kambalakkad [6718]	PACHILAKAD	81.0	0.0	17.9	63.0	77.8	Very High
WAYANAD	Kambalakkad [6718]	PADIKARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	PALAPETTA	81.0	0.0	16.0	65.0	80.2	Very High
WAYANAD	Kambalakkad [6718]	PALLIKUNNU CHURCH	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Kambalakkad [6718]	PALLIKUNNU TOWN	129.0	3.0	23.4	102.6	79.5	Very High
WAYANAD	Kambalakkad [6718]	PALLIMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	PANTHALADI	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Kambalakkad [6718]	PARALIKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kambalakkad [6718]	PARALIKUNNU SCHOOL	81.0	0.0	14.3	66.7	82.3	Very High
WAYANAD	Kambalakkad [6718]	PERATTAKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kambalakkad [6718]	POLICE STATION	129.0	0.0	22.0	107.0	82.9	Very High
WAYANAD	Kambalakkad [6718]	PONNAMKARA	129.0	0.0	10.0	119.0	92.2	Very High
WAYANAD	Kambalakkad [6718]	POOLAKOLLY	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Kambalakkad [6718]	POOVANARIKKUNU	129.0	0.0	11.0	118.0	91.5	Very High
WAYANAD	Kambalakkad [6718]	PUZHAKILIDOM	81.0	0.0	13.0	68.0	84.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kambalakkad [6718]	PUZHAKKAMVAYAL	81.0	0.0	14.2	66.8	82.5	Very High
WAYANAD	Kambalakkad [6718]	RASTHA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	SAI PACHILAKKAD	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Kambalakkad [6718]	SBI KAMBALAKAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	TELEPHONE EXCHANGE	81.0	3.0	15.0	63.0	77.8	Very High
WAYANAD	Kambalakkad [6718]	THAMARAKOLLY	81.0	0.0	20.5	60.5	74.7	High
WAYANAD	Kambalakkad [6718]	THAZHE VARADUR	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kambalakkad [6718]	THENGILPADI	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Kambalakkad [6718]	THERVADI KUNNU	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Kambalakkad [6718]	THOMSON	81.0	3.0	27.0	51.0	63.0	High
WAYANAD	Kambalakkad [6718]	VALAL PHED	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	VALAL POIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	VALAL SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	VANDIYAMBETTA	81.0	3.0	5.0	73.0	90.1	Very High
WAYANAD	Kambalakkad [6718]	VARADOOR MILK	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	VARUMMEL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	VENNIYODE	81.0	3.0	2.0	76.0	93.8	Very High
WAYANAD	Kambalakkad [6718]	VILAMBUKANDAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kambalakkad [6718]	VILAMBUKANDAM TOWN	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Kambalakkad [6718]	VYTHALAPARAMBAN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	55 TH MILE	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Kattikulam [6783]	AKKOLLYKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	ALATHOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	AMBEDKAR COLONY	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Kattikulam [6783]	ANANTHOTHUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	ANAPPARA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	APPAPARA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kattikulam [6783]	APPAPARA FOREST OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	APPAPARA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	ARANAPARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	ARANAPARA SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	ATHANADAKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Kattikulam [6783]	ATHATTUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	BARGIRI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	BAVALI TOWER	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Kattikulam [6783]	BAVALI TOWN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	BEGUR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	CHAKKINI COLONY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Kattikulam [6783]	CHALIGADHA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	CHELOOR	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	CHELOOR-1ST MILE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	CHEMBAKAMoola	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	CHEROOR	81.0	3.0	6.0	72.0	88.9	Very High
WAYANAD	Kattikulam [6783]	CHERUKUMBAM	81.0	20.0	5.0	56.0	69.1	High
WAYANAD	Kattikulam [6783]	CHERUMATHOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	CHOLANGADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	DEVATTAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	DHAMBATTA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	EDAYOOR KUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	ERALAMoola	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Kattikulam [6783]	GHS KATTIKULAM	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Kattikulam [6783]	HOLIDAY HILLS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	IRUMPUPALAM RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Kattikulam [6783]	IRUMPUPALAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kattikulam [6783]	KALANKODE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KALIKOLLY VAIDYAR PADY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	KALINDI THIRUNELLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KALIYATTUTHARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KALKUNY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KANANCHERY	20.0	0.0	3.0	17.0	85.0	Very High
WAYANAD	Kattikulam [6783]	KAPPIKKANDY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KARAMAD COLONY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KATTADI KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KATTIKULAM TOWN	129.0	0.0	5.0	124.0	96.1	Very High
WAYANAD	Kattikulam [6783]	KAVIKKAL	81.0	0.0	37.0	44.0	54.3	High
WAYANAD	Kattikulam [6783]	KOKANDAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KOODALKADAVE-KWA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KOODALKADAVU	81.0	0.0	25.8	55.2	68.1	High
WAYANAD	Kattikulam [6783]	KOSHIKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	KOTTAMOOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KOTTIYOOR COLONY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KUNDARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KUNNIYOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	KURUKKANMOOLA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	KURUVA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Kattikulam [6783]	MAKARA RESORT	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	MALAYIL PEEDIKA	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Kattikulam [6783]	MANIYAMKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	MANNUNDI RGGVY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	MAYOOKHAM THIRUNELLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	MEENKOLLY	51.0	0.0	0.0	51.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kattikulam [6783]	MELE MUTHUMARI	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Kattikulam [6783]	MOORIYOTTUKUNNU	20.0	0.0	6.0	14.0	70.0	High
WAYANAD	Kattikulam [6783]	MOORTHIMoola	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Kattikulam [6783]	MUDRAMoola	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	MULLANKOLLY	81.0	0.0	1.8	79.2	97.8	Very High
WAYANAD	Kattikulam [6783]	MUTTANKARA	81.0	5.0	0.0	76.0	93.8	Very High
WAYANAD	Kattikulam [6783]	MUTTANKARA PHC	81.0	5.0	2.7	73.3	90.5	Very High
WAYANAD	Kattikulam [6783]	NADUVANTHAR COLONY	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Kattikulam [6783]	NARIKKAL	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Kattikulam [6783]	NELLIYATTU COLONY	20.0	0.0	5.0	15.0	75.0	Very High
WAYANAD	Kattikulam [6783]	NITTAMMANI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	ONDAYANGADY MOTTA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PADAMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PALAPEEDIKA	81.0	0.0	18.0	63.0	77.8	Very High
WAYANAD	Kattikulam [6783]	PALLIKAVALA THRISSILERY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	PALVELICHAM KWA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PALVELICHAM SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PANAVALLY CITY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PANAVALLY EMMADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PANAVALLY KALLANTHULLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PANAVALLY TOWER	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PANDURANGA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PARCY JUNCTION	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PAYYAMPALLY CHURCH	81.0	3.0	34.0	44.0	54.3	High
WAYANAD	Kattikulam [6783]	PAYYAMPALLY COLONY	129.0	0.0	12.0	117.0	90.7	Very High
WAYANAD	Kattikulam [6783]	PAYYAMPALLY TOWN	81.0	0.0	28.0	53.0	65.4	High
WAYANAD	Kattikulam [6783]	POTHUMoola MELADI	81.0	0.0	5.2	75.8	93.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kattikulam [6783]	PULIMOODUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PUTHIYOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PUTHIYOOR RGGVY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	PUZHAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	RUSSALKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Kattikulam [6783]	SARVANI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	SECOND GATE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	SECOND GATE TOWER	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Kattikulam [6783]	SREEMANGALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	THANKACHANKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Kattikulam [6783]	THAZHE 54	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Kattikulam [6783]	THAZHE MUTHUMARI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	THIRUNELLY POLICESTN	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Kattikulam [6783]	THIRUNELLY TEMPLE	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Kattikulam [6783]	THOLPETTY CHECK POST	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	THOLPETTY HS	81.0	0.0	20.0	61.0	75.3	Very High
WAYANAD	Kattikulam [6783]	THOLPETTY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	THONNIKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	THRISSILERY H S	129.0	0.0	44.0	85.0	65.9	High
WAYANAD	Kattikulam [6783]	THRISSILLERY MOTTA	20.0	0.0	6.0	14.0	70.0	High
WAYANAD	Kattikulam [6783]	VAKERY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	VARINILAM COLONY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Kattikulam [6783]	VARINILAM MOTTA	81.0	3.0	3.0	75.0	92.6	Very High
WAYANAD	Kattikulam [6783]	VAYALKKARA	81.0	0.0	16.0	65.0	80.2	Very High
WAYANAD	Kattikulam [6783]	VELLANCHERY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	VELLARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Kattikulam [6783]	VELLARA COLONY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Kattikulam [6783]	YATHRINIVAS	81.0	45.0	0.0	36.0	44.4	Medium
WAYANAD	Korom [6806]	12TH MILE	81.0	0.0	22.0	59.0	72.8	High
WAYANAD	Korom [6806]	ADAI JALANIDHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	AMBALAKKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	AREEKKARA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Korom [6806]	ARIMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	ARIMALA PRINCES OF WAYANAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	ATHIYAMKODE	81.0	3.0	12.0	66.0	81.5	Very High
WAYANAD	Korom [6806]	CHALIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	CHALIL SAMASTHY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	CHEEPAD	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Korom [6806]	CHEEPPADA HOSPITAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	CHERIYAMOOLA	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Korom [6806]	CHIRAMOOLA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Korom [6806]	CHURULY RGGVY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	CT MUKKU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Korom [6806]	DISCO KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	EDACHERI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	ILLATHUMoola	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Korom [6806]	IRUMANATHOOR	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Korom [6806]	KALIMANDAM	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Korom [6806]	KALLINKAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	KANJIRANGAD TOWER	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Korom [6806]	KARACHAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	KARIMBIL	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Korom [6806]	KARIMBIL THODU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	KARIVALAM	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Korom [6806]	KOLICHAL TVL SECTION	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	KOLLYKANDAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	KOODAMKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Korom [6806]	KOROM PUMP	129.0	0.0	36.0	93.0	72.1	High
WAYANAD	Korom [6806]	KOROM SCHOOL	81.0	3.0	12.0	66.0	81.5	Very High
WAYANAD	Korom [6806]	KOROM TOWN	129.0	0.0	21.0	108.0	83.7	Very High
WAYANAD	Korom [6806]	KUNHOME	129.0	3.0	61.0	65.0	50.4	High
WAYANAD	Korom [6806]	KUNHOME TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	KUNIYINMMEL KUTTIVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	MAKKIYAD	202.0	0.0	20.7	181.3	89.8	Very High
WAYANAD	Korom [6806]	MANAPPATTIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	MARACHUVADU	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Korom [6806]	MATTILAYAM	81.0	0.0	27.0	54.0	66.7	High
WAYANAD	Korom [6806]	MAVILLI JALANIDHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	MUNDAKOMBU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	NANMA COFFEE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	NEELOM BHAJANAMADAM	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Korom [6806]	NEELOME	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Korom [6806]	NEELOME-PANTHANAMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	NELLERI	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Korom [6806]	NELLERY MILLUMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	NIRAVILPUZHA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	NJARALODE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	PALERY-I	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Korom [6806]	PANNIPPAD	81.0	0.0	5.2	75.8	93.6	Very High
WAYANAD	Korom [6806]	PATHIRIMANNAM	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Korom [6806]	PAZHAYANGADY	81.0	0.0	12.0	69.0	85.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Korom [6806]	PERINJERI1	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Korom [6806]	PERINJERI2	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Korom [6806]	PILAKKAVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	PORLOME	129.0	0.0	2.0	127.0	98.4	Very High
WAYANAD	Korom [6806]	PULIKKAATUKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	PURVENCHERI	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Korom [6806]	PUTHIYADATHUKOMBIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	PUTHOOR-TVL SECTION	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	PUTHUSERY TWR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	PUTHUSSERY ALAKKAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	PUTHUSSERY TOWN	81.0	0.0	19.0	62.0	76.5	Very High
WAYANAD	Korom [6806]	SCHOLASTICA	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Korom [6806]	SETHOOS	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Korom [6806]	THOLAKKARA	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Korom [6806]	TREE SHADOW	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	UDIRACHIRA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	VALAD HS	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Korom [6806]	VALAD JALANIDHI-TVL SECTION	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	VALAD-TVL SECTION	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	VALAMTHODE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	VALAMTHODE CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	VALAMTHODE TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	VALAVIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	VANHODE CHURCH	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Korom [6806]	VANHODE CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Korom [6806]	VANHODE-I	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Mananthavady [6589]	AMBALAVAYAL	81.0	0.0	27.0	54.0	66.7	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Mananthavady [6589]	AMBUKUTHY	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Mananthavady [6589]	ANJUKUNNU JALANIDHI	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Mananthavady [6589]	APPOOS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	ARATTUTHARA ADIVARAM	129.0	0.0	7.0	122.0	94.6	Very High
WAYANAD	Mananthavady [6589]	ARATTUTHARA SCHOOL	81.0	0.0	27.0	54.0	66.7	High
WAYANAD	Mananthavady [6589]	ARAVIND MILL	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Mananthavady [6589]	B STREET	129.0	0.0	52.0	77.0	59.7	High
WAYANAD	Mananthavady [6589]	BAMBOO	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	BISHOPS HOUSE	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Mananthavady [6589]	BRAHMAGIRI HOLYDAYS	129.0	0.0	10.0	119.0	92.2	Very High
WAYANAD	Mananthavady [6589]	BUS STAND	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Mananthavady [6589]	CENTURY TOURIST HOME	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	CHAMADIPOYIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	CHENNALAY	81.0	0.0	35.0	46.0	56.8	High
WAYANAD	Mananthavady [6589]	CHERUVAYAL	51.0	0.0	3.0	48.0	94.1	Very High
WAYANAD	Mananthavady [6589]	CHETTAPALAM	81.0	0.0	35.4	45.6	56.3	High
WAYANAD	Mananthavady [6589]	CHETTAPALAM BYPASS	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Mananthavady [6589]	CHOLAVAYAL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Mananthavady [6589]	CHOOTTAKADAV	129.0	0.0	19.7	109.3	84.7	Very High
WAYANAD	Mananthavady [6589]	CITY CENTER	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Mananthavady [6589]	CIVIL STATION	81.0	60.0	0.0	21.0	25.9	Medium
WAYANAD	Mananthavady [6589]	CLIFTON BUNGLOW	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Mananthavady [6589]	CLUBKUNNU	129.0	0.0	25.0	104.0	80.6	Very High
WAYANAD	Mananthavady [6589]	COURT JUNCTION	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Mananthavady [6589]	CSI	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Mananthavady [6589]	DREEM LAND	129.0	0.0	7.0	122.0	94.6	Very High
WAYANAD	Mananthavady [6589]	DREEM LAND BUILDING	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Mananthavady [6589]	ELLUMANNAM JALANIDHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	ESTATEMUKKU	81.0	0.0	21.0	60.0	74.1	High
WAYANAD	Mananthavady [6589]	FASHION VILLAGE BUILDING	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Mananthavady [6589]	GANDHI PARK	202.0	0.0	15.0	187.0	92.6	Very High
WAYANAD	Mananthavady [6589]	GOVIND BUILDING	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Mananthavady [6589]	GOVT COLLEGE	129.0	0.0	8.0	121.0	93.8	Very High
WAYANAD	Mananthavady [6589]	GOVT HOSPITAL	81.0	0.0	27.0	54.0	66.7	High
WAYANAD	Mananthavady [6589]	GOVT HOSPITAL GATE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	HOTEL MANASASARASS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	IDEA TOWER B STREET	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Mananthavady [6589]	ILLATHUMoola	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Mananthavady [6589]	ILLATHUVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	ILLATHUVAYAL KALAM	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Mananthavady [6589]	INDUS	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Mananthavady [6589]	JESSY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	JOSE THEATER	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Mananthavady [6589]	KABANI VALLEY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Mananthavady [6589]	KAKKANChERI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Mananthavady [6589]	KALLATT	648.0	0.0	0.0	648.0	100.0	Very High
WAYANAD	Mananthavady [6589]	KALLIYOTTUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	KALLUMOTTOMKUNNU	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Mananthavady [6589]	KAMMANA	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Mananthavady [6589]	KANIYARAM	129.0	0.0	11.0	118.0	91.5	Very High
WAYANAD	Mananthavady [6589]	KANIYARAM LP SCHOOL	81.0	0.0	30.0	51.0	63.0	High
WAYANAD	Mananthavady [6589]	KANIYARAM TOWN	81.0	0.0	7.0	74.0	91.4	Very High
WAYANAD	Mananthavady [6589]	KANIYARAM TTI	81.0	0.0	4.0	77.0	95.1	Very High
WAYANAD	Mananthavady [6589]	KANNIVAYAL	81.0	0.0	6.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Mananthavady [6589]	KARINTHIRIKKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	KATTAKKALAM	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Mananthavady [6589]	KAVANAKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Mananthavady [6589]	KOILERY	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Mananthavady [6589]	KOILERY FERRY	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Mananthavady [6589]	KOILERY TOWER	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Mananthavady [6589]	KONIYANMUKKU	81.0	3.0	6.0	72.0	88.9	Very High
WAYANAD	Mananthavady [6589]	KOONARVAYAL	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Mananthavady [6589]	KOZHICODE ROAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	KSRTC	129.0	0.0	8.1	120.9	93.7	Very High
WAYANAD	Mananthavady [6589]	KUMARAMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	KUNNAMANGALAM	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Mananthavady [6589]	KURISINGAL	81.0	0.0	21.0	60.0	74.1	High
WAYANAD	Mananthavady [6589]	KURISINGAL FOOD FACTORY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	KURISINGAL LF CHURCH	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Mananthavady [6589]	KUZHINILAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	LAKSHAMVEEDU	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Mananthavady [6589]	LIC	81.0	0.0	80.7	0.3	0.3	Very Low
WAYANAD	Mananthavady [6589]	MADATHINKARA COLONY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Mananthavady [6589]	MANGALADY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	MANIYANKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	MARUTHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	MARUTHI FUELS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	MAZHUVANCHERY	20.0	0.0	9.0	11.0	55.0	High
WAYANAD	Mananthavady [6589]	MEENKOLLY KOYILERY	51.0	0.0	22.7	28.3	55.4	High
WAYANAD	Mananthavady [6589]	MGM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	MILK SOCIETY MANATHAVADI	81.0	0.0	57.0	24.0	29.6	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Mananthavady [6589]	MILMA CHILLING PLANT	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Mananthavady [6589]	MUTHAPPAN MADAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	MUTHUPILLA JUNCTION	81.0	5.0	28.9	47.1	58.1	High
WAYANAD	Mananthavady [6589]	MY G	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Mananthavady [6589]	MYTHRI NAGAR	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Mananthavady [6589]	NADAVAYAL COLONY	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Mananthavady [6589]	NAMBOORIKUNNU	81.0	0.0	11.4	69.6	85.9	Very High
WAYANAD	Mananthavady [6589]	ONDAYANGADI TOWN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	ONDAYANGADY	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Mananthavady [6589]	ORALERYKUNNU KAMMANA	81.0	5.0	16.0	60.0	74.1	High
WAYANAD	Mananthavady [6589]	OZHAKKODY	81.0	5.0	12.0	64.0	79.0	Very High
WAYANAD	Mananthavady [6589]	PADACHIKKUNNU	81.0	0.0	17.0	64.0	79.0	Very High
WAYANAD	Mananthavady [6589]	PAIGATTIRY MILK SOCIETY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	PAINGATRY	129.0	0.0	11.0	118.0	91.5	Very High
WAYANAD	Mananthavady [6589]	PAKISTHAN KAVALA	81.0	0.0	19.0	62.0	76.5	Very High
WAYANAD	Mananthavady [6589]	PALAKKULY	81.0	0.0	20.9	60.1	74.2	High
WAYANAD	Mananthavady [6589]	PALAKKULY RGGVY	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Mananthavady [6589]	PALANCHERRY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	PALLIYARAKKOLLY	81.0	0.0	7.4	73.6	90.9	Very High
WAYANAD	Mananthavady [6589]	PANCHARAKKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	PANDIKADAVU	202.0	3.0	40.0	159.0	78.7	Very High
WAYANAD	Mananthavady [6589]	PANDIKADAVU KWA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	PARIYARAM KUNNU TOWER	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Mananthavady [6589]	PARIYARAMKUNNU	81.0	0.0	26.0	55.0	67.9	High
WAYANAD	Mananthavady [6589]	PAYODE	129.0	0.0	22.0	107.0	82.9	Very High
WAYANAD	Mananthavady [6589]	PAYODE SAW MILL	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Mananthavady [6589]	PERUVAKA	202.0	0.0	32.0	170.0	84.2	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Mananthavady [6589]	PILAKKAVU ADIVARAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	PILAKKAVU RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Mananthavady [6589]	PILAKKAVU TOWN	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Mananthavady [6589]	POLICE STATION	81.0	0.0	84.0	0.0	0.0	Very Low
WAYANAD	Mananthavady [6589]	POOLAKKAL	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Mananthavady [6589]	POTTANKOLLY MI	129.0	0.0	5.0	124.0	96.1	Very High
WAYANAD	Mananthavady [6589]	PRIYADARSINI RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Mananthavady [6589]	PRIYADARSSINI ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	PRIYANKA	81.0	0.0	24.0	57.0	70.4	High
WAYANAD	Mananthavady [6589]	PULIKKAD	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Mananthavady [6589]	PULINCHUVAD	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Mananthavady [6589]	PUTHENMITTAM	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Mananthavady [6589]	PUTHIYADAM TOWN	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Mananthavady [6589]	PUTHIYADAM VAYAL	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Mananthavady [6589]	R D O	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Mananthavady [6589]	RANDENAL	129.0	0.0	19.5	109.5	84.9	Very High
WAYANAD	Mananthavady [6589]	RIVERA HOTEL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	ROYAL HOLIDAYS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	SHANTHINAGAR	81.0	0.0	10.0	71.0	87.6	Very High
WAYANAD	Mananthavady [6589]	SILA	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Mananthavady [6589]	SIMRON	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	ST CAMILUS	81.0	0.0	22.2	58.8	72.6	High
WAYANAD	Mananthavady [6589]	ST JOSEPH HOSPITAL	81.0	0.0	28.0	53.0	65.4	High
WAYANAD	Mananthavady [6589]	ST JUDE KAMMANA	81.0	0.0	26.0	55.0	67.9	High
WAYANAD	Mananthavady [6589]	TABOUR CHURCH	81.0	0.0	26.0	55.0	67.9	High
WAYANAD	Mananthavady [6589]	TABOUR HILL KOYLERY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	THANIYAD	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Mananthavady [6589]	THANIYAD ROAD	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Mananthavady [6589]	THANNIKKAL	129.0	0.0	16.0	113.0	87.6	Very High
WAYANAD	Mananthavady [6589]	THAZHEYANGADI	81.0	0.0	56.0	25.0	30.9	Medium
WAYANAD	Mananthavady [6589]	THONICHAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	THONICHAL JALANIDHI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Mananthavady [6589]	TP TILES	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	VALLIYOORKAVU	81.0	0.0	27.0	54.0	66.7	High
WAYANAD	Mananthavady [6589]	VARADIMOOLA	81.0	0.0	24.3	56.7	70.0	High
WAYANAD	Mananthavady [6589]	VATTARKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	VEETIERY COLONY	20.0	0.0	3.0	17.0	85.0	Very High
WAYANAD	Mananthavady [6589]	VILANILAM COLONY	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Mananthavady [6589]	VINAYAKA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Mananthavady [6589]	VINCENTGIRI	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Mananthavady [6589]	VINCENTGIRI HOSPITAL	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Mananthavady [6589]	VISITATION CONVENT	129.0	0.0	35.0	94.0	72.9	High
WAYANAD	Mananthavady [6589]	WAREHOUSE	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Mananthavady [6589]	WAYNAD SQUERE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	54 TH MILE	129.0	0.0	25.0	104.0	80.6	Very High
WAYANAD	Meenangadi [6593]	A K G	81.0	0.0	14.8	66.2	81.7	Very High
WAYANAD	Meenangadi [6593]	ADICHILADI	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	AKG CHELLICHIRAKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	ALILAKKUNNU	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Meenangadi [6593]	ANNA FOODS	81.0	60.0	0.0	21.0	25.9	Medium
WAYANAD	Meenangadi [6593]	ANNAMVAYAL	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Meenangadi [6593]	APPAD	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Meenangadi [6593]	ARIMULA ESTATE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	ARIMULA FACTORY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meenangadi [6593]	ARIMULA PALAM	51.0	3.0	3.0	45.0	88.2	Very High
WAYANAD	Meenangadi [6593]	ARIMULA SCHOOL JN	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	AROGYA MEENANGADY	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Meenangadi [6593]	ATHIKKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	ATHINILAM	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	ATHIRATTUKUNNU TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	B S N L MEENANGADI	129.0	3.0	17.0	109.0	84.5	Very High
WAYANAD	Meenangadi [6593]	CHARGENGO	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	CHEERAM KUNNU	81.0	0.0	34.0	47.0	58.0	High
WAYANAD	Meenangadi [6593]	CHENDAKKUNI	81.0	0.0	16.0	65.0	80.2	Very High
WAYANAD	Meenangadi [6593]	CHIRATTAYAMBAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	CHOMADI	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Meenangadi [6593]	CHUNDAKKUZHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	EADAKKARAVAYAL	20.0	0.0	5.0	15.0	75.0	Very High
WAYANAD	Meenangadi [6593]	ELLAR COFFEE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	EYE HOSPITAL	81.0	0.0	19.0	62.0	76.5	Very High
WAYANAD	Meenangadi [6593]	FAMOUS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	FC I MEENANGADI	81.0	0.0	30.2	50.8	62.7	High
WAYANAD	Meenangadi [6593]	GINGER PASTE	81.0	0.0	75.0	6.0	7.4	Very Low
WAYANAD	Meenangadi [6593]	GLORY MILL KARYAMBADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	HOSPITAL KUNNU	129.0	0.0	20.0	109.0	84.5	Very High
WAYANAD	Meenangadi [6593]	HOSPITALKUNNU TOWER	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meenangadi [6593]	ICE PLANT FIZZY	81.0	60.0	0.0	21.0	25.9	Medium
WAYANAD	Meenangadi [6593]	IRUKANNI	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KADAKULAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KALLANCHIRA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KALLUVAYAL	81.0	0.0	5.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meenangadi [6593]	KALLUVETTY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	KANALVADI KUNNU	81.0	0.0	30.0	51.0	63.0	High
WAYANAD	Meenangadi [6593]	KAPPIKUNNU I	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	KAPPIKUNNU TOWER	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	KARACHAL	81.0	0.0	7.3	73.7	91.0	Very High
WAYANAD	Meenangadi [6593]	KARACHAL TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KARANI	81.0	0.0	19.3	61.7	76.2	Very High
WAYANAD	Meenangadi [6593]	KARANI TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KARIYAMBADI	129.0	3.0	17.0	109.0	84.5	Very High
WAYANAD	Meenangadi [6593]	KEERIPETTAKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KELAMANGALAM	51.0	0.0	11.0	40.0	78.4	Very High
WAYANAD	Meenangadi [6593]	KELAMANGALAMKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KENICHIRA B S N L	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KENICHIRA CHURCH	81.0	0.0	19.5	61.5	76.0	Very High
WAYANAD	Meenangadi [6593]	KENICHIRA MILL	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Meenangadi [6593]	KENICHIRA REST INN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KENICHIRA SCHOOL	81.0	0.0	9.7	71.3	88.0	Very High
WAYANAD	Meenangadi [6593]	KENICHIRA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KENICHIRA TOWN	129.0	0.0	8.0	121.0	93.8	Very High
WAYANAD	Meenangadi [6593]	KOLAMPETTA	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KOLAVAYAL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meenangadi [6593]	KOLERI PALAM	81.0	0.0	9.9	71.1	87.8	Very High
WAYANAD	Meenangadi [6593]	KOLERI TOWN	51.0	0.0	14.0	37.0	72.5	High
WAYANAD	Meenangadi [6593]	KONGIYAMBAM	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	KOTTAKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KOTTAVAYAL JN	20.0	0.0	4.0	16.0	80.0	Very High
WAYANAD	Meenangadi [6593]	KOYAS TOWER BUILDING	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meenangadi [6593]	KRISHNAGERI TOWER	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Meenangadi [6593]	KRISHNAGIRI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KRISHNAGIRI STADIUM	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Meenangadi [6593]	KSHEERRABHAVAN	81.0	0.0	26.0	55.0	67.9	High
WAYANAD	Meenangadi [6593]	KUPPADI	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Meenangadi [6593]	KUTTIRAYINPALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	KUTTIRAYINPALAM TOURIST HOME	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	M K SAW MILL KARANI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MADATHUMPADI	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meenangadi [6593]	MADHUKOLLY	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Meenangadi [6593]	MALAMTHOTTAM	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Meenangadi [6593]	MANANGUVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MANGALAMKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MANGALATH VAYAL	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MANGODU	81.0	3.0	5.0	73.0	90.1	Very High
WAYANAD	Meenangadi [6593]	MANGODU CHURCH	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MANIKAVE	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Meenangadi [6593]	MANIKUNI	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MANIVAYAL	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MARAMALA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	MARIYAMMAN	51.0	0.0	8.4	42.6	83.5	Very High
WAYANAD	Meenangadi [6593]	MARKET	129.0	4.0	14.5	110.5	85.7	Very High
WAYANAD	Meenangadi [6593]	MARYLAND 54 TH MILE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MATHAMOOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MEENANGADI TOWN	129.0	0.0	6.0	123.0	95.3	Very High
WAYANAD	Meenangadi [6593]	MEENANGADY ATTAKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MELE PANDIYATTU	20.0	0.0	3.0	17.0	85.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meenangadi [6593]	MENMA	51.0	0.0	9.0	42.0	82.4	Very High
WAYANAD	Meenangadi [6593]	MOONNANAKUZHI	51.0	5.0	16.0	30.0	58.8	High
WAYANAD	Meenangadi [6593]	MOTHIROTTU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MOTTAKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MOTTANKARA	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MURANI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MYLAMBADI	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Meenangadi [6593]	MYLAMBADI COLANY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MYLAMBADI GOKHELE NAGAR	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MYLAMBADI PALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	MYLAMBADI TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	NECHIYAN COMPLEX	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Meenangadi [6593]	NELlichODE	51.0	0.0	12.0	39.0	76.5	Very High
WAYANAD	Meenangadi [6593]	NJATTADI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	P B M	81.0	0.0	23.0	58.0	71.6	High
WAYANAD	Meenangadi [6593]	PADARIKKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	PADAVAYAL	20.0	0.0	4.0	16.0	80.0	Very High
WAYANAD	Meenangadi [6593]	PADMASREEKAVALA	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Meenangadi [6593]	PALAKKAMOOLA	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Meenangadi [6593]	PALLIKKAMOOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	PANAMKANDI	51.0	0.0	3.0	48.0	94.1	Very High
WAYANAD	Meenangadi [6593]	PANDA ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	PANNIMUNDA	81.0	0.0	24.0	57.0	70.4	High
WAYANAD	Meenangadi [6593]	PANNIMUNDA COLONY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	PAPPLASSERY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	PARALIKKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	PATHILPEEDIKA	81.0	0.0	3.0	78.0	96.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meenangadi [6593]	PATHIRIKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	POLY	81.0	0.0	20.0	61.0	75.3	Very High
WAYANAD	Meenangadi [6593]	PONGINITHODI	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	POOTHADI SCHOOL	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Meenangadi [6593]	POOTHADI TEMPLE	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Meenangadi [6593]	POPULAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	PRIYADARSINI	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	PULIKAL KUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	PURAKKADI TEMPLE	20.0	0.0	3.0	17.0	85.0	Very High
WAYANAD	Meenangadi [6593]	PUZHAMKUNI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	RAJEEV GANDHI JUNCTION	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	RATTAKKUNDU	81.0	5.0	9.0	67.0	82.7	Very High
WAYANAD	Meenangadi [6593]	RATTAKUNDU CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	RDC KOLAGAPPARA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Meenangadi [6593]	S L S	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	SALOM MEENANGADY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	SHA ENTERPRISES	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	SOCIATY KAVALA	81.0	0.0	10.5	70.5	87.1	Very High
WAYANAD	Meenangadi [6593]	TATA POWER EV CHARGING STATION	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	THACHAMBAM	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Meenangadi [6593]	THARUVARAM KUNNU I	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	THARUVARAMKUNNU PALAM	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	THAZHAMUNDA	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Meenangadi [6593]	THAZHAMUNDA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	THAZHATHANGADI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	THAZHATHUVAYAL	81.0	0.0	21.0	60.0	74.1	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meenangadi [6593]	THAZHE KARANI	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Meenangadi [6593]	THAZHE PANDIYATTUVAYAL	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	THENERI COLONY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	THOPPIPPARA	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Meenangadi [6593]	TRENDS MEENANGADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	TRIVENI	129.0	0.0	101.1	27.9	21.6	Low
WAYANAD	Meenangadi [6593]	VALANCHERI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	VALAVAYAL	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Meenangadi [6593]	VALLIPPATTA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meenangadi [6593]	VANDICHIRA	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Meenangadi [6593]	VARIYATTUKUNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meenangadi [6593]	VATTAKAVE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	VATTAKKAVU TOWER	81.0	4.0	0.0	77.0	95.1	Very High
WAYANAD	Meenangadi [6593]	VATTATHANI	81.0	0.0	9.3	71.7	88.5	Very High
WAYANAD	Meenangadi [6593]	VEENGOOR	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Meenangadi [6593]	VELLIMALA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meenangadi [6593]	VELLITHODU	81.0	2.0	5.0	74.0	91.4	Very High
WAYANAD	Meenangadi [6593]	VIVEKANANDA SCHOOL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meenangadi [6593]	YOOKKALI KAVALA	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Meppadi [6588]	1 ST MILE	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Meppadi [6588]	1STMILE PODAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	46 TH MILE	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meppadi [6588]	5 ACRA TEMPLE	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meppadi [6588]	5 ACRE	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Meppadi [6588]	AAPPALAM	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Meppadi [6588]	AMBEDKER COLONY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	ANADICAP	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meppadi [6588]	ANJAMNUMBER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	ANNAMMA KAVALA	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Meppadi [6588]	ARAMANGALAMCHAL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meppadi [6588]	ARANAMALA TOP	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meppadi [6588]	ARAPETTA CLUB	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	ARUNAMALA	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meppadi [6588]	ATHIVAYAL	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Meppadi [6588]	ATTAMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	ATTAMALA PUMP	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	BETTER SUIT	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Meppadi [6588]	BUSSTAND	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meppadi [6588]	CHEMBOTHARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	CHOLAMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	CHOLAMALA PUMP	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	CHOOALMALA TELEX	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	CHOOALMALA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	CHOOALMALA TOWN	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Meppadi [6588]	CHULIKKA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	CHUNGATHARA	81.0	0.0	7.0	74.0	91.4	Very High
WAYANAD	Meppadi [6588]	COFEE PULPING	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	COLERY	81.0	5.0	0.0	76.0	93.8	Very High
WAYANAD	Meppadi [6588]	COTTANAD PULPPING	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	ELAMBILERY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	ELAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	ERUMAKOLLY 22	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Meppadi [6588]	EYYAMPARA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meppadi [6588]	EYYAMPARA FOREST	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meppadi [6588]	FAISAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	FAMILY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	GOVT PRESS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	GRAMADEEPAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	JAIHIND	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	JYOTHI PAIN AND PALIATIVE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	K B ROAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KADACHIKUNNU MATTAM	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Meppadi [6588]	KADASSERY	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Meppadi [6588]	KADASSIKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KADOOR	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Meppadi [6588]	KAIRALY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KALLADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KALLAIVALAVU	81.0	0.0	4.0	77.0	95.1	Very High
WAYANAD	Meppadi [6588]	KALLUMALA	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meppadi [6588]	KANNADI AMBALAM	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Meppadi [6588]	KAPPANKOLLI	81.0	0.0	20.0	61.0	75.3	Very High
WAYANAD	Meppadi [6588]	KAPPANKOLLY TOWER	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Meppadi [6588]	KAPPIKKAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KARAPUZHA KALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KASHMEER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KK NAIR CHOORALMALA SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KOTANAD	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Meppadi [6588]	KOTTATHARAVAYAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meppadi [6588]	KUNDUPARAMBAN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KUNJAHAMMED	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meppadi [6588]	KUNNAMANGALAM KUNNU	81.0	0.0	2.0	79.0	97.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meppadi [6588]	KUNNAMANGALAM VAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KUNNAMBETTA SOCIETY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KUNNAMBETTA TOWN	81.0	0.0	4.2	76.8	94.8	Very High
WAYANAD	Meppadi [6588]	KUPPACHICOLONY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KUTHUMUNDA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	KUTTAPPAN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	LONTANO	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	LUKY HILL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	MALAYACHAMKOLLY	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Meppadi [6588]	MAMMIKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meppadi [6588]	MANIVAYAL	129.0	5.0	7.0	117.0	90.7	Very High
WAYANAD	Meppadi [6588]	MANKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meppadi [6588]	MEENAKSHI	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Meppadi [6588]	MEENAKSHI ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	MELE ARRAPATTA	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meppadi [6588]	MEPPADI LP SCHOOL	81.0	0.0	22.0	59.0	72.8	High
WAYANAD	Meppadi [6588]	MEPPADI PALLY	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meppadi [6588]	MEPPADI TOWN	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Meppadi [6588]	METRO	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	MOOPAINAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	MUKKIL PEEDIKA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Meppadi [6588]	MUNDAKKAI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	NALLANNOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	NALLANNOR KALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	NEDUMKARANA	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Meppadi [6588]	NEDUMPALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	NELLIMUNDA CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meppadi [6588]	NELLIMUNDA PADY	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Meppadi [6588]	NELLIMUNDA PUMP	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Meppadi [6588]	PADIVAYAL	81.0	0.0	4.8	76.2	94.1	Very High
WAYANAD	Meppadi [6588]	PALATTUMURANI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	PALAVAYAL	81.0	5.0	14.1	61.9	76.4	Very High
WAYANAD	Meppadi [6588]	PALLYKAVALA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meppadi [6588]	PARAKKAMVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	PARU KUNNU	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Meppadi [6588]	PODAR PUMP	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	POLICE STATION	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	POOLAKKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	POOTHAKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	PULLOORKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	PULLUKUNNU COLONY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	PUTHUKKAD	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Meppadi [6588]	PUTHUKKUDIMUKKU	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Meppadi [6588]	PUTTAD TOWER	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meppadi [6588]	RIPPON 14	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	RIPPON 52	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Meppadi [6588]	RIPPON FACTORY	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Meppadi [6588]	ROSE GUARDEN	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Meppadi [6588]	SAIPPUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	SHIHAB	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	SITHARAMVAYAL	51.0	0.0	14.5	36.5	71.6	High
WAYANAD	Meppadi [6588]	SKY SIERA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	SPICES GUARDEN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	SUJATHA ESTATE	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Meppadi [6588]	SUNRISE VALLEY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meppadi [6588]	THALAKKAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meppadi [6588]	THANJILODE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	THAZHE ARAPETTA MILL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	THAZHE ARRAPETTA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	THINAPURAM	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Meppadi [6588]	VALATHOOR	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Meppadi [6588]	VALATHOOR PALLY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Meppadi [6588]	VARIPRA	81.0	14.0	22.3	44.7	55.2	High
WAYANAD	Meppadi [6588]	VATTATHUVAYAL	20.0	3.0	0.0	17.0	85.0	Very High
WAYANAD	Meppadi [6588]	VATTATHUVAYAL 60	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Meppadi [6588]	VEDAN COLONEY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	VEETIMATTAM	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Meppadi [6588]	VELLAPPANKANDY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	VILLAGE	81.0	0.0	50.0	31.0	38.3	Medium
WAYANAD	Meppadi [6588]	VITHUKAD COLONY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Meppadi [6588]	WIMS VILLA	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Meppadi [6588]	WINSON KAPPAMKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	100 KV PALLIPPADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	A K TILES	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	AFIA	81.0	0.0	28.0	53.0	65.4	High
WAYANAD	Muttil [6792]	AK TILES	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	ALIYARPADY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	AMANA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	AMBUKUTHY	81.0	0.0	23.0	58.0	71.6	High
WAYANAD	Muttil [6792]	AMBUKUTHY CANAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	ANAND	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Muttil [6792]	CHAZHIVAYAL	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Muttil [6792]	CHILANJICHAL	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Muttil [6792]	COFEE GREENEN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	EDAPETTY	129.0	0.0	26.5	102.5	79.5	Very High
WAYANAD	Muttil [6792]	EDATHARAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	EDATHIL COLONY	20.0	0.0	6.0	14.0	70.0	High
WAYANAD	Muttil [6792]	EZHAMCHIRA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	HYUNDAI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	HYUNDAI MUTTIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	IDINJAKOLLI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	INDUS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	INDUS MOTORS	81.0	0.0	27.0	54.0	66.7	High
WAYANAD	Muttil [6792]	JOY KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	K K JUCTION KWA	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Muttil [6792]	K K JUNCTION	51.0	0.0	3.0	48.0	94.1	Very High
WAYANAD	Muttil [6792]	KADAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KADHARPADY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KAIPPADAM KUNNU	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Muttil [6792]	KAIPPADAMKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KAIPPANIMOOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KAKKAVAYAL SCHOOL	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Muttil [6792]	KAKKAVAYAL TOWN	129.0	0.0	25.7	103.3	80.1	Very High
WAYANAD	Muttil [6792]	KAKKAVAYALSCHOOL	81.0	0.0	13.4	67.6	83.4	Very High
WAYANAD	Muttil [6792]	KAKKAVYAL TOWN 160 KVA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Muttil [6792]	KALLUPADI I	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Muttil [6792]	KALLUPADI II	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Muttil [6792]	KALLYANAMANDHIRAM	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Muttil [6792]	KARAPUZHA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Muttil [6792]	KARAPUZHA LAKE ROSE	129.0	0.0	50.0	79.0	61.2	High
WAYANAD	Muttil [6792]	KARAPUZHA M PHONE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KARAPUZHA RESORT	129.0	0.0	20.0	109.0	84.5	Very High
WAYANAD	Muttil [6792]	KARAPUZHA TURISUM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KARIMKANNIKUNNU	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Muttil [6792]	KARIYATHANPARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KOLAMPETTA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KOLAVAYAL SHAJI MILL	81.0	3.0	11.0	67.0	82.7	Very High
WAYANAD	Muttil [6792]	KOLAVAYAL WOOD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KOLEMPETTA 100KVA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KOLPARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KUMBALAD MILK	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KUNCHUNIPADI	81.0	0.0	24.0	57.0	70.4	High
WAYANAD	Muttil [6792]	KUTTAMAGALAM SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	KUTTAMANGALAM	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Muttil [6792]	KUZHIVAYAL	81.0	0.0	9.7	71.3	88.0	Very High
WAYANAD	Muttil [6792]	KWA SWARGAMKUNNU	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Muttil [6792]	M KALLUVAYAL	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Muttil [6792]	M KOLAVAYAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Muttil [6792]	M VELLITHODE KAKKAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	MANDAD	129.0	0.0	15.0	114.0	88.4	Very High
WAYANAD	Muttil [6792]	MANDAD KALLUMKORI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	MANIKUNI	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Muttil [6792]	MOORTHIKUNNU	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Muttil [6792]	MUKKAMKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	MUNDUPARA	81.0	5.0	0.0	76.0	93.8	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Muttil [6792]	MUNDUPARA ANGANAVADI	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Muttil [6792]	MUNNAR RESORT	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Muttil [6792]	MUTTIL PANCHAYTH	81.0	0.0	45.0	36.0	44.4	Medium
WAYANAD	Muttil [6792]	MUTTIL TOWN	129.0	0.0	22.0	107.0	82.9	Very High
WAYANAD	Muttil [6792]	MUTTIL VIVEKANANDA ROAD	81.0	3.0	11.8	66.2	81.7	Very High
WAYANAD	Muttil [6792]	NAIKOLLY COLONY	20.0	0.0	8.0	12.0	60.0	High
WAYANAD	Muttil [6792]	NELLIMALAM	51.0	0.0	8.0	43.0	84.3	Very High
WAYANAD	Muttil [6792]	NENMANI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	NENMENI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	OLAVATHOOR	81.0	3.0	3.0	75.0	92.6	Very High
WAYANAD	Muttil [6792]	OLEDAN KUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Muttil [6792]	OTIPS	81.0	50.0	4.0	27.0	33.3	Medium
WAYANAD	Muttil [6792]	P S FRAME PARAKKAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	PAKKAM	51.0	0.0	11.0	40.0	78.4	Very High
WAYANAD	Muttil [6792]	PAKKAM SCHOOL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Muttil [6792]	PAKKIYANIKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	PAKYANIKUNNU	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Muttil [6792]	PALAKKATTU KUNNU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Muttil [6792]	PALLIPADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	PANNIKUZH	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	PARAKKAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	PARIYARAM	81.0	0.0	22.0	59.0	72.8	High
WAYANAD	Muttil [6792]	PATTAMBIKUNNU I	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Muttil [6792]	PATTAMBIKUNNU II	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Muttil [6792]	POOTHAMoola	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	QATAR VARIAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	RANJITH	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Muttill [6792]	SARADHA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	SASTHRINAGAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	SHAJI MILL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	SLICE UP	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	SLICEUP	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	SWARGAM KUNNU	81.0	5.0	0.0	76.0	93.8	Very High
WAYANAD	Muttill [6792]	THANAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	THAZHEMUTTIL	202.0	0.0	30.0	172.0	85.1	Very High
WAYANAD	Muttill [6792]	THEKKUMPADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	THEKKUMPADY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Muttill [6792]	THENERI CHURCH	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Muttill [6792]	THENERI WOOD	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Muttill [6792]	THOMSON	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Muttill [6792]	THONDUPALI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	THONIKADAVE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	THRIKKAIPETTA TOWER	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Muttill [6792]	UPPUPARA	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Muttill [6792]	UPPUPARA RESORT	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Muttill [6792]	URAVU	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Muttill [6792]	VARIAD	81.0	0.0	9.4	71.6	88.4	Very High
WAYANAD	Muttill [6792]	VARIAD ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	VARIYATTU ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	VAZHAVATTA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Muttill [6792]	VAZHAVATTA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	VAZHIYORAM	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Muttill [6792]	VEGHACHOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttill [6792]	VELLAKETTU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Muttil [6792]	VELLITHODU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Muttil [6792]	VIMAL KUMAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Muttil [6792]	WMO COLLAGE	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Muttil [6792]	WMO ORPHANAGE	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Padichira [6811]	60 KAVALA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padichira [6811]	AISHWARYAKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	AKKATTUKAVALA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Padichira [6811]	ALATHOOR	81.0	3.0	53.0	25.0	30.9	Medium
WAYANAD	Padichira [6811]	ASHA JUNCTION	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Padichira [6811]	BADHAMKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	BHOODANAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	C V TOWER	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padichira [6811]	CHACHIKKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	CHAMAPARA	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Padichira [6811]	CHANNOTH KOLLY	81.0	5.0	8.0	68.0	84.0	Very High
WAYANAD	Padichira [6811]	CHELOOR	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Padichira [6811]	CHOONATTU KAVALA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Padichira [6811]	CHUKKANKUNDU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	CV KAVALA	81.0	0.0	19.0	62.0	76.5	Very High
WAYANAD	Padichira [6811]	DIPPO	81.0	3.0	16.0	62.0	76.5	Very High
WAYANAD	Padichira [6811]	EATTIMUKKU	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Padichira [6811]	GRAHANOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	GRIHANNOOR RGGVY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	IRUPPOOD	81.0	5.0	5.0	71.0	87.7	Very High
WAYANAD	Padichira [6811]	KABANI GIRI	129.0	0.0	27.0	102.0	79.1	Very High
WAYANAD	Padichira [6811]	KABANI RIVER SIDE NO I	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	KABANI RIVER SIDE NO II	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Padichira [6811]	KABANIGIRI SOCIETY	81.0	0.0	33.0	48.0	59.3	High
WAYANAD	Padichira [6811]	KACHERIMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	KINNNANCHIRA	81.0	0.0	4.0	77.0	95.1	Very High
WAYANAD	Padichira [6811]	KOLAVALLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	KOLAVALLY ANGANVADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	KOLAVALLY MAPPANATH	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Padichira [6811]	KULAKKATTIKAVALA	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Padichira [6811]	KURISUMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	LOORDUNAGAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	MADAL	81.0	0.0	11.2	69.8	86.1	Very High
WAYANAD	Padichira [6811]	MARAKADAVU CHURCH	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Padichira [6811]	MARAKADAVU SCHOOL	81.0	0.0	28.0	53.0	65.4	High
WAYANAD	Padichira [6811]	MARAKKADAVU M I	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Padichira [6811]	MELE PADICHIRA	81.0	0.0	46.8	34.2	42.2	Medium
WAYANAD	Padichira [6811]	MITTATHANIKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	MOONNUPALAM	81.0	0.0	8.2	72.8	89.9	Very High
WAYANAD	Padichira [6811]	MOONNUPALAM OSALLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	MULLANKOLLY	129.0	5.0	45.7	78.3	60.7	High
WAYANAD	Padichira [6811]	MULLENKOLLY SOCIETY	81.0	0.0	9.2	71.8	88.6	Very High
WAYANAD	Padichira [6811]	PACHIKKARAMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	PADICHIRA	81.0	0.0	26.0	55.0	67.9	High
WAYANAD	Padichira [6811]	PADICHIRA EXCHANGE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padichira [6811]	PALAKOLLY	81.0	0.0	24.5	56.5	69.7	High
WAYANAD	Padichira [6811]	PALATHANAM	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Padichira [6811]	PARAKKADAVU	81.0	0.0	47.0	34.0	42.0	Medium
WAYANAD	Padichira [6811]	PARAKKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	PARISH HALL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Padichira [6811]	PARUDEESA	81.0	0.0	19.0	62.0	76.5	Very High
WAYANAD	Padichira [6811]	PATHIRI AMMAVANMUKKU	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Padichira [6811]	PATHIRI MANCHUVADU	81.0	5.0	14.0	62.0	76.5	Very High
WAYANAD	Padichira [6811]	PATTANIKOOP	81.0	0.0	44.0	37.0	45.7	Medium
WAYANAD	Padichira [6811]	PATTANIKOOP JACOBITE CHURCH	81.0	0.0	29.0	52.0	64.2	High
WAYANAD	Padichira [6811]	PATTANIKOOP KUNNATHU	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Padichira [6811]	PERIKKALLOOR	81.0	3.0	22.0	56.0	69.1	High
WAYANAD	Padichira [6811]	PERIKKALLOOR M I	81.0	0.0	5.9	75.1	92.7	Very High
WAYANAD	Padichira [6811]	PERIKKALLOR SOCIETY	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Padichira [6811]	PRABHATHKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	PULARI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	PUNYALANKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	SASIMALA CHURCH	81.0	3.0	35.0	43.0	53.1	High
WAYANAD	Padichira [6811]	SAVIAMKOLLY	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Padichira [6811]	SEETHAMOUNT	81.0	5.0	8.0	68.0	84.0	Very High
WAYANAD	Padichira [6811]	SRUTHINAGAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	SURABHI KAVALA	81.0	5.0	49.5	26.5	32.7	Medium
WAYANAD	Padichira [6811]	THARAPATHKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	THENMAVINKADAV	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	THONDANODY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	VADANAKAVALA	81.0	5.0	33.2	42.8	52.8	High
WAYANAD	Padichira [6811]	VADANAKAVALA SAW MILL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padichira [6811]	VANAMOOLIKA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padichira [6811]	VANDIKADAV	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Padichira [6811]	VARAVOOR	81.0	0.0	14.4	66.6	82.3	Very High
WAYANAD	Padichira [6811]	VENGASSERY KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	10THMILE	81.0	0.0	9.5	71.5	88.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Padinjarethara [6782]	13 MILE	81.0	0.0	3.3	77.7	95.9	Very High
WAYANAD	Padinjarethara [6782]	16TH MAIL	129.0	0.0	11.0	118.0	91.5	Very High
WAYANAD	Padinjarethara [6782]	8TH MAIL	81.0	0.0	16.0	65.0	80.2	Very High
WAYANAD	Padinjarethara [6782]	9 TH MILE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	ADHIKARIPADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	ALAKKANDY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	AMBEDKER COLONY	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	ANAPPRA	51.0	0.0	18.0	33.0	64.7	High
WAYANAD	Padinjarethara [6782]	ARAMPATTA KUNNU	81.0	0.0	19.0	62.0	76.5	Very High
WAYANAD	Padinjarethara [6782]	ARICAL KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	ASARIKAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	AYIROOR ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	AYYAR ARCADE	129.0	0.0	5.0	124.0	96.1	Very High
WAYANAD	Padinjarethara [6782]	BANKKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	BAPPANAMALA	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Padinjarethara [6782]	BONITA BANASURA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	BSNL KAVUMANNAM	81.0	3.0	2.0	76.0	93.8	Very High
WAYANAD	Padinjarethara [6782]	BSNL PADINJARATHARA	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Padinjarethara [6782]	BSP	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Padinjarethara [6782]	CHEMBAKACHAL	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	CHENNALODE	129.0	3.0	24.0	102.0	79.1	Very High
WAYANAD	Padinjarethara [6782]	CHENNALODE HOSPITAL	81.0	3.0	36.0	42.0	51.9	High
WAYANAD	Padinjarethara [6782]	CHENNALODE UP SCHOOL	51.0	3.0	12.0	36.0	70.6	High
WAYANAD	Padinjarethara [6782]	CHERYEMKOLLY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	CHITTALAKKUNNU	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Padinjarethara [6782]	DAM TOP	405.0	0.0	0.0	405.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	EDAKADAMUKKU	129.0	0.0	11.0	118.0	91.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Padinjarethara [6782]	EV CHARGING STATION	405.0	0.0	0.0	405.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KAKKANAMKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	KALLAMKARI	81.0	0.0	16.0	65.0	80.2	Very High
WAYANAD	Padinjarethara [6782]	KALLAMTHODU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KALLIKUNNI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	KALLUVETTUMTHAZHE	51.0	3.0	0.0	48.0	94.1	Very High
WAYANAD	Padinjarethara [6782]	KANNOTHUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KAPPIKKALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KAPPUMKUNU KWA	81.0	0.0	37.0	44.0	54.3	High
WAYANAD	Padinjarethara [6782]	KAPPUNDIKKAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KAPPUVAYAL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Padinjarethara [6782]	KARIPALIMUKK	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Padinjarethara [6782]	KARLAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KAVUMMANNAM	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Padinjarethara [6782]	KODANCHERY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	KODUMCHOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KOPIDI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KOTTUKULAM	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Padinjarethara [6782]	KUNDILANGADI	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Padinjarethara [6782]	KUPPADITHARA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KURUMANI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	KUTTIYAMVAYAL	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Padinjarethara [6782]	KUZHIVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	LOUIS MOUNT HOSPITAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	MAKKOTTUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	MANJOORA	81.0	0.0	44.0	37.0	45.7	Medium
WAYANAD	Padinjarethara [6782]	MEENMUTTY JUNCTION	81.0	3.0	6.0	72.0	88.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Padinjarethara [6782]	MOIDUKUTTYPADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	MOONLIGHT	81.0	3.0	13.0	65.0	80.2	Very High
WAYANAD	Padinjarethara [6782]	MULLANKKANDY KWA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	MUNDAKUTTY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	MUSTHAFA MILL	81.0	0.0	24.0	57.0	70.4	High
WAYANAD	Padinjarethara [6782]	NADAMMAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	NAGATHINKAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	PADAYAN PADINJARATHARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	PADINHARATARA TOWN	129.0	0.0	25.0	104.0	80.6	Very High
WAYANAD	Padinjarethara [6782]	PADINHARATHARA VILLAGE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	PAKAL VEEDU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	PALLITHAZAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	PANDANKODE	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Padinjarethara [6782]	PANTHIPOYIL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Padinjarethara [6782]	PERAL	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Padinjarethara [6782]	PERUVADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	PETTALS RESORT	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	POLICE STATION	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	PUNJAVAYAL	81.0	0.0	4.0	77.0	95.1	Very High
WAYANAD	Padinjarethara [6782]	PURATHOOTT	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	PUTHUSSERIKADVE MI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	PUTHUSSERYKADAVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	PUZHAKKAL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Padinjarethara [6782]	Q TEAM LLP	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	SANTHINAGAR	129.0	10.0	17.5	101.5	78.7	Very High
WAYANAD	Padinjarethara [6782]	SAROVARAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	SERINITY RESORT	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Padinjarethara [6782]	SHAROY RESORT	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	SILVERGREEN RESORTS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	SPELLWAY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	STADIUM KUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	TEACHERMUKKU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	TERACE RESORT	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	THAZHAKANDY USS	81.0	0.0	4.0	77.0	95.1	Very High
WAYANAD	Padinjarethara [6782]	THAZHAYIDAM	81.0	0.0	9.5	71.5	88.3	Very High
WAYANAD	Padinjarethara [6782]	THENGUMUNDA	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	THOTTOLIPADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	UTHIRAMCHERY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	VALARAMKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	VALIYANARIPARA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Padinjarethara [6782]	VARAMBETTA	81.0	0.0	23.0	58.0	71.6	High
WAYANAD	Padinjarethara [6782]	VEETTIKKAMoola	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Padinjarethara [6782]	VYPADI	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Padinjarethara [6782]	VYSALI	81.0	0.0	9.7	71.3	88.0	Very High
WAYANAD	Panamaram [6590]	5 TH AVENUE	202.0	0.0	31.0	171.0	84.7	Very High
WAYANAD	Panamaram [6590]	5TH MILE BSNL	129.0	0.0	19.0	110.0	85.3	Very High
WAYANAD	Panamaram [6590]	5TH MILE PETROL PUMP	81.0	5.0	33.0	43.0	53.1	High
WAYANAD	Panamaram [6590]	6TH MILE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	7 TH MILE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	ALUMoola	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	ALUNKA THAZHE	81.0	0.0	22.7	58.3	72.0	High
WAYANAD	Panamaram [6590]	AMALANAGAR TOWN	129.0	0.0	18.0	111.0	86.0	Very High
WAYANAD	Panamaram [6590]	AMMANI	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Panamaram [6590]	AMMANI VAYAL	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Panamaram [6590]	ANAKKUZHI	81.0	4.0	4.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	ANAPPARA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	ANCHUKUNNU TOWN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	APPANKAVALA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	ARIYANNOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	ARUMOTTANKUNNU	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Panamaram [6590]	CHANDANAKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	CHEENGODE	81.0	5.0	22.0	54.0	66.7	High
WAYANAD	Panamaram [6590]	CHEENGODE KWA	129.0	0.0	6.0	123.0	95.3	Very High
WAYANAD	Panamaram [6590]	CHEENGODE TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	CHERUKATTOOR TOWN	81.0	4.0	19.0	58.0	71.6	High
WAYANAD	Panamaram [6590]	CHERUKATTOOR VEETTICHODE	81.0	0.0	22.0	59.0	72.8	High
WAYANAD	Panamaram [6590]	CHERYEMKOLLY BRIDGE	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Panamaram [6590]	CHITTALOORKUNNU	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	CHUNDAKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	CLUB CENTER	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	CRESCENT SCHOOL	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	DASANAKKARA	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Panamaram [6590]	DOCTER PADI	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Panamaram [6590]	EDATHAMKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	ENTE VEEDU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	ERANALLOOR	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Panamaram [6590]	ERATTAMUNDA	81.0	0.0	20.0	61.0	75.3	Very High
WAYANAD	Panamaram [6590]	ETTUKAYAM	81.0	3.0	3.0	75.0	92.6	Very High
WAYANAD	Panamaram [6590]	HARITHAGIRI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	I P P	81.0	0.0	23.0	58.0	71.6	High
WAYANAD	Panamaram [6590]	KAIPATTUKUNNU	129.0	0.0	3.5	125.5	97.3	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Panamaram [6590]	KAITHAKKAL	81.0	0.0	13.0	68.0	83.9	Very High
WAYANAD	Panamaram [6590]	KAITHAKKAL DIPPO	81.0	3.0	3.0	75.0	92.6	Very High
WAYANAD	Panamaram [6590]	KAKKANCHIRA	81.0	0.0	24.2	56.8	70.1	High
WAYANAD	Panamaram [6590]	KALLUVAYAL	81.0	0.0	7.7	73.3	90.5	Very High
WAYANAD	Panamaram [6590]	KANNADIMUKKU	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	KAPPAMCHAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	KAPPAMKUNNU-DOCTOR PADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	KAPPUMKUNNU SCHOOL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Panamaram [6590]	KARAKKAMALA COFFIE MILL	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	KARAKKAMALA GLASS	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Panamaram [6590]	KARAKKAMALA WOOD MILL	81.0	0.0	7.0	74.0	91.4	Very High
WAYANAD	Panamaram [6590]	KARATTUKUNNU	202.0	0.0	3.4	198.6	98.3	Very High
WAYANAD	Panamaram [6590]	KARIMBUMMAL	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Panamaram [6590]	KARIMBUMMAL MILL	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Panamaram [6590]	KARIMUMKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	KATTADI KAVALA	81.0	3.0	9.0	69.0	85.2	Very High
WAYANAD	Panamaram [6590]	KATTICHIRAKKAL	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Panamaram [6590]	KAVADAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	KAVADAM TEMPLE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	KAYAKKUNNU	81.0	0.0	13.3	67.7	83.6	Very High
WAYANAD	Panamaram [6590]	KEENJHUKADAVU	81.0	3.0	3.0	75.0	92.6	Very High
WAYANAD	Panamaram [6590]	KELLOOR	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Panamaram [6590]	KOLATHARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	KOODAMMADI POYIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	KOOLIVAYAL	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Panamaram [6590]	KRISHNAMoola	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	KRISHNAMoola ROAD	81.0	3.0	12.5	65.5	80.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Panamaram [6590]	KSFE PANAMARAM	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Panamaram [6590]	KUNDALA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	KUNDALA MILL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	KUNDALA-IDEAL MILL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	KURISSUMTHOTTY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	LAKSHMI COLONY	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Panamaram [6590]	MANAL VAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	MANCHERI PARAKKUNI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	MANJAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	MANKANI	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Panamaram [6590]	MATHAMKODE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	MATHISSERI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	MATHOOR	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	MATHOOR KWA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	MATHOTHUPOLIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	MAYYAMBAVU	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	MILMA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	MOKKAM	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	MOOLAKKARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	NADAVAYAL CHURCH	81.0	25.0	34.9	21.1	26.0	Medium
WAYANAD	Panamaram [6590]	NADAVAYAL MALL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	NADAVAYAL SCHOOL	81.0	0.0	28.7	52.3	64.5	High
WAYANAD	Panamaram [6590]	NADAVAYAL TOWN	81.0	0.0	17.3	63.7	78.6	Very High
WAYANAD	Panamaram [6590]	NEERATTADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	NEERATTADI KWA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Panamaram [6590]	NEERATTADI POIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	NEERATTADI RIVER	81.0	0.0	10.0	71.0	87.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Panamaram [6590]	NEERVARAM BRIDGE	129.0	0.0	6.0	123.0	95.3	Very High
WAYANAD	Panamaram [6590]	NEERVARAM KWA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	NEERVARAM TOWN	81.0	0.0	18.0	63.0	77.8	Very High
WAYANAD	Panamaram [6590]	NELLIYAMBAM AYURVEDA	81.0	3.0	3.4	74.6	92.1	Very High
WAYANAD	Panamaram [6590]	NELLIYAMBAM CHOYIKOLLY	121.0	0.0	7.0	114.0	94.2	Very High
WAYANAD	Panamaram [6590]	NELLIYAMBAM TOWER	81.0	5.0	8.0	68.0	84.0	Very High
WAYANAD	Panamaram [6590]	NEYKUKUPPA AKG	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	NEYKUPPA BRIDGE	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Panamaram [6590]	NEYKUPPA FOREST	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	ODAKOLLY-KOTTA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	OSHANA BHAVAN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	PADIKKAM VAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	PADIKKUNNU	81.0	0.0	17.0	64.0	79.0	Very High
WAYANAD	Panamaram [6590]	PALACHAL	81.0	0.0	39.0	42.0	51.9	High
WAYANAD	Panamaram [6590]	PALAMANDAPAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	PALLIMUKKU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	PALUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	PANAMARAM BRIDGE	81.0	0.0	19.0	62.0	76.5	Very High
WAYANAD	Panamaram [6590]	PANAMARAM BSNL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	PANAMARAM HOSPITAL	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Panamaram [6590]	PANAMARAM TOWN	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Panamaram [6590]	PANAMARAM-VIJAYACOLLEGE	81.0	3.0	11.0	67.0	82.7	Very High
WAYANAD	Panamaram [6590]	PARAKKUNI	121.0	3.0	3.0	115.0	95.0	Very High
WAYANAD	Panamaram [6590]	PARIYARAM	81.0	0.0	7.7	73.3	90.5	Very High
WAYANAD	Panamaram [6590]	PARIYARAM VAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	PATHIRIYAMBAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	PAYANCHERIKUNNU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Panamaram [6590]	PAYMOOLA	81.0	0.0	7.0	74.0	91.4	Very High
WAYANAD	Panamaram [6590]	PORLOTH BUILDING	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	PULIKKALKAVALA	81.0	0.0	15.2	65.8	81.2	Very High
WAYANAD	Panamaram [6590]	PUNCHAKUNNU TOWER	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	PUNCHAVAYAL TOWN	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	PUNCHVAYAL MILL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	SBI PANAMARAM	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	URALUKUNNU	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Panamaram [6590]	VADOCHAL	81.0	5.0	14.8	61.2	75.6	Very High
WAYANAD	Panamaram [6590]	VAZHAMBADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	VEETTIPURA	81.0	0.0	9.4	71.6	88.3	Very High
WAYANAD	Panamaram [6590]	VELLARIVAYAL	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Panamaram [6590]	VELUKKARAKUNNU	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Panamaram [6590]	VIKKALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Panamaram [6590]	VILAMBUKANDAM	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Panamaram [6590]	VILAMBUKANDAM KWA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Panamaram [6590]	VILAMBUKANDAM TOWER	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Pulpally [6594]	17 ACRE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	73 KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	ADIKOLLY	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Pulpally [6594]	AGRO CLINIC KURICHIPPATTA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	ALOORKUNNU	81.0	0.0	24.0	57.0	70.4	High
WAYANAD	Pulpally [6594]	ALOORKUNNU-II	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Pulpally [6594]	AMARAKKUNI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	AMBATHARU-56	81.0	5.0	13.0	63.0	77.8	Very High
WAYANAD	Pulpally [6594]	AMRUTHA SCHOOL	81.0	0.0	24.0	57.0	70.4	High
WAYANAD	Pulpally [6594]	ANANTHAPURAM	81.0	3.0	11.0	67.0	82.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Pulpally [6594]	ANAPPARA	129.0	5.0	14.0	110.0	85.3	Very High
WAYANAD	Pulpally [6594]	ANGADICHERY	81.0	0.0	20.0	61.0	75.3	Very High
WAYANAD	Pulpally [6594]	ANUPAMA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Pulpally [6594]	ATHIRATTUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	ATHIRATTUKUNNU KWA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	BASAVANKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	BLUE MOON	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	CHAINDHA	81.0	0.0	20.7	60.3	74.4	High
WAYANAD	Pulpally [6594]	CHATHAMANGALAMKUNNU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Pulpally [6594]	CHATHANKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	CHEEYAMBAM 73	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	CHEEYAMBAM VALAVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	CHEKADI	81.0	0.0	8.5	72.5	89.5	Very High
WAYANAD	Pulpally [6594]	CHEPPILA	81.0	11.0	5.0	65.0	80.2	Very High
WAYANAD	Pulpally [6594]	CHERIYAMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	CHETTAPALAM I	129.0	4.0	11.4	113.6	88.0	Very High
WAYANAD	Pulpally [6594]	CHETTIPAMBRA	81.0	0.0	7.0	74.0	91.4	Very High
WAYANAD	Pulpally [6594]	CHILLING PLANT	81.0	0.0	20.0	61.0	75.3	Very High
WAYANAD	Pulpally [6594]	CHUNDAKOLLY	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Pulpally [6594]	CRYSTAL KURUVA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Pulpally [6594]	DEVARGHADHA	81.0	0.0	8.5	72.5	89.5	Very High
WAYANAD	Pulpally [6594]	DEVI TEMPLE	81.0	20.0	41.3	19.7	24.3	Low
WAYANAD	Pulpally [6594]	EAST AVENUE	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Pulpally [6594]	ELLAKOLLY	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Pulpally [6594]	ERIYAPALLY	81.0	0.0	65.0	16.0	19.8	Low
WAYANAD	Pulpally [6594]	ERIYAPPALLI RATIONSHOP	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	ESSAR PUMP	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Pulpally [6594]	IRULAM FOREST	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	IRULAM MILL	81.0	0.0	21.0	60.0	74.1	High
WAYANAD	Pulpally [6594]	IRULAM TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	KALANADIKKOLLY	81.0	5.0	31.0	45.0	55.6	High
WAYANAD	Pulpally [6594]	KALLONIKUNNU	81.0	0.0	20.0	61.0	75.3	Very High
WAYANAD	Pulpally [6594]	KALLUVAYAL I	81.0	5.0	31.0	45.0	55.6	High
WAYANAD	Pulpally [6594]	KALLUVAYAL-II	81.0	6.0	23.0	52.0	64.2	High
WAYANAD	Pulpally [6594]	KANDAMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	KANNARAMPUZHA	81.0	3.0	25.0	53.0	65.4	High
WAYANAD	Pulpally [6594]	KAPPISET	81.0	5.0	0.0	76.0	93.8	Very High
WAYANAD	Pulpally [6594]	KELAKAVALA	81.0	0.0	39.7	41.3	51.0	High
WAYANAD	Pulpally [6594]	KOLARATTUKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	KOONAMTHEKKU	81.0	0.0	40.0	41.0	50.6	High
WAYANAD	Pulpally [6594]	KOTTAKOLLY	81.0	6.0	3.0	72.0	88.9	Very High
WAYANAD	Pulpally [6594]	KOTTAVAYAL	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Pulpally [6594]	KULATHOOR	81.0	0.0	18.0	63.0	77.8	Very High
WAYANAD	Pulpally [6594]	KUNDUVADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	KURICHIPATTA I	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Pulpally [6594]	KURICHIPATTA-II	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	KURISU PALLI TRANSFORMER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	MADAPARAMBA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	MANALVAYAL I	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	MANALVAYAL-II	20.0	0.0	8.0	12.0	60.0	High
WAYANAD	Pulpally [6594]	MANIVAYAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Pulpally [6594]	MARAKAVU	81.0	0.0	20.9	60.1	74.2	High
WAYANAD	Pulpally [6594]	MARAPPAN MOOLA	81.0	0.0	54.4	26.6	32.8	Medium
WAYANAD	Pulpally [6594]	MARIYA	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Pulpally [6594]	MARIYA BAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	MARIYANAD	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Pulpally [6594]	MATHAMANGALAM ANGANVADY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	MATHAMANGALAM RESORT	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	MATHAMANGALAM TOWER	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Pulpally [6594]	MEENAMKOLLY	81.0	0.0	17.0	64.0	79.0	Very High
WAYANAD	Pulpally [6594]	MLA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Pulpally [6594]	MOOZHIMALA	81.0	0.0	23.0	58.0	71.6	High
WAYANAD	Pulpally [6594]	MOOZHIMALA TOWER	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Pulpally [6594]	NARIVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	PAKKAM-I	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	PAKKAM-II	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Pulpally [6594]	PALAMOOOLA	81.0	0.0	26.4	54.6	67.4	High
WAYANAD	Pulpally [6594]	PALLICHIRA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	PANNIKKAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	PAROTTIKAVALA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Pulpally [6594]	PENTA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	PHC	81.0	0.0	11.3	69.7	86.0	Very High
WAYANAD	Pulpally [6594]	POLICE STATION	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	PRC I	81.0	10.0	37.8	33.2	41.0	Medium
WAYANAD	Pulpally [6594]	PRC-II	81.0	0.0	75.0	6.0	7.4	Very Low
WAYANAD	Pulpally [6594]	SHED	81.0	3.0	30.0	48.0	59.3	High
WAYANAD	Pulpally [6594]	ST GEORGE	81.0	0.0	20.7	60.3	74.5	High
WAYANAD	Pulpally [6594]	THANNITHERUVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	THAZHECHETTAPALAM	81.0	8.0	31.0	42.0	51.8	High
WAYANAD	Pulpally [6594]	THAZHEYANGADI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Pulpally [6594]	THAZHEYANGADI MILL	81.0	0.0	10.0	71.0	87.7	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Pulpally [6594]	THENGUMUDUKUNNU	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Pulpally [6594]	THOOPRA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	THOOTHILERY	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Pulpally [6594]	UDAYA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	VALIYAKURISSU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	VELIYAMBAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	VELUKOLLY	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Pulpally [6594]	VETTATHUR	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Pulpally [6594]	VIJAYA	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Pulpally [6594]	VIMALA MARY	81.0	8.0	40.2	32.8	40.5	Medium
WAYANAD	Pulpally [6594]	WAYANAD RICE MILLS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Pulpally [6594]	WYN JUNGLE BAY	129.0	0.0	15.0	114.0	88.4	Very High
WAYANAD	Sultan Bathery West [6720]	5TH MILE	81.0	0.0	14.5	66.5	82.1	Very High
WAYANAD	Sultan Bathery West [6720]	A E TOWER	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	AALINCHUVADU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	AANAVEEDU	81.0	0.0	23.0	58.0	71.6	High
WAYANAD	Sultan Bathery West [6720]	AAVAYAL	81.0	2.0	16.0	63.0	77.8	Very High
WAYANAD	Sultan Bathery West [6720]	AISWARYA INDOOR	405.0	0.0	100.0	305.0	75.3	Very High
WAYANAD	Sultan Bathery West [6720]	AMMAYIPPALAM	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Sultan Bathery West [6720]	ARIMANI	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery West [6720]	ARIVAYAL CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	ASSUMPTION	202.0	5.0	14.8	182.2	90.2	Very High
WAYANAD	Sultan Bathery West [6720]	ASSUMSSION DI ADICTION	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	AURIA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	AUTO MECH	81.0	0.0	65.9	15.1	18.6	Low
WAYANAD	Sultan Bathery West [6720]	AXIS BANK	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	BEENACHI -ANGANVADI	81.0	0.0	36.0	45.0	55.6	High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery West [6720]	BEENACHI SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	BHOODANAM FRANKLIN	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery West [6720]	BLUE STAR COFFEE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	C C FOREST OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	CC - SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	CC - TOWN	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery West [6720]	CC PRAKRITHI GRAMAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	CHAPPAKOLLY	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Sultan Bathery West [6720]	CHECK DAM-POOTHIKKAD	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery West [6720]	CHEMBUMKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	CHERUMAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	CHETTIMOOLA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery West [6720]	CHINGLI AMMAYIPALAM BRICK	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	CHOLAS COFFE	81.0	0.0	3.7	77.3	95.4	Very High
WAYANAD	Sultan Bathery West [6720]	CHOORIMALA	81.0	2.0	40.0	39.0	48.1	Medium
WAYANAD	Sultan Bathery West [6720]	CHULLIYODE	129.0	0.0	5.0	124.0	96.1	Very High
WAYANAD	Sultan Bathery West [6720]	CHULLIYODE PHC	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	CITYCENTRE	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	DHOTTAPPANKULAM	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Sultan Bathery West [6720]	E-PLANET	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	EDAKKAD	129.0	0.0	10.0	119.0	92.2	Very High
WAYANAD	Sultan Bathery West [6720]	FEDERAL BANK	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	GALERIYA BEENACHI	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	GANESHAPURAM	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery West [6720]	GAS-PUMP	81.0	0.0	12.8	68.2	84.1	Very High
WAYANAD	Sultan Bathery West [6720]	GRANT AK TOWER	255.0	0.0	0.0	255.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	HAPPY 7 DAYS	129.0	0.0	0.0	129.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery West [6720]	HDFC	81.0	0.0	18.0	63.0	77.8	Very High
WAYANAD	Sultan Bathery West [6720]	JUBILEE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	K T TOWER	129.0	4.5	33.9	90.6	70.2	High
WAYANAD	Sultan Bathery West [6720]	KABANI	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery West [6720]	KABANI -COFFEE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KAIPENCHERY	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Sultan Bathery West [6720]	KAIVATTAMoola	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Sultan Bathery West [6720]	KAKKADAM KUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KALLINKARA	81.0	0.0	5.2	75.8	93.6	Very High
WAYANAD	Sultan Bathery West [6720]	KALLOORKUNNU	81.0	0.0	16.0	65.0	80.2	Very High
WAYANAD	Sultan Bathery West [6720]	KALLUMUKKU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KALLUVAYAL	202.0	0.0	18.0	184.0	91.1	Very High
WAYANAD	Sultan Bathery West [6720]	KALLUVAYAL COLONEY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KALPANA ESTATE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KANYAKA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KARADI MOOLA	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Sultan Bathery West [6720]	KATTAYAD	81.0	0.0	18.9	62.1	76.7	Very High
WAYANAD	Sultan Bathery West [6720]	KATTAYAD -ANGANVADI	81.0	5.0	5.0	71.0	87.7	Very High
WAYANAD	Sultan Bathery West [6720]	KAZHAMBU	81.0	0.0	4.0	77.0	95.1	Very High
WAYANAD	Sultan Bathery West [6720]	KOLAGAPPARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KOLIMOOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KOLIYADI -KRISHIBHAVAN	129.0	5.0	8.0	116.0	89.9	Very High
WAYANAD	Sultan Bathery West [6720]	KOLIYADI ICE	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery West [6720]	KOODALLOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KOTTAYIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KOZHUVANA -SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KTDC PEPPER GROVE	81.0	3.0	6.0	72.0	88.9	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery West [6720]	KUNNATH ANCOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KUNTHANI	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Sultan Bathery West [6720]	KUPPAMUDI	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Sultan Bathery West [6720]	KURUKKAN KUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	KWA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	LIC	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MAANIVAYAL	81.0	0.0	3.3	77.7	95.9	Very High
WAYANAD	Sultan Bathery West [6720]	MADAKKARA -VILLAGE	81.0	0.0	7.0	74.0	91.4	Very High
WAYANAD	Sultan Bathery West [6720]	MADAKKARA-TOWN	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery West [6720]	MADOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MADOOR KAVALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MADOORKUNNU	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MAITHANIKUNNU	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Sultan Bathery West [6720]	MALABAR GOLD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MALANKARA	81.0	0.0	21.0	60.0	74.1	High
WAYANAD	Sultan Bathery West [6720]	MALANKARA -KURISH	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MALAVAYAL	81.0	5.0	8.0	68.0	84.0	Very High
WAYANAD	Sultan Bathery West [6720]	MANDOKARA	81.0	5.0	15.0	61.0	75.3	Very High
WAYANAD	Sultan Bathery West [6720]	MANGALAM	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Sultan Bathery West [6720]	MANGALAM CARP	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MANGALAMCARP ESTATE	81.0	0.0	67.0	14.0	17.3	Low
WAYANAD	Sultan Bathery West [6720]	MANICHIRA	129.0	0.0	9.0	120.0	93.0	Very High
WAYANAD	Sultan Bathery West [6720]	MANISWAMI	81.0	2.0	17.0	62.0	76.5	Very High
WAYANAD	Sultan Bathery West [6720]	MANJADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MANJAKKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MANTHAMKOLLY	81.0	0.0	9.8	71.2	87.9	Very High
WAYANAD	Sultan Bathery West [6720]	MARIYAMMAN	81.0	0.0	60.0	21.0	25.9	Medium

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery West [6720]	MATHOORPALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MAVADI	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Sultan Bathery West [6720]	MAVADIVAYAL	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MEKKADAN	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MOODAKKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	MSMIM -CONVENT	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery West [6720]	MUNCIPALITY	129.0	0.0	25.9	103.1	79.9	Very High
WAYANAD	Sultan Bathery West [6720]	MUNDAKKAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	NADEERA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	NAMBEESAN -KAVALA	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Sultan Bathery West [6720]	NEXUS ARCADE	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	NOOLAKKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	NORTH MANICHIRA	81.0	0.0	31.0	50.0	61.7	High
WAYANAD	Sultan Bathery West [6720]	P K TOWER	255.0	0.0	0.0	255.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	PADIKKOLLY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	PADIYERI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	PALAKKUNI	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery West [6720]	PALAKKUTTY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	PALLIKANDY	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Sultan Bathery West [6720]	PAMBUMKUNI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery West [6720]	PATHROSE A E	81.0	0.0	6.7	74.3	91.7	Very High
WAYANAD	Sultan Bathery West [6720]	PAZHAMPALLI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	PAZHUPATHOOR SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	PAZHUPPATHOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	PLAZA	81.0	0.0	77.0	4.0	4.9	Very Low
WAYANAD	Sultan Bathery West [6720]	POOMALA	81.0	0.0	28.0	53.0	65.4	High
WAYANAD	Sultan Bathery West [6720]	POOTHIKAD RGGY	20.0	0.0	0.0	20.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery West [6720]	POOTHIKADU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	POST OFFICE	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	PULINCHAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	PULLUMALA	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery West [6720]	PUNCHAVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	RAMPALLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	RESORT	81.0	0.0	56.0	25.0	30.9	Medium
WAYANAD	Sultan Bathery West [6720]	ROCKVALLEY	81.0	0.0	45.8	35.2	43.5	Medium
WAYANAD	Sultan Bathery West [6720]	ROYAL GALLERY	324.0	0.0	0.0	324.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	SAKATHI	81.0	0.0	19.9	61.1	75.5	Very High
WAYANAD	Sultan Bathery West [6720]	SAN GEORGIA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	SHEELISATCH	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	SN PURAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	SOAP FACTORY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	T V A KALLUVAYAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	THALLOOR	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery West [6720]	THALLOOR CHIRA	81.0	5.0	21.2	54.8	67.6	High
WAYANAD	Sultan Bathery West [6720]	THANNIVAYAL	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	THAZHATHANGADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	THOVARIMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	TP INSPIRE	162.0	0.0	0.0	162.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	TRAFFIC JUNCTION	129.0	0.0	20.0	109.0	84.5	Very High
WAYANAD	Sultan Bathery West [6720]	UAR PLASTIC	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	VADAKARA MUKKU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	VAKERY	81.0	0.0	36.0	45.0	55.5	High
WAYANAD	Sultan Bathery West [6720]	VAKERY SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	VALLEY	81.0	0.0	15.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery West [6720]	VATTATHIMOOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	VELLACHAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery West [6720]	VINAYAKA	129.0	0.0	25.0	104.0	80.6	Very High
WAYANAD	Sultan Bathery West [6720]	VINAYAKA NURSING COLLEGE	81.0	0.0	80.0	1.0	1.2	Very Low
WAYANAD	Sultan Bathery [6592]	AISWARIYA	129.0	0.0	5.0	124.0	96.1	Very High
WAYANAD	Sultan Bathery [6592]	AJS AGENCY BLOCK OFFICE-DS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	ALFA	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	AMARAMBAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	ARMAD	81.0	0.0	19.3	61.7	76.2	Very High
WAYANAD	Sultan Bathery [6592]	ASHRAMAM	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	BENNY PAUL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	BHIMA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	BLOCK OFFICE	81.0	0.0	19.0	62.0	76.5	Very High
WAYANAD	Sultan Bathery [6592]	C G MILL	81.0	0.0	17.0	64.0	79.0	Very High
WAYANAD	Sultan Bathery [6592]	CHEERAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	CHEERAL SCHOOL	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery [6592]	CHEERAL VILLAGE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	CHEMBAKAPPALY	81.0	0.0	12.4	68.6	84.6	Very High
WAYANAD	Sultan Bathery [6592]	CHETHALAYAM	129.0	3.4	12.0	113.6	88.1	Very High
WAYANAD	Sultan Bathery [6592]	CHETHALAYAM 6TH MILE	81.0	0.0	7.5	73.5	90.7	Very High
WAYANAD	Sultan Bathery [6592]	CHETHALAYAM TOWER	81.0	3.0	0.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	CHIRAKKAMBAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	CHUNDAKKARA	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	DONBOSCO	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Sultan Bathery [6592]	E CHARGING KAIPANCHERY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	E CHARGING MUTHANGA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	E CHARGING THIRUNELLY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery [6592]	EDACHILADI	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Sultan Bathery [6592]	FAIR LAND TOWER	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Sultan Bathery [6592]	FAIRLAND HOSPITAL	81.0	0.0	8.0	73.0	90.1	Very High
WAYANAD	Sultan Bathery [6592]	FOREIGN KAVALA	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Sultan Bathery [6592]	FOREST KUPPADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	FUEL BRIQUETTE	81.0	0.0	14.5	66.5	82.1	Very High
WAYANAD	Sultan Bathery [6592]	GOLDEN COFFEE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	GUEST HOUSE	81.0	0.0	27.0	54.0	66.7	High
WAYANAD	Sultan Bathery [6592]	HEALTH WAVE SULTHAN BATHERY	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	J T S	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KADAMBAKAD	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KAIPANCHERY	81.0	0.0	28.0	53.0	65.4	High
WAYANAD	Sultan Bathery [6592]	KALANKANDY	81.0	0.0	3.3	77.7	95.9	Very High
WAYANAD	Sultan Bathery [6592]	KALANOORKUNNU	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Sultan Bathery [6592]	KALLOOR	81.0	3.0	33.3	44.7	55.2	High
WAYANAD	Sultan Bathery [6592]	KALLOR BSNL TOWER	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Sultan Bathery [6592]	KALLUMUKKU	81.0	0.0	6.7	74.3	91.7	Very High
WAYANAD	Sultan Bathery [6592]	KALLUMUKKU TOWER	81.0	0.0	7.7	73.3	90.5	Very High
WAYANAD	Sultan Bathery [6592]	KAMBAKODI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KANNANGODE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	KAPPISTORE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	KARAPOOTHADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KARASSERY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KARINKALIKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KARIPOOR TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KARUVALLIKKUNNU	81.0	8.0	6.0	67.0	82.7	Very High
WAYANAD	Sultan Bathery [6592]	KARUVALLIKUNNU RATION SHOP	81.0	0.0	8.0	73.0	90.1	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery [6592]	KKM VILLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KODATHIPADY	81.0	0.0	10.9	70.1	86.6	Very High
WAYANAD	Sultan Bathery [6592]	KOLOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KOTTANODE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KSRTC	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KUDUKKI	81.0	0.0	26.7	54.3	67.0	High
WAYANAD	Sultan Bathery [6592]	KUMIZHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KUMIZHI VALATTUMoola	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KUNDOOR KAPPAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	KUPPADI SCHOOL	81.0	0.0	42.0	39.0	48.1	Medium
WAYANAD	Sultan Bathery [6592]	KUPPADY TOWER	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Sultan Bathery [6592]	LE EDEN PALLIPPADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	LE SAPHARE	129.0	0.0	90.0	39.0	30.2	Medium
WAYANAD	Sultan Bathery [6592]	MAKKUTTY	129.0	0.0	8.0	121.0	93.8	Very High
WAYANAD	Sultan Bathery [6592]	MAKKUTTY COLONEL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MAKKUTTY PUMP	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	MANIMUDA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MANMADAMoola	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Sultan Bathery [6592]	MANOORKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MARODE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MARUTHI	129.0	0.0	20.0	109.0	84.5	Very High
WAYANAD	Sultan Bathery [6592]	MATHAMANGALAM	81.0	0.0	10.0	71.0	87.7	Very High
WAYANAD	Sultan Bathery [6592]	MEERA POLYCLINIC	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MELE PUTHANKUNNU	81.0	0.0	16.5	64.5	79.7	Very High
WAYANAD	Sultan Bathery [6592]	MERCYDAZ	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MESTHIRI JUNCTION	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Sultan Bathery [6592]	MINI CIVIL STATION	81.0	0.0	13.0	68.0	84.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery [6592]	MINI INDUSTRIAL	202.0	0.0	29.1	172.9	85.6	Very High
WAYANAD	Sultan Bathery [6592]	MINT MALL LT INDOOR	510.0	0.0	0.0	510.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MLA	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Sultan Bathery [6592]	MOOLANKAV SCHOOL	81.0	0.0	33.0	48.0	59.3	High
WAYANAD	Sultan Bathery [6592]	MOOLANKAV TOWER	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Sultan Bathery [6592]	MUNDAKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MUTHANGA FOREST	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MUTHANGA MOSQUE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	MYKKARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	NAGARAMCHAL	81.0	0.0	29.0	52.0	64.2	High
WAYANAD	Sultan Bathery [6592]	NAIKETTY	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Sultan Bathery [6592]	NAMBIARKUNNU	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	NAMBIARKUNNU KALLOOR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	NAMBIARKUNNU POST OFFICE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	NAMBIKOLLY	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Sultan Bathery [6592]	NENMENIKKUNNU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	NENMENIKUNNU TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	NIRAPPAM	81.0	0.0	15.3	65.7	81.1	Very High
WAYANAD	Sultan Bathery [6592]	NIRAPPAM PHC INDOOR	81.0	0.0	40.0	41.0	50.6	High
WAYANAD	Sultan Bathery [6592]	NOOLPUZHA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	NRS	202.0	0.0	0.0	202.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	ODAPPALLAM	81.0	0.0	11.0	70.0	86.4	Very High
WAYANAD	Sultan Bathery [6592]	OTTATHEKKU	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	P AND T	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	PACHADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PALAKKARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PALLIVAYAL RGGVY	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery [6592]	PALLIVAYAL TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PANAYAMBAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PANICKERPADI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	PAUL AND MERCY TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PAZHERI	81.0	0.0	13.2	67.8	83.7	Very High
WAYANAD	Sultan Bathery [6592]	PAZHOOR SCHOOL	81.0	0.0	3.7	77.3	95.4	Very High
WAYANAD	Sultan Bathery [6592]	PAZHOOR TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PEPPER YARD 4 TH MILE	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PILAKAVE 1	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PILAKAVE 2	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PITCO NAIKETTY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	PLATINUM CENTRE	255.0	0.0	0.0	255.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	POLICE STATION	129.0	0.0	11.5	117.5	91.1	Very High
WAYANAD	Sultan Bathery [6592]	PONKUZHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	POOJAKOOTTAM	81.0	0.0	4.0	77.0	95.1	Very High
WAYANAD	Sultan Bathery [6592]	POOLAKUNDU	51.0	0.0	8.0	43.0	84.3	Very High
WAYANAD	Sultan Bathery [6592]	POOLAVAYAL	81.0	0.0	33.0	48.0	59.3	High
WAYANAD	Sultan Bathery [6592]	POST OFFICE KUPPADY	81.0	0.0	11.6	69.4	85.6	Very High
WAYANAD	Sultan Bathery [6592]	PRETHEEKSHA	81.0	0.0	31.7	49.3	60.9	High
WAYANAD	Sultan Bathery [6592]	PRIYA	202.0	0.0	16.7	185.3	91.7	Very High
WAYANAD	Sultan Bathery [6592]	PUTHANCHIRAKUNNU	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Sultan Bathery [6592]	PUTHENKUNNU	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Sultan Bathery [6592]	PUTHUCHOLA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	R T O	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	RAHMATH NAGAR	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	RAIN DROPS NAMBIKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	RAJEEV GANDHI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery [6592]	ROYAL SIUTE INDOOR	162.0	0.0	0.0	162.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	SAGAR	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Sultan Bathery [6592]	SAHYADRI OILS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	SANDAL OIL	51.0	0.0	3.0	48.0	94.1	Very High
WAYANAD	Sultan Bathery [6592]	SANTHINAGAR	81.0	0.0	29.6	51.5	63.5	High
WAYANAD	Sultan Bathery [6592]	SANU PAUL -KAIPPANCHERY ROAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	SETCOS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	ST JOSEPH SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	ST MARYS COLLEGE	81.0	0.0	10.2	70.8	87.5	Very High
WAYANAD	Sultan Bathery [6592]	ST MARYS KUPPADI	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Sultan Bathery [6592]	SUBSTATION	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	SWATHANDRA MAIDANI	129.0	0.0	23.0	106.0	82.2	Very High
WAYANAD	Sultan Bathery [6592]	THAKARAPPADY	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Sultan Bathery [6592]	THELAMPATTA	81.0	0.0	38.1	42.9	53.0	High
WAYANAD	Sultan Bathery [6592]	THELAMPATTA SAMSKARIKANILAY AM	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Sultan Bathery [6592]	THELEMPETTA MILL	81.0	6.0	20.9	54.1	66.8	High
WAYANAD	Sultan Bathery [6592]	THERVAYAL	81.0	8.0	18.5	54.5	67.3	High
WAYANAD	Sultan Bathery [6592]	THIRUNELLY	129.0	0.0	21.2	107.8	83.6	Very High
WAYANAD	Sultan Bathery [6592]	THIRUNELLY HOUSING COLONY	81.0	0.0	55.2	25.8	31.8	Medium
WAYANAD	Sultan Bathery [6592]	THOTTAMOOLA	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Sultan Bathery [6592]	THUDUVATTY	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	TKH ARCADE	129.0	0.0	10.0	119.0	92.2	Very High
WAYANAD	Sultan Bathery [6592]	VADACHIRA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Sultan Bathery [6592]	VADAKKANAD	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	VADAKKANAD SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	VALANCHERI	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Sultan Bathery [6592]	VALLUVADI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	VALLUVADI KOLATHOORKAVALA	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Sultan Bathery [6592]	VATTILI	81.0	0.0	11.5	69.5	85.8	Very High
WAYANAD	Sultan Bathery [6592]	VATTUVADY	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Sultan Bathery [6592]	VEETTIKUTTY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	VENDOLE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	VENGOOR	81.0	0.0	3.4	77.6	95.8	Very High
WAYANAD	Sultan Bathery [6592]	VENGOOR PHC	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	VIPANCHIKA	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Sultan Bathery [6592]	WOODS RESORT	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Thavinhal [6719]	37TH MILE	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhal [6719]	8TH NO PAADY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	AK COFFEE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	AK TEA	51.0	0.0	3.0	48.0	94.1	Very High
WAYANAD	Thavinhal [6719]	ALATTIL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	ALATTIL SUVALA KAVALA	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Thavinhal [6719]	AROLA	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Thavinhal [6719]	ASHIYANA GREENS	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhal [6719]	AYANIKKAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	BAVALI FARMS	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	BOYS TOWN GLENLEVEN	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	CHEMBAKAMoola	81.0	0.0	11.3	69.7	86.0	Very High
WAYANAD	Thavinhal [6719]	CHIRAKARA BUNGLOW	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	CHOIMOOLA	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhal [6719]	CHULLI RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhal [6719]	CHUNGAM	81.0	0.0	20.3	60.7	74.9	High
WAYANAD	Thavinhal [6719]	COFFEE BOARD	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Thavinhall [6719]	EDALAKUNI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	EDAMANA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhall [6719]	EDATHANA	81.0	0.0	25.0	56.0	69.1	High
WAYANAD	Thavinhall [6719]	ENGINEERING COLLAGE QUARTERS	405.0	0.0	0.0	405.0	100.0	Very High
WAYANAD	Thavinhall [6719]	ENGINEERING COLLEGE	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhall [6719]	GOTHAVERY 4	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	GOTHAVERY-1	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	GOTHAVERY-2	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	GOTHAVERY-3	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	GREEN WOOD	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	HARILAND	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	IDIKKARA	81.0	8.0	9.0	64.0	79.0	Very High
WAYANAD	Thavinhall [6719]	INDUS TOWER S VALAVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	INTERLOCK	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhall [6719]	JOSEKAVALA	129.0	3.0	3.0	123.0	95.3	Very High
WAYANAD	Thavinhall [6719]	KAITHAKOLLY RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	KAMBAMALA RGGY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	KAMBETTY	81.0	10.0	12.0	59.0	72.8	High
WAYANAD	Thavinhall [6719]	KAMPIPALAM	81.0	3.0	9.0	69.0	85.2	Very High
WAYANAD	Thavinhall [6719]	KANDATHAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	KANNOTHMALA	81.0	0.0	6.9	74.1	91.5	Very High
WAYANAD	Thavinhall [6719]	KAPPATTUMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	KAPPATTUMALA TOWER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	KAPPIKALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	KAPPIKALAM-KWA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	KARAKULATHINKARA	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Thavinhal [6719]	KARAMKOTTU RGGVY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhal [6719]	KARIMANI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	KATTERIKUNNU	81.0	0.0	7.0	74.0	91.4	Very High
WAYANAD	Thavinhal [6719]	KATTIMOOLA	81.0	0.0	12.0	69.0	85.2	Very High
WAYANAD	Thavinhal [6719]	KAZHAKOTTOOR	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Thavinhal [6719]	KOLICHAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	KOMPARA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	KULANGODE	81.0	3.0	3.0	75.0	92.6	Very High
WAYANAD	Thavinhal [6719]	KULATHADA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	KUTTIPLANTATION	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhal [6719]	KUTTIYOTTUCOLONY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	KUZHINILAM	81.0	4.0	18.0	59.0	72.8	High
WAYANAD	Thavinhal [6719]	MAKKIKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	MAKKIMALA RGGY	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhal [6719]	MAKKIMALA-1_6TH NO	51.0	0.0	5.0	46.0	90.2	Very High
WAYANAD	Thavinhal [6719]	MAKKIMALA-2_SCHOOL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	MAMBE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	MANDAKAMOOLA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	MAROTTIKAVALA	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	MELE CHIRAKKARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	MELEVARAYAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	MULLAL	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	MUNDIYATH	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	MUTHIRERY	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Thavinhal [6719]	MYLATTUMALA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	NAGATHANKUNNU	81.0	0.0	4.0	77.0	95.1	Very High
WAYANAD	Thavinhal [6719]	NARIKKUNDU	81.0	0.0	0.0	81.0	100.0	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Thavinhal [6719]	NAVARATHNA	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhal [6719]	NAZEEMA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	NIRAVATH	81.0	3.0	10.0	68.0	84.0	Very High
WAYANAD	Thavinhal [6719]	ORAPU	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Thavinhal [6719]	PALAKKOLY DYUTHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	PALAKOLY MUNDAKOLY	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhal [6719]	PALERIKUNNU RGGVY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	PALODE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	PANAMTHARA	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	PANICHIPALAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	PERIA TOWN	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	PERIYA-INDUS TOWER	81.0	0.0	6.0	75.0	92.6	Very High
WAYANAD	Thavinhal [6719]	PILASSERY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	POLE CASTING YARD	81.0	0.0	3.5	77.5	95.7	Very High
WAYANAD	Thavinhal [6719]	POLLAMPARA	51.0	0.0	3.0	48.0	94.1	Very High
WAYANAD	Thavinhal [6719]	PONNAN VALAVU	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	POOKOT CHAPPARAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	PRASANTHAGIRI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhal [6719]	PRIYADARSINI-1	81.0	0.0	2.0	79.0	97.5	Very High
WAYANAD	Thavinhal [6719]	PRIYADARSINI-2	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	PUNCHAKADAVU	81.0	0.0	13.0	68.0	84.0	Very High
WAYANAD	Thavinhal [6719]	PUTHIYIDAM CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhal [6719]	PUTHIYIDAM-2	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Thavinhal [6719]	PUTHOOR	81.0	0.0	18.0	63.0	77.8	Very High
WAYANAD	Thavinhal [6719]	RAZIYANA GREENS VARAYAL TOWN	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhal [6719]	ROYAL CASTLE-VALAD	81.0	0.0	15.0	66.0	81.5	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Thavinhall [6719]	S VALAVU	81.0	0.0	30.0	51.0	63.0	High
WAYANAD	Thavinhall [6719]	SAROJA ESTATE	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhall [6719]	SHIVAGIRIKUNNU	81.0	0.0	5.0	76.0	93.8	Very High
WAYANAD	Thavinhall [6719]	THALAPUZHA BUNGLOW	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	THALAPUZHA TOWN	129.0	0.0	3.0	126.0	97.7	Very High
WAYANAD	Thavinhall [6719]	THAVINAL CRUSHER	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	THAVINHALL CITY	81.0	3.0	3.0	75.0	92.6	Very High
WAYANAD	Thavinhall [6719]	THAZHE CHIRAKKARA	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhall [6719]	THEKKEKARA	81.0	0.0	15.0	66.0	81.5	Very High
WAYANAD	Thavinhall [6719]	THIDANGAZHY	81.0	8.0	18.0	55.0	67.9	High
WAYANAD	Thavinhall [6719]	THINDUMMEL-I	81.0	0.0	16.0	65.0	80.2	Very High
WAYANAD	Thavinhall [6719]	THIYARIKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	THREE STAR	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VALAD EXCHANGE	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VALAD JALANIDHI	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VALAD TOWN	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhall [6719]	VALLITHODE 4	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VALLITHODE-1	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VALLITHODE-2	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VALLITHODE-3	20.0	0.0	0.0	20.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VARAYAL	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VARAYAL HOSPITAL	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VATTAPOYIL	51.0	0.0	0.0	51.0	100.0	Very High
WAYANAD	Thavinhall [6719]	VENMANI	81.0	0.0	3.0	78.0	96.3	Very High
WAYANAD	Thavinhall [6719]	VIMALANAGAR	81.0	0.0	9.0	72.0	88.9	Very High
WAYANAD	Thavinhall [6719]	YAVANARKULAM	81.0	5.0	8.0	68.0	84.0	Very High
WAYANAD	Vellamunda [6591]	10 TH MILE AMBALAM	81.0	0.0	6.0	75.0	92.6	Very High

District	Section	Transformer	90% Cap (kW)	Issued (kW)	Connected (kW)	Balance (kW)	%	Class
WAYANAD	Vellamunda [6591]	10 TH MILE TOWER	81.0	0.0	18.2	62.8	77.5	Very High
WAYANAD	Vellamunda [6591]	4 TH MILE	129.0	0.0	0.0	129.0	100.0	Very High
WAYANAD	Vellamunda [6591]	ADIVARAM	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Vellamunda [6591]	ALENCHERY	81.0	0.0	17.0	64.0	79.0	Very High
WAYANAD	Vellamunda [6591]	AMBEDKAR	129.0	0.0	45.0	84.0	65.1	High
WAYANAD	Vellamunda [6591]	ANCHAM PEEDIKA	81.0	0.0	14.0	67.0	82.7	Very High
WAYANAD	Vellamunda [6591]	ARUVAL	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Vellamunda [6591]	ATHIKOLLY	81.0	0.0	0.0	81.0	100.0	Very High
WAYANAD	Vellamunda [6591]	AYILAMOOLA	81.0	3.0	11.2	66.8	82.5	Very High