

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. U3008559S37275597

Dated: 18/06/2026

It is certified that an inspection team headed by **Shalini Shukla, Lab Incharge, District Level Water Analysis Laboratory, Sitapur** (Name of officers with designation) from **UP Jal Nigam (Rural) Sitapur** (Name of Department/office) Inspected the **J S PUBLIC SCHOOL Kakori, Lauli Sitapur, Uttar Pradesh 261403** (Name & Address of the school) on **15-06-2026** (Date of inspection) and on the basis of water test report (Attached) Report no. **U3008559S37275597** dated **15/06/2026** of **District Level Water Analysis Laboratory, Sitapur (PHED)** lab certified that the **J S PUBLIC SCHOOL Kakori, Lauli Sitapur, Uttar Pradesh 261403** (Name of school) has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T. Govt.

Note:

This certificate is valid till **01 Year** from date of issue. In case, if there is any change in Drinking Source /gone under maintenance before Expiry of certificate, then this certificate will be no more valid. School will also need to maintain same water source condition. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory, Sitapur.

Signature with Seal.....

Name **Santosh Kumar** सहायक अभियन्ताDesignation..... **AE** जल निगम (ग्रामीण) सीतापुर

Name & Address of the office/Department

Arya Nagar Water Tank Sitapur

To

J S PUBLIC SCHOOL**Machhrehta, Kakori, Lauli, Sitapur, Uttar Pradesh U.P. 261403**

(Name & Address of the Institution)



Analysis Report
District Level Water Analysis Laboratory
U.P Jal Nigam (Rural), SITAPUR, Uttar Pradesh, India
Address : Arya Nagar Water Tank , Sitapur



Rept No	U3008559537275597	Date	17-06-2026	Page No.	1
Customer Name	J S PUBLIC SCHOOL				

Basic details of sample

District	SITAPUR	Block	Machhrehta
Gram Panchayat	Kakori	Village/Mohalla	Kakori
Habitation	Kakori	Location/Site Name	Kakori Lauli (School Campus Area)
Water Source	Borewell	Sample No.	48506
Quantity of Sample	1L	Date of Sample Collection	15-06-2026
Receiving Date	15-06-2026	Sample Collector	Durgesh Kumar
Sample Depositer	Durgesh Kumar	Sampling Method	17614 Part 01
Analysis Start Date	15-06-2026	Analysis Completion Date	17-06-2026

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH @25°C	-	7.52	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2022
2	Turbidity	(NTU)	0.20	1	5	IS 3025 (Part 10) : 2023
3	TDS	(mg/L)	196	500	2000	IS 3025 (Part 16) : 2023
4	Chloride	(mg/L)	12	250	1000	IS 3025 (Part 32) : 2019
5	Total Alkalinity	(mg/L)	136	200	600	IS 3025 (Part 23) : 2023
6	Total Hardness	(mg/L)	140	200	600	IS 3025 (Part 21) : 2019
7	Calcium	(mg/L)	16	75	200	IS 3025 (Part 40) : 2023
8	Magnesium	(mg/L)	24.3	30	100	IS 3025 (Part 46) : 2023
9	Sulphate	(mg/L)	BDL	200	400	APHA 24 Edition -4500 SO4 method (Turbidity method):2023
10	Nitrate	(mg/L)	BDL	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method):2023
11	Fluoride	(mg/L)	0.05	1	1.5	APHA 24 Edition -4500-F Method C (Electrode Method) : 2023
12	Iron	(mg/L)	BDL	1	No relaxation	APHA 24 Edition -3500-Fe Method B (Phenanthroline Method) : 2023
13	Color	Hazen	<5	5	15	IS 3025 (Part 4) : 2021

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (In case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
5. BDL Stands for Below Deduction Line that means water is in safe range.

Authorized Signatory

Shallni Shukla
Chemist

Shallni Shukla

LAB INCHARGE

Laboratory Contact details :- Email - stplabupjalnigam@gmail.com, Mob :- +91 8318597887

District Level Water Analysis Laboratory
UPJN (RURAL), SITAPUR

End of the report