

Nepal Import Review Draft for SunBridge Trading

1. Executive Summary

The supplied documents provide evidence of PV inverter testing and certification activities, but they do not appear to describe the same inverter model family.

The test report appears to cover CHISAGE CE-1P single-phase inverter models.

The certificate appears to cover Deye SUN G06P3 inverter models.

Several NEPQA-relevant standards were identified, including IEC 61727, IEC 62116, and IEC 62109-1.

However, the exact inverter model intended for import could not be confirmed from the provided documents.

Additional documentation may be required before a Nepal import review can be completed.

2. Key Review Findings

1. The supplied documents appear to describe different inverter model families.
2. The exact inverter model intended for Nepal import could not be confirmed.
3. Evidence for IEC 61727, IEC 62116, and IEC 62109-1 was identified.
4. Additional documentation is still required before a full Nepal import review can be completed.

3. Manufacturer and Certificate Information

Item	Information found
Manufacturer named in test report	Zhejiang CHISAGE New Energy Technology Co., Ltd
Applicant named in test report	Zhejiang CHISAGE New Energy Technology Co., Ltd
Factory named in test report	NingBo Deye Inverter Technology Co., Ltd.
Certificate holder named in certificate	NingBo Deye Inverter Technology Co., Ltd.
Certificate number	PCS-24-1022
Test report number	GZES230100125901

4. Documents Reviewed

- SGS IEC/EN 62109-1 Test Report
- SGS Certificate of Conformity

5. Product and Variant Review

The reviewed documents appear to describe different grid-connected photovoltaic inverter families.

SGS IEC/EN 62109-1 Test Report - CHISAGE CE-1P single-phase inverter models

- Product type: Single phase inverter
- IP rating: IP67
- Models: CE-1P series, full list in Appendix A

SGS Certificate of Conformity - Deye SUN G06P3 inverter models

- Product type: Grid-connected PV Inverter
- IP rating: IP65
- Models: SUN G06P3 AM2 and AM2-P1 variants, full list in Appendix A

6. Test and Standards Evidence

NEPQA-relevant standards identified:

- IEC 61727:2004
- IEC 62109-1:2010
- IEC 62116:2014

Other referenced standards identified:

- IEC 17065:2012
- IEC 60309
- IEC 60364-1
- IEC 60364-5-54
- IEC 60417
- IEC 60529
- IEC 60664
- IEC 60664-1
- IEC 60707
- IEC 60755
- IEC 60990
- IEC 62020
- IEC 62109
- IEC 62852

Standards by reviewed document:

- SGS IEC/EN 62109-1 Test Report: IEC 60309, IEC 60364-1, IEC 60364-5-54, IEC 60417, IEC 60529, IEC 60664, IEC 60664-1, IEC 60707, IEC 60755, IEC 60990, IEC 62020, IEC 62109, IEC 62109-1:2010, IEC 62852
- SGS Certificate of Conformity: IEC 17065:2012, IEC 61727:2004, IEC 62116:2014

7. Nepal Import Review Snapshot

Evidence identified in supplied documents

Review item	Status
IEC 61727 evidence	Evidence identified
IEC 62116 evidence	Evidence identified
IEC 62109-1 evidence	Evidence identified
IP65 or higher protection evidence	Evidence identified
Manufacturer information	Evidence identified
Model information	Evidence identified

Additional evidence recommended

Review item	Status
IEC 62891 MPPT efficiency evidence	Not found in supplied documents
IEC 62109-2 inverter safety evidence	Not found in supplied documents
Warranty agreement	Not found in supplied documents
Technical datasheet/catalogue for exact imported model	Not found in supplied documents
Data logging / monitoring evidence	Not found in supplied documents
Efficiency, THD, and no-load loss evidence	Not found in supplied documents

8. Consistent Information Across Documents

The following information appears broadly consistent:

- Both documents relate to grid-connected photovoltaic inverters.
- Both documents originate from SGS certification or testing processes.
- Both documents reference IEC-based standards.
- Both documents relate to products associated with NingBo Deye Inverter Technology Co., Ltd.

9. Mismatches and Items Requiring Confirmation

- Model family mismatch: the test report appears to cover CE-1P series, while the certificate appears to cover SUN G06P3 series.
- Product type mismatch: the test report identifies Single phase inverter, while the certificate identifies Grid-connected PV Inverter.
- IP rating mismatch: the test report identifies IP67, while the certificate identifies IP65.

- Manufacturer and certificate identity should be confirmed: the test report names Zhejiang CHISAGE New Energy Technology Co., Ltd as manufacturer, while the certificate holder is NingBo Deye Inverter Technology Co., Ltd.
- Standards evidence is split across the document set. The certificate supports IEC 61727 and IEC 62116 evidence; the test report supports IEC 62109-1 evidence.
- The exact inverter model intended for Nepal import could not be confirmed from the supplied documents.

10. Additional Documents Recommended

- IEC 62891 MPPT efficiency evidence.
- IEC 62109-2 inverter safety evidence.
- Warranty agreement with the principal inverter manufacturer.
- Technical catalogue and datasheet for the exact imported model.
- Voltage, frequency, phase sequence, THD, flicker, DC injection, and power factor specifications for Nepal grid-code review.
- Efficiency information, including MPPT efficiency, inverter efficiency, Euro efficiency, and no-load loss.
- Data logging and external user-interface information.
- Protection-function documentation for DC reverse polarity, grid fault, lightning feeder protection, automatic wake-up, synchronization, and shutdown.
- Final product label or nameplate showing rated power, input/output voltage and frequency, maximum input voltage, MPPT range, and serial number.

11. Limitations

- This draft is based only on the supplied documents and identified facts available at the time of review.
- It does not certify compliance or make an import approval decision.
- Certification-body listing, testing scope, and current certificate status were not independently verified.
- The exact inverter model intended for import should be confirmed before relying on this review package.

12. Appendix A - Full Model List

SGS IEC/EN 62109-1 Test Report - CHISAGE CE-1P single-phase inverter models

- CE-1P3001G-230-EU
- CE-1P5001G-230-EU
- CE-1P6001G-230-EU
- CE-1P8001G-230-EU
- CE-1P10001G-230-EU
- CE-1P13001G-230-EU
- CE-1P16001G-230-EU

- CE-1P18001G-230-EU
- CE-1P20001G-230-EU

SGS Certificate of Conformity - Deye SUN G06P3 inverter models

AM2 models:

- SUN-3K-G06P3-EU-AM2
- SUN-4K-G06P3-EU-AM2
- SUN-5K-G06P3-EU-AM2
- SUN-6K-G06P3-EU-AM2
- SUN-7K-G06P3-EU-AM2
- SUN-8K-G06P3-EU-AM2
- SUN-9K-G06P3-EU-AM2
- SUN-10K-G06P3-EU-AM2
- SUN-12K-G06P3-EU-AM2
- SUN-15K-G06P3-EU-AM2

AM2-P1 models:

- SUN-3K-G06P3-EU-AM2-P1
- SUN-4K-G06P3-EU-AM2-P1
- SUN-5K-G06P3-EU-AM2-P1
- SUN-6K-G06P3-EU-AM2-P1
- SUN-7K-G06P3-EU-AM2-P1
- SUN-8K-G06P3-EU-AM2-P1
- SUN-9K-G06P3-EU-AM2-P1
- SUN-10K-G06P3-EU-AM2-P1
- SUN-12K-G06P3-EU-AM2-P1
- SUN-15K-G06P3-EU-AM2-P1