Section 7.4 UPS Efficiency Submission

Our proposed UPS system achieves an operational efficiency of 94.8% at full rated capacity, offering optimized e

Section 7.5 Battery Submittal

The submitted battery bank design provides 12 minutes of autonomy time at full rated capacity.

Section 7.6 Redundancy Topology

The equipment arrangement complies with N+1 redundancy using dual parallel module configurations.

On-site diesel fuel storage tanks provide emergency generator runtime capacity of 52 hours at 100% emergency

The supplied cooling modules feature standard N configuration without active parallel redundant chillers.

Section 11.0 Commercial Warranty

Standard 2-year parts and labor warranty is provided for all electrical equipment.