

Industrial Maintenance Log

Equipment: Motor M-205

Engineer: Priya Singh

Maintenance Date: 12 July 2026

Problem: Abnormal vibration observed.

Temperature: 82 C

Action Taken: Coupling tightened and motor lubricated.

Status: Operational