| Number | Name | Object Function | Description | Group Address | Length | С | R | W | Т | U | Data Type | Priority |
|--------|---|----------------------------|-------------------|---------------|---------|---|---|---|---|---|----------------|----------|
| 0 | Control_ On/Off [DPT_1.001] | 0-Off;1-On | Asia Control_ On | 1/1/0 | 1 bit | С | - | W | Т | - | switch | Low |
| 1 | Control_ Mode [DPT_20.105] | 0-Aut;1-Hea;3-Coo;9-Fan; | 1Asia Control_ Mo | 1/1/1 | 1 byte | С | - | W | Т | - | HVAC control | . Low |
| 2 | Control_ Mode Cool/Heat [DPT_1.100] | 0-Cool;1-Heat | Asia Control_ Mo | o 1/1/2 | 1 bit | С | - | W | Т | - | cooling/heatin | g Low |
| 3 | Control_ Mode Auto [DPT_1.002] | 1-Set AUTO mode | Asia Control_ Mo | 1/1/3 | 1 bit | С | - | W | Т | - | boolean | Low |
| 4 | Control_ Mode Heat [DPT_1.002] | 1-Set HEAT mode | Asia Control_ Mo | 1/1/4 | 1 bit | С | - | W | Т | - | boolean | Low |
| 5 | Control_ Mode Cool [DPT_1.002] | 1-Set COOL mode | Asia Control_ Mo | 1/1/5 | 1 bit | С | - | W | Т | - | boolean | Low |
| 6 | Control_ Mode Fan [DPT_1.002] | 1-Set FAN mode | Asia Control_ Mo | 1/1/6 | 1 bit | С | - | W | Т | - | boolean | Low |
| 7 | Control_ Mode Dry [DPT_1.002] | 1-Set DRY mode | Asia Control_ Mo | 1/1/7 | 1 bit | С | - | W | Т | - | boolean | Low |
| 9 | Control_ Fan Speed / 4 Speeds [DPT_5.010] | Speed values: 1,2,3,4 | Asia Control_ Fa. | 1/1/9 | 1 byte | С | - | W | Т | - | counter pulse. | Low |
| 10 | Control_ Fan Speed / 4 Speeds [DPT_5.001] | Thresholds:38%, 63% and | i | | 1 byte | С | - | W | Т | - | percentage (0 | Low |
| 11 | Control_ Fan Speed Man/Auto [DPT_1.002] | 0-Manual;1-Auto | | | 1 bit | С | - | W | Т | - | boolean | Low |
| 17 | Control_ Vanes U-D / 5 Pos [DPT_5.010] | Position values: 1,2,3,4,5 | | | 1 byte | С | - | W | Т | - | counter pulse. | Low |
| 18 | Control_ Vanes U-D / 5 Pos [DPT_5.001] | Thresholds:30%,50%,70% | , 0 | | 1 byte | С | - | W | Т | - | percentage (0 | Low |
| 19 | Control_ Vanes U-D Man/Auto [DPT_1.002] | 0-Manual;1-Auto | | | 1 bit | С | - | W | Т | - | boolean | Low |
| 20 | Control_ Vanes U-D Pos 1 [DPT_1.002] | 1-Set Position 1 | | | 1 bit | С | - | W | Т | - | boolean | Low |
| 21 | Control_ Vanes U-D Pos 2 [DPT_1.002] | 1-Set Position 2 | | | 1 bit | С | - | W | Т | - | boolean | Low |
| 22 | Control_ Vanes U-D Pos 3 [DPT_1.002] | 1-Set Position 3 | | | 1 bit | С | - | W | Т | - | boolean | Low |
| 23 | Control_ Vanes U-D Pos 4 [DPT_1.002] | 1-Set Position 4 | | | 1 bit | С | - | W | Т | - | boolean | Low |
| 24 | Control_ Vanes U-D Pos 5 [DPT_1.002] | 1-Set Position 5 | | | 1 bit | С | - | W | Т | - | boolean | Low |
| 25 | Control_ Vanes U-D Swing [DPT_1.002] | 0-Off;1-Swing | | | 1 bit | С | - | W | Т | - | boolean | Low |
| 27 | Control_ Setpoint Temperature [DPT_9.001] | (°C) | Asia Control_ Se | t1/1/27 | 2 bytes | С | - | W | Т | - | temperature (| Low |
| 46 | Status_ On/Off [DPT_1.001] | 0-Off;1-On | Asia Status_ On/ | 1/1/46 | 1 bit | С | R | - | Т | - | switch | Low |
| 47 | Status_ Mode [DPT_20.105] | 0-Aut;1-Hea;3-Coo;9-Fan; | 1Asia Status_ Mod | de 1/1/47 | 1 byte | С | R | - | Т | - | HVAC control | . Low |
| 48 | Status_ Mode Cool/Heat [DPT_1.100] | 0-Cool;1-Heat | | | 1 bit | С | R | - | Т | - | cooling/heatin | g Low |
| 49 | Status_ Mode Auto [DPT_1.002] | 1-AUTO mode is active | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 50 | Status_ Mode Heat [DPT_1.002] | 1-HEAT mode is active | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 51 | Status_ Mode Cool [DPT_1.002] | 1-COOL mode is active | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 52 | Status_ Mode Fan [DPT_1.002] | 1-FAN mode is active | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 53 | Status_ Mode Dry [DPT_1.002] | 1-DRY mode is active | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 55 | Status_ Fan Speed / 4 Speeds [DPT_5.010] | Speed Values: 1,2,3,4 | Asia Status_ Fan | 1/1/55 | 1 byte | С | R | - | Т | - | counter pulse. | Low |
| 56 | Status_ Fan Speed / 4 Speeds [DPT_5.001] | 25%, 50%, 75% and 100% | % | | 1 byte | С | R | - | Т | - | percentage (0 | Low |
| 57 | Status_ Fan Speed Man/Auto [DPT_1.002] | 0-Manual;1-Auto | | | 1 bit | С | R | - | Т | - | boolean | Low |
| | | | | | | | | | | | | |

Klimatyzacja - 1.1.7 ME AC Asia

| Number | Name | Object Function | Description 0 | Group Address | Length | С | R | W | Т | U | Data Type | Priority |
|--------|---|--------------------------|-------------------|---------------|---------|---|---|---|---|---|---------------|----------|
| 63 | Status_ Vanes U-D / 5 pos [DPT_5.010] | Position values: 1,2,3,4 | 4,5 | | 1 byte | С | R | - | Т | - | counter pulse | . Low |
| 64 | Status_ Vanes U-D / 5 pos [DPT_5.001] | 20%, 40, 60%, 80% a | and 1 | | 1 byte | С | R | - | Т | - | percentage (0 | Low |
| 65 | Status_ Vanes U-D Man/Auto [DPT_1.002] | 0-Manual;1-Auto | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 66 | Status_ Vanes U-D Pos 1 [DPT_1.002] | 1-Vanes in Position 1 | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 67 | Status_ Vanes U-D Pos 2 [DPT_1.002] | 1-Vanes in Position 2 | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 68 | Status_ Vanes U-D Pos 3 [DPT_1.002] | 1-Vanes in Position 3 | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 69 | Status_ Vanes U-D Pos 4 [DPT_1.002] | 1-Vanes in Position 4 | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 70 | Status_ Vanes U-D Pos 5 [DPT_1.002] | 1-Vanes in Position 5 | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 71 | Status_ Vanes U-D Swing [DPT_1.002] | 0-Off;1-Swing | | | 1 bit | С | R | - | Т | - | boolean | Low |
| 73 | Status_ AC Setpoint Temperature [DPT_9.001] | (°C) | Asia Status_ AC 1 | /1/73 | 2 bytes | С | R | - | Т | - | temperature (| .Low |
| 74 | Status_ AC Return Temperature [DPT_9.001] | (°C) | Asia Status_ AC 1 | /1/74 | 2 bytes | С | R | - | Т | - | temperature (| .Low |
| 75 | Status_ Error/Alarm [DPT_1.005] | 0-No alarm;1-Alarm | | | 1 bit | С | R | - | Т | - | alarm | Low |