

Performance of grid-connected PV

PVGIS-5 estimates of solar electricity generation:


Provided inputs:

Latitude/Longitude: 41.519,-8.594
Horizon: Calculated
Database used: PVGIS-ERA5
PV technology: Cryst Sil Original
PV installed: 3.84 kWp
System loss: 12 %


Simulation outputs

Slope angle: 30 °
Azimuth angle: 0 °
Yearly PV energy production: 5901.38 kWh
Yearly in-plane irradiation: 1912.01 kWh/m²
Year-to-year variability: 201.90 kWh
Changes in output due to:
Angle of incidence: -2.61 %
Spectral effects: 0.76 %
Temperature and low irradiance: -6.91 %
Total loss: -19.62 %


Outline of horizon at chosen location:



Monthly energy output from fix-angle PV system:



Monthly in-plane irradiation for fixed-angle:



Monthly PV energy and solar irradiation

Month	E_m	H(i)_m	SD_m
January	330.1	100.4	67.2
February	396.9	122.6	71.3
March	511.7	160.8	74.2
April	550.2	177.3	48.2
May	614.6	202.0	37.3
June	605.2	201.6	30.3
July	658.7	221.8	25.9
August	641.0	216.6	25.9
September	545.3	180.8	36.6
October	434.1	139.4	59.0
November	323.5	100.2	68.6
December	290.2	88.6	47.3

E_m: Average monthly electricity production from the defined system [kWh].

H(i)_m: Average monthly sum of global irradiation per square meter received by the modules of the given system [kWh/m²].

SD_m: Standard deviation of the monthly electricity production due to year-to-year variation [kWh].