Northbridge Analytical Labs

Independent testing laboratory · Gachibowli, Hyderabad 500032, India

TEST REPORT

Report No.	NAL/26/10/4471	**Report date**	01.11.2026
Sample	Ferric Chloride Solution 40% (CAS 7705-08-0)	**Lot No.**	FC-2611-12
Manufacturer	Kutch Coastal Chemicals	**Date of mfg.**	29.10.2026
Tested on	31.10.2026	**Best before**	28.10.2027

Parameter	Test method	Units	Result	Limits
Assay as FeCl3	NAL-WI-112	% w/w	**40.6**	≥ 40.0
Fe	NAL-WI-112	% w/w	**13.95**	≥ 13.8
Free acidity	NAL-WI-118	% w/w	**0.30**	≤ 0.5
Fe(II)	NAL-WI-121	% w/w	**0.11**	≤ 0.25
Water insolubles	NAL-WI-130	% w/w	**0.05**	≤ 0.10
SG	Density meter	—	**1.432**	1.40 – 1.45
Appearance	Visual	—	**Complies**	Dark brown liquid

Results relate only to the sample as received. This report shall not be reproduced except in full without written approval of the laboratory.

Authorised signatory, Chemical Testing