

Rainwater Harvesting Assessment Report

Assessment ID: test-pdf-download

Site Details

Parameter	Value
Site Name	Test Site for Download
Location	28.704100, 77.102500
Roof Area	150.00 m²
Roof Material	Concrete
Roof Condition	Good
Soil Type	Loamy
Annual Rainfall	1200.00 mm
Daily Water Demand	300.00 L/day

Assessment Results

Parameter	Value
Harvestable Volume	120.00 m³/year
Recommended Option	Hybrid
Storage Volume	100.00 m³
Storage Days	45 days
Recharge Pit Area	7.07 m²
Recharge Trench	8.00m x 1.50m x 2.00m
Infiltration Rate	12.00 mm/hr
Suitability Score	9/10

Cost Analysis

Component	Cost (INR)
Storage System	■75,000.00
Recharge Structure	■45,000.00
Piping & Fittings	■15,000.00
Filtration System	■20,000.00
Labor Cost	■25,000.00

Material Contingency	■8,000.00
Tax (GST)	■18,000.00
Total Cost	■206,000.00

Savings Analysis

Parameter	Value
Annual Water Saved	120.00 m³
Annual Cost Savings	■60,000.00
Monthly Savings	■5,000.00
Water Tariff Used	■50.00/m³
Payback Period	3.4

Bill of Quantities

Item	Quantity	Rate (INR)	Amount (INR)
Storage Tank (10,000L)	1	■75,000.00	■75,000.00
PVC Piping (100mm)	100m	■150.00	■15,000.00
Filtration System	1	■20,000.00	■20,000.00
Labor Cost	10 days	■2,500.00	■25,000.00
Total			■206,000.00

Safety and Compliance Checks

WARNING: Check local building codes for rooftop access

INFO: Ensure proper drainage around recharge structures

CRITICAL: Verify structural capacity for additional weight