



Universiteit Gent
Faculteit Wetenschappen
Vakgroep Fysica en Sterrenkunde

² No title yet

³ No sub-title neither, obviously...

⁴ Alexis Fagot

5



Thesis to obtain the degree of
Doctor of Philosophy in Physics
Academic years 2012-2017





Universiteit Gent
Faculteit Wetenschappen
Vakgroep Fysica en Sterrenkunde


Promotoren: Dr. Michael Tytgat
Prof. Dr. Dirk Ryckbosch

Universiteit Gent
Faculteit Wetenschappen
Vakgroep Fysica en Sterrenkunde
Proeftuinstraat 86, B-9000 Gent, België
Tel.: +32 9 264.65.28
Fax.: +32 9 264.66.97

17



Thesis to obtain the degree of
Doctor of Philosophy in Physics
Academic years 2012-2017



Acknowledgements

¹⁹ Ici on remerciera tous les gens que j'ai pu croiser durant cette aventure et qui m'ont permis de passer
²⁰ un bon moment

²¹ *Gent, ici la super date de la mort qui tue de la fin d'écriture*
²² *Alexis Fagot*

Table of Contents

24	Acknowledgements	i
25	Nederlandse samenvatting	vii
26	English summary	ix
27	1 Introduction	1-1
28	1.1 A story of High Energy Physics	1-1
29	1.2 Organisation of this study	1-1
30	2 Investigating the TeV scale	2-1
31	2.1 The Standard Model of Particle Physics	2-1
32	2.2 The Large Hadron Collider & the Compact Muon Solenoid	2-2
33	2.2.1 LHC, the most powerful particle accelerator	2-2
34	2.2.1.1 Particle acceleration	2-3
35	2.2.1.2 LHC discoveries and LHC physics program	2-6
36	2.2.1.3 High Luminosity LHC	2-7
37	2.2.2 CMS, a multipurpose experiment	2-7
38	2.2.3 Muon Phase-II Upgrade	2-7
39	3 Physics of Resistive plate chambers	3-1
40	3.1 Principle	3-1
41	3.1.1 Electron drift velocity	3-4
42	3.2 Rate capability and time resolution of Resistive Plate Chambers	3-4
43	3.2.1 Operation modes	3-4
44	3.2.2 Detector designs and performance	3-6
45	3.2.2.1 Double-gap RPC	3-7
46	3.2.2.2 Multigap RPC (MRPC)	3-8
47	3.2.2.3 Charge distribution and performance limitations	3-9
48	3.3 Signal formation	3-12
49	3.4 Gas transport parameters	3-12
50	4 Longevity studies and Consolidation of the present CMS RPC subsystem	4-1
51	4.1 Resistive Plate Chambers at CMS	4-1
52	4.1.1 Overview	4-1
53	4.1.2 The present RPC system	4-2
54	4.1.3 Pulse processing of CMS RPCs	4-3
55	4.2 Testing detectors under extreme conditions	4-4
56	4.2.1 The Gamma Irradiation Facilities	4-7
57	4.2.1.1 GIF	4-7
58	4.2.1.2 GIF++	4-9

59	4.3 Preliminary tests at GIF	4-11
60	4.3.1 Resistive Plate Chamber test setup	4-11
61	4.3.2 Data Acquisition	4-13
62	4.3.3 Geometrical acceptance of the setup layout to cosmic muons	4-13
63	4.3.3.1 Description of the simulation layout	4-14
64	4.3.3.2 Simulation procedure	4-16
65	4.3.3.3 Results	4-17
66	4.3.4 Photon flux at GIF	4-17
67	4.3.4.1 Expectations from simulations	4-17
68	4.3.4.2 Dose measurements	4-22
69	4.3.5 Results and discussions	4-23
70	4.4 Longevity tests at GIF++	4-24
71	4.4.1 Description of the Data Acquisition	4-27
72	4.4.2 RPC current, environmental and operation parameter monitoring	4-28
73	4.4.3 Measurement procedure	4-29
74	4.4.4 Longevity studies results	4-29
75	5 Investigation on high rate RPCs	5-1
76	5.1 Rate limitations and ageing of RPCs	5-1
77	5.1.1 Low resistivity electrodes	5-1
78	5.1.2 Low noise front-end electronics	5-1
79	5.2 Construction of prototypes	5-1
80	5.3 Results and discussions	5-1
81	6 Conclusions and outlooks	6-1
82	6.1 Conclusions	6-1
83	6.2 Outlooks	6-1
84	A A data acquisition software for CAEN VME TDCs	A-1
85	A.1 GIF++ DAQ file tree	A-1
86	A.2 Usage of the DAQ	A-2
87	A.3 Description of the readout setup	A-3
88	A.4 Data read-out	A-3
89	A.4.1 V1190A TDCs	A-4
90	A.4.2 DataReader	A-6
91	A.4.3 Data quality flag	A-10
92	A.5 Communications	A-12
93	A.5.1 V1718 USB Bridge	A-13
94	A.5.2 Configuration file	A-13
95	A.5.3 WebDCS/DAQ intercommunication	A-17
96	A.5.4 Example of inter-process communication cycle	A-18
97	A.6 Software export	A-18
98	B Details on the offline analysis package	B-1
99	B.1 GIF++ Offline Analysis file tree	B-1
100	B.2 Usage of the Offline Analysis	B-2
101	B.2.1 Output of the offline tool	B-3
102	B.2.1.1 ROOT file	B-3
103	B.2.1.2 CSV files	B-5
104	B.3 Analysis inputs and information handling	B-6

105	B.3.1 Dimensions file and IniFile parser	B-6
106	B.3.2 TDC to RPC link file and Mapping	B-7
107	B.4 Description of GIFT++ setup within the Offline Analysis tool	B-9
108	B.4.1 RPC objects	B-9
109	B.4.2 Trolley objects	B-10
110	B.4.3 Infrastructure object	B-11
111	B.5 Handeling of data	B-12
112	B.5.1 RPC hits	B-13
113	B.5.2 Clusters of hits	B-14
114	B.6 DAQ data Analysis	B-15
115	B.6.1 Determination of the run type	B-16
116	B.6.2 Beam time window calculation for efficiency runs	B-17
117	B.6.3 Data loop and histogram filling	B-18
118	B.6.4 Results calculation	B-19
119	B.6.4.1 Rate normalisation	B-19
120	B.6.4.2 Rate and activity	B-21
121	B.6.4.3 Strip masking tool	B-23
122	B.6.4.4 Output CSV files filling	B-25
123	B.7 Current data Analysis	B-29

¹²⁴

Nederlandse samenvatting –Summary in Dutch–

¹²⁵

¹²⁶ Le resume en Neerlandais (j'aurais peut-être pu apprendre la langue juste pour ça...).

¹²⁷

English summary

¹²⁸ Le meme résume mais en Anglais (on commencera par la hein!).

List of Figures

129

130	2.1	CERN accelerator complex.	2-3
131	2.2	Pictures of the different accelerators. From top to bottom: first the LINAC 2 and the <i>Pb</i> source of LINAC 3. Then the Booster and the LEIR. Finally, the PS, the SPS and the LHC.	2-5
132			
133	2.3	Figure 2.3a: schematics of the LHC cryodipoles. 1: Superconducting Coils, 2: Beam pipe, 3: Heat exchanger Pipe, 4: Helium-II Vessel, 5: Superconducting Bus-bar, 6: Iron Yoke, 7: Non-Magnetic Collars, 8: Vacuum Vessel, 9: Radiation Screen, 10: Thermal Shield, 11: Auxiliary Bus-bar Tube, 12: Instrumentation Feed Throughs, 13: Protection Diode, 14: Quadrupole Bus-bars, 15: Spool Piece Bus-bars. Figure 2.3b: magnetic field and resulting motion force applied on the beam particles. . .	2-6
134			
135	2.4	Figure 2.4a: picture of the LHC quadrupoles. Figure 2.4b: magnetic fields and resulting focussing force applied on the beam by 2 consecutive quadrupoles.	2-6
136			
137	2.5	Absorbed dose in the CMS cavern after an integrated luminosity of 3000 fb. R is the transverse distance from the beamline and Z is the distance along the beamline from the Interaction Point at Z=0.	2-7
138			
139	2.6	A quadrant of the muon system, showing DTs (yellow), RPCs (light blue), and CSCs (green). The locations of new forward muon detectors for Phase-II are contained within the dashed box and indicated in red for GEM stations (ME0, GE1/1, and GE2/1) and dark blue for improved RPC (iRPC) stations (RE3/1 and RE4/1).	2-8
140			
141	2.7	RMS of the multiple scattering displacement as a function of muon p_T for the proposed forward muon stations. All of the electromagnetic processes such as bremsstrahlung and magnetic field effect are included in the simulation.	2-9
142			
143	3.1	Different phases of the avalanche development in the RPC gas volume subjected to a constant electric field E_0 . a) An avalanche is initiated by the primary ionisation caused by the passage of a charged particle through the gas volume. b) Due to its growing size, the avalanche starts to locally influence the electric field. c) The electrons, lighter than the cations reach the anode first. d) The ions reach the cathode. While the charges have not recombined, the electric field in the small region around the avalanche stays affected and locally blind the detector.	3-2
144			
145	3.2	Effeciency (circles and stars with 30 mV and 100 mV thresholds respectively) and streamer probability (opened circles) as function of the operating voltatge of a 2 mm single gap HPL RPC flushed with a gas mixture containing (a) 5%, (b) 2%, (c) 1% and (d) no SF_6 [33].	3-3
146			
147	3.3	Movement of the charge carriers in an RPC. Figure 3.3a: Voltage across an RPC whose electrode have a relative permittivity of 5 at the moment the tension s applied. Figure 3.3b: After the charge carriers moved, the electrodes are charged and there is no voltage drop over the electrodes anymore. The full potential is applied on the gas gap only. Figure 3.3c: The streamer discharge initiated by a charged particle transports electrons and cations towards the anode and cathode respectively.	3-5
148			
149			
150			
151			
152			
153			
154			
155			
156			
157			
158			
159			
160			
161			
162			
163			
164			
165			
166			
167			
168			

169	3.4	Typical oscilloscope pulses in streamer mode (Figure 3.4a) and avalanche mode(Figure 3.4b). In the case of streamer mode, the very small avalanche signal is visible.	3-5
170			
171	3.5	Rate capability comparison for the streamer and avalanche mode of operation. An order of magnitude in rate capability for a maximal efficiency drop of 10% is gained by using the avalanche mode over the streamer mode.	3-6
172			
173			
174	3.6	Possible double-gap RPC layouts: a) "standard" 1D double-gap RPC, as used in CMS experiment, where the anodes are facing each other and a 1D read-out plane is sandwiched in between them, b) double read-out double-gap RPC as used in ATLAS experiment, where the cathodes are facing each other and 2 read-out planes are used on the outer surfaces. This last layout can offer the possibility to use a 2D reconstruction by using orthogonal read-out planes.	3-7
175			
176			
177			
178			
179			
180	3.7	Comparison of performance of CMS double and single gap RPCs using cosmic muons [44]. Figure 3.7a: Comparison of efficiency sigmoids. Figure 3.7b: Voltage distribution at 95% of maximum efficiency. Figure 3.7c: $\Delta_{10\%}^{90\%}$ distribution.	3-7
181			
182			
183	3.8	Presentation of ALICE MRPC using 250 μm gas gaps, 620 μm outer glass electrodes and 550 μm inner floating electrodes. More details on the labels are given in [45].	3-8
184			
185	3.9	Particle identification applied to electrons in the STAR experiment. The identification is performed combining ToF and dE/dx measurements [50].	3-9
186			
187	3.10	Comparison of the detector performance of ALICE ToF MRPC [51] at fixed applied voltage (in blue) and at fixed effective voltage (in red). The effective voltage is kept fixed by increasing the applied voltage accordingly to the current drawn by the detector.	3-9
188			
189			
190	3.11	Ratio between total induced and drifting charge have been simulated for single gap, double-gap and multigap layouts [52]. The total induced charge for a double-gap RPC is a factor 2 higher than for a multigap.	3-10
191			
192			
193	3.12	Charge spectra have been simulated for single gap, double-gap and multigap layouts [52]. It appears that when single gap shows a decreasing spectrum, double and multigap layouts exhibit a spectrum whose peak is detached from the origin. The detachment gets stronger as the number of gaps increases.	3-11
194			
195			
196			
197	3.13	The maximal theoretical efficiency is simulated for single gap, double-gap and multigap layouts [52] at a constant gap thickness of 2 mm and using an effective Townsend coefficient of 9 mm^{-1}	3-11
198			
199			
200	4.1	Signals from the RPC strips are shaped by the FEE described on Figure 4.1a. Output LVDS signals are then read-out by a TDC module connected to a computer or converted into NIM and sent to scalers. Figure 4.1b describes how these converted signals are put in coincidence with the trigger.	4-3
201			
202			
203			
204	4.2	Description of the principle of a CFD. A comparison of threshold triggering (left) and constant fraction triggering (right) is shown in Figure 4.2a. Constant fraction triggering is obtained thanks to zero-crossing technique as explained in Figure 4.2b. The signal arriving at the input of the CFD is split into three components. A first one is delayed and connected to the inverting input of a first comparator. A second component is connected to the noninverting input of this first comparator. A third component is connected to the noninverting input of another comparator along with a threshold value connected to the inverting input. Finally, the output of both comparators is fed through an AND gate.	4-4
205			
206			
207			
208			
209			
210			
211			
212			
213	4.3	(4.3a) Extrapolation from 2016 data of single hit rate per unit area in the barrel region. (4.3b) Extrapolation from 2016 data of single hit rate per unit area in the endcap region.	4-6
214			
215			

216	4.4	Background Fluka simulation compared to 2016 Data at $L = 10^{34} \text{ cm}^{-2} \cdot \text{s}^{-1}$ in the fourth endcap disk region. A mismatch in between simulation and data can be observed. [To be understood.]	4-7
217			
218			
219	4.5	Layout of the test beam zone called X5c GIF at CERN. Photons from the radioactive source produce a sustained high rate of random hits over the whole area. The zone is surrounded by 8 m high and 80 cm thick concrete walls. Access is possible through three entry points. Two access doors for personnel and one large gate for material. A crane allows installation of heavy equipment in the area.	4-8
220			
221			
222			
223	4.6	^{137}Cs decays by β^- emission to the ground state of ^{137}Ba (BR = 5.64%) and via the 662 keV isomeric level of ^{137}Ba (BR = 94.36%) whose half-life is 2.55 min.	4-9
224			
225			
226	4.7	Floor plan of the GIF++ facility. When the facility downstream of the GIF++ takes electron beam, a beam pipe is installed along the beam line (z-axis). The irradiator can be displaced laterally (its center moves from $x = 0.65$ m to 2.15 m), to increase the distance to the beam pipe.	4-9
227			
228			
229	4.8	Simulated unattenuated current of photons in the xz plane (Figure 4.8a) and yz plane (Figure 4.8b) through the source at $x = 0.65$ m and $y = 0$ m. With angular correction filters, the current of 662 keV photons is made uniform in xy planes.	4-10
230			
231			
232	4.9	Description of the RPC setup. Dimensions are given in mm. A tent containing RPCs is placed at 1720 mm from the source container. The source is situated in the center of the container. RE-4-2-BARC-161 chamber is 160 mm inside the tent. This way, the distance between the source and the chambers plan is 2060 mm. Figure 4.9a provides a side view of the setup in the xz plane while Figure 4.9b shows a top view in the yz plane.	4-11
233			
234			
235			
236			
237			
238			
239	4.10	RE-4-2-BARC-161 chamber is inside the tent as described in Figure 4.9. In the top right, the two scintillators used as trigger can be seen. This trigger system has an inclination of 10° relative to horizontal and is placed above half-partition B2 of the RPCs. PMT electronics are shielded thanks to lead blocks placed in order to protect them without stopping photons from going through the scintillators and the chamber.	4-12
240			
241			
242			
243			
244	4.11	Hit distributions over all 3 partitions of RE-4-2-BARC-161 chamber is showed on these plots. Top, middle and bottom figures respectively correspond to partitions A, B, and C. These plots show that some events still occur in other half-partitions than B2, which corresponds to strips 49 to 64, in front of which the trigger is placed, con- tributing to the inefficiency of detection of cosmic muons. In the case of partitions A and C, the very low amount of data can be interpreted as noise. On the other hand, it is clear that a little portion of muons reach the half-partition B1, corresponding to strips 33 to 48.	4-13
245			
246			
247			
248			
249			
250			
251			
252	4.12	Results are derived from data taken on half-partition B2 only. On the 18 th of June 2014, data has been taken on chamber RE-2-BARC-161 at building 904 (Prevessin Site) with cosmic muons providing us a reference efficiency plateau of $(97.54 \pm$ $0.15)\%$ represented by a black curve. A similar measurement has been done at GIF on the 21 st of July with the same chamber giving a plateau of $(78.52 \pm 0.94)\%$ represented by a red curve.	4-14
253			
254			
255			
256			
257			
258	4.13	Representation of the layout used for the simulations of the test setup. The RPC is represented as a yellow trapezoid while the two scintillators as blue cuboids looking at the sky. A green plane corresponds to the muon generation plane within the sim- ulation. Figure 4.9a shows a global view of the simulated setup. Figure 4.9b shows a zommed view that allows to see the 2 scintillators as well as the full RPC plane.	4-15
259			
260			
261			
262			
263	4.14	γ flux $F(D)$ is plot using values from table 4.1. As expected, the plot shows similar attenuation behaviours with increasing distance for each absorption factors.	4-18
264			

265	4.15	Figure 4.15a shows the linear approximation fit done via formulae 4.7 on data from table 4.2. Figure 4.15b shows a comparison of this model with the simulated flux using a and b given in figure 4.15a in formulae 4.4 and the reference value $D_0 =$ 50cm and the associated flux for each absorption factor F_0^{ABS} from table 4.1	4-20
266			
267			
268			
269	4.16	Dose measurements has been done in a plane corresponding to the tents front side. This plan is 1900 mm away from the source. As explained in the first chapter, a lens-shaped lead filter provides a uniform photon flux in the vertical plan orthogonal to the beam direction. If the second line of measured fluxes is not taken into account because of lower values due to experimental equipments in the way between the source and the tent, the uniformity of the flux is well showed by the results.	4-22
270			
271			
272			
273			
274			
275	4.17	4-23
276			
277	4.18	Evolution of the maximum efficiency for RE2 (4.18a) and RE4 (4.18b) chambers with increasing extrapolated γ rate per unit area at working point. Both irradiated (blue) and non irradiated (red) chambers are shown.	4-25
278			
279	4.19	Evolution of the working point for RE2 (4.19a) and RE4 (4.19b) with increasing extrapolated γ rate per unit area at working point. Both irradiated (blue) and non irradiated (red) chambers are shown.	4-25
280			
281			
282	4.20	Evolution of the maximum efficiency at HL-LHC conditions, i.e. a background hit rate per unit area of 300 Hz/cm^2 , with increasing integrated charge for RE2 (4.20a) and RE4 (4.20b) detectors. Both irradiated (blue) and non irradiated (red) chambers are shown. The integrated charge for non irradiated detectors is recorded during test beam periods and stays small with respect to the charge accumulated in irradiated chambers.	4-26
283			
284			
285			
286			
287			
288	4.21	Comparison of the efficiency sigmoid before (triangles) and after (circles) irradiation for RE2 (4.21a) and RE4 (4.21b) detectors. Both irradiated (blue) and non irradiated (red) chambers are shown.	4-26
289			
290			
291	4.22	Evolution of the Bakelite resistivity for RE2 (4.22a) and RE4 (4.22b) detectors. Both irradiated (blue) and non irradiated (red) chambers are shown.	4-27
292			
293	4.23	Evolution of the noise rate per unit area for the irradiated chamber RE2-2-BARC-9 only.	4-27
294			
295	A.1	(A.1a) View of the front panel of a V1190A TDC module [58]. (A.1b) View of the front panel of a V1718 Bridge module [59]. (A.1c) View of the front panel of a 6U 6021 VME crate [60].	A-3
296			
297			
298	A.2	Module V1190A <i>Trigger Matching Mode</i> timing diagram [58].	A-4
299			
300	A.3	Structure of the ROOT output file generated by the DAQ. The 5 branches (<code>EventNumber</code> , <code>number_of_hits</code> , <code>Quality_flag</code> , <code>TDC_channel</code> and <code>TDC_TimeStamp</code>) are visible on the left panel of the ROOT browser. On the right panel is visible the histogram cor- responding to the variable <code>nHits</code> . In this specific example, there were approximately 50k events recorded to measure the gamma irradiation rate on the detectors. Each event is stored as a single entry in the <code>TTree</code>	A-10
301			
302			
303			
304			
305	A.4	The effect of the quality flag is explained by presenting the content of <code>TBranch</code> <code>number_of_hits</code> of a data file without <code>Quality_flag</code> in Figure A.4a and the con- tent of the same <code>TBranch</code> for data corresponding to a <code>Quality_flag</code> where all TDCs were labelled as <code>GOOD</code> in Figure A.4b taken with similar conditions. It can be noted that the number of entries in Figure A.4b is slightly lower then in Figure A.4a due to the excluded events.	A-12
306			
307			
308			
309			
310			

311	A.5	Using the same data as previously showed in Figure A.4, the effect of the quality flag is explained by presenting the reconstructed hit multiplicity of a data file without <code>Quality_flag</code> in Figure A.5a and the reconstructed content of the same RPC partition for data corresponding to a <code>Quality_flag</code> where all TDCs were labelled as <code>GOOD</code> in Figure A.5b taken with similar conditions. The artificial high content of bin 0 is completely suppressed.	A-12
312	A.6	WebDCS DAQ scan page. On this page, shifters need to choose the type of scan (Rate, Efficiency or Noise Reference scan), the gamma source configuration at the moment of data taking, the beam configuration, and the trigger mode. These information will be stored in the DAQ ROOT output. Are also given the minimal measurement time and waiting time after ramping up of the detectors is over before starting the data acquisition. Then, the list of HV points to scan and the number of triggers for each run of the scan are given in the table underneath.	A-14
324	B.1	Example of expected hit time distributions in the cases of efficiency (Figure B.1a) and noise/gamma rate per unit area (Figure B.1b) measurements as extracted from the raw ROOT files. The unit along the x-axis corresponds to ns. The fact that "the" muon peak is not well defined in Figure B.1a is due to the contribution of all the RPCs being tested at the same time that don't necessarily have the same signal arrival time. Each individual peak can have an offset with the ones of other detectors. The inconsistancy in the first 100 ns of both time distributions is an artefact of the TDCs and are systematically rejected during the analysis.	B-16
332	B.2	The effect of the quality flag is explained by presenting the reconstructed hit multiplicity of a data file without <code>Quality_flag</code> . The artificial high content of bin 0 is the effect of corrupted data.	B-19
335	B.3	Display of the masking tool page on the webDCS. The window on the left allows the shifter to edit <code>ChannelsMapping.csv</code> . To mask a channel, it only is needed to set the 3rd field corresponding to the strip to mask to 0. It is not necessary for older mapping file formats to add a 1 for each strip that is not masked as the code is versatile and the default behaviour is to consider missing mask fields as active strips. The effect of the mask is directly visible for noisy channels as the corresponding bin turns red. The global effect of masking strips will be an update of the rate value showed on the histogram that will take into consideration the rejected channels.	B-24
341			
342			

List of Tables

343

344	3.1 Properties of the most used electrode materials for RPCs.	3-4
345	4.1 Total photon flux ($E\gamma \leq 662$ keV) with statistical error predicted considering a	
346	^{137}Cs activity of 740 GBq at different values of the distance D to the source along	
347	the x-axis of irradiation field [55].	4-17
348	4.2 Correction factor c is computed thanks to formulae 4.5 taking as reference $D_0 =$	
349	50 cm and the associated flux F_0^{ABS} for each absorption factor available in table 4.1. .	4-19
350	4.3 The data at D_0 in 1997 is taken from [55]. In a second step, using Equations 4.8	
351	and 4.9, the flux at D can be estimated in 1997. Then, taking into account the	
352	attenuation of the source activity, the flux at D can be estimated at the time of the	
353	tests in GIF in 2014. Finally, assuming a sensitivity of the RPC to γ $s = 2 \cdot 10^{-3}$,	
354	an estimation of the hit rate per unit area is obtained.	4-21
355	A.1 Inter-process communication cycles in between the webDCS and the DAQ through	
356	file string signals.	A-19

List of Acronyms

357

358

List of Acronyms

359

360

A

361

362

363 AFL

Almost Full Level

364

365

B

366

367

368 BARC

Bhabha Atomic Research Centre

369 BLT

Block Transfer

370 BR

Branching Ratio

371

372

C

373

374

375 CAEN

Costruzioni Apparecchiature Elettroniche Nucleari S.p.A.

376 CERN

European Organization for Nuclear Research

377 CFD

Constant Fraction Discriminator

378 CMS

Compact Muon Solenoid

379 CSC

Cathode Strip Chamber

380

381

D

382

383

384 DAQ

Data Acquisition

385 DCS

Detector Control Software

386 DQM

Data Quality Monitoring

387 DT

Drift Tube

388

389

F

390

391

392	FEE	Front-End Electronics
393	FEB	Front-End Board
394		
395		
396	G	
397		
398	GE-/-	Find a good description
399	GE1/1	Find a good description
400	GE2/1	Find a good description
401	GEANT	GEometry ANd Tracking - a series of software toolkit platforms developed by CERN
402		
403	GEM	Gas Electron Multiplier
404	GIF	Gamma Irradiation Facility
405	GIF++	new Gamma Irradiation Facility
406		
407		
408	H	
409		
410	HL-LHC	High Luminosity LHC
411	HPL	High-pressure laminate
412	HV	High Voltage
413		
414		
415	I	
416		
417	iRPC	improved RPC
418	IRQ	Interrupt Request
419	ISR	Intersecting Storage Rings
420		
421		
422	L	
423		
424	LEIR	Low Energy Ion Ring
425	LEP	Large Electron-Positron
426	LHC	Large Hadron Collider
427	LS1	First Long Shutdown
428	LS3	Third Long Shutdown
429	LV	Low Voltage
430	LVDS	Low-Voltage Differential Signaling
431		
432		
433	M	
434		
435	MC	Monte Carlo

436	MCNP	Monte Carlo N-Particle
437	ME-/	Find good description
438	ME0	Find good description
439	MRPC	Multigap RPC
440		
441	N	
442		
443		
444	NIM	Nuclear Instrumentation Module logic signals
445		
446		
447	P	
448		
449	PS	Proton Synchrotron
450	PMT	PhotoMultiplier Tube
451		
452		
453	R	
454		
455	RE-/	Find a good description
456	RE2/2	Find a good description
457	RE3/1	Find a good description
458	RE3/2	Find a good description
459	RE4/1	Find a good description
460	RE4/2	Find a good description
461	RE4/3	Find a good description
462	RMS	Root Mean Square
463	ROOT	a framework for data processing born at CERN
464	RPC	Resistive Plate Chamber
465		
466		
467	S	
468		
469	SC	Synchrocyclotron
470	SM	Standard Model
471	SPS	Super Proton Synchrotron
472		
473		
474	T	
475		
476	TDC	Time-to-Digital Converter
477	ToF	Time-of-flight

478

479

480

481

482 webDCS

W

Web Detector Control System

1

Introduction

483

484

⁴⁸⁵ **1.1 A story of High Energy Physics**

⁴⁸⁶ **1.2 Organisation of this study**

2

487

488

Investigating the TeV scale

489 Throughout history, physics experiment became more and more powerful in order to investigate finer
490 details of nature and helped understanding the elementary blocks of matter and the fundamental interactions
491 that bond them in the microscopic world. Nowadays, the Standard Model (SM) of particle physics is the most accurate theory designed to explain the behaviour of particles and was able to make very precise predictions that are constantly verified, although some hints of new physics are visible as bricks are still missing to have a global comprehension of the Universe.

495 To highlight the limits of the SM and test the different alternative theories, ever more powerful machines are needed. This is in this context that the Large Hadron Collider (LHC) has been thought
496 and built to accelerate and collide particles at energies exceeding anything that had been done before.
497 Higher collision energies and high pile-up imply the use of enormous detectors to measure the properties of the interaction products. The Compact Muon Solenoid (CMS) is a multipurpose experiment that have been designed to study the proton-proton collisions of the LHC and give answers on various high energy physics scenari. Nevertheless, the luminosity delivered by the collider will in the future be increased to levels beyond the original plans to improve its discovery potential giving no choice to experiments such as CMS to upgrade their technologies to cope with the increased radiation levels and detection rates.

505 2.1 The Standard Model of Particle Physics

506 In this early 21st century it is now widely accepted that matter is made of elementary blocks referred
507 to as *elementary particles*. The physics theory that describes the best the behaviour and interaction
508 of such elementary particles is the so called Standard Model that formalizes 3 of the 4 fundamental
509 interactions (electromagnetic, weak and strong interactions).

510 2.2 The Large Hadron Collider & the Compact Muon Solenoid

511 Throughout its history, CERN has played a leading role in high energy particle physics. Large
512 regional facilities such as CERN were thought after the second world war in an attempt to increase
513 international scientific collaboration and allows scientists to share the forever increasing costs of
514 experiment facilities required due to the need for increasing the energy in the center of mass to
515 deeper probe matter. The construction of the first accelerators at the end of the 50s, the Synchro-
516 cyclotron (SC) and the Proton Synchrotron (PS), was directly followed by the first observation of
517 antinuclei in 1965 [1]. Strong from the experience of the Intersecting Storage Rings (ISR), the very
518 first proton-proton collider that showed hints that protons are not elementary particles, the Super
519 Proton Synchrotron (SPS) was built in the 70s to investigate the structure of protons, the preference
520 for matter over antimatter, the state of matter in the early universe or exotic particles, and lead to
521 the discovery in 1983 of the W and Z bosons [2–5]. These newly discovered particles and the elec-
522 troweak interaction would then be studied in details by the Large Electron-Positron (LEP) collider
523 that will help to prove in 1989 that there only are three generations of elementary particles [6]. The
524 LEP would then be dismantled in 2000 to allow for the LHC to be constructed in the existing tunnel.

525 2.2.1 LHC, the most powerful particle accelerator

526 The LHC has always been considered as an option to the future of CERN. At the moment of the
527 construction of the LEP beneath the border between France and Switzerland, the tunnel was built in
528 order to accomodate what would be a Large Hadron Collider with a dipole field of 10 T and a beam
529 energy in between 8 and 9 TeV [7] directly followed in 1985 with the creation of a 'Working Group
530 on the Scientific and Technological Future of CERN' to investigate such a collider [8]. The decision
531 was finally taken almost 10 years later, in 1994, to construct the LHC in the LEP tunnel [9] and the
532 approval of the 4 main experiments that would take place at the 4 interaction points would come in
533 1997 [10] and 1998 [11]:

- 534 • ALICE [12] has been designed in the purpose of studying quark-gluon plasma that is believed
535 to have been a state of matter that existed in the very first moment of the universe.
- 536 • ATLAS [13] and CMS [14] are general purpose experiments that have been designed with
537 the goal of continuing the exploration of the Standard Model and investigate new physics.
- 538 • LHCb [15] has been designed to investigate the preference of matter over antimatter in the
539 universe through the CP violation.

540 These large scale experiments, as well as the full CERN accelerator complex, are displayed on
541 Figure 2.1.

CERN's Accelerator Complex




Figure 2.1: CERN accelerator complex.

542 The LHC is a 27 km long hadron collider and the most powerful accelerator used for particle
 543 physics since 2008 [16]. The LHC was originally designed to collide protons at a center-of-mass
 544 energy of 14 TeV and luminosity of $10^{34} \text{ cm}^{-2}\text{s}^{-1}$, as well as Pb ions at a center-of-mass energy
 545 of 2.8 TeV/A with a peak luminosity of $10^{27} \text{ cm}^{-2}\text{s}^{-1}$. Run 1 of LHC, when the center-of-mass
 546 energy only was half of the nominal LHC energy, was enough for both CMS and ATLAS to dis-
 547 cover the Higgs boson [17] and for LHCb to discover pentaquarks [18] and confirm the existance of
 548 tetraquarks [19]. Nevertheless, after the Third Long Shutdown (LS3) (2024-2026), the accelerator
 549 will be in the so called High Luminosity LHC (HL-LHC) configuration [20], increasing its instan-
 550 taneous luminosity to $10^{35} \text{ cm}^{-2}\text{s}^{-1}$ for pp collisions and to $4.5 \times 10^{27} \text{ cm}^{-2}\text{s}^{-1}$, boosting the
 551 discovery potential of the LHC.

552 **2.2.1.1 Particle acceleration**

553 The LHC is the last of a long series of accelerating devices. Before being accelerated by the LHC,
 554 the particles need to pass through different acceleration stages. All these acceleration stages are

555 visible on Figure 2.1 and pictures of the accelerators are showed in Figure 2.2.

556

557 The story of accelerated protons at CERN starts with a bottle of hydrogen gas injected into the
558 source chamber of the linear particle accelerator *LINAC 2* in which a strong electric field strips the
559 electron off the hygrodien molecules only to keep their nuclei, the protons. The cylindrical conductors,
560 alternatively positively or negatively charged by radiofrequency cavities, accelerate protons by
561 pushing them from behing and pulling them from the front and ultimately give them an energy of
562 50 MeV, increasing their mass by 5% in the process.

563

564 When exiting the LINAC 2, the protons are divided into 4 bunches and injected into the 4 su-
565 perimposed synchrotron rings of the *Booster* where they are then accelerated to reach an energy of
566 1.4 GeV before being injected into the *PS*. Before the Booster was operational in 1972, the protons
567 were directly injected into the PS from the LINAC 2 but the low injection energy limited the amount
568 of protons that could be accelerated at once by the PS. With the Booster, the PS accepts approxi-
569 mately 100 times more particles.

570

571 The 4 proton bunches are thus sent as one to the PS where their energy eventually reaches
572 26 GeV. Since the 70s, the main goal of this 628 m circumference synchrotron has been to sup-
573 ply other machines with accelerated particles. Nowadays, not only the PS accelerates protons, it also
574 accelerates heavy ions from the *Low Energy Ion Ring (LEIR)*. Indeed, the LHC experiments are not
575 only designed to study *pp*-collisions but also *Pb*-collisions. Lead is first injected into the dedicated
576 linear collider *LINAC 3*, that accelerate the ions using the same principle than LINAC 2. Electrons
577 are striped off the lead ions all along the acceleration process and eventually, only bare nuclei are
578 injected in the LEIR whose goal is to transform the long ion pulses received into short dense bunches
579 for LHC. Ions injected and stored in the PS were aceelerated by the LEIR from 4.2 MeV to 72 MeV.

580

581 Directly following the PS, is finally the last acceleration stage before the LHC, the 7 km long
582 *SPS*. The SPS accelerates the protons to 450 GeV and inject proton in both LHC accelerator rings
583 that will increase their energy up to 7 TeV. When the LHC runs with heavy lead ions for ALICE
584 and LHCb, ions are injected and accelerated to reach the energy of 2.8 TeV/A.




Figure 2.2: Pictures of the different accelerators. From top to bottom: first the LINAC 2 and the Pb source of LINAC 3. Then the Booster and the LEIR. Finally, the PS, the SPS and the LHC.

585 The LHC beams are not continuous and are rather organised in bunches of particles. When in pp -
 586 collision mode, the beams are composed of 2808 bunches of 1.15×10^{11} protons separated by 25 ns.
 587 When in Pb collision mode, the 592 Pb bunches are on the contrary composed of 2.2×10^8 ions
 588 separated by 100 ns. The two parallel proton beams of the LHC are contained in a single twin-

bore magnet due to the space restriction in the LEP tunnel. Indeed, building 2 completely separate accelerator rings next to each other was impossible. The dipoles of the 1232 twin-bore magnets are showed in Figure 2.3 alongside the magnetic field generated along the dipole section to accelerate the particles. The dipoles generate a nominal field of 8.33 T, needed to give protons and lead nucleons their nominal energy. Some 392 quadrupoles, presented in Figure 2.4, are also used to focus the beams, as well as other multipoles to correct smaller imperfections.




Figure 2.3: Figure 2.3a: schematics of the LHC cryodipoles. 1: Superconducting Coils, 2: Beam pipe, 3: Heat exchanger Pipe, 4: Helium-II Vessel, 5: Superconducting Bus-bar, 6: Iron Yoke, 7: Non-Magnetic Collars, 8: Vacuum Vessel, 9: Radiation Screen, 10: Thermal Shield, 11: Auxiliary Bus-bar Tube, 12: Instrumentation Feed Throughs, 13: Protection Diode, 14: Quadrupole Bus-bars, 15: Spool Piece Bus-bars. Figure 2.3b: magnetic field and resulting motion force applied on the beam particles.




Figure 2.4: Figure 2.4a: picture of the LHC quadrupoles. Figure 2.4b: magnetic fields and resulting focussing force applied on the beam by 2 consecutive quadrupoles.

595 2.2.1.2 LHC discoveries and LHC physics program

596 The very first proton beam successfully circulated in the LHC in September 2008 directly followed
 597 by an incident leading to mechanical damage that would delay the LHC program for a year until
 598 November 2009.

599 **2.2.1.3 High Luminosity LHC**

600 **2.2.2 CMS, a multipurpose experiment**

601 **2.3 Muon Phase-II Upgrade**

602 After the more than two years lasting First Long Shutdown (LS1), the Large Hadron Collider (LHC)
 603 delivered its very first Run-II proton-proton collisions early 2015. LS1 gave the opportunity to the
 604 LHC and to the its experiments to undergo upgrades. The accelerator is now providing collisions
 605 at center-of-mass energy of 13 TeV and bunch crossing rate of 40 MHz, with a peak luminosity
 606 exceeding its design value. During the first and upcoming second LHC Long Shutdown, the Compact
 607 Muon Solenoid (CMS) detector is also undergoing a number of upgrades to maintain a high system
 608 performance [21].

609 From the LHC Phase-2 or High Luminosity LHC (HL-LHC) period onwards, i.e. past the Third
 610 Long Shutdown (LS3), the performance degradation due to integrated radiation as well as the average
 611 number of inelastic collisions per bunch crossing, or pileup, will rise substantially and become a
 612 major challenge for the LHC experiments, like CMS that are forced to address an upgrade program
 613 for Phase-II [22]. Simulations of the expected distribution of absorbed dose in the CMS detector
 614 under HL-LHC conditions, show in figure 4.16 that detectors placed close to the beamline will have
 615 to withstand high irradiation, the radiation dose being of the order of a few tens of Gy.




Figure 2.5: Absorbed dose in the CMS cavern after an integrated luminosity of 3000 fb. R is the transverse distance from the beamline and Z is the distance along the beamline from the Interaction Point at Z=0.

616 The measurement of small production cross-section and/or decay branching ratio processes, such
 617 as the Higgs boson coupling to charge leptons or the $B_s \rightarrow \mu^+\mu^-$ decay, is of major interest and
 618 specific upgrades in the forward regions of the detector will be required to maximize the physics
 619 acceptance on the largest possible solid angle. To ensure proper trigger performance within the
 620 present coverage, the muon system will be completed with new chambers. In figure 2.6 one can
 621 see that the existing Cathode Strip Chambers (CSCs) will be completed by Gas Electron Multipliers
 622 (GEMs) and Resistive Plate Chambers (RPCs) in the pseudo-rapidity region $1.6 < |\eta| < 2.4$ to
 623 complete its redundancy as originally scheduled in the CMS Technical Proposal [23].




Figure 2.6: A quadrant of the muon system, showing DTs (yellow), RPCs (light blue), and CSCs (green). The locations of new forward muon detectors for Phase-II are contained within the dashed box and indicated in red for GEM stations (ME0, GE1/1, and GE2/1) and dark blue for improved RPC (iRPC) stations (RE3/1 and RE4/1).

624 RPCs are used by the CMS first level trigger for their good timing performances. Indeed, a very
 625 good bunch crossing identification can be obtained with the present CMS RPC system, given their
 626 fast response of the order of 1 ns. In order to contribute to the precision of muon momentum mea-
 627 surements, muon chambers should have a spatial resolution less or comparable to the contribution
 628 of multiple scattering [21]. Most of the plausible physics is covered only considering muons with
 629 $p_T < 100$ GeV thus, in order to match CMS requirements, a spatial resolution of $\mathcal{O}(\text{few mm})$ the
 630 proposed new RPC stations, as shown by the simulation in figure 2.7. According to preliminary
 631 designs, RE3/1 and RE4/1 readout pitch will be comprised between 3 and 6 mm and 5 η -partitions
 632 could be considered.




Figure 2.7: RMS of the multiple scattering displacement as a function of muon p_T for the proposed forward muon stations. All of the electromagnetic processes such as bremsstrahlung and magnetic field effect are included in the simulation.

3

633

634

Physics of Resistive plate chambers

635 A Resistive Plate Chamber (RPC) is a gaseous detector using the same physical processes described
636 in Chapter 3. It has been developed in 1981 by Santonico and Cardarelli [24], under the name of
637 *Resistive Plate Counter*, as an alternative to the local-discharge spark counters proposed in 1978
638 by Pestov and Fedotovich [25, 26]. Working with spark chambers implied using high-pressure gas
639 and high mechanical precision which the RPC simplified by formerly using a gas mixture of argon
640 and butane flowed at atmospheric pressure and a constant and uniform electric field propagated
641 in between two parallel electrode plates. Moreover, a significant increase in rate capability was
642 introduced by the use of electrode plate material with high bulk resistivity, preventing the discharge
643 from growing throughout the whole gas gap. Indeed, the effect of using resistive electrodes is that
644 the constant electric field is locally canceled out by the development of the discharge, limiting its
645 growth.

646 Through its development history, different operating modes [27–29] and new detector designs [30–
647 32] have been discovered, leading to further improvement of the rate capability of such a detector.
648 Moreover, the addition of SF_6 into the gas mix improved the stability of operation of the RPC [33,
649 34].

650 The low developing costs and easily achievable large detection areas offered by RPCs, as well as
651 the wide range of possible designs, made them a natural choice to as muon chambers and/or trigger
652 detectors in multipurpose experiments such as CMS [21] or ATLAS [35], time-of-flight detectors in
653 ALICE [36], calorimeter with CALICE [37] or even detectors for volcanic muography with ToMu-
654 Vol [38].

655 3.1 Principle

656 RPCs are ionisation detectors composed of two parallel resistive plate electrodes in between which
657 a constant electric field is set. The space in between the electrodes, referred as *gap*, is filled with a
658 dense gas that is used to generate primary ionization into the gas volume. The free charge carriers
659 (electrons and cations) created by the ionization of the gas molecules are then accelerated towards

660 the electrodes by the electric field, as shown in Figure 3.1 [39].




Figure 3.1: Different phases of the avalanche development in the RPC gas volume subjected to a constant electric field E_0 . a) An avalanche is initiated by the primary ionisation caused by the passage of a charged particle through the gas volume. b) Due to its growing size, the avalanche starts to locally influence the electric field. c) The electrons, lighter than the cations reach the anode first. d) The ions reach the cathode. While the charges have not recombined, the electric field in the small region around the avalanche stays affected and locally blind the detector.

661 RPCs being passive detectors, a current on pick-up copper read-out placed outside of the gas
 662 volume is induced by the charge accumulation during the growth of the avalanche. As a result,
 663 the time resolution of the detector is substantially increased as the output signal is generated while
 664 the electrons are still in movement. The advantage of a constant electric field, over multi-wire
 665 proportional chambers, is that the electrons are being fully accelerated from the moment charge
 666 carriers are freed and feel the full strength of the electric field that doesn't depend on the distance to
 667 the readout and that the output signal doesn't need for the electrons to be physically collected.

668 The typical gas mixture RPCs are operated with is generally composed of 3 gas compounds.

- 669 • Tetrafluoroethane ($C_2F_4H_2$), also referred to as *Freon*, is the principal compound of the RPC
 670 gas mixtures, with a typical fraction above 90%. It is used for it's high effective Townsend
 671 coefficient and the great average fast charge that allows to operate the detector with a high
 672 threshold with respect to argon, for example, that has similar effective Townsend coefficient
 673 but suffers from a lower fast charge. To operate with similar conditions, argon would require a
 674 higher electric field leading to a higher fraction of streamers, thus limiting the rate capability
 675 of the detector [40].
- 676 • Isobutane (i- C_4H_{10}), only present in a few percent in the gas mixtures, is used for its UV
 677 quenching properties [41] helping to prevent streamers due to UV photon emission during the
 678 avalanche growth.
- 679 • Sulfur hexafluoride, (SF_6), referred to simply as *SF6*, is used in very little quantities for its
 680 high electronegativity. Excess of electrons are being absorbed by the compound and streamers

are suppressed [34]. Nevertheless, a fraction of SF_6 higher than 1% will not bring any extra benefit in terms of streamer cancelation power but will lead to higher operating voltage [33], as can be understood through Figure 3.2.




Figure 3.2: Effeciency (circles and stars with 30 mV and 100 mV thresholds respectively) and streamer probability (opened circles) as function of the operating voltatge of a 2 mm single gap HPL RPC flushed with a gas mixture containing (a) 5%, (b) 2%, (c) 1% and (d) no SF_6 [33].

After an avalanche developed in the gas, a time long compared to the development of a discharge is needed to recombine the charge carriers in the electrode material due to their resistivity. This property has the advantage of affecting the local electric field and avoiding sparks in the detector but, on the other hand, the rate capability is intrinsically limited by the time constant τ_{RPC} of the detector. Using a quasi-static approximation of Maxwell's equations for weakly conducting media, it can be shown that the time constant τ_{RPC} necessary to the charge recombination at the interface in between the electrode and the gas volume is given by the Formula 3.1 [42].

$$\tau_{RPC} = \frac{\epsilon_{electrode} + \epsilon_{gas}}{\sigma_{electrode} + \sigma_{gas}} \quad (3.1)$$

A gas can be assimilated to vacuum, leading to $\epsilon_{gas} = \epsilon_0$ and $\sigma_{gas} = 0$, and the electrodes permittivity and conductivity can be written as $\epsilon_{electrode} = \epsilon_r \epsilon_0$ and $\sigma_{electrode} = 1/\rho_{electrode}$, showing the strong dependence of the time constant to the electrodes resistivity in Formula 3.2.

$$\tau_{RPC} = (\epsilon_r + 1)\epsilon_0 \times \rho_{electrode} \quad (3.2)$$

Very few materials with a low enough resistivity exist in nature. The resistivity targeted to build RPCs ranges from 10^9 to $10^{12} \Omega \cdot \text{cm}$. The most common RPC electrode materials are displayed in Table 3.1. When the doped glass and ceramics can offer short time constants of the order of 1 ms,

697 the developing cost of such materials is quite high due to the very low demand. Thus, High-pressure
 698 laminate (HPL) is often the choice for high rate experiments using very large RPC detection areas.
 699 Other experiments working at cosmic muon fluxes can safely operate with ordinary float glass.

Material	$\rho_{electrode}$ ($\Omega \cdot \text{cm}$)	ϵ_r	τ_{RPC} (ms)
Float glass	10^{12}	~ 7	~ 700
High-pressure laminate	10^{10} to 10^{12}	~ 6	~ 6 to 600
Doped glass (LR S)	10^9 to 10^{11}	~ 10	~ 1 to 100
Doped ceramics (SiN/SiC)	10^9	~ 8.5	~ 1
Doped ceramics (Ferrite)	10^8 to 10^{12}	~ 20	~ 0.2 to 2000

Table 3.1: Properties of the most used electrode materials for RPCs.

700 3.1.1 Electron drift velocity

701 Talk about the electron drift velocity and mention the time resolution of RPCs.

702 3.2 Rate capability and time resolution of Resistive Plate Cham- 703 bers

704 As already previously discussed, the electrode material plays a key role in the max intrinsic rate
 705 capability of RPCs. R&D is being done to develop at always cheaper costs material with lower
 706 resistivity. Nevertheless, the amount of charge released, i.e. the size of the discharge, if reduced
 707 leads to a smaller blind area in the detector, increasing the rate capability of the detector.

708 3.2.1 Operation modes

709 RPCs where developed early 1980s. At that time it was using an operating mode now referred to
 710 as *streamer mode*. Streamers are large discharges that develop in between the 2 electrodes enough
 711 to locally discharge the electrodes. If the electric field inside of the gas volume is strong enough,
 712 with electrons being fast compared to ions, a large and dense cloud of positive ions will develop
 713 nearby the anode and extend toward the cathode while the electrons are being collected, eventually
 714 leading to a streamer discharge due to the increase of field seen at the cathode. the field is then strong
 715 enough so that electrons are pulled out of the cathode. Electrodes, though they are a unique volume
 716 of resistive material, can be assimilated to capacitors. At the moment an electric field is applied in
 717 between their outer surfaces, the charge carriers inside of the volume will start moving leading to
 718 a situation where there is no voltage across the electrodes and a higher density of negative charges,
 719 i.e. electrons, on the inner surface of the cathode. Finally, when a streamer discharge occurs, these
 720 electrons are partially released in the gas volume contributing to increase the discharge strength until
 721 the formation of a conductive plasma, the streamer. This can be understood through Figure 3.3 [27].
 722 Streamer signals are very convenient in terms of read-out as no amplification is required with output
 723 pulses amplitudes of the order of a few tens to few hundreds of mV as can be seen on Figure 3.4.




Figure 3.3: Movement of the charge carriers in an RPC. Figure 3.3a: Voltage across an RPC whose electrode have a relative permittivity of 5 at the moment the tension is applied. Figure 3.3b: After the charge carriers moved, the electrodes are charged and there is no voltage drop over the electrodes anymore. The full potential is applied on the gas gap only. Figure 3.3c: The streamer discharge initiated by a charged particle transports electrons and cations towards the anode and cathode respectively.

When the electric field is reduced though, the electronic gain is small until the electrons get close enough to the anode and the positive ion cloud is much smaller. The electric field cannot rise to the point a field emission of electrons on the cathode is possible. The resulting signal is weak, of the order of a few mv as shown on Figure 3.4, and requires amplification. This is the *avalanche mode* of RPC operation.




Figure 3.4: Typical oscilloscope pulses in streamer mode (Figure 3.4a) and avalanche mode (Figure 3.4b). In the case of streamer mode, the very small avalanche signal is visible.




Figure 3.5: Rate capability comparison for the streamer and avalanche mode of operation. An order of magnitude in rate capability for a maximal efficiency drop of 10% is gained by using the avalanche mode over the streamer mode.

This mode offers a higher rate capability by providing smaller discharges that don't affect the electrodes charge and are more locally contained in the gas volume as was demonstrated by Crotty with Figure 3.5 [27]. The detector only stays locally blind the time the charge carriers are recombined and there is no need for electrode recharge which is a long process affecting a large portion of the detector. Another advantage of avalanche signals over streamer is the great time consistency. Figure 3.4 shows very clearly that avalanche signals have a very small time jitter. This is a natural choice for high rate experiments.

3.2.2 Detector designs and performance

Different RPC design have been used and each of them present its own advantages. Historically, the first type of RPC to have been developed is what is referred now to *narrow gap* RPC [24, 43]. After the avalanche mode has been discovered [27], it has been proven that increasing the width of the gas gap lead to higher rate capability, due to lower charge deposition per avalanche, and lower power dissipation [43]. Nevertheless, by increasing the gas gap width, the time resolution of the detector decreases. This is a natural result if the increase of active gas volume in the detector is taken into account. Indeed, for a given threshold, only the small fraction of gas closest to the cathode will provide enough gain to have a detectable signal. In the case of a wider gas volume, the active region is then larger and a larger time jitter is introduced with the variation of starting position of the avalanche, as discussed in [30]. To solve improve both the time resolution and the rate capability, different methods were used trying to get advantages of both narrow and wide gap RPCs.

748 **3.2.2.1 Double-gap RPC**

749 Double-gap RPCs are made out of 2 narrow RPC detectors. The 2 RPC gaps are stacked on top of
 750 each other as shown in Figure 3.6. This detector layout, popularized by the two multipurpose experiments
 751 CMS [21] and ATLAS [35] at LHC, can be used as an OR system in which each individual
 752 chamber participates in the output signal. The gain of such a detector is greatly reduced with respect
 753 to single-gap RPCs with an efficiency plateau reached at lower voltage, as visible on Figure 3.7.




Figure 3.6: Possible double-gap RPC layouts: a) "standard" 1D double-gap RPC, as used in CMS experiment, where the anodes are facing each other and a 1D read-out plane is sandwiched in between them, b) double read-out double-gap RPC as used in ATLAS experiment, where the cathodes are facing each other and 2 read-out planes are used on the outer surfaces. This last layout can offer the possibility to use a 2D reconstruction by using orthogonal read-out planes.




Figure 3.7: Comparison of performance of CMS double and single gap RPCs using cosmic muons [44]. Figure 3.7a: Comparison of efficiency sigmoids. Figure 3.7b: Voltage distribution at 95% of maximum efficiency. Figure 3.7c: $\Delta_{10\%}^{90\%}$ distribution.

754 **3.2.2.2 Multigap RPC (MRPC)**

755 MRPCs are layouts in which floating sub electrode plates are placed into a wide gap RPC to divide
 756 the gas volume and create a sum of narrow gaps [30, 31]. The time resolution of such a detector can
 757 reach of few tens of ps, with gas gaps of the order of a few hundred μm as shown in Figure 3.8
 758 representing ALICE Time-of-flight (ToF) MRPCs.




Figure 3.8: Presentation of ALICE MRPC using $250 \mu\text{m}$ gas gaps, $620 \mu\text{m}$ outer glass electrodes and $550 \mu\text{m}$ inner floating electrodes. More details on the labels are given in [45].

759 Sometimes used as a double multigap RPC, taking advantage of the OR of double gap RPCs,
 760 the MRPC is mainly used as ToF detector [45–49] due to its excellent timing properties that allow
 761 to perform particle identification as explained by Williams in [50]. The principle of particle iden-
 762 tification using ToF is simply the measurement of the velocity of a particle. Indeed, particles are
 763 defined by their mass (for the parameter of interest here, their electric charge being measured using
 764 the bending angle of the particles traveling through a magnetic field) and this mass can be calculated
 765 by measuring the velocity β and momentum of the particle:

$$\beta = \frac{p}{\sqrt{p^2 + m^2}} \quad (3.3)$$

766 Intuitively, it is trivial to understand that 2 different particles having the same momentum will
 767 have a different velocity due to the mass difference and thus a different flight time T_1 and T_2 through
 768 the detector and this is used to separate and identify particles. The better the time resolution of the
 769 ToF system used, the stronger will the separation be:

$$T = \frac{L}{v} = \frac{L}{c \cdot \beta}, \quad \Delta T = T_1 - T_2 = \frac{L}{c} \left(\sqrt{1 + m_1^2/p^2} - \sqrt{1 + m_2^2/p^2} \right) \cong (m_1^2 - m_2^2) \frac{L}{2cp^2} \quad (3.4)$$

770 An example of particle identification is given for the case of STAR experiment in Figure 3.9.




Figure 3.9: Particle identification applied to electrons in the STAR experiment. The identification is performed combining ToF and dE/dx measurements [50].

771 Another benefice of using such small gas gaps is the strong reduction of the average avalanche
772 volume and thus of the blind spot on MRPCs leading to an improved rate capability. Multigaps can
773 sustain backgrounds of several kHz/cm² as demonstrated in Figure 3.10.




Figure 3.10: Comparison of the detector performance of ALICE ToF MRPC [51] at fixed applied voltage (in blue) and at fixed effective voltage (in red). The effective voltage is kept fixed by increasing the applied voltage accordingly to the current drawn by the detector.

774 3.2.2.3 Charge distribution and performance limitations

775 The direct consequence of the different RPC layouts is a variation of intrinsic time resolution of the
776 RPC as the gap size decreases. An advantage is given to multigaps whose design use sub-millimeter
777 gas volumes providing very consistent signals.

778 On the charge spectrum point of view, each layout has its own advantages. When the double-gap
 779 has the highest induced over drifting charge ratio, as seen in Figure 3.11, the multigap has a charge
 780 spectrum strongly detached from the origin, as visible in Figure 3.12. A high induced over drifting
 781 charge ratio means that the double gap can be safely operated at high threshold or that at similar
 782 threshold it can be operated with a twice smaller drifting charge, meaning a higher rate capability.
 783 On the other hand, the strong detachment of the charge spectrum from the origin in the MRPC case
 784 allows to reach a higher efficiency with increasing threshold as most of the induced charge is not low
 785 due to the convolution of several single gap spectra. The range of stable efficiency increases with
 786 the number of gap, as presented in Figure 3.13.




Figure 3.11: Ratio between total induced and drifting charge have been simulated for single gap, double-gap and multigap layouts [52]. The total induced charge for a double-gap RPC is a factor 2 higher than for a multigap.




Figure 3.12: Charge spectra have been simulated for single gap, double-gap and multigap layouts [52]. It appears that when single gap shows a decreasing spectrum, double and multigap layouts exhibit a spectrum whose peak is detached from the origin. The detachment gets stronger as the number of gaps increases.




Figure 3.13: The maximal theoretical efficiency is simulated for single gap, double-gap and multigap layouts [52] at a constant gap thickness of 2 mm and using an effective Townsend coefficient of 9 mm^{-1} .

⁷⁸⁷ **3.3 Signal formation**

⁷⁸⁸ **3.4 Gas transport parameters**

4

789

790

791

Longevity studies and Consolidation of the present CMS RPC subsystem

792

4.1 Resistive Plate Chambers at CMS

793

4.1.1 Overview

794

The Resistive Plate Chambers (RPC) system, located in both barrel and endcap regions, provides a fast, independent muon trigger with a looser p_T threshold over a large portion of the pseudorapidity range ($|\eta| < 1.6$) [add reconstruction].

797

798

During High-Luminosity LHC (HL-LHC) operations the expected conditions in terms of background and pile-up will make the identification and correct P_T assignment a challenge for the Muon system. The goal of RPC upgrade is to provide additional hits to the Muon system with precise timing. All these informations will be elaborated by the trigger system in a global way enhancing the performance of the trigger in terms of efficiency and rate control. The RPC Upgrade is based on two projects: an improved Link Board System and the extension of the RPC coverage up to $|\eta| = 2.4$. [FIXME 2.4 or 2.5?]

805

806

807

808

809

810

The Link Board system, that will be described in section xxx, is responsible to process, synchronize and zero-suppress the signals coming from the RPC front end boards. The Link Board components have been produced between 2006 and 2007 and will be subjected to aging and failure in the long term. The upgraded Link Board system will overcome the aging problems described in section xxx and will allow for a more precise timing information to the RPC hits from 25 to 1 ns [ref section xxx].

811

812

813

814

815

The extension of the RPC system up to $|\eta| = 2.1$ was already planned in the CMS TDR [ref cmstdr] and staged because of budget limitations and expected background rates higher than the rate capability of the present CMS RPCs in that region. An extensive R&D program has been done in order to develop an improved RPC that fulfills the CMS requirements. Two new RPC layers in the innermost ring of stations 3 and 4 will be added with benefits to the neutron-induced background

816 reduction and efficiency improvement for both trigger and offline reconstruction.

817 4.1.2 The present RPC system

818 The RPC system is organized in 4 stations called RB1 to RB4 in the barrel region, and RE1 to RE4
 819 in the endcap region. The innermost barrel stations, RB1 and RB2, are instrumented with 2 layers
 820 of RPCs facing the innermost (RB1in and RB2in) and outermost (RB1out and RB2out) sides of the
 821 DT chambers. Every chamber is then divided from the read-out point of view into 2 or 3 η partitions
 822 called “rolls”. The RPC system consist of 480 barrel chambers and 576 endcap chambers. Details
 823 on the geometry are discussed in the paper [ref to geo paper].

824 The CMS RPC chamber is a double-gap, operated in avalanche mode to ensure reliable operation
 825 at high rates. Each RPC gap consists of two 2-mm-thick resistive High-Pressure Laminate (HPL)
 826 plates separated by a 2-mm-thick gas gap. The outer surface of the HPL plates is coated with a thin
 827 conductive graphite layer, and a voltage is applied. The RPCs are operated with a 3-component,
 828 non-flammable gas mixture consisting of 95.2% freon ($C_2H_2F_4$, known as R134a), 4.5% isobutane
 829 ($i-C_4H_{10}$), and 0.3% sulphur hexafluoride (SF_6) with a relative humidity of 40% - 50%. Readout
 830 strips are aligned in η between the 2 gas gaps. [\[Add a sentence on FEBs.\]](#)

831 The discriminated signals coming from the Front End boards feed via twisted cables (10 to 20 m
 832 long) the Link Board System located in UXC on the balconies around the detector. The Link System
 833 consist of the 1376 Link Boards (LBs) and the 216 Control Boards (CBs), placed in 108 Link Boxes.
 834 The Link Box is a custom crate (6U high) with 20 slots (for two CBs and eighteen LBs). The Link
 835 Box contains custom backplane to which the cables from the chambers are connected, as well as the
 836 cables providing the LBs and CBs power supply and the cables for the RPC FEBs control with use
 837 of the I2C protocol (trough the CB). The backplane itself contains only connectors (and no any other
 838 electronic devices).

839 The Link Board has 96 input channels (one channel corresponds to one RPC strip). The input
 840 signals are the ~ 100 ns binary pulses which are synchronous to the RPC hits, but not to the LHC
 841 clock (which drives the entire CMS electronics). Thus the first step of the FEB signals processing
 842 is synchronization, i.e. assignment of the signals to the BXes (25 ns periods). Then the data are
 843 compressed with a simple zero-suppressing algorithm (the input channels are grouped into 8 bit
 844 partitions, only the partitions with at least one nonzero bit are selected for each BX). Next, the non-
 845 empty partitions are time-multiplexed i.e. if there are more than one such partition in a given BX,
 846 they are sent one-by-one in consecutive BXes. The data from 3 neighbouring LBs are concentrated
 847 by the middle LB which contains the optical transmitter for sending them to the USC over a fiber at
 848 1.6 Gbps.

849 The Control Boards provide the communication of the control software with the LBs via the
 850 FEC/CCU system. The CBs are connected into token rings, each ring consists of 12 CBs of one
 851 detector tower and a FEC mezzanine board placed on the CCS board located in the VME crate in
 852 the USC. In total, there are 18 rings in the entire Link System. The CBs also perform automatic
 853 reloading of the LB's firmware which is needed in order to avoid accumulation of the radiation
 854 induced SEUs in the LBs firmware.

855 Both LBs and CB are based on the Xilinx Spartan III FPGAs, the CB additionally contains
 856 radiation-tolerant (FLASH based) FPGA Actel ProAsicPlus.

857 The High Voltage power system is located in USC, not exposed to radiation and easily accessible
 858 for any reparation. A single HV channel powers 2 RPC chambers both in the barrel and endcap
 859 regions. The Low Voltage boards are located in UXC on the balconies and provide the voltage to the

860 front end electronics.

861 4.1.3 Pulse processing of CMS RPCs

862 Signals induced by cosmic particle in the RPC strips are shaped by standard CMS RPC Front-End
 863 Electronics (FEE) following the scheme of Figure 4.1. On a first stage, analogic signals are amplified
 864 and then sent to the Constant Fraction Discriminator (CFD) described in Figure 4.2. At the end of
 865 the chain, 100 ns long pulses are sent in the LVDS output. These output signal are sent on one side to
 866 a V1190A Time-to-Digital Converter (TDC) module from CAEN and on the other to an OR module
 867 to count the number of detected signals. Trigger and hit coïncidences are monitored using scalers.
 868 The TDC is used to store the data into ROOT files. These files are thus analysed to understand the
 869 detectors performance.




Figure 4.1: Signals from the RPC strips are shaped by the FEE described on Figure 4.1a. Output LVDS signals are then read-out by a TDC module connected to a computer or converted into NIM and sent to scalers. Figure 4.1b describes how these converted signals are put in coincidence with the trigger.




Figure 4.2: Description of the principle of a CFD. A comparison of threshold triggering (left) and constant fraction triggering (right) is shown in Figure 4.2a. Constant fraction triggering is obtained thanks to zero-crossing technique as explained in Figure 4.2b. The signal arriving at the input of the CFD is split into three components. A first one is delayed and connected to the inverting input of a first comparator. A second component is connected to the noninverting input of this first comparator. A third component is connected to the noninverting input of another comparator along with a threshold value connected to the inverting input. Finally, the output of both comparators is fed through an AND gate.


870 4.2 Testing detectors under extreme conditions

871 The upgrade from LHC to HL-LHC will increase the peak luminosity from $10^{34} \text{ cm}^{-2} \text{ s}^{-1}$ to reach
 872 $5 \times 10^{34} \text{ cm}^{-2} \text{ s}^{-1}$, increasing in the same way the total expected background to which the RPC
 873 system will be subjected to. Composed of low energy gammas and neutrons from $p\text{-}p$ collisions, low
 874 momentum primary and secondary muons, puch-through hadrons from calorimeters, and particles
 875 produced in the interaction of the beams with collimators, the background will mostly affect the
 876 regions of CMS that are the closest to the beam line, i.e. the RPC detectors located in the endcaps.
 877 [To update.]


878

879 The 2016 data allowed to study the values of the background rate in all RPC system. In Fig-
880 ure 4.3, the distribution of the chamber background hit rate per unit area is shown at a luminosity
881 of $5 \times 10^{34} cm^{-2}.s^{-1}$ linearly extrapolating from data collected in 2016 [ref mentioning the linear
882 dependency of rate vs lumi]. The maximum rate per unit area at HL-LHC conditions is expected to
883 be of the order of $600 Hz/cm^2$ (including a safety factor 3). Nevertheless, Fluka simulations have
884 conducted in order to understand the background at HL-LHC conditions. The comparison to the
885 data has shown, in Figure 4.4, a discrepancy of a factor 2 even though the order of magnitude is
886 consistent. [Understand mismatch.]

887



(a)



(b)

Figure 4.3: (4.3a) Extrapolation from 2016 data of single hit rate per unit area in the barrel region. (4.3b) Extrapolation from 2016 data of single hit rate per unit area in the endcap region.




Figure 4.4: Background Fluka simulation compared to 2016 Data at $L = 10^{34} \text{ cm}^{-2} \cdot \text{s}^{-1}$ in the fourth endcap disk region. A mismatch in between simulation and data can be observed. [\[To be understood.\]](#)

In the past, extensive long-term tests were carried out at several gamma and neutron facilities certifying the detector performance. Both full size and small prototype RPCs have been irradiated with photons up to an integrated charge of $\sim 0.05 \text{ C/cm}^2$ and $\sim 0.4 \text{ C/cm}^2$, respectively [53, 54]. During Run-I, the RPC system provided stable operation and excellent performance and did not show any aging effects for integrated charge of the order of 0.01 C/cm^2 . Projections on currents from 2016 Data, has allowed to determine that the total integrated charge, by the end of HL-LHC, would be of the order of 1 C/cm^2 (including a safety factor 3). [\[Corresponding figure needed.\]](#)

895

896 4.2.1 The Gamma Irradiation Facilities

897 4.2.1.1 GIF

898 Located in the SPS West Area at the downstream end of the X5 test beam, the Gamma Irradiation
 899 Facility (GIF) was a test area in which particle detectors were exposed to a particle beam in presence
 900 of an adjustable gamma background [55]. Its goal was to reproduce background conditions these
 901 detectors would suffer in their operating environment at LHC. GIF layout is shown in Figure 4.5.
 902 Gamma photons are produced by a strong ^{137}Cs source installed in the upstream part of the zone
 903 inside a lead container. The source container includes a collimator, designed to irradiate a $6 \times 6 \text{ m}^2$
 904 area at 5 m maximum to the source. A thin lens-shaped lead filter helps providing with a uniform
 905 outgoing flux in a vertical plane, orthogonal to the beam direction. The principal collimator hole
 906 provides a pyramidal aperture of $74^\circ \times 74^\circ$ solid angle and provides a photon flux in a pyramidal vol-

ume along the beam axis. The photon rate is controled by further lead filters allowing the maximum rate to be limited and to vary within a range of four orders of magnitude. Particle detectors under test are then placed within the pyramidal volume in front of the source, perpendicularly to the beam line in order to profit from the homogeneous photon flux. Adjusting the background flux of photons can then be done by using the filters and choosing the position of the detectors with respect to the source.

912




Figure 4.5: Layout of the test beam zone called X5c GIF at CERN. Photons from the radioactive source produce a sustained high rate of random hits over the whole area. The zone is surrounded by 8 m high and 80 cm thick concrete walls. Access is possible through three entry points. Two access doors for personnel and one large gate for material. A crane allows installation of heavy equipment in the area.

As described on Figure 4.6, the ^{137}Cs source emits a 662 keV photon in 85% of the decays. An activity of 740 GBq was measured on the 5th March 1997. To estimate the strength of the flux in 2014, it is necessary to consider the nuclear decay through time assiciated to the Cesium source whose half-life is well known ($t_{1/2} = (30.05 \pm 0.08)$ y). The GIF tests where done in between the 20th and the 31st of August 2014, i.e. at a time $t = (17.47 \pm 0.02)$ y resulting in an attenuation of the activity from 740 GBq in 1997 to 494 GBq in 2014.

919




Figure 4.6: ^{137}Cs decays by β^- emission to the ground state of ^{137}Ba ($BR = 5.64\%$) and via the 662 keV isomeric level of ^{137}Ba ($BR = 94.36\%$) whose half-life is 2.55 min.

920 4.2.1.2 GIF++

921 The new Gamma Irradiation Facility (GIF++), located in the SPS North Area at the downstream end
 922 of the H4 test beam, has replaced its predecessor during LS1 and has been operational since spring
 923 2015 [56]. Like GIF, GIF++ features a ^{137}Cs source of 662 keV gamma photons, their fluence being
 924 controlled with a set of filters of various attenuation factors. The source provides two separated large
 925 irradiation areas for testing several full-size muon detectors with continuous homogeneous irradiation,
 926 as presented in Figure 4.7.

927




Figure 4.7: Floor plan of the GIF++ facility. When the facility downstream of the GIF++ takes electron beam, a beam pipe is installed along the beam line (z -axis). The irradiator can be displaced laterally (its center moves from $x = 0.65 \text{ m}$ to 2.15 m), to increase the distance to the beam pipe.

928 The source activity was measured to be about 13.5 TBq in March 2016. The photon flux being
 929 far greater than HL-LHC expectations, GIF++ provides an excellent facility for accelerated aging
 930 tests of muon detectors.

931




Figure 4.8: Simulated unattenuated current of photons in the xz plane (Figure 4.8a) and yz plane (Figure 4.8b) through the source at $x = 0.65$ m and $y = 0$ m. With angular correction filters, the current of 662 keV photons is made uniform in xy planes.

932 The source is situated in the muon beam line with the muon beam being available a few times a
 933 year. The H4 beam, composed of muons with a momentum of about 150 GeV/c, passes through the
 934 GIF++ zone and is used to study the performance of the detectors. Its flux is of 104 particles/ s cm^2

935 focused in an area similar to $10 \times 10 \text{ cm}^2$. Therefore, with properly adjusted filters, one can imitate
 936 the HL-LHC background and study the performance of muon detectors with their trigger/readout
 937 electronics in HL-LHC environment.

938

939 4.3 Preliminary tests at GIF

940 4.3.1 Resistive Plate Chamber test setup

941 During summer 2014, preliminary tests have been conducted in the GIF area on a newly produced
 942 RE4/2 chamber labelled RE-4-2-BARC-161. This chamber has been placed into a trolley covered
 943 with a tent. The position of the RPC inside the tent and of the tent related to the source is described
 944 in Figure 4.9. To test this CMS RPC, three different absorber settings were used. First of all,
 945 measurements were done with fully opened source. Then, to complete this preliminary study, the
 946 gamma flux has been attenuated from a factor 2 and a factor 5. The expected gamma flux at the level
 947 of our detector will be discussed in subsection ??.




Figure 4.9: Description of the RPC setup. Dimensions are given in mm. A tent containing RPCs is placed at 1720 mm from the source container. The source is situated in the center of the container. RE-4-2-BARC-161 chamber is 160 mm inside the tent. This way, the distance between the source and the chambers plan is 2060 mm. Figure 4.9a provides a side view of the setup in the xz plane while Figure 4.9b shows a top view in the yz plane.



Figure 4.10: RE-4-2-BARC-I61 chamber is inside the tent as described in Figure 4.9. In the top right, the two scintillators used as trigger can be seen. This trigger system has an inclination of 10° relative to horizontal and is placed above half-partition B2 of the RPCs. PMT electronics are shielded thanks to lead blocks placed in order to protect them without stopping photons from going through the scintillators and the chamber.

948 At the time of the tests, the beam not being operational anymore, a trigger composed of 2 plastic
 949 scintillators has been placed in front of the setup with an inclination of 10 deg with respect to the
 950 detector plane in order to look at cosmic muons. Using this particular trigger layout, shown on Fig-
 951 ure 4.10, leads to a cosmic muon hit distribution into the chamber similar to the one in Figure 4.11.
 952 Measured without gamma irradiation, two peaks can be seen on the profile of partition B, centered
 953 on strips 52 and 59. Section ?? will help us understand that these two peaks are due respectively to
 954 forward and backward coming cosmic particles where forward coming particles are first detected by
 955 the scintillators and then the RPC while the backward coming muons are first detected in the RPC.




Figure 4.11: Hit distributions over all 3 partitions of RE-4-2-BARC-161 chamber is showed on these plots. Top, middle and bottom figures respectively correspond to partitions A, B, and C. These plots show that some events still occur in other half-partitions than B2, which corresponds to strips 49 to 64, in front of which the trigger is placed, contributing to the inefficiency of detection of cosmic muons. In the case of partitions A and C, the very low amount of data can be interpreted as noise. On the other hand, it is clear that a little portion of muons reach the half-partition B1, corresponding to strips 33 to 48.

956 4.3.2 Data Acquisition

957 4.3.3 Geometrical acceptance of the setup layout to cosmic muons

958 In order to profit from a constant gamma irradiation, the detectors inside of the GIF bunker need
 959 to be placed in a plane orthogonal to the beam line. The muon beam that used to be available was
 960 meant to test the performance of detectors under test. This beam not being active anymore, another
 961 solution to test detector performance had to be used. Thus, it has been decided to use cosmic muons
 962 detected through a telescope composed of two scintillators. Lead blocks were used as shielding to

963 protect the photomultipliers from gammas as can be seen from Figure 4.10.

964 An inclination has been given to the cosmic telescope to maximize the muon flux. A good com-
 965 promise had to be found between good enough muon flux and narrow enough hit distribution to
 966 be sure to contain all the events into only one half partitions as required from the limited available
 967 readout hardware. Nevertheless, a consequence of the misplaced trigger, that can be seen as a loss
 968 of events in half-partition B1 in Figure 4.11, is an inefficiency. Nevertheless, the inefficiency of ap-
 969 proximately 20 % highlighted in Figure 4.12 by comparing the performance of chamber BARC-161
 970 in 904 and at GIF without irradiation seems too important to be explained only by the geometri-
 971 cal acceptance of the setup itself. Simulations have been conducted to show how the setup brings
 972 inefficiency.




Figure 4.12: Results are derived from data taken on half-partition B2 only. On the 18th of June 2014, data has been taken on chamber RE-2-BARC-161 at building 904 (Prevessin Site) with cosmic muons providing us a reference efficiency plateau of $(97.54 \pm 0.15)\%$ represented by a black curve. A similar measurement has been done at GIF on the 21st of July with the same chamber giving a plateau of $(78.52 \pm 0.94)\%$ represented by a red curve.

973 4.3.3.1 Description of the simulation layout

974 The layout of GIF setup has been reproduced and incorporated into a Monte Carlo (MC) simulation
 975 to study the influence of the disposition of the telescope on the final distribution measured by the
 976 RPC. A 3D view of the simulated layout is given into Figure 4.13. Muons are generated randomly
 977 in a horizontal plane located at a height corresponding to the lowest point of the PMTs. This way,
 978 the needed size of the plane in order to simulate events happening at very big azimuthal angles (i.e.
 979 $\theta \approx \pi$) can be kept relatively small. The muon flux is designed to follow the usual $\cos^2\theta$ distribution
 980 for cosmic particle. The goal of the simulation is to look at muons that pass through the muon
 981 telescope composed of the two scintillators and define their distribution onto the RPC plane. During
 982 the reconstruction, the RPC plane is then divided into its strips and each muon track is assigned to a
 983 strip.




Figure 4.13: Representation of the layout used for the simulations of the test setup. The RPC is represented as a yellow trapezoid while the two scintillators as blue cuboids looking at the sky. A green plane corresponds to the muon generation plane within the simulation. Figure 4.9a shows a global view of the simulated setup. Figure 4.9b shows a zoomed view that allows to see the 2 scintillators as well as the full RPC plane.

984 In order to further refine the quality of the simulation and understand deeper the results the
 985 dependance of the distribution has been studied for a range of telescope inclinations. Moreover,
 986 the threshold applied on the PMT signals has been included into the simulation in the form of a
 987 cut. In the approximation of uniform scintillators, it has been considered that the threshold can be
 988 understood as the minimum distance particles need to travel through the scintillating material to give
 989 a strong enough signal. Particles that travel a distance smaller than the set "threshold" are thus not
 990 detected by the telescope and cannot trigger the data taking. Finally, the FEE threshold also has
 991 been considered in a similar way. The mean momentum of horizontal cosmic rays is higher than
 992 those of vertical ones but the stopping power of matter for momenta ranging from 1 GeV to 1 TeV
 993 stays comparable. It is then possible to assume that the mean number of primary e^-/ion pairs per
 994 unit length will stay similar and thus, depending on the applied discriminator threshold, muons with

995 the shortest path through the gas volume will deposit less charge and induce a smaller signal on the
 996 pick-up strips that could eventually not be detected. These two thresholds also restrain the overall
 997 geometrical acceptance of the system.

998 **4.3.3.2 Simulation procedure**

999 The simulation software has been designed using C++ and the output data is saved into ROOT
 1000 histograms. Simulations start for a threshold T_{scint} varying in a range from 0 to 45 mm in steps
 1001 of 5 mm, where $T_{scint} = 0$ mm corresponds to the case where there isn't any threshold apply on
 1002 the input signal while $T_{scint} = 45$ mm, which is the scintillator thickness, is the case where muons
 1003 cannot arrive orthogonally onto the scintillator surface. For a given T_{scint} , a set of RPC thresholds
 1004 are considered. The RPC threshold, T_{RPC} varies from 2 mm, the thickness of the gas volume, to
 1005 3 mm in steps of 0.25 mm. For each $(T_{scint}; T_{RPC})$ pair, $N_\mu = 10^8$ muons are randomly generated
 1006 inside the muon plane described in the previous paragraph with an azimuthal angle θ chosen to follow
 1007 a $\cos^2\theta$ distribution.

1008 Planes are associated to each surface of the scintillators. Knowing muon position into the muon
 1009 plane and its direction allows us, by assuming that muons travel in a straight line, to compute the
 1010 intersection of the muon track with these planes. Applying conditions to the limits of the surfaces
 1011 of the scintillator faces then gives us an answer to whether or not the muon passed through the
 1012 scintillators. In the case the muon has indeed passed through the telescope, the path through each
 1013 scintillator is computed and muons whose path was shorter than T_{scint} are rejected and are thus
 1014 considered as having not interacted with the setup.

1015 On the contrary, if the muon is labeled as good, its position within the RPC plane is computed
 1016 and the corresponding strip, determined by geometrical tests in the case the distance through the
 1017 gas volume was enough not to be rejected because of T_{RPC} , gets a hit and several histograms
 1018 are filled in order to keep track of the generation point on the muon plane, the intersection points
 1019 of the reconstructed muons within the telescope, or on the RPC plane, the path traveled through
 1020 each individual scintillator or the gas volume, as well as other histograms. Moreover, muons fill
 1021 different histograms whether they are forward or backward coming muons. They are discriminated
 1022 according to their direction components. When a muon is generated, an (x, y, z) position is assigned
 1023 into the muon plane as well as a $(\theta; \phi)$ pair that gives us the direction it's coming from. This way,
 1024 muons satisfying the condition $0 \leq \phi < \pi$ are designated as backward coming muons while muons
 1025 satisfying $\pi \leq \phi < 2\pi$ as forward coming muons.

1026 This simulation is then repeated for different telescope inclinations ranging in between 4 and 20°
 1027 and varying in steps of 2° . Due to this inclination and to the vertical position of the detector under
 1028 test, the muon distribution reconstructed in the detector plane is asymmetrical. The choice as been
 1029 made to chose a skew distribution formula to fit the data built as the multiplication of gaussian and
 1030 sigmoidal curves together. A typical gaussian formula is given as 4.1 and has three free parameters
 1031 as A_g , its amplitude, \bar{x} , its mean value and σ , its root mean square. Sigmoidal curves as given by
 1032 formula 4.2 are functions converging to 0 and A_s as x diverges. The inflexion point is given as x_i
 1033 and λ is proportional to the slope at $x = x_i$. In the limit where $\lambda \rightarrow \infty$, the sigmoid becomes a
 1034 step function.

$$g(x) = A_g e^{-\frac{(x-\bar{x})^2}{2\sigma^2}} \quad (4.1)$$

$$s(x) = \frac{A_s}{1 + e^{-\lambda(x-x_i)}} \quad (4.2)$$

Finally, a possible representation of a skew distribution is given by formula 4.3 and is the product of 4.1 and 4.2. Naturally, here $A_{sk} = A_g \times A_s$ and represents the theoretical maximum in the limit where the skew tends to a gaussian function.

$$sk(x) = g(x) \times s(x) = A_{sk} \frac{e^{\frac{-(x-\bar{x})^2}{2\sigma^2}}}{1 + e^{-\lambda(x-x_i)}} \quad (4.3)$$

4.3.3.3 Results

Influence of T_{scint} on the muon distribution

Influence of T_{RPC} on the muon distribution

Influence of the telescope inclination on the muon distribution

Comparison to data taken at GIF without irradiation

4.3.4 Photon flux at GIF

4.3.4.1 Expectations from simulations

In order to understand and evaluate the γ flux in the GIF area, simulations had been conducted in 1999 and published by S. Agosteo et al [55]. Table 4.1 presented in this article gives us the γ flux for different distances D to the source. This simulation was done using GEANT and a Monte Carlo N-Particle (MCNP) transport code, and the flux F is given in number of γ per unit area and unit time along with the estimated error from these packages expressed in %.

Nominal ABS	Photon flux F [$s^{-1}cm^{-2}$]			
	at $D = 50$ cm	at $D = 155$ cm	at $D = 300$ cm	at $D = 400$ cm
1	$0.12 \cdot 10^8 \pm 0.2\%$	$0.14 \cdot 10^7 \pm 0.5\%$	$0.45 \cdot 10^6 \pm 0.5\%$	$0.28 \cdot 10^6 \pm 0.5\%$
2	$0.68 \cdot 10^7 \pm 0.3\%$	$0.80 \cdot 10^6 \pm 0.8\%$	$0.25 \cdot 10^6 \pm 0.8\%$	$0.16 \cdot 10^6 \pm 0.6\%$
5	$0.31 \cdot 10^7 \pm 0.4\%$	$0.36 \cdot 10^6 \pm 1.2\%$	$0.11 \cdot 10^6 \pm 1.2\%$	$0.70 \cdot 10^5 \pm 0.9\%$

Table 4.1: Total photon flux ($E\gamma \leq 662$ keV) with statistical error predicted considering a ^{137}Cs activity of 740 GBq at different values of the distance D to the source along the x -axis of irradiation field [55].




Figure 4.14: γ flux $F(D)$ is plot using values from table 4.1. As expected, the plot shows similar attenuation behaviours with increasing distance for each absorption factors.

The simulation doesn't directly provides us with an estimated flux at the level of our RPC. First of all, it is needed to extract the value of the flux from the available data contained in the original paper and then to estimate the flux in 2014 at the time the experimentation took place. Figure 4.14 that contains the data from Table 4.1. In the case of a pointlike source emitting isotropic and homogeneous gamma radiations, the gamma flux F at a distance D to the source with respect to a reference point situated at D_0 where a known flux F_0 is measured will be expressed like in Equation 4.4, assuming that the flux decreases as $1/D^2$, where c is a fitting factor.

$$F^{ABS} = F_0^{ABS} \times \left(\frac{cD_0}{D} \right)^2 \quad (4.4)$$

By rewriting Equation 4.4, it comes that :

$$c = \frac{D}{D_0} \sqrt{\frac{F^{ABS}}{F_0^{ABS}}} \quad (4.5)$$

$$\Delta c = \frac{c}{2} \left(\frac{\Delta F^{ABS}}{F^{ABS}} + \frac{\Delta F_0^{ABS}}{F_0^{ABS}} \right) \quad (4.6)$$

Finally, using Equation 4.5 and the data in Table 4.1 with $D_0 = 50$ cm as reference point, we can build Table 4.2. It is interesting to note that c for each value of D doesn't depend on the absorption factor.

Nominal ABS	Correction factor c		
	at $D = 155$ cm	at $D = 300$ cm	at $D = 400$ cm
1	$1.059 \pm 0.70\%$	$1.162 \pm 0.70\%$	$1.222 \pm 0.70\%$
2	$1.063 \pm 1.10\%$	$1.150 \pm 1.10\%$	$1.227 \pm 0.90\%$
5	$1.056 \pm 1.60\%$	$1.130 \pm 1.60\%$	$1.202 \pm 1.30\%$

Table 4.2: Correction factor c is computed thanks to formulae 4.5 taking as reference $D_0 = 50$ cm and the associated flux F_0^{ABS} for each absorption factor available in table 4.1.

1061 For the range of D/D_0 values available, it is possible to use a simple linear fit to get the evolution
 1062 of c . The linear fit will then use only 2 free parameters, a and b , as written in Equation 4.7. This gives
 1063 us the results showed in Figure 4.15. Figure 4.15b confirms that using only a linear fit to extract c is
 1064 enough as the evolution of the rate that can be obtained superimposes well on the simulation points.

$$c \left(\frac{D}{D_0} \right) = a \frac{D}{D_0} + b \quad (4.7)$$

$$F^{ABS} = F_0^{ABS} \left(a + \frac{bD_0}{D} \right)^2 \quad (4.8)$$

$$\Delta F^{ABS} = F^{ABS} \left[\frac{\Delta F_0^{ABS}}{F_0^{ABS}} + 2 \frac{\Delta a + \Delta b \frac{D_0}{D}}{a + \frac{bD_0}{D}} \right] \quad (4.9)$$




Figure 4.15: Figure 4.15a shows the linear approximation fit done via formulae 4.7 on data from table 4.2. Figure 4.15b shows a comparison of this model with the simulated flux using a and b given in figure 4.15a in formulae 4.4 and the reference value $D_0 = 50\text{cm}$ and the associated flux for each absorption factor F_0^{ABS} from table 4.1

In the case of the 2014 GIF tests, the RPC plane is located at a distance $D = 206$ cm to the source. Moreover, to estimate the strength of the flux in 2014, it is necessary to consider the nuclear decay through time associated to the Cesium source whose half-life is well known ($t_{1/2} = (30.05 \pm 0.08)$ y). The very first source activity measurement has been done on the 5th of March 1997 while the GIF

1069 tests where done in between the 20th and the 31st of August 2014, i.e. at a time $t = (17.47 \pm 0.02)$ y
 1070 resulting in an attenuation of the activity from 740 GBq in 1997 to 494 GBq in 2014. All the needed
 1071 information to extrapolate the flux through our detector in 2014 has now been assembled, leading
 1072 to the Table 4.3. It is interesting to note that for a common RPC sensitivity to γ of $2 \cdot 10^{-3}$, the
 1073 order of magnitude of the estimated hit rate per unit area is of the order of the kHz for the fully
 1074 opened source. Moreover, taking profit of the two working absorbers, it will be possible to scan
 1075 background rates at 0 Hz, ~ 300 Hz as well as ~ 600 Hz. Without source, a good estimate of the
 1076 intrinsic performance will be available. Then at 300 Hz, the goal will be to show that the detectors
 1077 fulfill the performance certification of CMS RPCs. Then a first idea of the performance of the
 1078 detectors at higher background will be provided with absorption factors 2 (~ 600 Hz) and 1 (no
 1079 absorption). *[Here I will also put a reference to the plot showing the estimated background rate at
 1080 the level of RE3/1 in the case of HL-LHC but this one being in another chapter, I will do it later.]*

Nominal ABS	Photon flux F [$s^{-1}cm^{-2}$]			Hit rate/unit area [$Hz cm^{-2}$] at $D^{2014} = 206$ cm
	at $D_0^{1997} = 50$ cm	at $D^{1997} = 206$ cm	at $D^{2014} = 206$ cm	
1	$0.12 \cdot 10^8 \pm 0.2\%$	$0.84 \cdot 10^6 \pm 0.3\%$	$0.56 \cdot 10^6 \pm 0.3\%$	1129 ± 32
2	$0.68 \cdot 10^7 \pm 0.3\%$	$0.48 \cdot 10^6 \pm 0.3\%$	$0.32 \cdot 10^6 \pm 0.3\%$	640 ± 19
5	$0.31 \cdot 10^7 \pm 0.4\%$	$0.22 \cdot 10^6 \pm 0.3\%$	$0.15 \cdot 10^6 \pm 0.3\%$	292 ± 9

Table 4.3: The data at D_0 in 1997 is taken from [55]. In a second step, using Equations 4.8 and 4.9, the flux at D can be estimated in 1997. Then, taking into account the attenuation of the source activity, the flux at D can be estimated at the time of the tests in GIF in 2014. Finally, assuming a sensitivity of the RPC to γ $s = 2 \cdot 10^{-3}$, an estimation of the hit rate per unit area is obtained.

¹⁰⁸¹ **4.3.4.2 Dose measurements**




Figure 4.16: Dose measurements has been done in a plane corresponding to the tents front side. This plan is 1900 mm away from the source. As explained in the first chapter, a lens-shaped lead filter provides a uniform photon flux in the vertical plan orthogonal to the beam direction. If the second line of measured fluxes is not taken into account because of lower values due to experimental equipments in the way between the source and the tent, the uniformity of the flux is well showed by the results.

¹⁰⁸² **4.3.5 Results and discussions**




Figure 4.17

1083 4.4 Longevity tests at GIF++

1084 Longevity studies imply a monitoring of the performance of the detectors probed using a high inten-
1085 sity muon beam in a irradiated environment by periodically measuring their rate capability, the dark
1086 current running through them and the bulk resistivity of the Bakelite composing their electrodes.
1087 GIF++, with its very intense ^{137}Cs source, provides the perfect environment to perform such kind
1088 of tests. Assuming a maximum acceleration factor of 3, it is expected to accumulate the equivalent
1089 charge in 1.7 years.

1090 As the maximum background is found in the endcap, the choice naturally was made to focus the
1091 GIF++ longevity studies on endcap chambers. Most of the RPC system was installed in 2007. Nev-
1092 ertheless, the large chambers in the fourth endcap (RE4/2 and RE4/3) have been installed during
1093 LS1 in 2014. The Bakelite of these two different productions having different properties, four spare
1094 chambers of the present system were selected, two RE2,3/2 spares and two RE4/2 spares. Having
1095 two chambers of each type allows to always keep one of them non irradiated as reference, the per-
1096 formance evolution of the irradiated chamber being then compared through time to the performance
1097 of the non irradiated one.

1098 The performance of the detectors under different level of irradiation is measured periodically dur-
1099 ing dedicated test beam periods using the H4 muon beam. In between these test beam periods, the
1100 two RE2,3/2 and RE4/2 chambers selected for this study are irradiated by the ^{137}Cs source in order
1101 to accumulate charge and the gamma background is monitored, as well as the currents. The two
1102 remaining chambers are kept non-irradiated as reference detectors. Due to the limited gas flow in
1103 GIF++, the RE4 chamber remained non-irradiated until end of November 2016 where a new mass
1104 flow controller has been installed allowing for bigger volumes of gas to flow in the system.

1105 Figures 4.18 and 4.19 give us for different test beam periods, and thus for increasing integrated
1106 charge through time, a comparison of the maximum efficiency, obtained using a sigmoid-like func-
1107 tion, and of the working point of both irradiated and non irradiated chambers [**SIGMOID2005**]. No
1108 aging is yet to see from this data, the shifts in γ rate per unit area in between irradiated and non
1109 irradiated detectors and RE2 and RE4 types being easily explained by a difference of sensitivity due
1110 to the various Bakelite resistivities of the HPL electrodes used for the electrode production.

1111 Collecting performance data at each test beam period allows us to extrapolate the maximum effi-
1112 ciency for a background hit rate of $300\text{ Hz}/\text{cm}^2$ corresponding to the expected HL-LHC conditions.
1113 Aging effects could emerge from a loss of efficiency with increasing integrated charge over time,
1114 thus Figure 4.20 helps us understand such degradation of the performance of irradiated detectors in
1115 comparison with non irradiated ones. The final answer for an eventual loss of efficiency is given in
1116 Figure 4.21 by comparing for both irradiated and non irradiated detectors the efficiency sigmoids
1117 before and after the longevity study. Moreover, to complete the performance information, the Bake-
1118 lite resistivity is regularly measured thanks to Ag scans (Figure 4.22) and the noise rate is monitored
1119 weekly during irradiation periods (Figure 4.23). At the end of 2016, no signs of aging were observed
1120 and further investigation is needed to get closer to the final integrated charge requirements proposed
1121 for the longevity study of the present CMS RPC sub-system.

1122




Figure 4.18: Evolution of the maximum efficiency for RE2 (4.18a) and RE4 (4.18b) chambers with increasing extrapolated γ rate per unit area at working point. Both irradiated (blue) and non irradiated (red) chambers are shown.




Figure 4.19: Evolution of the working point for RE2 (4.19a) and RE4 (4.19b) with increasing extrapolated γ rate per unit area at working point. Both irradiated (blue) and non irradiated (red) chambers are shown.




Figure 4.20: Evolution of the maximum efficiency at HL-LHC conditions, i.e. a background hit rate per unit area of 300 Hz/cm², with increasing integrated charge for RE2 (4.20a) and RE4 (4.20b) detectors. Both irradiated (blue) and non irradiated (red) chambers are shown. The integrated charge for non irradiated detectors is recorded during test beam periods and stays small with respect to the charge accumulated in irradiated chambers.




Figure 4.21: Comparison of the efficiency sigmoid before (triangles) and after (circles) irradiation for RE2 (4.21a) and RE4 (4.21b) detectors. Both irradiated (blue) and non irradiated (red) chambers are shown.




Figure 4.22: Evolution of the Bakelite resistivity for RE2 (4.22a) and RE4 (4.22b) detectors. Both irradiated (blue) and non-irradiated (red) chambers are shown.




Figure 4.23: Evolution of the noise rate per unit area for the irradiated chamber RE2-2-BARC-9 only.

4.4.1 Description of the Data Acquisition

For the longevity studies, four spare chambers of the present system are used. Two spare RPCs of the RE2,3 stations as well as two spare RPCs from the new RE4 stations have been mounted in a Trolley. Six RE4 gaps are also placed in the trolley. The trolley is placed inside the GIFT++ in the upstream region of the bunker, taking the cesium source as a reference. The trolley is oriented for the detection surface of the chambers to be orthogonal to the beam line. The system can be moved along the orthogonal plane in order to have the beam in all η -partitions. For the aging the trolley is

1130 moved outside the beam line and is placed in a distance of 5.2 m to the source, which irradiates the
 1131 bunker using an attenuation filter of 2.2 which corresponds to a fluence of 10^7 gamma/cm^2 .

1132 During GIF++ operation, the data collected can be divided into different categories as several
 1133 parameters are monitored in addition to the usual RPC performance data. On one hand, to know
 1134 the performance of a chamber, it is need to measure its efficiency and to know the background
 1135 conditions in which it is operated. To do this, the hit signals from the chamber are recorded and
 1136 stored in a ROOT file via a Data Acquisition (DAQ) software. On the other hand, it is also very
 1137 important to monitor parameters such as environmental pressure and temperature, gas temperature
 1138 and humidity, RPC HV, LV, and currents, or even source and beam status. This is done through the
 1139 GIF++ web Detector Control Software (DCS) that stores this information in a database.

1140 Two different types of tests are conducted on RPCs via the DAQ. Indeed, the performance of the
 1141 detectors is measured periodically during dedicated test beam periods using the H4 muon beam. In
 1142 between these test beam periods, when the beam is not available, the chambers are irradiated by the
 1143 ^{137}Cs in order to accumulate deposited charge and the gamma background is measured.

1144 RPCs under test are connected through LVDS cables to V1190A Time-to-Digital Converter
 1145 (TDC) modules manufactured by CAEN. These modules, located in the rack area outside of the
 1146 bunker, get the logic signals sent by the chambers and save them into their buffers. Due to the
 1147 limited size of the buffers, the collected data is regularly erased and replaced. A trigger signal is
 1148 needed for the TDC modules to send the useful data to the DAQ computer via a V1718 CAEN USB
 1149 communication module.

1150 In the case of performance test, the trigger signal used for data acquisition is generated by the
 1151 coincidence of three scintillators. A first one is placed upstream outside of the bunker, a second one
 1152 is placed downstream outside of the bunker, while a third one is placed in front of the trolley, close by
 1153 the chambers. Every time a trigger is sent to the TDCs, i.e. every time a muon is detected, knowing
 1154 the time delay in between the trigger and the RPC signals, signals located in the right time window
 1155 are extracted from the buffers and saved for later analysis. Signals are taken in a time window of
 1156 400 ns centered on the muon peak (here we could show a time spectrum). On the other hand, in the
 1157 case of background rate measurement, the trigger signal needs to be "random" not to measure muons
 1158 but to look at gamma background. A trigger pulse is continuously generated at a rate of 300 Hz using
 1159 a dual timer. To integrate an as great as possible time, all signals contained within a time window of
 1160 10us prior to the random trigger signal are extracted form the buffers and saved for further analysis
 1161 (here another time spectrum to illustrate could be useful, maybe even place both spectrum together
 1162 as a single Figure).

1163 The signals sent to the TDCs correspond to hit collections in the RPCs. When a particle hits
 1164 a RPC, it induce a signal in the pickup strips of the RPC readout. If this signal is higher than the
 1165 detection threshold, a LVDS signal is sent to the TDCs. The data is then organised into 4 branches
 1166 keeping track of the event number, the hit multiplicity for the whole setup, and the time and channel
 1167 profile of the hits in the TDCs.

1168 4.4.2 RPC current, environmental and operation parameter monitoring

1169 In order to take into account the variation of pressure and temperature between different data taking
 1170 periods the applied voltage is corrected following the relationship :

$$1171 HV_{eff} = HV_{app} \times \left(0.2 + 0.8 \cdot \frac{P_0}{P} \times \frac{T}{T_0} \right) \quad (4.10)$$

¹¹⁷¹ where T_0 (=293 K) and P_0 (=990 mbar) are the reference values.

¹¹⁷² **4.4.3 Measurement procedure**

¹¹⁷³ Insert a short description of the online tools (DAQ, DCS, DQM).

¹¹⁷⁴ Insert a short description of the offline tools : tracking and efficiency algorithm.

¹¹⁷⁵ Identify long term aging effects we are monitoring the rates per strip.

¹¹⁷⁶ **4.4.4 Longevity studies results**

5

1177

1178

Investigation on high rate RPCs

1179 **5.1 Rate limitations and ageing of RPCs**

1180 **5.1.1 Low resistivity electrodes**

1181 **5.1.2 Low noise front-end electronics**

1182 **5.2 Construction of prototypes**

1183 **5.3 Results and discussions**

6

Conclusions and outlooks

1184

1185

1186 **6.1 Conclusions**

1187 **6.2 Outlooks**

A

1188

1189

A data acquisition software for CAEN VME TDCs

1190

1191 Certifying detectors in the perspective of HL-LHC required to develop tools for the GIF++ expe-
1192 riment. Among them was the C++ Data Acquisition (DAQ) software that allows to make the com-
1193 munications in between a computer and TDC modules in order to retrieve the RPC data [57]. In this
1194 appendix, details about this software, as of how the software was written, how it functions and how
1195 it can be exported to another similar setup, will be given.

1196 A.1 GIF++ DAQ file tree

1197 GIF++ DAQ source code is fully available on github at [https://github.com/afagot/GIF_](https://github.com/afagot/GIF_DAQ)
1198 DAQ. The software requires 3 non-optional dependencies:


- 1199 • CAEN USB Driver, to mount the VME hardware,
1200 • CAEN VME Library, to communicate with the VME hardware, and
1201 • ROOT, to organize the collected data into a TTree.

1202 The CAEN VME library will not be packaged by distributions and will need to be installed man-
1203 ually. To compile the GIF++ DAQ project via a terminal, from the DAQ folder use the command:

1204 make

1206 The source code tree is provided below along with comments to give an overview of the files' con-
1207 tent. The different objects created for this project (`v1718`, `v1190a`, `IniFile` & `DataReader`) will be
1208 described in details in the following sections.

1209



1210 A.2 Usage of the DAQ

1211 GIF++ DAQ, as used in GIF++, is not a standalone software. Indeed, the system being more complexe,
 1212 the DAQ only is a sub-layer of the software architecture developped to control and monitor
 1213 the RPCs that are placed into the bunker for performance study in an irradiated environment. The top
 1214 layer of GIF++ is a Web Detector Control System (webDCS) application. The DAQ is only called
 1215 by the webDCS when data needs to be acquired. The webDCS operates the DAQ through command
 1216 line. To start the DAQ, the webDCS calls:

1217
 1218 bin/daq /path/to/the/log/file/in/the/output/data/folder

1219 where /path/to/the/log/file/in/the/output/data/folder is the only argument required. This
 1220 log file is important for the webDCS as this file contains all the content of the communication of the
 1221 webDCS and the different systems monitored by the webDCS. Its content is constantly displayed
 1222 during data taking for the users to be able to follow the operations. The communication messages
 1223 are normally sent to the webDCS log file via the functions declared in file MsgSvc.h, typically
 1224 MSG_INFO(string message).

1225

1226 A.3 Description of the readout setup

1227 The CMS RPC setup at GIF++ counts 5 V1190A Time-to-Digital Converter (TDC) manufactured
 1228 by CAEN [58]. V1190A are VME units accepting 128 independent Multi-Hit/Multi-Event TDC
 1229 channels whose signals are treated by 4 100 ps high performance TDC chips developed by CERN
 1230 / ECP-MIC Division. The communication between the computer and the TDCs to transfer data is
 1231 done via a V1718 VME master module also manufactured by CAEN and operated from a USB
 1232 port [59]. These VME modules are all hosted into a 6U VME 6021 powered crate manufactured by
 1233 W-Ie-Ne-R than can accommodate up to 21 VME bus cards [60]. These 3 components of the DAQ
 1234 setup are shown in Figure A.1.

1235




Figure A.1: (A.1a) View of the front panel of a V1190A TDC module [58]. (A.1b) View of the front panel of a V1718 Bridge module [59]. (A.1c) View of the front panel of a 6U 6021 VME crate [60].

1236

A.4 Data read-out

1237 To efficiently perform a data readout algorithm, C++ objects to handle the VME modules (TDCs
 1238 and VME bridge) have been created along with objects to store data and read the configuration file

1239 that comes as an input of the DAQ software.

1240

1241 A.4.1 V1190A TDCs

1242 The DAQ used at GIF takes profit of the *Trigger Matching Mode* offered by V1190A modules.
 1243 This setting is enabled through the method `v1190a::SetTrigMatching (int ntdcs)` where `ntdcs`
 1244 is the total number of TDCs in the setup this setting needs to be enabled for (Source Code A.1). A
 1245 trigger matching is performed in between a trigger time tag, a trigger signal sent into the TRIGGER
 1246 input of the TDC visible on Figure A.1a, and the channel time measurements, signals recorded from
 1247 the detectors under test in our case. Control over this data acquisition mode, explained through
 1248 Figure A.2, is offered via 4 programmable parameters:

- 1249 • **match window:** the matching between a trigger and a hit is done within a programmable time
 1250 window. This is set via the method

```
1251     void v1190a::SetTrigWindowWidth(UINT windowWidth, int ntdcs)
```

- 1252 • **window offset:** temporal distance between the trigger tag and the start of the trigger matching
 1253 window. This is set via the method

```
1254     void v1190a::SetTrigWindowWidth(UINT windowWidth, int ntdcs)
```

- 1255 • **extra search margin:** an extended time window is used to ensure that all matching hits are
 1256 found. This is set via the method

```
1257     void v1190a::SetTrigSearchMargin(UINT searchMargin, int ntdcs)
```

- 1258 • **reject margin:** older hits are automatically rejected to prevent buffer overflows and to speed
 1259 up the search time. This is set via the method

```
1260     void v1190a::SetTrigRejectionMargin(UINT rejectMargin, int ntdcs)
```




Figure A.2: Module V1190A Trigger Matching Mode timing diagram [58].

1261 Each of these 4 parameters are given in number of clocks, 1 clock being 25 ns long. It is easy to
 1262 understand at this level that there are 3 possible functioning settings:

- 1263 • **1:** the match window is entirely contained after the trigger signal,

- 1264 • **2:** the match window overlaps the trigger signal, or

- 1265 • **3:** the match window is entirely contained before the trigger signal as displayed on Figure A.2.

1266 In both the first and second cases, the sum of the window width and of the offset can be set to
1267 a maximum of 40 clocks, which corresponds to 1 μ s. Evidently, the offset can be negative, allowing
1268 for a longer match window, with the constraint of having the window ending at most 1 μ s after the
1269 trigger signal. In the third case, the maximum negative offset allowed is of 2048 clocks (12 bit) cor-
1270 responding to 51.2 μ s, the match window being strictly smaller than the offset. In the case of GIF++,
1271 the choice has been made to use this last setting by delaying the trigger signal. During the studies
1272 performed in GIF++, both the efficiency of the RPCs, probed using a muon beam, and the noise or
1273 gamma background rate are monitored. The extra search and reject margins are left unused.
1274 To probe the efficiency of RPC detectors, the trigger time tag is provided by the coïncidence of
1275 scintillators when a bunch of muons passes through GIF++ area is used to trigger the data acquisi-
1276 tion. For this measurement, it is useful to reduce the match window width only to contain the muon
1277 information. Indeed, the delay in between a trigger signal and the detection of the corresponding
1278 muon in the RPC being very contant (typically a few tens of ns due to jitter and cable length), the
1279 muon signals are very localised in time. Thus, due to a delay of approximalety 325 ns in between
1280 the muons and the trigger, the settings where chosen to have a window width of 24 clocks (600 ns)
1281 centered on the muon peak thanks to a negative offset of 29 clocks (725 ns).
1282 On the otherhand, monitoring the rates don't require for the DAQ to look at a specific time window.
1283 It is important to integrate enough time to have a robust measurement of the rate as the number of
1284 hits per time unit. The triggerring signal is provided by a pulse generator at a frequency of 300 Hz
1285 to ensure that the data taking occurs in a random way, with respect to beam physics, to probe only
1286 the irradiation spectrum on the detectors. The match window is set to 400 clocks (10 μ s) and the
1287 negative offset to 401 clocks as it needs to exceed the value of the match window.

```

1288
class v1190a
{
    private :
        long             Handle;
        vector<Data32>   Address;
        CVDataWidth      DataWidth;
        CVAddressModifier AddressModifier;

    public:

        v1190a(long handle, IniFile *inifile, int ntdcs);
        ~v1190a();
        Data16 write_op_reg(Data32 address, int code, string error);
        Data16 read_op_reg(Data32 address, string error);
        void Reset(int ntdcs);
        void Clear(int ntdcs);
        void TestWR(Data16 value,int ntdcs);
        void CheckTDCStatus(int ntdcs);
        void CheckCommunication(int ntdcs);
        void SetTDCTestMode(Data16 mode,int ntdcs);
        void SetTrigMatching(int ntdcs);
        void SetTrigTimeSubtraction(Data16 mode,int ntdcs);
        void SetTrigWindowWidth(Uint windowHeight,int ntdcs);
        void SetTrigWindowOffset(Uint windowOffset,int ntdcs);
        void SetTrigSearchMargin(Uint searchMargin,int ntdcs);
        void SetTrigRejectionMargin(Uint rejectMargin,int ntdcs);
        void GetTrigConfiguration(int ntdcs);
        void SetTrigConfiguration(IniFile *inifile,int ntdcs);
        void SetTDCDetectionMode(Data16 mode,int ntdcs);
        void SetTDCResolution(Data16 lsb,int ntdcs);
        void SetTDCDeadTime(Data16 time,int ntdcs);
        void SetTDCHeadTrailer(Data16 mode,int ntdcs);
        void SetTDCEventSize(Data16 size,int ntdcs);
        void SwitchChannels(IniFile *inifile,int ntdcs);
        void SetIRQ(Data32 level, Data32 count,int ntdcs);
        void SetBlockTransferMode(Data16 mode,int ntdcs);
        void Set(IniFile *inifile,int ntdcs);
        void CheckStatus(CVErrorCodes status) const;
        int ReadBlockD32(Uint tdc, const Data16 address,
                         Data32 *data, const Uint words, bool ignore_berr);
        Uint Read(RAWData *DataList,int ntdcs);
};

1290

```

Source Code A.1: Description of C++ object v1190a.

1291 The v1190a object, defined in the DAQ software as in Source Code A.1, offers the possibility to
1292 concatenate all TDCs in the readout setup into a single object containing a list of hardware addresses
1293 (addresses to access the TDCs' buffer through the VME crate) and each constructor and method acts
1294 on the list of TDCs.
1295

1296 A.4.2 DataReader

1297 Enabled thanks to v1190a::SetBlockTransferMode(Data16 mode, int ntdcs), the data transfer
1298 is done via Block Transfer (BLT). Using BLT allows to tranfer a fixed number of events called a
1299 *block*. This is used together with an Almost Full Level (AFL) of the TDCs' output buffers, defined

1300 through `v1190a::SetIRQ(Data32 level, Data32 count, int ntdcs)`. This AFL gives the maximum amount of 32735 words (16 bits, corresponding to the depth of a TDC output buffer) that can
 1301 written in a buffer before an Interrupt Request (IRQ) is generated and seen by the VME Bridge,
 1302 stopping the data acquisition to transfer the content of each TDC buffers before resuming. For each
 1303 trigger, 6 words or more are written into the TDC buffer:

- 1305 • a **global header** providing information of the event number since the beginning of the data
 acquisition,
- 1307 • a **TDC header**,
- 1308 • the **TDC data** (*if any*), 1 for each hit recorded during the event, providing the channel and the
 time stamp associated to the hit,
- 1310 • a **TDC error** providing error flags,
- 1311 • a **TDC trailer**,
- 1312 • a **global trigger time tag** that provides the absolute trigger time relatively to the last reset,
 and
- 1314 • a **global trailer** providing the total word count in the event.

1315 As previously described in Section ??, CMS RPC FEEs provide us with 100 ns long LVDS out-
 1316 put signals that are injected into the TDCs' input. Any avalanche signal that gives a signal above the
 1317 FEEs threshold is thus recorded by the TDCs as a hit within the match window. Each hit is assigned
 1318 to a specific TDC channel with a time stamp, with a precision of 100 ps. The reference time, $t_0 = 0$,
 1319 is provided by the beginning of the match window. Thus for each trigger, coming from a scintillator
 1320 coïncidence or the pulse generator, a list of hits is stored into the TDCs' buffers and will then be
 1321 transferred into a ROOT Tree.

1322 When the BLT is used, it is easy to understand that the maximum number of words that have
 1323 been set as ALF will not be a finite number of events or, at least, the number of events that would
 1324 be recorded into the TDC buffers will not be a multiple of the block size. In the last BLT cycle to
 1325 tranfer data, the number of events to transfer will most probably be lower than the block size. In that
 1326 case, the TDC can add fillers at the end of the block but this option requires to send more data to the
 1327 computer and is thus a little slower. Another solution is to finish the transfer after the last event by
 1328 sending a bus error that states that the BLT reached the last event in the pile. This method has been
 1329 chosen in GIF++.

1331 Due to irradiation, an event in GIF++ can count up to 300 words per TDC. A limit of 4096 words
 1332 (12 bits) has been set to generate IRQ which represent from 14 to almost 700 events depending on
 1333 the average of hits collected per event. Then the block size has been set to 100 events with enabled
 1334 bus errors. When an AFL is reached for one of the TDCs, the VME bridge stops the acquisition by
 1335 sending a BUSY signal.

1337

1338 The data is then transferred one TDC at a time into a structure called `RAWData` (Source Code A.2).

```
1339
1340     struct RAWData{
1341         vector<int>           *EventList;
1342         vector<int>           *NHitsList;
1343         vector<int>           *QFlagList;
1344         vector<vector<int>>   *Channellist;
1345         vector<vector<float>>  *TimeStampList;
1346     };
```

1341 *Source Code A.2: Description of data holding C++ structure `RAWData`.*

1342 In order to organize the data transfer and the data storage, an object called `DataReader` was
 1343 created (Source Code A.3). On one hand, it has `v1718` and `v1190a` objects as private members for
 1344 communication purposes, such as VME modules settings via the configuration file `*iniFile` or data
 1345 read-out through `v1190a::Read()` and on the other hand, it contains the structure `RAWData` that allows
 1346 to organise the data in vectors reproducing the tree structure of a ROOT file.

```
1347
1348     class DataReader
1349     {
1350         private:
1351             bool      StopFlag;
1352             IniFile *iniFile;
1353             Data32  MaxTriggers;
1354             v1718   *VME;
1355             int       nTDCs;
1356             v1190a  *TDCs;
1357             RAWData TDCData;
1358
1359         public:
1360             DataReader();
1361             virtual ~DataReader();
1362             void      SetIniFile(string inifilename);
1363             void      SetMaxTriggers();
1364             Data32  GetMaxTriggers();
1365             void      SetVME();
1366             void      SetTDC();
1367             int       GetQFlag(Uint it);
1368             void      Init(string inifilename);
1369             void      FlushBuffer();
1370             void      Update();
1371             string  GetFileName();
1372             void      WriteRunRegistry(string filename);
1373             void      Run();
1374     };
```

1349 *Source Code A.3: Description of C++ object `DataReader`.*

1350 Each event is transferred from `TDCData` and saved into branches of a ROOT `TTree` as 3 integers
 1351 that represent the event ID (`EventCount`), the number of hits read from the TDCs (`nHits`), and the
 1352 quality flag that provides information for any problem in the data transfer (`qflag`), and 2 lists of
 1353 `nHits` elements containing the fired TDC channels (`TDCCh`) and their respective time stamps (`TDCTS`),
 1354 as presented in Source Code A.4. The ROOT file file is named using information contained into
 1355 the configuration file, presented in section A.5.2. The needed information is extracted using method
 1356 `DataReader::GetFileName()` and allow to build the output filename format `ScanXXXXXX_HVX_DAQ.root`

1357 where ScanXXXXXX is a 6 digit number representing the scan number into GIFT++ database and HVX
 1358 the HV step within the scan that can be more than a single digit. An example of ROOT data file is
 1359 provided with Figure A.3.

```
1360
RAWData TDCData;
TFile *outputFile = new TFile(outputFileName.c_str(),"recreate");
TTree *RAWDataTree = new TTree("RAWData","RAWData");

int EventCount = -9;
int nHits = -8;
int qflag = -7;
vector<int> TDCCh;
vector<float> TDCTS;

RAWDataTree->Branch("EventNumber",&EventCount, "EventNumber/I");
RAWDataTree->Branch("number_of_hits",&nHits,"number_of_hits/I");
RAWDataTree->Branch("Quality_flag",&qflag,"Quality_flag/I");
RAWDataTree->Branch("TDC_channel",&TDCCh);
RAWDataTree->Branch("TDC_TimeStamp",&TDCTS);

1361
//...
//Here read the TDC data using v1190a::Read() and place it into
//TDCData for as long as you didn't collect the requested amount
//of data.
//...

for(Uint i=0; i<TDCData.EventList->size(); i++){
    EventCount = TDCData.EventList->at(i);
    nHits = TDCData.NHitsList->at(i);
    qflag = TDCData.QFlagList->at(i);
    TDCCh = TDCData.ChannelList->at(i);
    TDCTS = TDCData.TimeStampList->at(i);
    RAWDataTree->Fill();
}
```

1362 *Source Code A.4: Highlight of the data transfer and organisation within DataReader::Run() after the data has been collected into TDCData.*




Figure A.3: Structure of the ROOT output file generated by the DAQ. The 5 branches (EventNumber, number_of_hits, Quality_flag, TDC_channel and TDC_TimeStamp) are visible on the left panel of the ROOT browser. On the right panel is visible the histogram corresponding to the variable nHits. In this specific example, there were approximately 50k events recorded to measure the gamma irradiation rate on the detectors. Each event is stored as a single entry in the TTree.

1363 A.4.3 Data quality flag

1364 Among the parameters that are recorded for each event, the quality flag, defined in Source Code A.5,
 1365 is determined on the fly by checking the data recorded by every single TDC. From method `v1190a::Read()`,
 1366 it can be understood that the content of each TDC buffer is readout one TDC at a time. Entries are
 1367 created in the data list for the first TDC and then, when the second buffer is readout, events corre-
 1368 sponding to entries that have already been created to store data for the previous TDC are added to
 1369 the existing list element. On the contrary, when an event entry has not been yet created in the data
 1370 list, a new entry is created.

```
1371
 1372   typedef enum _QualityFlag {
 1373     GOOD      = 1,
 1374     CORRUPTED = 0
 1375   } QualityFlag;
```

1373 *Source Code A.5: Definition of the quality flag `enum`.*

1374 It is possible that each TDC buffer contains a different number of events. In cases where the first
 1375 element in the buffer list is an event for corresponds to a new entry, the difference in between the
 1376 entry from the buffer and the last entry in the data list is recorded and checked. If it is greater than 1,
 1377 what should never be the case, the quality flag is set to CORRUPTED for this TDC and an empty entry
 1378 is created in the place of the missing ones. Missing entries are believe to be the result of a bad hold

1379 on the TDC buffers at the moment of the readout. Indeed, the software hold is effective only on 1
 1380 TDC at a time and no solution as been found yet to completely block the writting in the buffers when
 1381 an IRQ is received.

1382 At the end of each BLT cycle, the ID of the last entry stored for each TDC buffer is not recorded.
 1383 When starting the next cycle, if the first entry in the pile corresponds to an event already existing
 1384 in the list, the readout will start from this list element and will not be able to check the difference
 1385 in between this entry's ID and the one of the last entry that was recorded for this TDC buffer in
 1386 the previous cycle. In the case events were missing, the flag stays at its initial value of 0, which is
 1387 similar to CORRUPTED and it is assumed that then this TDC will not contribute to `number_of_hits`,
 1388 `TDC_channel` or `TDC_TimeStamp`.

1389 Finally, since there will be 1 `RAWData` entry per TDC for each event (meaning `nTDCs` entries,
 1390 referring to `DataReader` private attribute), the individual flags of each TDC will be added together.
 1391 The final format is an integer composed `nTDCs` digits where each digit is the flag of a specific TDC.
 1392 This is constructed using powers of 10 like follows:

```
1393 TDC 0: QFlag = 100 × _QualityFlag
1394 TDC 1: QFlag = 101 × _QualityFlag
1395 ...
1396 TDC N: QFlag = 10N × _QualityFlag
```

1397 and the final flag to be with N digits:

```
1398 QFlag = n....3210
```

1399 each digit being 1 or 0. Below is given an example with a 4 TDCs setup.

1400 If all TDCs were good : `QFlag = 1111`,

1401 but if TDC 2 was corrupted : `QFlag = 1011`.

1402 When data taking is over and the data contained in the dynamical `RAWData` structure is transferred
 1403 to the ROOT file, all the 0s are changed into 2s by calling the method `DataReader::GetQFlag()`.
 1404 This will help translating the flag without knowing the number of TDCs beforehand. Indeed, a flag
 1405 111 could be due to a 3 TDC setup with 3 good individual TDC flags or to a more than 3 TDC setup
 1406 with TDCs those ID is greater than 2 being CORRUPTED, thus giving a 0.

1407 The quality flag has been introduced quite late, in October 2017 only, to the list of GIF++ DAQ
 1408 parameters to be recorded into the output ROOT file. Before this addition, the missing data, corrupting
 1409 the quality for the offline analysis, was contributing to artificially fill data with lower multiplicity.
 1410 Looking at `TBranch number_of_hits` provides an information about the data of the full GIF++
 1411 setup. When a TDC is not able to transfer data for a specific event, the effect is a reduction of the
 1412 total number of hits recorded in the full setup, this is what can be seen from Figure A.4. After offline
 1413 reconstruction detector by detector, the effect of missing events can be seen in the artificially filled
 1414 bin at multiplicity 0 shown in Figure A.5. Nonetheless, for data with high irradiation levels, as it is
 1415 the case for Figure A.5a, discarding the fake multiplicity 0 data can be done easily during the offline
 1416 analysis. At lower radiation, the missing events contribution becomes more problematic as the multi-
 1417 tiplicity distribution overlaps the multiplicity 0 and that in the same time the proportion of missing

events decreases. Attempts to fit the distribution with a Poisson or skew distribution function were not conclusive and this very problem has been at the origin of the quality flag that allows to give a non ambiguous information about each event quality.

1421




Figure A.4: The effect of the quality flag is explained by presenting the content of TBranch `number_of_hits` of a data file without `Quality_flag` in Figure A.4a and the content of the same TBranch for data corresponding to a `Quality_flag` where all TDCs were labelled as `GOOD` in Figure A.4b taken with similar conditions. It can be noted that the number of entries in Figure A.4b is slightly lower than in Figure A.4a due to the excluded events.




Figure A.5: Using the same data as previously showed in Figure A.4, the effect of the quality flag is explained by presenting the reconstructed hit multiplicity of a data file without `Quality_flag` in Figure A.5a and the reconstructed content of the same RPC partition for data corresponding to a `Quality_flag` where all TDCs were labelled as `GOOD` in Figure A.5b taken with similar conditions. The artificial high content of bin 0 is completely suppressed.

1422

A.5 Communications

1423
1424

To ensure data readout and dialog in between the machine and the TDCs or in between the webDCS and the DAQ, different communication solutions were used. First of all, it is important to have a

1425 module to allow the communication in between the TDCs and the computer from which the DAQ
1426 operates. When this communication is effective, shifters using the webDCS to control data taking
1427 can thus send instructions to the DAQ.

1428

1429 A.5.1 V1718 USB Bridge

In the previous section, the data transfer has been discussed. The importance of the `v1718` object (Source Code A.6), used as private member of `DataReader`, was not explicated. VME master modules are used for communication purposes as they host the USB port that connects the powered crate buffer to the computer where the DAQ is installed. From the source code point of view, this object is used to control the communication status, by reading the returned error codes with `v1718::CheckStatus()`, or to check for IRQs coming from the TDCs through `v1718::CheckIRQ()`. Finally, to ensure that triggers are blocked at the hardware level, a NIM pulse is sent out of one of the 5 programmable outputs (`v1718::SendBUSY()`) to the VETO of the coincidence module where the trigger signals originate from. As long as this signal is ON, no trigger can reach the TDCs anymore.

```
1439
class v1718{
    private:
        int Handle;
        Data32 Data; // Data
        CVIRQLevels Level; // Interrupt level
        CVAddressModifier AM; // Addressing Mode
        CVDataWidth DataSize; // Data Format
        Data32 BaseAddress; // Base Address

    public:
        v1718(IniFile *inifile);
        ~v1718();
        long GetHandle(void) const;
        int SetData(Data16 data);
        GetData(void);
        SetLevel(CVIRQLevels level);
        GetLevel(void);
        SetAM(CVAddressModifier am);
        CVAddressModifier GetAM(void);
        SetDatasize(CVDataWidth datasize);
        GetDataSize(void);
        SetBaseAddress(Data16 baseaddress);
        GetBaseAddress(void);
        void CheckStatus(CVErrorCodes status) const;
        bool CheckIRQ();
        SetPulsers();
        SendBUSY(BusyLevel level);
};

1440
```

1441 *Source Code A.6: Description of C++ object v1718.*

1442 A.5.2 Configuration file

1443 The DAQ software takes as input a configuration file written using INI standard [61]. This file is
1444 partly filled with the information provided by the shifters when starting data acquisition using the
1445 webDCS, as shown by Figure A.6. This information is written in section [**General**] and will later

1446 be stored in the ROOT file that contains the DAQ data as can be seen from Figure A.3. Indeed,
 1447 another `TTree` called `RunParameters` as well as the 2 histograms `ID`, containing the scan number,
 1448 start and stop time stamps, and `Triggers`, containing the number of triggers requested by the shifter,
 1449 are available in the data files. Moreover, `ScanID` and `HV` are then used to construct the file name
 1450 thanks to the method `DataReader::GetFileName()`.




Figure A.6: WebDCS DAQ scan page. On this page, shifters need to choose the type of scan (Rate, Efficiency or Noise Reference scan), the gamma source configuration at the moment of data taking, the beam configuration, and the trigger mode. These information will be stored in the DAQ ROOT output. Are also given the minimal measurement time and waiting time after ramping up of the detectors is over before starting the data acquisition. Then, the list of HV points to scan and the number of triggers for each run of the scan are given in the table underneath.

1451 The rest of the information is written beforehand in the configuration file template, as explicated
 1452 in Source Code A.7, and contains the hardware addresses to the different VME modules in the
 1453 setup as well as settings for the TDCs. As the TDC settings available in the configuration file are not
 1454 supposed to be modified, an improvement would be to remove them from the configuration file and
 1455 to hardcode them inside of the DAQ code itself or to place them into a different INI file that would
 1456 host only the TDC settings to lower the probability for a bad manipulation of the configuration file
 1457 that can be modified from one of webDCS' menus.

1458

```
[General]
TdcS=4
ScanID=$scanid
HV=$HV
RunType=$runtype
MaxTriggers=$maxtriggers
Beam=$beam
[VMEInterface]
Type=V1718
BaseAddress=0xFF0000
Name=VmeInterface
[TDC0]
Type=V1190A
BaseAddress=0x00000000
Name=Tdc0
StatusA00-15=1
StatusA16-31=1
StatusB00-15=1
StatusB16-31=1
StatusC00-15=1
StatusC16-31=1
StatusD00-15=1
StatusD16-31=1
[TDC1]
Type=V1190A
BaseAddress=0x11110000
Name=Tdc1
StatusA00-15=1
StatusA16-31=1
StatusB00-15=1
StatusB16-31=1
StatusC00-15=1
StatusC16-31=1
StatusD00-15=1
StatusD16-31=1
[TDC2]
Type=V1190A
BaseAddress=0x22220000
Name=Tdc2
StatusA00-15=1
StatusA16-31=1
StatusB00-15=1
StatusB16-31=1
StatusC00-15=1
StatusC16-31=1
StatusD00-15=1
StatusD16-31=1
[TDC3]
Type=V1190A
BaseAddress=0x44440000
Name=Tdc3
StatusA00-15=1
StatusA16-31=1
StatusB00-15=1
StatusB16-31=1
StatusC00-15=1
StatusC16-31=1
StatusD00-15=1
StatusD16-31=1
[TDCSettings]
TriggerExtraSearchMargin=0
TriggerRejectMargin=0
TriggerTimeSubtraction=0b1
TdcDetectionMode=0b01
TdcResolution=0b10
TdcDeadTime=0b00
TdcHeadTrailer=0b1
TdcEventSize=0b1001
TdcTestMode=0b0
BLTMode=1
```

Source Code A.7: INI configuration file template for 4 TDCs. In section [General], the number of TDCs is explicitated and information about the ongoing run is given. Then, there are sections for each and every VME modules. There buffer addresses are given and for the TDCs, the list of channels to enable is given. Finally, in section [TDCSettings], a part of the TDC settings are given.

1461 In order to retrieve the information of the configuration file, the object `IniFile` has been developed
 1462 to provide an INI parser, presented in Source Code A.8. It contains private methods returning a
 1463 boolean to check the type of line written in the file, whether a comment, a group header or a key line
 1464 (`IniFile::CheckIfComment()`, `IniFile::CheckIfGroup()` and `IniFile::CheckIfToken()`). The
 1465 key may sometimes be referred to as *token* in the source code. Moreover, the private element
 1466 `FileData` is a map of `const string` to `string` that allows to store the data contained inside the
 1467 configuration file via the public method `IniFile::GetFileData()` following the formatting (see
 1468 method `IniFile::Read()`):

```
1469
1470     string group, token, value;
    // Get the field values for the 3 strings.
    // Then concatenate group and token together as a single string
    // with a dot separation.
    token = group + "." + token;
    FileData[token] = value;
```

1471 More methods have been written to translate the different keys into the right variable format
 1472 when used by the DAQ. For example, to get a `float` value out of the configuration file data, knowing
 1473 the group and the key needed, the method `IniFile::floatType()` can be used. It takes 3 arguments
 1474 being the group name and key name (both `string`), and a default `float` value used as exception in
 1475 the case the expected combination of group and key cannot be found in the configuration file. This
 1476 default value is then used and the DAQ continues on working after sending an alert in the log file for
 1477 further debugging.

```

1478 typedef map< const string, string > IniFileData;
1479
class IniFile{
    private:
        bool          CheckIfComment (string line);
        bool          CheckIfGroup(string line, string& group);
        bool          CheckIfToken(string line, string& key, string& value);
        string         FileName;
        IniFileData   FileData;
        int           Error;

    public:
        IniFile();
        IniFile(string filename);
        virtual      ~IniFile();

        // Basic file operations
        void          SetFileName(string filename);
        int           Read();
        int           Write();
        IniFileData GetFileData();

        // Data readout methods
        Data32         addressType (string groupname, string keyname, Data32
→     defaultvalue);
        long          intType     (string groupname, string keyname, long
→     defaultvalue);
        long long    longType    (string groupname, string keyname, long long
→     defaultvalue );
        string         stringType  (string groupname, string keyname, string
→     defaultvalue );
        float         floatType   (string groupname, string keyname, float
→     defaultvalue );

        // Error methods
        string         GetErrorMsg();
    };

```

1480 *Source Code A.8: Description of C++ object `IniFile` used as a parser for INI file format.*

1481 A.5.3 WebDCS/DAQ intercommunication

1482 When shifters send instructions to the DAQ via the configuration file, it is the webDCS itself that
 1483 gives the start command to the DAQ and then the 2 softwares use inter-process communication
 1484 through file to synchronise themselves. This communication file is represented by the variable **const**
 1485 string __runstatuspath.

1486 On one side, the webDCS sends commands or status that are readout by the DAQ:

- 1487 • INIT, status sent when launching a scan and read via function `CtrlRunStatus(...)`,
- 1488 • START, command to start data taking and read via function `CheckSTART()`,
- 1489 • STOP, command to stop data taking at the end of the scan and read via function `CheckSTOP()`,
 1490 and
- 1491 • KILL, command to kill data taking sent by user and read via function `CheckKILL()`

and on the other, the DAQ sends status that are controled by the webDCS:

- 1493 ● `DAQ_RDY`, sent with `SendDAQReady()` to signify that the DAQ is ready to receive commands
1494 from the webDCS,
- 1495 ● `RUNNING`, sent with `SendDAQRunning()` to signify that the DAQ is taking data,
- 1496 ● `DAQ_ERR`, sent with `SendDAQError()` to signify that the DAQ didn't receive the expected com-
1497 mand from the webDCS or that the launch command didn't have the right number of argu-
1498 ments,
- 1499 ● `RD_ERR`, sent when the DAQ wasn't able to read the communication file, and
- 1500 ● `WR_ERR`, sent when the DAQ wasn't able to write into the communication file.

1501 **A.5.4 Example of inter-process communication cycle**

1502 Under normal conditions, the webDCS and the DAQ processes exchange commands and status via
1503 the file hosted at the address `__runstatuspath`, as explained in subsection A.5.3. An example of
1504 cycle is given in Table A.1. In this example, the steps 3 to 5 are repeated as long as the webDCS tells
1505 the DAQ to take data. A data taking cycle is the equivalent as what is called a *Scan* in GIFT++ jargon,
1506 referring to a set a runs with several HV steps. Each repetition of steps 3 to 5 is then equivalent to a
1507 single *Run*.

1508 At any moment during the data taking, for any reason, the shifter can decide that the data taking
1509 needs to be stopped before it reached the end of the scheduled cycle. Thus at any moment on the
1510 cycle, the content of the inter-process communication file will be changed to `KILL` and the DAQ will
1511 shut down right away. The DAQ checks for `KILL` signals every 5s after the TDCs configuration is
1512 over. So far, the function `CheckKILL()` has been used only inside of the data taking loop of method
1513 `DataReader::Run()` and thus, if the shifter decides to KILL the data taking during the TDC con-
1514 figuration phase or the HV ramping in between 2 HV steps, the DAQ will not be stopped smoothly
1515 and a *force kill* command will be sent to stop the DAQ process that is still awake on the computer.
1516 Improvements can be brought on this part of the software to make sure that the DAQ can safely
1517 shutdown at any moment.

1520 **A.6 Software export**

1521 In section A.2 was discussed the fact that the DAQ as written in its last version is not a standalone
1522 software. It is possible to make it a standalone program that could be adapted to any VME setup
1523 using V1190A and V1718 modules by creating a GUI for the software or by printing the log mes-
1524 sages that are normally printed in the webDCS through the log file, directly into the terminal. This
1525 method was used by the DAQ up to version 3.0 moment where the webDCS was completed. Also, it
1526 is possible to check branches of DAQ v2.X to have example of communication through a terminal.

1527 DAQ v2.X is nonetheless limited in it's possibilities and requires a lot of offline manual interven-
1528 tions from the users. Indeed, there is no communication of the software with the detectors' power
1529 supply system that would allow for a user a predefine a list of voltages to operate the detectors at

step	actions of webDCS	status of DAQ	__runstatuspath
1	launch DAQ ramp voltages ramping over wait for currents stabilization	readout of IniFile configuration of TDCs	INIT
2		configuration done send DAQ ready wait for START signal	DAQ_RDY
3	waiting time over send START		START
4	wait for run to end monitor DAQ run status	data taking ongoing check for KILL signal	RUNNING
5		run over send DAQ_RDY wait for next DCS signal	DAQ_RDY
6	ramp voltages ramping over wait for currents stabilization		DAQ_RDY
3	waiting time over send START		START
4	wait for run to end monitor DAQ run status	update IniFile information data taking ongoing check for KILL signal	RUNNING
5		run over send DAQ_RDY wait for next DCS signal	DAQ_RDY
7	send command STOP	DAQ shuts down	STOP

Table A.1: Inter-process communication cycles in between the webDCS and the DAQ through file string signals.

1531 and loop over to take data without any further manual intervention. In v2.X, the data is taken for a
1532 single detector setting and at the end of each run, the softwares asks the user if he intends on taking
1533 more runs. If so, the software invites the user to set the operating voltages accordingly to what is
1534 necessary and to manual update the configuration file in consequence. This working mode can be a
1535 very first approach before an evolution and has been successfully used by colleagues from different
1536 collaborations.

1537

1538 For a more robust operation, it is recommended to develop a GUI or a web application to inter-
1539 face the DAQ. Moreover, to limit the amount of manual interventions, and thus the probability to
1540 make mistakes, it is also recommended to add an extra feature into the DAQ by installing the HV
1541 Wrapper library provided by CAEN of which an example of use in a similar DAQ software devel-
1542 opped by a master student of UGent, and called TinyDAQ, is provided on UGent's github. Then, this
1543 HV Wrapper will help you communicating with and give instructions to a CAEN HV powered crate
1544 and can be added into the DAQ at the same level where the communication with the user was made
1545 in DAQ v2.X. In case you are using another kind of power system for your detectors, it is stringly
1546 adviced to use HV modules or crates that can be remotely controled via a using C++ libraries.

1547

B

1548

1549

Details on the offline analysis package

1550 The data collected in GIF++ thanks to the DAQ described in Appendix A is difficult to interpret by
1551 a human user that doesn't have a clear idea of the raw data architecture of the ROOT data files. In
1552 order to render the data human readable, a C++ offline analysis tool was designed to provide users
1553 with detector by detector histograms that give a clear overview of the parameters monitored during
1554 the data acquisition [62]. In this appendix, details about this software in the context of GIF++, as of
1555 how the software was written and how it functions will be given.

1556 B.1 GIF++ Offline Analysis file tree

1557 GIF++ Offline Analysis source code is fully available on github at https://github.com/aafagot/GIF_OfflineAnalysis. The software requires ROOT as non-optionnal dependency
1558 as it takes ROOT files in input and write an output ROOT file containing histograms. To compile the
1559 GIF++ Offline Analysis project is compiled with cmake. To compile, first a build/ directory must
1560 be created to compile from there:

```
1562 mkdir build
1563 cd build
1564 cmake ..
1565 make
1566 make install
```

1564 To clean the directory and create a new build directory, the bash script cleandir.sh can be used:

```
1565
1566 ./cleandir.sh
```

1567 The source code tree is provided below along with comments to give an overview of the files' con-
1568 tent. The different objects created for this project (`Infrastructure`, `Trolley`, `RPC`, `Mapping`, `RPCHit`,
1569 `RPCCluster` and `Inifile`) will be described in details in the following sections.

1570

```

GIF_OfflineAnalysis
├── bin
│   └── offlineanalysis ..... EXECUTABLE
├── build..... CMAKE COMPILATION DIRECTORY
└── ...
    ├── include..... LIST OF C++ HEADER FILES
    │   ├── Cluster.h..... DECLARATION OF OBJECT RPCCLUSTER
    │   ├── Current.h..... DECLARATION OF GETCURRENT ANALYSIS MACRO
    │   ├── GIFTrolley.h..... DECLARATION OF OBJECT TROLLEY
    │   ├── Infrastructure.h..... DECLARATION OF OBJECT INFRASTRUCTURE
    │   ├── IniFile.h..... DECLARATION OF OBJECT INI FILE FORINI PARSER
    │   ├── Mapping.h..... DECLARATION OF OBJECT MAPPING
    │   ├── MsgSvc.h..... DECLARATION OF OFFLINE LOG MESSAGES
    │   ├── OfflineAnalysis.h..... DECLARATION OF DATA ANALYSIS MACRO
    │   ├── RPCTracker.h..... DECLARATION OF OBJECT RPC
    │   ├── RPCHit.h..... DECLARATION OF OBJECT RPCHIT
    │   ├── types.h..... DEFINITION OF USEFUL VARIABLE TYPES
    │   └── utils.h..... DECLARATION OF USEFUL FUNCTIONS
    ├── obj..... BINARY FILES CREATED BY COMPILER
    └── ...
        ├── src..... LIST OF C++ SOURCE FILES
        │   ├── Cluster.cc..... DEFINITION OF OBJECT RPCCLUSTER
        │   ├── Current.cc..... DEFINITION OF GETCURRENT ANALYSIS MACRO
        │   ├── GIFTrolley.cc..... DEFINITION OF OBJECT TROLLEY
        │   ├── Infrastructure.cc..... DEFINITION OF OBJECT INFRASTRUCTURE
        │   ├── IniFile.cc..... DEFINITION OF OBJECT INI FILE FORINI PARSER
        │   ├── main.cc..... MAIN FILE
        │   ├── Mapping.cc..... DEFINITION OF OBJECT MAPPING
        │   ├── MsgSvc.cc..... DECLARATION OF OFFLINE LOG MESSAGES
        │   ├── OfflineAnalysis.cc..... DECLARATION OF DATA ANALYSIS MACRO
        │   ├── RPCTracker.cc..... DECLARATION OF OBJECT RPC
        │   ├── RPCHit.cc..... DECLARATION OF OBJECT RPCHIT
        │   └── utils.cc..... DEFINITION OF USEFUL FUNCTIONS
        ├── cleandir.sh..... BASH SCRIPT TO CLEAN BUILD DIRECTORY
        ├── CMakeLists.txt..... SET OF INSTRUCTIONS FOR CMAKE
        ├── config.h.in..... DEFINITION OF VERSION NUMBER
        └── README.md..... README FILE FOR GITHUB

```

1571

B.2 Usage of the Offline Analysis

1572

In order to use the Offline Analysis tool, it is necessary to know the Scan number and the HV Step of the run that needs to be analysed. This information needs to be written in the following format:

1574

1575

```
Scan00XXXX_HVY
```

1576

where XXXX is the scan ID and Y is the high voltage step (in case of a high voltage scan, data will be taken for several HV steps). This format corresponds to the base name of data files in the database

1577

1578 of the Gif++ webDCS. Usually, the offline analysis tool is automatically called by the webDCS at
 1579 the end of data taking or by a user from the webDCS panel if an update of the tool was brought.
 1580 Nonetheless, an expert can locally launch the analysis for tests on the Gif++ computer, or a user can
 1581 get the code on its local machine from github and download data from the webDCS for its own anal-
 1582 ysis. To launch the code, the following command can be used from the `GIF_OfflineAnalysis` folder:

1583
 1584 `bin/offlineanalysis /path/to/Scan00XXXX_HVY`

1585 where, `/path/to/Scan00XXXX_HVY` refers to the local data files. Then, the offline tool will by itself
 1586 take care of finding all available ROOT data files present in the folder, as listed below:

- 1587
 - 1588 ● `Scan00XXXX_HVY_DAQ.root` containing the TDC data as described in Appendix ?? (events, hit
 and timestamp lists), and
 - 1589 ● `Scan00XXXX_HVY_CAEN.root` containing the CAEN mainframe data recorded by the monitor-
 ing tool webDCS during data taking (HVs and currents of every HV channels). This file is
 created independently of the DAQ.

1592 **B.2.1 Output of the offline tool**

1593 **B.2.1.1 ROOT file**

1594 The analysis gives in output ROOT datafiles that are saved into the data folder and called using the
 1595 naming convention `Scan00XXXX_HVY_Offline.root`. Inside those, a list of `TH1` histograms can be
 1596 found. Its size will vary as a function of the number of detectors in the setup as each set of histograms
 1597 is produced detector by detector. For each partition of each chamber, can be found:


- 1598
 - 1599 ● `Time_Profile_Tt_Sc_p` shows the time profile of all recorded events (number of events per
 time bin),
 - 1600 ● `Hit_Profile_Tt_Sc_p` shows the hit profile of all recorded events (number of events per chan-
 nel),
 - 1602 ● `Hit_Multiplicity_Tt_Sc_p` shows the hit multiplicity (number of hits per event) of all recorded
 events (number of occurrences per multiplicity bin),
 - 1604 ● `Strip_Mean_Noise_Tt_Sc_p` shows noise/gamma rate per unit area for each strip in a se-
 lected time range. After filters are applied on `Time_Profile_Tt_Sc_p`, the filtered version
 of `Hit_Profile_Tt_Sc_p` is normalised to the total integrated time and active detection area
 of a single channel,
 - 1608 ● `Strip_Activity_Tt_Sc_p` shows noise/gamma activity for each strip (normalised version of
 previous histogram - strip activity = strip rate / average partition rate),
 - 1610 ● `Strip_Homogeneity_Tt_Sc_p` shows the *homogeneity* of a given partition ($\text{homogeneity} = \exp(-\text{strip rates standard deviation(strip rates in partition/average partition rate)})$),
 - 1612 ● `mask_Strip_Mean_Noise_Tt_Sc_p` shows noise/gamma rate per unit area for each masked
 strip in a selected time range. Offline, the user can control the noise/gamma rate and decide to
 mask the strips that are judged to be noisy or dead. This is done via the *Masking Tool* provided
 by the webDCS,

- 1616 ● `mask_Strip_Activity_Tt_Sc_p` shows noise/gamma activity per unit area for each masked
1617 strip with respect to the average rate of active strips,
- 1618 ● `NoiseCSize_H_Tt_Sc_p` shows noise/gamma cluster size, a cluster being constructed out of
1619 adjacent strips giving a signal at the *same time* (hits within a time window of 25 ns),
- 1620 ● `NoiseCMult_H_Tt_Sc_p` shows noise/gamma cluster multiplicity (number of reconstructed
1621 clusters per event),
- 1622 ● `Chip_Mean_Noise_Tt_Sc_p` shows the same information than `Strip_Mean_Noise_Tt_Scp` us-
1623 ing a different binning (1 chip corresponds to 8 strips),
- 1624 ● `Chip_Activity_Tt_Sc_p` shows the same information than `Strip_Activity_Tt_Scp` using
1625 chip binning,
- 1626 ● `Chip_Homogeneity_Tt_Sc_p` shows the homogeneity of a given partition using chip binning,
- 1627 ● `Beam_Profile_Tt_Sc_p` shows the estimated beam profile when taking efficiency scan. This
1628 is obtained by filtering `Time_Profile_Tt_Sc_p` to only consider the muon peak where the
1629 noise/gamma background has been subtracted. The resulting hit profile corresponds to the
1630 beam profile on the detector channels,
- 1631 ● `L0_Efficiency_Tt_Sc_p` shows the level 0 efficiency that was estimated **without** muon track-
1632 ing,
- 1633 ● `MuonCSize_H_Tt_Sc_p` shows the level 0 muon cluster size that was estimated **without** muon
1634 tracking, and
- 1635 ● `MuonCMult_H_Tt_Sc_p` shows the level 0 muon cluster multiplicity that was estimated **without**
1636 muon tracking.

1637 In the histogram labels, t stands for the trolley number (1 or 3), c for the chamber slot label in
1638 trolley t and p for the partition label (A, B, C or D depending on the chamber layout) as explained
1639 in Chapter ??.

1640 In the context of GIF++, an extra script called by the webDCS is called to extract the histograms
1641 from the ROOT files. The histograms are then stored in PNG and PDF formats into the correspond-
1642 ing folder (a single folder per HV step, so per ROOT file). the goal is to then display the histograms
1643 on the Data Quality Monitoring (DQM) page of the webDCS in order for the users to control the
1644 quality of the data taking at the end of data taking. An example of histogram organisation is given
1645 below:

1646



1648 Here can put some screens from the webDCS to show the DQM and the plots available to users.

1649

1650 B.2.1.2 CSV files

1651 Moreover, up to 3 CSV files can be created depending on which ones of the 3 input files were in the

1652 data folder:

- 1653 • Offline-Corrupted.csv , is used to keep track of the amount of data that was corrupted and**
- 1654 removed from old data format files that don't contain any data quality flag.**
- 1655 • Offline-Current.csv , contains the summary of the currents and voltages applied on each**
- 1656 RPC HV channel.**
- 1657 • Offline-L0-EffC1.csv , is used to write the efficiencies, cluster size and cluster multiplicity**
- 1658 of efficiency runs. Note that L0 refers here to *Level 0* and means that the results of efficiency and**
- 1659 clusterization are a first approximation calculated without performing any muon tracking in**

1660 between the different detectors. This offline tool provides the user with a preliminar calculation
 1661 of the efficiency and of the muon event parameters. Another analysis software especially
 1662 dedicated to muon tracking is called on selected data to retrieve the results of efficiency and
 1663 muon clusterization using a tracking algorithm to discriminate noise or gamma from muons
 1664 as muons are the only particles that pass through the full setup, leaving hits than can be used
 1665 to reconstruct their tracks.

- 1666 • `Offline-Rate.csv`, is used to write the noise or gamma rates measured in the detector readout
 1667 partitions.

1668 Note that these 4 CSV files are created along with their *headers* (`Offline-[...]-Header.csv`
 1669 containing the names of each data columns) and are automatically merged together when the offline
 1670 analysis tool is called from the webDCS, contrary to the case where the tool is runned locally from
 1671 the terminal as the merging bash script is then not called. Thus, the resulting files, used to make
 1672 official plots, are:

- 1673 • `Corrupted.csv`,
 1674 • `Current.csv`,
 1675 • `L0-EffCl.csv`.
 1676 • `Rate.csv`.

1677 B.3 Analysis inputs and information handling

1678 The usage of the Offline Analysis tool as well as its output have been presented in the previous section.
 1679 It is now important to dig further and start looking at the source code and the inputs necessary
 1680 for the tool to work. Indeed, other than the raw ROOT data files that are analysed, more information
 1681 needs to be imported inside of the program to perform the analysis such as the description of the
 1682 setup inside of GIFT++ at the time of data taking (number of trolleys, of RPCs, dimensions of the
 1683 detectors, etc...) or the mapping that links the TDC channels to the coresponding RPC channels in
 1684 order to translate the TDC information into human readable data. 2 files are used to transmit all this
 1685 information:
 1686

- 1687 • `Dimensions.ini`, that provides the necessary setup and RPC information, and
 1688 • `ChannelsMapping.csv`, that gives the link between the TDC and RPC channels as well as the
 1689 *mask* for each channel (masked or not?).

1690 B.3.1 Dimensions file and InFile parser

1691 This input file, present in every data folder, allows the analysis tool to know of the number of active
 1692 trolleys, the number of active RPCs in those trolleys, and the details about each RPCs such as
 1693 the number of RPC gaps, the number of pseudo-rapidity partitions (for CMS-like prototypes), the
 1694 number of strips per partion or the dimensions. To do so, there are 3 types of groups in the INI file
 1695 architecture. A first general group, appearing only once at the head of the document, gives information
 1696 about the number of active trolleys as well as their IDs, as presented in Source Code B.1. For

1697 each active trolley, a group similar to Source Code B.2 can be found containing information about
 1698 the number of active detectors in the trolley and their IDs. Each trolley group as a `Tt` name format,
 1699 where `t` is the trolley ID. Finally, for each detector stored in slots of an active trolley, there is a group
 1700 providing information about their names and dimensions, as shown in Source Code B.3. Each slot
 1701 group as a `TtSs` name format, where `s` is the slot ID of trolley `t` where the active RPC is hosted.

```
1702 [General]
1703 nTrolleys=2
  TrolleysID=13
```

1704 *Source Code B.1: Example of `[General]` group as might be found in `Dimensions.ini`. In Gif++, only 2
 trolleys are available to hold RPCs and place them inside of the bunker for irradiation. The IDs of the trolleys
 are written in a single string as "13" and then read character by character by the program.*

```
1705 [T1]
  nSlots=4
  SlotsID=1234
```

1706 *Source Code B.2: Example of trolley group as might be found in `Dimensions.ini`. In this example, the file
 tells that there are 4 detectors placed in the holding slots of the trolley `T1` and that their IDs, written as a single
 string variable, are 1, 2, 3 and 4.*

```
1707 [T1S1]
  Name=RE2-2-NPD-BARC-8
  Partitions=3
  Gaps=3
  Gap1=BOT
  Gap2=TN
  Gap3=TW
  AreaGap1=11694.25
  AreaGap2=6432
  AreaGap3=4582.82
  Strips=32
  ActiveArea-A=157.8
  ActiveArea-B=121.69
  ActiveArea-C=93.03
```

1708 *Source Code B.3: Example of slot group as might be found in `Dimensions.ini`. In this example, the file
 provides information about a detector named `RE2-2-NPD-BARC-8`, having 3 pseudo-rapidity readout partitions
 and stored in slot `S1` of trolley `T1`. This is a CMS RE2-2 type of detector. This information will then be used for
 example to compute the rate per unit area calculation.*

1709 This information is readout and stored in a C++ object called `IniFile`, that parses the information
 1710 in the INI input file and stores it into a local buffer for later use. This INI parser is the exact same
 1711 one that was previously developed for the Gif++ DAQ and described in Appendix A.5.2.

1712 B.3.2 TDC to RPC link file and Mapping

1713 The same way the INI dimension file information is stored using `map`, the channel mapping and mask
 1714 information is stored and accessed through `map`. First of all, the mapping CSV file is organised into
 1715 3 columns separated by tabulations (and not by commas, as expected for CSV files as it is easier using
 1716 streams to read tab or space separated data using C++):

1717

1718 RPC_channel TDC_channel mask

1719 using as formatting for each field:

1720 TSCCC TCCC M

1722 TSCCC is a 5-digit integer where T is the trolley ID, s the slot ID in which the RPC is held insite
 1723 the trolley T and CCC is the RPC channel number, or *strip* number, that can take values up to
 1724 3-digits depending on the detector,

1725 TCCC is a 4 digit integer where T is the TDC ID, CCC is the TDC channel number that can take values
 1726 in between 0 and 127, and

1727 M is a 1-digit integer indicating if the channel should be considered ($M = 1$) or discarded ($M = 0$)
 1728 during analysis.

1729 This mapping and masking information is readout and stored thanks to the object `Mapping`, pre-
 1730 sented in Source Code B.4. Similarly to `IniFile` objects, this class has private methods. The first
 1731 one, `Mapping::CheckIfNewLine()` is used to find the newline character '`\n`' or return character
 1732 '`\r`' (depending on which kind of operating system interacted with the file). This is used for the
 1733 simple reason that the masking information has been introduced only during the year 2017 but the
 1734 channel mapping files exist since 2015 and the very beginning of data taking at GIF++. This means
 1735 that in the older data folders, before the upgrade, the channel mapping file only had 2 columns, the
 1736 RPC channel and the TDC channel. For compatibility reasons, this method helps controling the
 1737 character following the readout of the 2 first fields of a line. In case any end of line character is
 1738 found, no mask information is present in the file and the default $M = 1$ is used. On the contrary, if
 1739 the next character was a tabulation or a space, the mask information is present.

1740 Once the 3 fields have been readout, the second private method `Mapping::CheckIfTDCCh()` is
 1741 used to control that the TDC channel is an existing TDC channel. Finally, the information is stored
 1742 into 3 different maps (`Link`, `ReverseLink` and `Mask`) thanks to the public method `Mapping::Read()`.
 1743 `Link` allows to get the RPC channel by knowing the TDC channel while `ReverseLink` does the op-
 1744 posite by returning the TDC channel by knowing the RPC channel. Finally, `Mask` returns the mask
 1745 associated to a given RPC channel.

```

1746 typedef map<UInt, UInt> MappingData;

1747 class Mapping {
1748     private:
1749         bool          CheckIfNewLine(char next);
1750         bool          CheckIfTDCCh(UInt channel);
1751         string        FileName;
1752         MappingData Link;
1753         MappingData ReverseLink;
1754         MappingData Mask;
1755         int           Error;
1756
1757     public:
1758         Mapping();
1759         Mapping(string baseName);
1760         ~Mapping();
1761
1762         void SetFileName(const string filename);
1763         int Read();
1764         UInt GetLink(UInt tdcchannel);
1765         UInt GetReverse(UInt rpcchannel);
1766         UInt GetMask(UInt rpcchannel);
1767     };

```

1748 *Source Code B.4: Description of C++ object Mapping used as a parser for the channel mapping and mask file.*

1749 B.4 Description of GIF++ setup within the Offline Analysis tool

1750 In the previous section, the tool input files have been discussed. The dimension file information is
 1751 stored in a map hosted by the `IniFile` object. But this information is then used to create a series of
 1752 new objects that helps defining the GIF++ infrastructure directly into the Offline Analysis. Indeed,
 1753 from the `RPC`, to the more general `Infrastructure`, every element of the GIF++ infrastrucutre is
 1754 recreated for each data analysis based on the information provided in input. All this information
 1755 about the infrastructure will be used to assign each hit signal to a specific strip channel of a specific
 1756 detector, and having a specific active area. This way, rate per unit area calculation is possible.
 1757

1758 B.4.1 RPC objects

1759 `RPC` objects have been developped to represent physical active detectors in GIF++ at the moment
 1760 of data taking. Thus, there are as many `RPC` objects created during the analysis than there were
 1761 active `RPCs` tested during a run. Each `RPC` hosts the information present in the corresponding INI
 1762 slot group, as shown in B.3, and organises it using a similar architecture. This can be seen from
 1763 Source B.5.

1764 To make the object more compact, the lists of gap labels, of gap active areas and strip active
 1765 areas are stored into `vector` dynamical containers. `RPC` objects are always contructed thanks to the
 1766 dimension file information stored into the `IniFILE` and their ID, using the format `TtSs`. Using the
 1767 `RPC` ID, the constructor calls the methods of `IniFILE` to initialise the `RPC`. The other constructors
 1768 are not used but exist in case of need. Finally, some getters have been written to access the different
 1769 private parameters storing the detector information.

```

1770
class RPC{
    private:
        string      name;           //RPC name as in webDCS database
        Uint        nGaps;          //Number of gaps in the RPC
        Uint        nPartitions;    //Number of partitions in the RPC
        Uint        nStrips;         //Number of strips per partition
        vector<string> gaps;       //List of gap labels (BOT, TOP, etc...)
        vector<float>  gapGeo;        //List of gap active areas
        vector<float>  stripGeo;      //List of strip active areas

    public:
        RPC();
        RPC(string ID, IniFile* geofile);
        RPC(const RPC& other);
        ~RPC();
        RPC& operator=(const RPC& other);

        string GetName();
        Uint GetNGaps();
        Uint GetNPartitions();
        Uint GetNStrips();
        string GetGap(Uint g);
        float GetGapGeo(Uint g);
        float GetStripGeo(Uint p);
};

1771

```

1772 *Source Code B.5: Description of C++ objects RPC that describe each active detectors used during data taking.*

1773 B.4.2 Trolley objects

1774 Trolley objects have been developped to represent physical active trolleys in GIFT++ at the moment
 1775 of data taking. Thus, there are as many trolley objects created during the analysis than there were
 1776 active trolleys hosting tested RPCs during a run. Each Trolley hosts the information present in the
 1777 corresponding INI trolley group, as shown in B.2, and organises it using a similar architecture. In
 1778 addition to the information hosted in the INI file, these object have a dynamical container of RPC
 1779 objects, representing the active detectors the active trolley was hosting at the time of data taking.
 1780 This can been seen from Source Code B.6.

1781 Trolley objects are always contructed thanks to the dimension file information stored into the
 1782 IniFILE and their ID, using the format Tt. Using the Trolley ID, the constructor calls the methods
 1783 of IniFILE to initialise the Trolley. Retrieving the information of the RPC IDs via SlotsID, a new
 1784 RPC is constructed and added to the container RPCs for each character in the ID string. The other
 1785 constructors are not used but exist in case of need. Finally, some getters have been written to access
 1786 the different private parameters storing the trolley and detectors information.

```

1787
class Trolley{
    private:
        Uint          nSlots; //Number of active RPCs in the considered trolley
        string        SlotsID; //Active RPC IDs written into a string
        vector<RPC*> RPCs;   //List of active RPCs

    public:
        //Constructors, destructor and operator =
        Trolley();
        Trolley(string ID, IniFile* geofile);
        Trolley(const Trolley& other);
        ~Trolley();
        Trolley& operator=(const Trolley& other);

        //Get GIFTrolley members
        Uint  GetNSlots();
        string GetSlotsID();
        Uint   GetSlotID(Uint s);

        //Manage RPC list
        RPC*  GetRPC(Uint r);
        void  DeleteRPC(Uint r);

        //Methods to get members of RPC objects stored in RPCs
        string GetName(Uint r);
        Uint   GetNGaps(Uint r);
        Uint   GetNPartitions(Uint r);
        Uint   GetNStrips(Uint r);
        string GetGap(Uint r, Uint g);
        float  GetGapGeo(Uint r, Uint g);
        float  GetStripGeo(Uint r, Uint p);
    };

```

Source Code B.6: Description of C++ objects `Trolley` that describe each active trolley used during data taking.

1790 B.4.3 Infrastructure object

1791 The `Infrastructure` object has been developped to represent the GIFT++ bunker area dedicated to
 1792 CMS RPC experiments. With this very specific object, all the information about the CMS RPC
 1793 setup within GIFT++ at the moment of data taking is stored. It hosts the information present in the
 1794 corresponding INI general group, as shown in B.1, and organises it using a similar architecture. In
 1795 addition to the information hosted in the INI file, this object have a dynamical container of `Trolley`
 1796 objects, representing the active tolleys in GIFT++ area. This can be seen from Source Code B.7.

1797 The `Infrastructure` object is always contructed thanks to the dimension file information stored
 1798 into the `IniFILE`. Retrieving the information of the trolley IDs via `TrolleysID`, a new `Trolley` is
 1799 constructed and added to the container `Trolleys` for each character in the ID `string`. By extension,
 1800 it is easy to understand that the process described in Section B.4.2 for the construction of RPCs
 1801 takes place when a trolley is constructed. The other constructors are not used but exist in case of
 1802 need. Finally, some getters have been written to access the different private parameters storing the
 1803 infrastructure, tolleys and detectors information.

```

1804
class Infrastructure {
    private:
        Uint             nTrolleys;   //Number of active Trolleys in the run
        string          TrolleysID; //Active trolley IDs written into a string
        vector<Trolley*> Trolleys; //List of active Trolleys (struct)

    public:
        //Constructors and destructor
        Infrastructure();
        Infrastructure(IniFile* geofile);
        Infrastructure(const Infrastructure& other);
        ~Infrastructure();
        Infrastructure& operator=(const Infrastructure& other);

        //Get Infrastructure members
        Uint  GetNTrolleys();
        string GetTrolleysID();
        Uint   GetTrolleyID(Uint t);

1805
        //Manage Trolleys
        Trolley* GetTrolley(Uint t);
        void     DeleteTrolley(Uint t);

        //Methods to get members of GIFTrolley objects stored in Trolleys
        Uint  GetNSlots(Uint t);
        string GetSlotsID(Uint t);
        Uint   GetSlotID(Uint t, Uint s);
        RPC*  GetRPC(Uint t, Uint r);

        //Methods to get members of RPC objects stored in RPCs
        string GetName(Uint t, Uint r);
        Uint   GetNGaps(Uint t, Uint r);
        Uint   GetNPartitions(Uint t, Uint r);
        Uint   GetNStrips(Uint t, Uint r);
        string GetGap(Uint t, Uint r, Uint g);
        float  GetGapGeo(Uint t, Uint r, Uint g);
        float  GetStripGeo(Uint t, Uint r, Uint p);
};


```

Source Code B.7: Description of C++ object *Infrastructure* that contains the full information about CMS RPC experiment in GIF++.

1807 B.5 Handeling of data

1808 As discussed in Appendix A.4.2, the raw data as a `TTree` architecture where every entry is related to
 1809 a trigger signal provided by a muon or a random pulse, whether the goal of the data taking was to
 1810 measure the performance of the detector or the noise/gamma background respectively. Each of these
 1811 entries, referred also as events, contain a more or less full list of hits in the TDC channels to which
 1812 the detectors are connected. To this list of hits corresponds a list of time stamps, marking the arrival
 1813 of the hits within the TDC channel.

1814 The infrastructure of the CMS RPC experiment within GIF++ being defined, combining the
 1815 information about the raw data with the information provided by both the mapping/mask file and the
 1816 dimension file allows to build new physical objects that will help in computing efficiency or rates.

1817 B.5.1 RPC hits

1818 The raw data stored in the ROOT file as output of the GIFT++ DAQ, is readout by the analysis tool
 1819 using the structure `RAWData` presented in Source Code B.9 that differs from the structure presented
 1820 in Appendix A.4.2 as it is not meant to hold all of the data contained in the ROOT file. In this sense,
 1821 this structure is in the case of the offline analysis tool not a dynamical object and will only be storing
 1822 a single event contained in a single entry of the `TTree`.

```
1823
1824 class RPCHit {
1825     private:
1826         Uint Channel;      //RPC channel according to mapping (5 digits)
1827         Uint Trolley;      //0, 1 or 3 (1st digit of the RPC channel)
1828         Uint Station;      //Slot where is held the RPC in Trolley (2nd digit)
1829         Uint Strip;        //Physical RPC strip where the hit occurred (last 3
1830             digits)
1831         Uint Partition;    //Readout partition along eta segmentation
1832         float TimeStamp;   //Time stamp of the arrival in TDC
1833
1834     public:
1835         //Constructors, destructor & operator =
1836         RPCHit();
1837         RPCHit(Uint channel, float time, Infrastructure* Infra);
1838         RPCHit(const RPCHit& other);
1839         ~RPCHit();
1840         RPCHit& operator=(const RPCHit& other);
1841
1842         //Get RPCHit members
1843         Uint GetChannel();
1844         Uint GetTrolley();
1845         Uint GetStation();
1846         Uint GetStrip();
1847         Uint GetPartition();
1848         float GetTime();
1849     };
1850
1851     typedef vector<RPCHit> HitList;
1852     typedef struct GIFHitList { HitList rpc[NTROLLEYS][NSLOTS][NPARTITIONS]; } →
1853         GIFHitList;
1854
1855     bool SortHitbyStrip(RPCHit h1, RPCHit h2);
1856     bool SortHitbyTime(RPCHit h1, RPCHit h2);

```

1825 *Source Code B.8: Description of C++ object RPCHit.*

```
1826     struct RAWData{
1827         int iEvent;          //Event i
1828         int TDCNHits;       //Number of hits in event i
1829         int QFlag;           //Quality flag list (1 flag digit per TDC)
1830         vector<Uint> *TDCCh; //List of channels giving hits per event
1831         vector<float> *TDCTS; //List of the corresponding time stamps
1832     };

```

1827 *Source Code B.9: Description of C++ structure RAWData.*

1828 Each member of the structure is then linked to the corresponding branch of the ROOT data tree,
 1829 as shown in the example of Source Code B.10, and using the method `GetEntry(int i)` of the ROOT
 1830 class `TTree` will update the state of the members of `RAWData`.

```

1831 TTree* dataTree = (TTree*)dataFile.Get("RAWData");
1832 RAWData data;
1833
1834 dataTree->SetBranchAddress("EventNumber", &data.iEvent);
1835 dataTree->SetBranchAddress("number_of_hits", &data.TDCNHits);
1836 dataTree->SetBranchAddress("Quality_flag", &data.QFlag);
1837 dataTree->SetBranchAddress("TDC_channel", &data.TDCCh);
1838 dataTree->SetBranchAddress("TDC_TimeStamp", &data.TDCTS);

```

1833 *Source Code B.10: Example of link in between RAWData and TTree.*

1834 The data is then analysed entry by entry and to each element of the TDC channel list, a `RPCHit` is
1835 constructed by linking each TDC channel to the corresponding RPC channel thanks to the `Mapping`
1836 object. The information carried by the RPC channel format allows to easily retrieve the trolley and
1837 slot from which the hit was recorded (see section B.3.2). Using these 2 values, the readout partition
1838 can be found by knowing the strip channel and comparing it with the number of partitions and strips
1839 per partition stored into the `Infrastructure` object.

1840 Thus `RPCHit` objects are then stored into 3D dynamical list called `GIFHitList` (Source Code B.9)
1841 where the 3 dimensions refer to the 3 layers of the readout in `GIF++` : in the bunker there are *trolleys*
1842 (τ) holding detectors in *slots* (s) and each detector readout is divided into 1 or more pseudo-rapidity
1843 *partitions* (p). Using these 3 information allows to assign an address to each readout partition and
1844 this address will point to a specific hit list.

1845

1846 **B.5.2 Clusters of hits**

1847 All the hits contained in the ROOT file have been sorted into the different hit lists through the
1848 `GIFHitList`. At this point, it is possible to start looking for clusters. A cluster is a group of adjacent
1849 strips getting hits within a time window of 25 ns. These strips are then assumed to be part of the same
1850 physical avalanche signal generated by a muon passing through the chamber or by the interaction of
1851 a gamma stopping into the electrodes of the RPCs.

1852 To keep the cluster information, `RPCCluster` objects have been defined as shown in Source
1853 Code B.11. Using the information of each individual `RPCHit` taken out of the hit list, it stores
1854 the cluster size (number of adjacent strips composing the cluster), the first and last hit, the center for
1855 spatial reconstruction and finally the start and stop time stamps as well as the time spread in between
1856 the first and last hit.

```

1857
class RPCCluster{
    private:
        Uint ClusterSize; //Size of cluster #ID
        Uint FirstStrip; //First strip of cluster #ID
        Uint LastStrip; //Last strip of cluster #ID
        float Center; //Center of cluster #ID ((first+last)/2)
        float StartStamp; //Time stamp of the earliest hit of cluster #ID
        float StopStamp; //Time stamp of the latest hit of cluster #ID
        float TimeSpread; //Time difference between earliest and latest hits
                           //of cluster #ID

    public:
        //Constructors, destructor & operator =
        RPCCluster();
        RPCCluster(HitList List, Uint cID, Uint cSize, Uint first, Uint firstID);
        RPCCluster(const RPCCluster& other);
        ~RPCCluster();
        RPCCluster& operator=(const RPCCluster& other);

        //Get Cluster members
        Uint GetID();
        Uint GetSize();
        Uint GetFirstStrip();
        Uint GetLastStrip();
        float GetCenter();
        float GetStart();
        float GetStop();
        float GetSpread();
};

typedef vector<RPCCluster> ClusterList;

//Other functions to build cluster lists out of hit lists
void BuildClusters(HitList &cluster, ClusterList &clusterList);
void Clusterization(HitList &hits, TH1 *hcSize, TH1 *hcMult);

```

Source Code B.11: Description of C++ object cluster.

To investigate the hit list of a given detector partition, the function `Clusterization()` defined in `include/Cluster.h` needs the hits in the list to be time sorted. This is achieved by calling function `sort()` of library `<algorithm>` using the comparator `SortHitbyTime(RPCHit h1, RPCHit h2)` defined in `include/RPCHit.h` that returns `true` if the time stamp of hit `h1` is lower than that of `h2`. A first isolation of strips is made only based on time information. All the hits within the 25 ns window are taken separately from the rest. Then, this sub-list of hits is sorted this time by ascending strip number, using this time the comparator `SortHitbyStrip(RPCHit h1, RPCHit h2)`. Finally, the groups of adjacent strips are used to construct `RPCCluster` objects that are then stored in a temporary list of clusters that is at the end of the process used to know how many clusters were reconstructed and to fill their sizes into an histogram that will allows to know the mean size of muon or gamma clusters.

B.6 DAQ data Analysis

1873 All the ingredients to analyse GIF++ data have been defined. This section will focus on the different
1874 part of the analysis performed on the data, from determining the type of data the tool is dealing with

1875 to calculating the rate in each detector or reconstructing muon or gamma clusters.

1876 B.6.1 Determination of the run type

1877 In GIF++, both the performance of the detectors in detecting muons in an irradiated environment and
 1878 the gamma background can be independantly measured. These corresponds to different run types
 1879 and thus, to different TDC settings giving different data to look at.

1880
 1881 In the case of performance measurements, the trigger for data taking is provided by the coïncidence
 1882 of several scintillators when muons from the beam passing through the area are detected. Data
 1883 is collected in a 600 ns wide window around the arrival of muons in the RPCs. The expected time
 1884 distribution of hits is shown in Figure B.1a. The muon peak is clearly visible in the center of the
 1885 distribution and is to be extracted from the gamma background that composes the flat part of the
 1886 distribution.

1887 On the other hand, gamma background or noise measurements are focussed on the non muon
 1888 related physics and the trigger needs to be independant from the muons to give a good measurement
 1889 of the gamma/noise distribution as seen by the detectors. The trigger is then provided by a pulse
 1890 generator at a frequency of 300 Hz whose pulse is not likely to be on time with a muon. In order
 1891 to increase the integrated time without increasing the acquisition time too much, the width of the
 1892 acquisition windows are increased to 10 μ s. The time distribution of the hits is expected to be flat, as
 1893 shown by Figure B.1b.




Figure B.1: Example of expected hit time distributions in the cases of efficiency (Figure B.1a) and noise/gamma rate per unit area (Figure B.1b) measurements as extracted from the raw ROOT files. The unit along the x-axis corresponds to ns. The fact that "the" muon peak is not well defined in Figure B.1a is due to the contribution of all the RPCs being tested at the same time that don't necessarily have the same signal arrival time. Each individual peak can have an offset with the ones of other detectors. The inconsistency in the first 100 ns of both time distributions is an artefact of the TDCs and are systematically rejected during the analysis.

1894 The ROOT files include a TTree called RunParameters containing, among other things, the in-
 1895 formation related to the type of run. The run type can then be accessed as described by Source
 1896 Code B.12 and the function IsEfficiencyRun() is then used to determine if the run file is an effi-
 1897 ciency run or, on the contrary, another type of run (noise or gamma measurement).

```

1898
1899     TTree* RunParameters = (TTree*)dataFile.Get("RunParameters");
1900     TString* RunType = new TString();
1901     RunParameters->SetBranchAddress("RunType", &RunType);
1902     RunParameters->GetEntry(0);

```

1900 *Source Code B.12: Access to the run type contained in TTree* RunParameters.*

1901 Finally, the data files will have a slightly different content whether it was collected before or after
1902 October 2017 and the upgrade of the DAQ software that brought a new information into the ROOT
1903 output. This is discussed in Appendix A.4.3 and implies that the analysis will differ a little depending
1904 on the data format. Indeed, as no information on the data quality is stored, in older data files, the cor-
1905 rections for missing events has to be done at the end of the analysis. The information about the type
1906 of data format is stored in the variable **bool** `isNewFormat` by checking the list of branches contained
1907 in the data tree via the methods `TTree::GetListOfBranches()` and `TCollection::Contains()`.

1908 **B.6.2 Beam time window calculation for efficiency runs**

1909 Knowing the run type is important first of all to know the width of the acquisition window to be used
1910 for the rate calculation and finally to be able to seek for muons. Indeed, the peak that appears in the
1911 time distribution for each detectors is then fitted to extract the most probable time window in which
1912 the tool should look for muon hits. The data outside of this time window is then used to evaluate the
1913 noise or gamma background the detector was subjected to during the data taking. Computing the
1914 position of the peak is done calling the function `SetBeamWindow()` defined in file `src/RPCHit.cc` that
1915 loops a first time on the data. The data is first sorted in a 3D array of 1D histograms (`GIFH1Array`, see
1916 `include/types.h`). Then the location of the highest bin is determined using `TH1::GetMaximumBin()`
1917 and is used to define a window in which a gaussian fit will be applied to compute the peak width.
1918 This window is a 80 ns defined by Formula B.1 around the central bin.

$$t_{center}(ns) = bin \times width_{bin}(ns) \quad (\text{B.1a})$$

$$[t_{low}; t_{high}] = [t_{center} - 40; t_{center} + 40] \quad (\text{B.1b})$$

1919 Before the fit is performed, the average number of noise/gamma hits per bin is evaluated using
1920 the data outside of the fit window. Excluding the first 100 ns, the average number of hits per bin
1921 due to the noise or gamma is defined by Formula B.2 after extracting the amount of hits in the time
1922 windows $[100; t_{low}]$ and $[t_{high}; 600]$ thanks to the method `TH1::Integral()`. This average number
1923 of hits is then subtracted to every bin of the 1D histogram, in order to *clean* it from the noise or
1924 gamma contribution as much as possible to improve the fit quality. Bins where $\langle n_{hits} \rangle$ is greater
1925 than the actual bin content are set to 0.

$$\Delta t_{noise}(ns) = 600 \overbrace{-t_{high} + t_{low}}^{-80ns} - 100 = 420ns \quad (\text{B.2a})$$

$$\langle n_{hits} \rangle = width_{bin}(ns) \times \frac{\sum_{t=100}^{t_{low}} + \sum_{t=t_{high}}^{600}}{\Delta t_{noise}(ns)} \quad (\text{B.2b})$$

1926 Finally, the fit parameters are extracted and saved for each detector in 3D arrays of **float**
1927 (`muonPeak`, see `include/types.h`), a first one for the mean arrival time of the muons, `PeakTime`,

1928 and a second one for the width of the peak, `PeakWidth`. The width is defined as 6σ of the gaussian
 1929 fit. The same settings are applied to every partitions of the same detector. To determine which one
 1930 of the detector's partitions is directly illuminated by the beam, the peak height of each partition is
 1931 compared and the highest one is then used to define the peak settings.

1932 **B.6.3 Data loop and histogram filling**

1933 3D arrays of histogram are created to store the data and display it on the DQM of G4F++ webDCS
 1934 for the use of shifters. These histograms, presented in section B.2.1.1, are filled while looping on
 1935 the data. Before starting the analysis loop, it is necessary to control the entry quality for the new
 1936 file formats featuring `QFlag`. If the `QFlag` value for this entry shows that 1 TDC or more have a
 1937 `CORRUPTED` flag, then this event is discarded. The loss of statistics is low enough to be neglected.
 1938 `QFlag` is controlled using the function `IsCorruptedEvent()` defined in `src/utils.cc`. As explained
 1939 in Appendix A.4.3, each digit of this integer represents a TDC flag that can be 1 or 2. Each 2 is
 1940 the sign of a `CORRUPTED` state. Then, the data is accessed entry by entry in the ROOT `TTree` using
 1941 `RAWData` and each hit in the hit list is assigned to a detector channel and saved in the corresponding
 1942 histograms. In the first part of the analysis, in which the loop over the ROOT file's content is
 1943 performed, the different steps are:

1944 **1- RPC channel assignment and control:** a check is done on the RPC channel extracted thanks
 1945 to the mapping via the method `Mapping::GetLink()`. If the channel is not initialised and is 0, or if
 1946 the TDC channel was greater than 5127, the hit is discarded. This means there was a problem in the
 1947 mapping. Often a mapping problem leads to the crash of the offline tool.

1948 **2- Creation of a `RPCHit` object:** to easily get the trolley, slot and partition in which the hit has
 1949 been assigned, this object is particularly helpful.

1950 **3- General histograms are filled:** the hit is filled into the time distribution and the general hit
 1951 distribution histograms, and if the arrival time is within the first 100 ns, it is discarded and nothing
 1952 else happens and the loop proceeds with the next hit in the list.

1953 **4- Multiplicity counter:** the hit multiplicity counter of the corresponding detectors incremented.

1954 **5-a- Efficiency runs - Is the hit within the peak window? :** if the peak is contained in the peak
 1955 window previously defined in section B.6.2, the hit is filled into the beam hit profile histogram of
 1956 the corresponding chamber, added into the list of muon hits and increments the counter of *in time*
 1957 hits. The term *in time* here refers to the hits that are likely to be muons by arriving in the expected
 1958 time window. If the hit is outside of the peak window, it is filled into the noise profile histogram
 1959 of the corresponding detector, added into the list of noise/gamma hits and increments the counter of
 1960 noise/gamma hits.

1961 **5-b- Noise/gamma rate runs - Noise histograms are filled:** the hit is filled into the noise profile
 1962 histogram of the corresponding detector, added into the list of noise/gamma hits and increments the
 1963 counter of noise/gamma hits.

1965 After the loop on the hit list of the entry is over, the next step is to clusterize the 3D lists filled
 1966 in the previous steps. A 3D loop is then started over the active trolley, slot and RPC partitions to
 1967 access these objects. Each `NoiseHitList` and `MuonHitList`, in case of efficiency run, are clusterized
 1968 as described in section B.5.2. There corresponding cluster size and multiplicity histograms are filled
 1969 at the end of the clustering process. Then, the efficiency histogram is filled in case of efficiency run.
 1970 The selection is simply made by checking whether the RPC detected signals in the peak window
 1971 during this event. Nevertheless, it is useful to highlight that at this level, it is not possible yet to
 1972 discriminate in between a muon hit and noise or gamma hit. Thus, `MuonCSize_H`, `MuonCMult_H`
 1973 and `Efficiency0_H` are subjected to noise and gamma contamination. This contamination will be
 1974 estimated and corrected at the moment the results will be written into output CSV files. Finally, the
 1975 loop ends on the filling of the general hit multiplicity histogram.

1976 **B.6.4 Results calculation**

1977 As mentioned in section B.2.1, the analysis of DAQ data provides the user with 3 CSV files and
 1978 a ROOT file associated to each and every ROOT data file. The fourth CSV file is provided by the
 1979 extraction of the CEAN main frame data monitored during data taking and will be discussed later.
 1980 After looping on the data in the previous part of the analysis macro, the output files are created and a
 1981 3D loop on each RPC readout partitions is started to extract the histograms parameters and compute
 1982 the final results.

1983

1984 **B.6.4.1 Rate normalisation**




Figure B.2: The effect of the quality flag is explained by presenting the reconstructed hit multiplicity of a data file without `Quality_flag`. The artificial high content of bin 0 is the effect of corrupted data.

1985 To analyse old data format files, not containing any quality flag, it is needed to estimate the amount
 1986 of corrupted data via a fit as the corrupted data will always fill events with a fake "0 multiplicity".
 1987 Indeed, as no hits were stored in the DAQ ROOT files, these events artificially contribute to fill
 1988 the bin corresponding to a null multiplicity, as shown in Figure B.2. In the case the mean of the

1989 hit multiplicity distribution is high, the contribution of the corrupted data can easily be evaluated
 1990 for later correction by comparing the level of the bin at multiplicity 0 and of a skew fit curve that
 1991 should indicate a value consistent with 0. A skew fit has been chosen over a Poisson fit as it was
 1992 giving better results for lower mean multiplicity values. Nevertheless, for low irradiation cases,
 1993 as explained in Appendix A.4.3, the hit multiplicity distribution mean is, on the contrary, rather
 1994 small and the probability to record events without hits can't be considered small anymore, leading
 1995 to a difficult and non-reliable estimation of the corruption. As can be seen in Source Code B.13,
 1996 conditions have been applied to prevent bad fits and wrong corruption estimation in cases where :

1997 • The difference in between the data for multiplicity 1 and the corresponding fit value should be
 1998 lower than 1% of the total amount of data : $\frac{|n_{m=1} - sk(1)|}{N_{tot}} < 0.01$ where $n_{m=1}$ is the number
 1999 of entries with multiplicity 1, $sk(1)$ the value of the skew fit, as defined by Formula 4.3, for
 2000 multiplicity 1 and N_{tot} the total number of entries.

2001 • The amount of data contained in the multiplicity 0 bin should not exceed 40% : $\frac{n_{m=0}}{N_{tot}} \leq 0.4$
 2002 where $n_{m=0}$ is the number of entries with multiplicity 0. This number has been determined
 2003 to be the maximum to be able to separate the excess of data due to corruption from the hit
 2004 multiplicity distribution.

2005 Those 2 conditions need to be fulfilled to estimate the corruption of old data format files. If the
 2006 fit was successful, the level of corruption is written in `Offline-Corrupted.csv` and the number of
 2007 corrupted entries, refered as the integer `nEmptyEvent`, is subtracted from the total number of entries
 2008 when the rate normalisation factor is computed as explicit in Source Code B.13. Note that for new
 2009 data format files, the number of corrupted entries being set to 0, the definition of `rate_norm` stays
 2010 valid.

2011

```

if(!isNewFormat){
    TF1* GaussFit = new TF1("gaussfit","[0]*exp(-0.5*((x-[1])/[2])**2)",0,Xmax);
    GaussFit->SetParameter(0,100);
    GaussFit->SetParameter(1,10);
    GaussFit->SetParameter(2,1);
    HitMultiplicity_H.rpc[T][S][p]->Fit(GaussFit,"LIQR","");
    HitMultiplicity_H.rpc[T][S][p]->Fit(GaussFit,"LIQR","");
}

TF1* SkewFit = new TF1("skewfit","[0]*exp(-0.5*((x-[1])/[2])**2) / (1 +
→ exp(-[3]*(x-[4])))",0,Xmax);
SkewFit->SetParameter(0,GaussFit->GetParameter(0));
SkewFit->SetParameter(1,GaussFit->GetParameter(1));
SkewFit->SetParameter(2,GaussFit->GetParameter(2));
SkewFit->SetParameter(3,1);
SkewFit->SetParameter(4,1);
HitMultiplicity_H.rpc[T][S][p]->Fit(SkewFit,"LIQR","");
HitMultiplicity_H.rpc[T][S][p]->Fit(SkewFit,"LIQR","");

double fitValue = SkewFit->Eval(1,0,0,0);
double dataValue = (double)HitMultiplicity_H.rpc[T][S][p]->GetBinContent(2);
double difference = TMath::Abs(dataValue - fitValue);
double fitTOdataVSentries_ratio = difference / (double)nEntries;
bool isFitGOOD = fitTOdataVSentries_ratio < 0.01;

2012
double nSinglehit = (double)HitMultiplicity_H.rpc[T][S][p]->GetBinContent(1);
double lowMultRatio = nSinglehit / (double)nEntries;
bool isMultLOW = lowMultRatio > 0.4;

if(isFitGOOD && !isMultLOW){
    nEmptyEvent = HitMultiplicity_H.rpc[T][S][p]->GetBinContent(1);
    nPhysics = (int)SkewFit->Eval(0,0,0,0);
    if(nPhysics < nEmptyEvent)
        nEmptyEvent = nEmptyEvent-nPhysics;
}
}

double corrupt_ratio = 100.*(double)nEmptyEvent / (double)nEntries;
outputCorrCSV << corrupt_ratio << '\t';

float rate_norm = 0.;
float stripArea = GIFIInfra->GetStripGeo(tr,sl,p);

if(IsEfficiencyRun(RunType)){
    float noiseWindow = BMTDCWINDOW - TIMEREJECT - 2*PeakWidth.rpc[T][S][p];
    rate_norm = (nEntries-nEmptyEvent)*noiseWindow*1e-9*stripArea;
} else
    rate_norm = (nEntries-nEmptyEvent)*RDMNOISEWDW*1e-9*stripArea;

```

2013

Source Code B.13: Definition of the rate normalisation variable. It takes into account the number of non corrupted entries and the time window used for noise calculation, to estimate the total integrated time, and the strip active area to express the result as rate per unit area.

2014

B.6.4.2 Rate and activity

2015
2016
2017
2018
2019

At this point, the strip rate histograms, StripNoiseProfile_H.rpc[T][S][p], only contain an information about the total number of noise or rate hits each channel received during the data taking. As described in Source Code B.14, a loop on the strip channels will be used to normalise the content of the rate distribution histogram for each detector partitions. The initial number of hits recorded for a given bin will be extracted and 2 values will be computed:

- 2020 • the strip rate, defined as the number of hits recorded in the bin normalised like described in
 2021 the previous section, using the variable `rate_norm`, and

- 2022 • the strip activity, defined as the number of hits recorded in the bin normalised to the average
 2023 number of hits per bin contained in the partition histogram, using the variable `averageNhit`.
 2024 This value provides an information on the homogeneity of the detector response to the gamma
 2025 background or of the detector noise. An activity of 1 corresponds to an average response.
 2026 Above 1, the channel is more active than the average and bellow 1, the channel is less active.

```

int nNoise = StripNoiseProfile_H.rpc[T][S][p]->GetEntries();
float averageNhit = (nNoise>0) ? (float)(nNoise/nStripsPart) : 1.;

for(Uint st = 1; st <= nStripsPart; st++) {
  float stripRate =
    StripNoiseProfile_H.rpc[T][S][p]->GetBinContent(st)/rate_norm;
  float stripAct =
    StripNoiseProfile_H.rpc[T][S][p]->GetBinContent(st)/averageNhit;

  StripNoiseProfile_H.rpc[T][S][p]->SetBinContent(st,stripRate);
  StripActivity_H.rpc[T][S][p]->SetBinContent(st,stripAct);
}

```

2028 *Source Code B.14: Description of the loop that allows to set the content of each strip rate and strip activity
 channel for each detector partition.*

2029 On each detector partitions, which are readout by a single FEE, all the channels are not processed
 2030 by the same chip. Each chip can give a different noise response and thus, histograms using a chip
 2031 binning are used to investigate chip related noise behaviours. The average values of the strip rate
 2032 or activity grouped into a given chip are extracted using the using the function `GetChipBin()` and
 2033 stored in dedicated histograms as described in Source Codes B.15 and B.16 respectively.

```

float GetChipBin(TH1* H, Uint chip){
  Uint start = 1 + chip*NSTRIPSCHIP;
  int nActive = NSTRIPSCHIP;
  float mean = 0.;

  for(Uint b = start; b <= (chip+1)*NSTRIPSCHIP; b++) {
    float value = H->GetBinContent(b);
    mean += value;
    if(value == 0.) nActive--;
  }

  if(nActive != 0) mean /= (float)nActive;
  else mean = 0.;

  return mean;
}

```

2036 *Source Code B.15: Function used to compute the content of a bin for an histogram using chip binning.*

```

2037   for(UInt ch = 0; ch < (nStripsPart/NSTRIPSCHIP); ch++) {
      ChipMeanNoiseProf_H.rpc[T][S][p]->
          SetBinContent(ch+1,GetChipBin(StripNoiseProfile_H.rpc[T][S][p],ch));
      ChipActivity_H.rpc[T][S][p]->
          SetBinContent(ch+1,GetChipBin(StripActivity_H.rpc[T][S][p],ch));
}

```

Source Code B.16: Description of the loop that allows to set the content of each chip rate and chip activity bins for each detector partition knowing the information contained in the corresponding strip distribution histograms.

The activity variable is used to evaluate the homogeneity of the detector response to background or of the detector noise. The homogeneity h_p of each detector partition can be evaluated using the formula $h_p = \exp(-\sigma_p^R / \langle R \rangle_p)$, where $\langle R \rangle_p$ is the partition mean rate and σ_p^R is the rate standard deviation calculated over the partition channels. The more homogeneously the rates are distributed and the smaller will σ_p^R be, and the closer to 1 will h_p get. On the contrary, if the standard deviation of the channel's rates is large, h_p will rapidly get to 0. This value is saved into histograms as shown in Source Code B.17 and could in the future be used to monitor through time, once extracted, the evolution of every partition homogeneity. This could be of great help to understand the apparition of eventual hot spots due to ageing of the chambers subjected to high radiation levels. The monitored homogeneity information could then be combined with a monitoring of the activity of each individual channel in order to have a finer information. Monitoring tools have been suggested and need to be developed for this purpose.

```

2051   float MeanPartSDev = GetTH1StdDev(StripNoiseProfile_H.rpc[T][S][p]);
      float strip_homog = (MeanPartRate==0)
          ? 0.
          : exp(-MeanPartSDev/MeanPartRate);
      StripHomogeneity_H.rpc[T][S][p]->Fill("exp -#left(#frac{\#sigma_{Strip
          \rightarrow Rate}}{\#mu_{Strip Rate}}\#right)",strip_homog);
      StripHomogeneity_H.rpc[T][S][p]->GetYaxis()->SetRangeUser(0.,1.);

2052   float ChipStDevMean = GetTH1StdDev(ChipMeanNoiseProf_H.rpc[T][S][p]);
      float chip_homog = (MeanPartRate==0)
          ? 0.
          : exp(-ChipStDevMean/MeanPartRate);
      ChipHomogeneity_H.rpc[T][S][p]->Fill("exp -#left(#frac{\#sigma_{Chip
          \rightarrow Rate}}{\#mu_{Chip Rate}}\#right)",chip_homog);
      ChipHomogeneity_H.rpc[T][S][p]->GetYaxis()->SetRangeUser(0.,1.);

```

Source Code B.17: Storage of the homogeneity into dedicated histograms.

2054 B.6.4.3 Strip masking tool

The offline tool is automatically called at the end of each data taking to analyse the data and offer the shifter DQM histograms to control the data quality. After the histograms have been published online in the DQM page, the shifter can decide to mask noisy or dead channels that will contribute to bias the final rate calculation by editing the mask column of `ChannelsMapping.csv` as can be seen in Figure B.3.




Figure B.3: Display of the masking tool page on the webDCS. The window on the left allows the shifter to edit ChannelsMapping.csv. To mask a channel, it only is needed to set the 3rd field corresponding to the strip to mask to 0. It is not necessary for older mapping file formats to add a 1 for each strip that is not masked as the code is versatile and the default behaviour is to consider missing mask fields as active strips. The effect of the mask is directly visible for noisy channels as the corresponding bin turns red. The global effect of masking strips will be an update of the rate value showed on the histogram that will take into consideration the rejected channels.

2060 From the code point of view, the function `GetTH1Mean()` is used to retrieve the mean rate par-
 2061 tition by partition after the rates have been calculated strip by strip and filled into the histograms
 2062 `StripNoiseProfile_H.rpc[T][S][p]`, as described through Source Code B.18.

2063 Once the mask for each rejected channel has been updated, the shifter can manually run the of-
 2064 fline tool again to update the DQM plots, now including the masked strips, as well the rate results
 2065 written in the output CSV file `Offline-Rate.csv`. If not done during the shifts, the strip masking
 2066 procedure needs to be carefully done by the person in charge of data analysis on the scans that were
 2067 selected to produce the final results.

```

2068
2069     float GetTH1Mean(TH1* H) {
2070         int nBins = H->GetNbinsX();
2071         int nActive = nBins;
2072         float mean = 0.;

2073         for(int b = 1; b <= nBins; b++) {
2074             float value = H->GetBinContent(b);
2075             mean += value;
2076             if(value == 0.) nActive--;
2077         }

2078         if(nActive != 0) mean /= (float)nActive;
2079         else mean = 0.;

2080         return mean;
2081     }

```

Source Code B.18: The function `GetTH1Mean()` is used to return the mean along the y-axis of `TH1` histograms containing rate information. In order to take into account masked strips whose rate is set to 0, the function looks for masked channels and decrement the number of active channels for each null value found.

2071 B.6.4.4 Output CSV files filling

2072 All the histograms have been filled. Parameters will then be extracted from them to compute the
 2073 final results that will later be used to produce plots. Once the results have been computed, the very
 2074 last step of the offline macro is to write these values into the corresponding CSV outputs. Aside of
 2075 the file `Offline-Corrupted.csv`, 2 CSV files are being written by the macro `offlineAnalysis()`,
 2076 `Offline-Rates.csv` and `Offline-L0-EffCl.csv` that respectively contain information about noise
 2077 or gamma rates, cluster size and multiplicity, and about level 0 reconstruction of the detector effi-
 2078 ciency, muon cluster size and multiplicity. Details on the computation and file writing are respec-
 2079 tively given in Sources Codes B.19 and B.20.

2080 **Noise/gamma background variables** are computed and written in the output file for each detector
 2081 partitions. A detector average of the hit and cluster rate is also provided, as shown through Sources
 2082 Code B.19. The variables that are written for each partition are:

- 2083 • The mean partition hit rate per unit area, `MeanPartRate`, that is extracted from the histogram
 2084 `StripNoiseProfile_H` as the mean value along the y-axis, as described in section B.6.4.3. No
 2085 error is recorded for the hit rate as this is considered a single measurement. No statistical error
 2086 can be associated to it and the systematics are unknown.
- 2087 • The mean cluster size, `cSizePart`, is extracted from the histogram `NoiseCSize_H` and it's
 2088 statistical error, `cSizePartErr`, is taken to be 2σ of the total distribution.
- 2089 • The mean cluster multiplicity per trigger, `cMultPart`, is extracted from the histogram `NoiseCMult_H`
 2090 and it's statistical error, `cMultPartErr`, is taken to be 2σ of the total distribution. It is impor-
 2091 tant to point to the fact that this variable gives an information that is dependent on the buffer
 2092 window width used for each trigger for the calculation.
- 2093 • The mean cluster rate per unit area, `ClustPartRate`, is defined as the mean hit rate normalised

2094 to the mean cluster size and it's statistical error, `ClustPartRateErr`, is then obtained using the
 2095 relative statistical error on the mean cluster size.

```

for (UInt tr = 0; tr < GIFInfra->GetNTrolleys(); tr++) {
  UInt T = GIFInfra->GetTrolleyID(tr);

  for (UInt sl = 0; sl < GIFInfra->GetNSlots(tr); sl++) {
    UInt S = GIFInfra->GetSlotID(tr,sl) - 1;

    float MeanNoiseRate = 0.;
    float ClusterRate = 0.;
    float ClusterSDev = 0.;

    for (UInt p = 0; p < GIFInfra->GetNPartitions(tr,sl); p++) {
      float MeanPartRate = GetTH1Mean(StripNoiseProfile_H.rpc[T][S][p]);
      float cSizePart = NoiseCSIZE_H.rpc[T][S][p]->GetMean();
      float cSizePartErr = (NoiseCSIZE_H.rpc[T][S][p]->GetEntries()==0)
        ? 0.
        : 2*NoiseCSIZE_H.rpc[T][S][p]->GetStdDev() /
          sqrt(NoiseCSIZE_H.rpc[T][S][p]->GetEntries());
      float cMultPart = NoiseCMult_H.rpc[T][S][p]->GetMean();
      float cMultPartErr = (NoiseCMult_H.rpc[T][S][p]->GetEntries()==0)
        ? 0.
        : 2*NoiseCMult_H.rpc[T][S][p]->GetStdDev() /
          sqrt(NoiseCMult_H.rpc[T][S][p]->GetEntries());
      float ClustPartRate = (cSizePart==0) ? 0.
        : MeanPartRate/cSizePart;
      float ClustPartRateErr = (cSizePart==0) ? 0.
        : ClustPartRate * cSizePartErr/cSizePart;

      outputRateCSV << MeanPartRate << '\t'
        << cSizePart << '\t' << cSizePartErr << '\t'
        << cMultPart << '\t' << cMultPartErr << '\t'
        << ClustPartRate << '\t' << ClustPartRateErr << '\t';

      RPCarea += stripArea * nStripsPart;
      MeanNoiseRate += MeanPartRate * stripArea * nStripsPart;
      ClusterRate += ClustPartRate * stripArea * nStripsPart;
      ClusterSDev += (cSizePart==0)
        ? 0.
        : ClusterRate*cSizePartErr/cSizePart;
    }

    MeanNoiseRate /= RPCarea;
    ClusterRate /= RPCarea;
    ClusterSDev /= RPCarea;

    outputRateCSV << MeanNoiseRate << '\t'
      << ClusterRate << '\t' << ClusterSDev << '\t';
  }
}

```

2097 *Source Code B.19: Description of rate result calculation and writing into the CSV output Offline-Rate.csv.
 Are saved into the file for each detector, the mean partition rate, cluster size and cluster mutiplicity, along with
 their errors, for each partition and as well as a detector average.*

2098 **Muon performance variables** are computed and written in the output file for each detector parti-
 2099 tions as shown through Sources Code B.20. The variables that are written for each partition are:

- 2100 ● The muon efficiency, `eff`, extracted from the histogram `Efficiency0_H`. It is reminded that
2101 this offline tool doesn't include any tracking algorithm to identify muons from the beam and
2102 only relies on the hits arriving in the time window corresponding to the beam time. The con-
2103 tent of the efficiency histogram is thus biased by the noise/gamma background contribution
2104 into this window and is thus corrected by estimating the muon data content in the peak re-
2105 gion knowing the noise/gamma content in the rate calculation region. Both time windows
2106 being different, the choice was made to normalise the noise/gamma background calculation
2107 window to it's equivalent beam window in order to have comparable values using the variable
2108 `windowRatio`. Finally, to estimate the data ratio in the peak region, the variable `DataRatio`
2109 is defined as the ratio in between the estimated mean cluster multiplicity of the muons in the
2110 peak region, `MuonCM`, and of the total mean cluster multiplicity in the peak region, `PeakCM`.
2111 `MuonCM` is itself defined as the difference in between the total mean cluster multiplicity in the
2112 peak region and the normalised mean noise/gamma cluster multiplicity calculated outside of
2113 the peak region. The statistical error related to the efficiency, `eff_err`, is computed using a
2114 binomial distribution, as the efficiency measure the probability of "success" and "failure" to
2115 detect muons.
- 2116 ● The mean muon cluster size, `MuonCS`, is calculated using the total mean cluster size and multi-
2117 plicity in the peak region, respectively extracted from histograms `MuonCSize_H` and `MuonCMult_H`,
2118 the noise/gamma background mean cluster size and normalised multiplicity, extracted from
2119 `NoiseCSize_H` and `NoiseCMult_H`, and of the estimated muon cluster multiplicity `MuonCM` pre-
2120 viously explicated. The associated statistical error, `MuonCM_err`, is calculated using the propa-
2121 gation of errors of the mentioned variables.
- 2122 ● The mean muon cluster multiplicity in the peak region, `MuonCM`, explicated above whose sta-
2123 tistical error, `MuonCM_err`, is the sum of statistical error associated to the total mean clus-
2124 ter multiplicity in the peak reagion, `PeakCM_err`, and of the mean noise/gamma cluster size,
2125 `NoiseCM_err`.

2126 In addition to these 2 CSV files, the histograms are saved in ROOT file `Scan00XXXX_HVY_Offline.root`
2127 as explained in section B.2.1.1.

2128

```

for (UInt tr = 0; tr < GIFInfra->GetNTrolleys(); tr++) {
    UInt T = GIFInfra->GetTrolleyID(tr);
    for (UInt sl = 0; sl < GIFInfra->GetNSlots(tr); sl++) {
        UInt S = GIFInfra->GetSlotID(tr,sl) - 1;
        for (UInt p = 0; p < GIFInfra->GetNPartitions(tr,sl); p++) {
            float noiseWindow =
                BMTDCWINDOW - TIMEREJECT - 2*PeakWidth.rpc[T][S][p];
            float peakWindow = 2*PeakWidth.rpc[T][S][p];
            float windowRatio = peakWindow/noiseWindow;

            float PeakCM = MuonCMult_H.rpc[T][S][p]->GetMean();
            float PeakCS = MuonCSize_H.rpc[T][S][p]->GetMean();
            float NoiseCM = NoiseCMult_H.rpc[T][S][p]->GetMean() *windowRatio;
            float NoiseCS = NoiseCSize_H.rpc[T][S][p]->GetMean();
            float MuonCM = (PeakCM<NoiseCM) ? 0. : PeakCM-NoiseCM;
            float MuonCS = (MuonCM==0 || PeakCM*PeakCS<NoiseCM*NoiseCS)
                ? 0.
                : (PeakCM*PeakCS-NoiseCM*NoiseCS) / MuonCM;
            float PeakCM_err = (MuonCMult_H.rpc[T][S][p]->GetEntries()==0.)
                ? 0.
                : 2*MuonCMult_H.rpc[T][S][p]->GetStdDev() /
                    sqrt(MuonCMult_H.rpc[T][S][p]->GetEntries());
            float PeakCS_err = (MuonCSize_H.rpc[T][S][p]->GetEntries()==0.)
                ? 0.
                : 2*MuonCSize_H.rpc[T][S][p]->GetStdDev() /
                    sqrt(MuonCSize_H.rpc[T][S][p]->GetEntries());
            float NoiseCM_err = (NoiseCMult_H.rpc[T][S][p]->GetEntries()==0.)
                ? 0.
                : windowRatio*2*NoiseCMult_H.rpc[T][S][p]->GetStdDev() /
                    sqrt(NoiseCMult_H.rpc[T][S][p]->GetEntries());
            float NoiseCS_err = (NoiseCSize_H.rpc[T][S][p]->GetEntries()==0.)
                ? 0.
                : 2*NoiseCSize_H.rpc[T][S][p]->GetStdDev() /
                    sqrt(NoiseCSize_H.rpc[T][S][p]->GetEntries());
            float MuonCM_err = (MuonCM==0) ? 0. : PeakCM_err+NoiseCM_err;
            float MuonCS_err = (MuonCS==0 || MuonCM==0) ? 0.
                : (PeakCS*PeakCM_err + PeakCM*PeakCS_err +
                    NoiseCS*NoiseCM_err + NoiseCM*NoiseCS_err +
                    MuonCS*MuonCM_err) / MuonCM;

            float DataRatio = MuonCM/PeakCM;
            float DataRatio_err = (MuonCM==0) ? 0.
                : DataRatio*(MuonCM_err/MuonCM + PeakCM_err/PeakCM);
            float eff = DataRatio*Efficiency0_H.rpc[T][S][p]->GetMean();
            float eff_err = DataRatio*2*Efficiency0_H.rpc[T][S][p]->GetStdDev() /
                sqrt(Efficiency0_H.rpc[T][S][p]->GetEntries()) +
                Efficiency0_H.rpc[T][S][p]->GetMean()*DataRatio_err;

            outputEffCSV << eff << '\t' << eff_err << '\t'
                << MuonCS << '\t' << MuonCS_err << '\t'
                << MuonCM << '\t' << MuonCM_err << '\t';
        }
    }
}

```

2129

Source Code B.20: Description of efficiency result calculation and writing into the CSV output Offline-L0-EffCl.csv. Are saved into the file for each detector, the efficiency, corrected taking into account the background in the peak window of the time profile, muon cluster size and muon cluster multiplicity, along with their errors, for each partition and as well as a detector average.

2130

2131 B.7 Current data Analysis

2132 Detectors under test at GIF++ are connected both to a CAEN HV power supply and to a CAEN
2133 ADC that reads the currents inside of the RPC gaps bypassing the supply cable. During data tak-
2134 ing, the webDCS records into a ROOT file called `Scan00XXXX_HVY_CAEN.root` histograms with the
2135 monitored parameters of both CAEN devices. Are recorded for each RPC channels (in most cases,
2136 a channel corresponds to an RPC gap):

- 2137 • the effective voltage, HV_{eff} , set by the webDCS using the PT correction on the CAEN power
2138 supply,
- 2139 • the applied voltage, HV_{app} , monitored by the CAEN power supply, and the statistical error
2140 related to the variations of this value through time to follow the variation of the environmental
2141 parameters defined as the RMS of the histogram divided by the square root of the number of
2142 recorded points,
- 2143 • the monitored current, I_{mon} , monitored by the CAEN power supply, and the statistical error
2144 related to the variations of this value through time to follow the variation of the environmental
2145 parameters defined as the RMS of the histogram divided by the square root of the number of
2146 recorded points,
- 2147 • the corresponding current density, J_{mon} , defined as the monitored current per unit area,
2148 $J_{mon} = I_{mon}/A$, where A is the active area of the corresponding gap,
- 2149 • the ADC current, I_{ADC} , recorded through the CAEN ADC module that monitors the dark
2150 current in the gap itself. First of all, the resolution of such a module is better than that of
2151 CAEN power supplies and moreover, the current is not read-out through the HV supply line
2152 but directly at the chamber level giving the real current inside of the detector. The statistical
2153 error is defined as the RMS of the histogram distribution divided by the square root of the
2154 number of recorded points.

2155 Once extracted through a loop over the element of GIF++ infrastructure via the C++ macro
2156 `GetCurrent()`, these parameters, organised in 9 columns per detector HV supply line, are written in
2157 the output CSV file `Offline-Current.csv`. The macro can be found in the file `Current.cc`.

References

- 2159 [1] T. Massam et al. “Experimental observation of antideuteron production”. In: *Il Nuovo Cimento A* 63 (1965), pp. 10–14.
- 2160
- 2161 [2] UA1 Collaboration. “Experimental observation of isolated large transverse energy electrons with associated missing energy at $s = 540 \text{ GeV}$ ”. In: *Physics Letters B* 122 (1983), pp. 103–116.
- 2162
- 2163
- 2164 [3] UA2 Collaboration. “Observation of single isolated electrons of high transverse momentum in events with missing transverse energy at the CERN pp collider”. In: *Physics Letters B* 122 (1983), pp. 476–485.
- 2165
- 2166
- 2167 [4] UA1 Collaboration. “Experimental observation of lepton pairs of invariant mass around $95 \text{ GeV}/c^2$ at the CERN SPS collider”. In: *Physics Letters B* 126 (1983), pp. 398–410.
- 2168
- 2169 [5] UA2 Collaboration. “Evidence for $Z_0 \rightarrow e^+e^-$ at the CERN pp collider”. In: *Physics Letters B* 129 (1983), pp. 130–140.
- 2170
- 2171 [6] ALEPH Collaboration. “Determination of the number of light neutrino species”. In: *Physics Letters B* 231 (1989), pp. 519–529.
- 2172
- 2173 [7] CERN, ed. (1985).
- 2174 [8] CERN, ed. (1986).
- 2175 [9] CERN, ed. (1994).
- 2176 [10] CERN, ed. (1998).
- 2177 [11] CERN, ed. (1999).
- 2178 [12] CERN. Geneva. LHC Experiments Committee. *Letter of Intent for A Large Ion Collider Experiment [ALICE]*, note = CERN-LHCC-93-016. Tech. rep. ALICE Collaboration, 1993.
- 2179
- 2180 [13] CERN. Geneva. LHC Experiments Committee. *ATLAS : technical proposal for a general-purpose pp experiment at the Large Hadron Collider at CERN*, note = CERN-LHCC-94-43. Tech. rep. ATLAS Collaboration, 1994.
- 2181
- 2182
- 2183 [14] CERN. Geneva. LHC Experiments Committee. *CMS : letter of intent by the CMS Collaboration for a general purpose detector at LHC*, note = CERN-LHCC-92-003. Tech. rep. CMS Collaboration, 1992.
- 2184
- 2185
- 2186 [15] CERN. Geneva. LHC Experiments Committee. *LHCb : letter of intent*. Tech. rep. CERN-LHCC-95-5. LHCb Collaboration, 1995.
- 2187
- 2188 [16] L. Evans and P. Bryant. “LHC Machine”. In: *JINST* 3 (2008). S08001.
- 2189 [17] CMS Collaboration ATLAS Collaboration. “Combined Measurement of the Higgs Boson Mass in pp Collisions at $\sqrt{s} = 7$ and 8 TeV with the ATLAS and CMS Experiments”. In: *Physical Review Letters* 114 (2015). 191803.
- 2190
- 2191
- 2192 [18] LHCb Collaboration. “Observation of $J/\psi p$ Resonances Consistent with Pentaquark States in $\Lambda_b^0 \rightarrow J/\psi K^- p$ Decays”. In: *Physical Review Letters* 115 (2015). 072001.
- 2193

- 2194 [19] LHCb Collaboration. “Observation of $J/\psi\phi$ Structures Consistent with Exotic States from
2195 Amplitude Analysis of $B^+ \rightarrow J/\psi\phi K^+$ Decays”. In: *Physical Review Letters* 118 (2017).
2196 022003.
- 2197 [20] CERN. Geneva. *High-Luminosity Large Hadron Collider (HL-LHC) Technical Design Re-*
2198 *port V. 0.1*. Tech. rep. CERN-2017-007-M. 2017.
- 2199 [21] CERN. Geneva. LHC Experiments Committee. *The CMS muon project : Technical Design*
2200 *Report*. Tech. rep. CERN-LHCC-97-032. CMS Collaboration, 1997.
- 2201 [22] CERN. Geneva. LHC Experiments Committee. *Technical Proposal for the Phase-II Upgrade*
2202 *of the CMS Detector*. Tech. rep. CERN-LHCC-2015-010. CMS Collaboration, 2015.
- 2203 [23] CERN. Geneva. LHC Experiments Committee. *CMS, the Compact Muon Solenoid : technical*
2204 *proposal*. Tech. rep. CERN-LHCC-94-38. CMS Collaboration, 1994.
- 2205 [24] R. Santonico and R. Cardarelli. “Development of resistive plate counters”. In: *Nucl. Instr.*
2206 *Meth. Phys. Res.* 187 (1981), pp. 377–380.
- 2207 [25] Yu.N. Pestov and G.V. Fedotovich. *A picosecond time-of-flight spectrometer for the VEPP-2M*
2208 *based on local-discharge spark counter*. Tech. rep. SLAC-TRANS-0184. SLAC, 1978.
- 2209 [26] W.W. Ash, ed. *Spark Counter With A Localized Discharge*. Vol. SLAC-R-250. 1982, pp. 127–
2210 131.
- 2211 [27] I. Crotty et al. “The non-spark mode and high rate operation of resistive parallel plate cham-
2212 bers”. In: *NIMA* 337 (1993), pp. 370–381.
- 2213 [28] I. Crotty et al. “Further studies of avalanche mode operation of resistive parallel plate cham-
2214 bers”. In: *NIMA* 346 (1994), pp. 107–113.
- 2215 [29] R. Cardarelli et al. “Avalanche and streamer mode operation of resistive plate chambers”. In:
2216 *NIMA* 382 (1996), pp. 470–474.
- 2217 [30] E. Cerron Zeballos et al. “A new type of resistive plate chamber: The multigap RPC”. In:
2218 *NIMA* 374 (1996), pp. 132–135.
- 2219 [31] M.C.S. Williams. “The development of the multigap resistive plate chamber”. In: *Nucl. Phys.*
2220 *B* 61 (1998), pp. 250–257.
- 2221 [32] H. Czyrkowski et al. “New developments on resistive plate chambers for high rate operation”.
2222 In: *NIMA* 419 (1998), pp. 490–496.
- 2223 [33] P. Camarri et al. “Streamer suppression with SF6 in RPCs operated in avalanche mode”. In:
2224 *NIMA* 414 (1998), pp. 317–324.
- 2225 [34] E. Cerron Zeballos et al. “Effect of adding SF6 to the gas mixture in a multigap resistive plate
2226 chamber”. In: *NIMA* 419 (1998), pp. 475–478.
- 2227 [35] CERN. Geneva. LHC Experiments Committee. *ATLAS muon spectrometer: Technical design*
2228 *report*. Tech. rep. CERN-LHCC-97-22. ATLAS Collaboration, 1997.
- 2229 [36] CERN. Geneva. LHC Experiments Committee. *ALICE Time-Of-Flight system (TOF) : Tech-*
2230 *nical Design Report*. Tech. rep. CERN-LHCC-2000-012. ALICE Collaboration, 2000.
- 2231 [37] The CALICE collaboration. “First results of the CALICE SDHCAL technological proto-
2232 type”. In: *JINST* 11 (2016).
- 2233 [38] PoS, ed. *Density Imaging of Volcanoes with Atmospheric Muons using GRPCs*. International
2234 Europhysics Conference on High Energy Physics - HEP 2011. 2011.
- 2235 [39] C. Lippmann. “Detector Physics of Resistive Plate Chambers”. PhD thesis. Johann Wolfgang
2236 Goethe-Universität, 2003.

BIBLIOGRAPHY

- [40] M. Abbrescia et al. “Properties of C₂H₂F₄-based gas mixture for avalanche mode operation of resistive plate chambers”. In: *NIMA* 398 (1997), pp. 173–179.
- [41] G. Battistoni et al. “Sensitivity of streamer mode to single ionization electrons”. In: *NIMA* 235 (1985), pp. 91–97.
- [42] W. Riegler. “Induced signals in resistive plate chambers”. In: *NIMA* 491 (2002), pp. 258–271.
- [43] E. Cerron Zeballos et al. “A comparison of the wide gap and narrow gap resistive plate chamber”. In: *NIMA* 373 (1996), pp. 35–42.
- [44] M. Abbrescia et al. “Cosmic ray tests of double-gap resistive plate chambers for the CMS experiment”. In: *NIMA* 550 (2005), pp. 116–126.
- [45] ALICE Collaboration. “A study of the multigap RPC at the gamma irradiation facility at CERN”. In: *NIMA* 490 (2002), pp. 58–70.
- [46] B. Bonner et al. “A multigap resistive plate chamber prototype for time-of-flight for the STAR experiment at RHIC”. In: *NIMA* 478 (2002), pp. 176–179.
- [47] S. Yang et al. “Test of high time resolution MRPC with different readout modes for the BESIII upgrade”. In: *NIMA* 763 (2014), pp. 190–196.
- [48] A. Akindinov et al. “RPC with low-resistive phosphate glass electrodes as a candidate for the CBM TOF”. In: *NIMA* 572 (2007), pp. 676–681.
- [49] JINST, ed. *Development of the MRPC for the TOF system of the MultiPurpose Detector*. RPC2016: XII Workshop on Resistive Plate Chambers and Related Detectors. 2016.
- [50] M.C.S. Williams. “Particle identification using time of flight”. In: *Journal of Physics G* 39 (2012).
- [51] A. Alici et al. “Aging and rate effects of the Multigap RPC studied at the Gamma Irradiation Facility at CERN”. In: *NIMA* 579 (2007), pp. 979–988.
- [52] M. Abbrescia et al. “The simulation of resistive plate chambers in avalanche mode: charge spectra and efficiency”. In: *NIMA* 431 (1999), pp. 413–427.
- [53] M. Abbrescia et al. “Study of long-term performance of CMS RPC under irradiation at the CERN GIF”. In: *NIMA* 533 (2004), pp. 102–106.
- [54] H.C. Kim et al. “Quantitative aging study with intense irradiation tests for the CMS forward RPCs”. In: *NIMA* 602 (2009), pp. 771–774.
- [55] S. Agosteo et al. “A facility for the test of large-area muon chambers at high rates”. In: *NIMA* 452 (2000), pp. 94–104.
- [56] PoS, ed. *CERN GIF ++ : A new irradiation facility to test large-area particle detectors for the high-luminosity LHC program*. Vol. TIPP2014. 2014, pp. 102–109.
- [57] A. Fagot. *GIF++ DAQ v4.0*. 2017. URL: https://github.com/afagot/GIF_DAQ.
- [58] CAEN. *Mod. V1190-VX1190 A/B, 128/64 Ch Multihit TDC*. 14th ed. 2016.
- [59] CAEN. *Mod. V1718 VME USB Bridge*. 9th ed. 2009.
- [60] W-Ie-Ne-R. *VME 6021-23 VXI*. 5th ed. 2016.
- [61] Wikipedia. *INI file*. 2017. URL: https://en.wikipedia.org/wiki/INI_file.
- [62] S. Carrillo A. Fagot. *GIF++ Offline Analysis v6*. 2017. URL: https://github.com/afagot/GIF_OfflineAnalysis.