

Industrial Motor Maintenance Manual

Document ID: MAN-001

Category: General Maintenance

Applicability: Standard AC Induction Motors

1. Introduction

This manual provides general guidelines for the maintenance of industrial electric motors. Adherence to these guidelines ensures optimal performance, extends operational lifespan, and minimizes unexpected failures.

2. Baseline Environmental Conditions

- **Ambient Temperature:** Must not exceed 40°C (104°F) for standard insulation classes.
- **Ventilation:** Ensure a minimum clearance of 50cm around the motor cooling fins and fan intakes.
- **Humidity:** Operate below 85% non-condensing relative humidity unless specifically rated for harsh environments.

3. General Inspection Routines

Visual inspections should be conducted weekly. Look for signs of exterior damage, excessive dirt accumulation, or fluid leaks near the bearing seals. Any abnormal acoustic noise should be immediately logged and investigated using the Vibration Diagnosis Guide.