

REVISION NAME	DATE

ISSUE DATE: 2024 0927


Sheet Name:
**ELECTRICAL
LEGEND**

Page #:

E 0.0

ELECTRICAL LEGEND, ABBREVIATIONS & GENERAL NOTES

SECURITY SYSTEM	LIGHTING	POWER	POWER ONE-LINE DIAGRAM	ABBREVIATIONS	CODES USED & UTILITY
DOOR CONTACT/POSITION SECURITY VIDEO MONITOR SECURITY CAMERA C = CEILING MOUNT W = WALL MOUNT 1 = 1-WAY VIEW 2 = 2-WAY VIEW 4 = 4-WAY VIEW MOTION DETECTOR CARD READER NUMERIC KEYPAD MAGNETIC LOCK PANIC BUTTON DOOR POWER SUPPLY ACCESS CONTROL PANEL	1. UPPER-CASE LETTER ADJACENT TO LUMINAIRE INDICATES LUMINAIRE TYPE. 2. LOWER-CASE LETTER ADJACENT TO LUMINAIRE INDICATES SWITCHING SCHEME. 3. SHADING INDICATES EMERGENCY BATTERY OR CIRCUIT. DOWNLIGHT WALLWASHER PENDANT WALL MOUNT FIXTURE CEILING MOUNTED EXIT SIGN SHADING INDICATES FACE(S) ARROWS(S) AS INDICATED WALL MOUNTED EXIT SIGN SHADING INDICATES FACE(S) ARROWS(S) AS INDICATED EMERGENCY LIGHTING UNIT COMBINATION EXIT SIGN/ EMERGENCY LIGHTING UNIT 2X4 FIXTURE, FLUSH OR SURFACE 2X2 FIXTURE, FLUSH OR SURFACE 1X4 FIXTURE, FLUSH OR SURFACE 1X2 FIXTURE, FLUSH OR SURFACE TRACK LIGHT, SEE PLANS FOR LENGTHS CEILING FAN POLE MOUNT FIXTURE BOLLARD TYPE FIXTURE FLOOD LIGHT STEP LIGHT OCCUPANCY SENSOR, CEILING MOUNT PHOTOELECTRIC CELL, CEILING MOUNT POWER RELAY LIGHTING CONTACTOR SINGLE POLE SWITCH, UON SUBSCRIPT INDICATES SWITCHING LEG THREE-WAY SWITCH FOUR-WAY SWITCH DIMMER SWITCH PILOT LIGHT SWITCH KEY OPERATED SWITCH LOW VOLTAGE SWITCH OCCUPANCY SENSOR SWITCH OCCUPANCY SENSOR DIMMER SWITCH	CEIL FLOOR WALL MULTI-OUTLET ASSEMBLY SIMPLEX RECEPTACLE DUPLEX RECEPTACLE QUAD RECEPTACLE DUPLEX RECEPTACLE, SPLIT WIRED & SWITCHED EMERGENCY/STANDBY DUPLEX RECEPTACLE SPECIAL PURPOSE RECEPTACLE, CONFIGURATION NOTED FURNITURE POWER FEED COMBINATION POWER/COMMUNICATION OUTLET MOMENTARY CONTACT THERMAL OVERLOAD SWITCH MOTOR NON-FUSED DISCONNECT SWITCH FUSED DISCONNECT SWITCH ENCLOSED CIRCUIT BREAKER COMBINATION MAGNETIC MOTOR STARTER/FUSED DISCONNECT SWITCH MAGNETIC MOTOR STARTER WITH OVERLOADS UTILITY METER THERMOSTAT TRANSFORMER SWITCHGEAR/SWITCHBOARD DISTRIBUTION PANELBOARD BRANCH CIRCUIT PANELBOARD BUSBAR	TRANSFORMER WITH GROUNDED SECONDARY, KVA SIZE & VOLTAGE RATIO AS NOTED POTENTIAL TRANSFORMER CURRENT TRANSFORMER CONTACT DISCONNECT SWITCH FUSE FUSED DISCONNECT SWITCH 3-POLE, 400 AMPERE RATED SWITCH W/ 350 AMPERE RATED FUSES CIRCUIT BREAKER 400 AMPERE FRAME, 3-POLE, 350 AMPERE TRIP L = LONG, S = SHORT, I = INSTANTANEOUS, G = GROUND, MM = MAINTENANCE MODE CIRCUIT BREAKER, 30 AMPERE, 3-POLE AUTOMATIC TRANSFER SWITCH UTILITY METER GROUND GENERATOR SERVICE WEATHERHEAD POWER QUALITY METER SURGE PROTECTIVE DEVICE OVERLOAD HEATER SHORT CIRCUIT CURRENT KEY UTILITY SERVICE PANELBOARD	A AMPERE AAC ABOVE ACCESSIBLE CEILING ABOVE COUNTER ACI ARC FAULT CIRCUIT INTERRUPTER AF AMPERE FRAME, AMPERE FUSE AFF ABOVE FINISHED FLOOR AFG ABOVE FINISHED GRADE AIC AMPERES INTERRUPTING CAPACITY ANN ANNUNCIATOR AS ALERT SYSTEM AT AMPERE TRIP ATS AUTOMATIC TRANSFER SWITCH AWG AMERICAN WIRE GAUGE BC BELOW COUNTER C CONDUIT CCTV CLOSED CIRCUIT TELEVISION CO CARBON MONOXIDE CS CONTROL STATION E EXISTING EC EMPTY CONDUIT EM EMERGENCY EMT ELECTRIC METALLIC TUBING EP EXPLOSION PROOF EPO EMERGENCY POWER OFF EWC ELECTRIC WATER COOLER FACP FIRE ALARM CONTROL PANEL G GROUND GND GROUND GFI GROUND FAULT INTERRUPTOR HOA HAND-OFF-AUTO IDF INTERMEDIATE DISTRIBUTION FRAME IG ISOLATED GROUND IMC INTERMEDIATE METAL CONDUIT ISC SHORT CIRCUIT CURRENT KAIC KILO-AMPERES INTERRUPTING CAPACITY KCMIL THOUSAND CIRCULAR MILLIMETERS MAXIMUM MCA MINIMUM CIRCUIT AMPACITY MCB MAIN CIRCUIT BREAKER MCC MOTOR CONTROL CENTER MCM THOUSAND CIRCUIT MILLIMETERS MDF MAIN DISTRIBUTION FRAME MDP MAIN DISTRIBUTION PANEL MDSB MAIN DISTRIBUTION SWITCHBOARD MDSG MAIN DISTRIBUTION SWITCHGEAR MIN MINIMUM MLO MAIN LUGS ONLY MOCP MAXIMUM OVERCURRENT PROTECTION MTD MOUNTED NEC NATIONAL ELECTRIC CODE NEW NEW NC NORMALLY CLOSED NIC NOT IN CONTRACT NL NIGHT LIGHT NO NORMALLY OPEN NTS NOT TO SCALE OC ON CENTER OFCl INSTALLED FURNISHED, CONTRACTOR PC PULLCHAIN PNL PANELBOARD RGS RIGID STEEL RL RELOCATE SCCR SHORT CIRCUIT CURRENT RATING SPD SURGE PROTECTION DEVICE ST SHUNT TRIP SWBD SWITCHBOARD TP TAMPERPROOF TC TIMECLOCK TVSS TRANSIENT VOLTAGE SURGE SUPPRESSION TYP TYPICAL UON UNLESS OTHERWISE NOTED V VOLTS VFD VARIABLE FREQUENCY DRIVE W WITH W/O WITHOUT WP WEATHERPROOF XFMR TRANSFORMER	1. 2023 NFPA 70 NATIONAL ELECTRIC CODE (NEC) 2. 2021 INTERNATIONAL ENERGY CONSERVATION CODE (IECC) 3. 2021 INTERNATIONAL FIRE CODE ELECTRIC SERVICE PROVIDED BY UNITED POWER. PROJECT NOTES 1. ALL POWER CONDUCTORS SHALL BE #12AWG COPPER, UON. 2. ALL DEVICE BOXES AND CONDUITS SHALL BE CONCEALED AS MUCH AS POSSIBLE. 3. ALL CONDUITS/BOXES SHALL BE INSTALLED SUCH THAT RATINGS OF FIRE RATED ASSEMBLIES ARE NOT VIOLATED. APPLY ADDITIONAL FIRE-STOPPING AS NECESSARY TO MAINTAIN RATINGS. 4. POWER & SYSTEMS DEVICE ELEVATIONS INDICATED ON PLANS ARE TO CENTER OF DEVICE, UON. 6. LIGHT FIXTURE ELEVATIONS INDICATED ON PLANS ARE TO BOTTOM OF FIXTURE, UON. 7. REFERENCE TELECOM CONTRACTOR DRAWINGS FOR ADDITIONAL CONDUIT AND ROUGH-IN REQUIREMENTS. 8. ALL LOW VOLTAGE CONTROL CABLING & ETHERNET SHALL BE CONCEALED ABOVE ACCESSIBLE CEILING & WALLS, OR INSTALLED IN CONDUIT. 9. PROVIDE PULL STRINGS FOR ALL EMPTY CONDUITS. 10. PROVIDE FIRE ALARM SYSTEM IN FULL COMPLIANCE WITH LOCAL AHJ AND NFPA. CONTRACTOR SHALL BE RESPONSIBLE FOR COMPLETE DESIGN AND INSTALLATION OF SYSTEM. PROVIDE SUBMITTALS TO AHJ AS NECESSARY FOR PERMIT. REFERENCE SPECIFICATION SECTION 16721. FIRE ALARM DEVICES INDICATED ON DRAWINGS ARE FOR REFERENCE ONLY. 11. NUMBER IN PARENTHESES "(2)" NEXT TO DEVICES INDICATES QUANTITY OF CABLES, EITHER ETHERNET, COAXIAL, OR HDMI, DEPENDING ON DEVICE. 12. PROVIDE UN-SWITCHED HOT LEG TO ALL EMERGENCY EGRESS LIGHT FIXTURES AND EXIT SIGNS FROM LOCAL LIGHTING CIRCUIT. 13. LOW VOLTAGE CONTROL CABLING & ETHERNET ASSOCIATED WITH LIGHTING CONTROL & DIMMING NOT SHOWN. PROVIDE ALL CABLING, DEVICES, BOXES, AND CONDUIT AS NECESSARY FOR A COMPLETE AND OPERATIONAL SYSTEM. 14. ALL LOW VOLTAGE CONTROL CABLING & ETHERNET SHALL BE CONCEALED ABOVE ACCESSIBLE CEILING & WALLS, OR INSTALLED IN CONDUIT. 15. REFERENCE "FSA" DRAWINGS FOR ADDITIONAL INFORMATION. 16. REFERENCE AV DRAWINGS FOR ADDITIONAL REQUIREMENTS. 17. WIRING DEVICE FINISHES SHALL BE PER TABLE BELOW: WIRING DEVICE FINISHES TABLE 18. PHOTOVOLTAIC SYSTEM IS TO BE BID AS AN ADD ALTERNATE.
CEIL FLOOR WALL TELEPHONE OUTLET TELECOMMUNICATION OUTLET COMBINATION TELEPHONE/DATA OUTLET COMBINATION DATA/COAXIAL OUTLET COAXIAL CABLE OUTLET COMBINATION POWER/COMMUNICATION OUTLET FURNITURE TELE/DATA FEED COMMUNICATION/DATA BACKBOARD					
GENERAL NOTES: 1. DIMENSIONS ARE TO CENTER OF DEVICE WITH TRIM U.O.N. 2. ALL MOUNTING HEIGHTS SHALL CONFORM TO THE LATEST EDITION OF THE AMERICANS WITH DISABILITIES ACT (ADA) 1. DEVICE MOUNTING HEIGHT DETAIL NO SCALE					
MISCELLANEOUS () BOLD LINES INDICATE NEW OR RELOCATED EQUIPMENT. RELOCATED EQUIPMENT MAY INCLUDE "RL" () LIGHT LINES INDICATE EXISTING EQUIPMENT TO REMAIN. () DASHED/LIGHT LINES INDICATE EQUIPMENT TO BE DEMOLISHED OR REMOVED. () CROSS HATCHING THROUGH EXISTING EQUIPMENT INDICATES EQUIPMENT TO BE DEMOLISHED OR REMOVED. (1) KEYED NOTE REFERENCE (TAG) SCHEDULE EQUIPMENT REFERENCE					




LOAD TYPE	CONNECTED (KVA)				DEMAND FACTOR	DEMAND (KVA)			
	A	B	C	TOTAL		A	B	C	TOTAL
LIGHTING (L)	3.1	2.3	3.3	8.7	1.00	3.1	2.3	3.3	8.7
RECEPTACLE (R)	14.0	12.6	13.0	39.6	1.00	3.3	3.3	3.3	10.0
REC (>1000VA) (R)					0.50	5.4	4.6	4.8	14.8
HVAC (H)	25.9	22.8	23.0	71.8	0.85	22.1	19.4	19.6	61.0
LARGEST MOTOR (M)	2.1	2.1	2.1	6.3	1.25	2.6	2.6	2.6	7.9
REMAIN MOTOR (M)	8.4	7.3	9.9	25.5	1.00	8.4	7.3	9.9	25.5
CONTINUOUS MOTOR (CM)	0.0	0.0	0.0	0.0	1.25	0.0	0.0	0.0	0.0
KITCHEN LOADS (K)	4.8	3.8	4.9	13.5	0.65	3.1	2.5	3.2	8.8
SPECIFIC LOADS (S)	20.5	22.4	16.5	59.4	0.85	17.4	19.1	14.0	50.5
NONCOINCIDENTAL (N)	0.0	0.0	0.0	0.0	0.00	0.0	0.0	0.0	0.0
ELECTRIC VEHICLE (EV)	13.3	13.3	13.3	39.9	1.25	16.6	16.6	16.6	49.9
EXISTING(E)	0.0	0.0	0.0	0.0	1.25	0.0	0.0	0.0	0.0
TOTAL DEMAND (KVA)						82.0	77.7	77.4	237.1
TOTAL (A/PH)						295.0	280.7	279.3	285.2

	CONNECTED (KVA)				DEMAND FACTOR	DEMAND (KVA)			
LOAD TYPE	A	B	C	TOTAL		A	B	C	TOTAL
LIGHTING (L)	3.1	2.3	3.3	8.7	1.00	3.1	2.3	3.3	8.7
RECEPTACLE (R)	14.0	12.6	13.0	39.6	1.00	3.3	3.3	3.3	10.0
REC (>10000VA) (R)					0.50	5.4	4.6	4.8	14.8
HVAC (H)	25.9	22.8	23.0	71.8	0.85	22.1	19.4	19.6	61.0
LARGEST MOTOR (M)	2.1	2.1	2.1	6.3	1.25	2.6	2.6	2.6	7.9
REMAIN MOTOR (M)	8.4	7.3	9.9	25.5	1.00	8.4	7.3	9.9	25.5
CONTINUOUS MOTOR (CM)	0.0	0.0	0.0	0.0	1.25	0.0	0.0	0.0	0.0
KITCHEN LOADS (K)	4.8	3.8	4.9	13.5	0.65	3.1	2.5	3.2	8.8
SPECIFIC LOADS (S)	20.5	22.4	16.5	59.4	0.85	17.4	19.1	14.0	50.5
NONCOINCIDENTAL (N)	0.0	0.0	0.0	0.0	0.00	0.0	0.0	0.0	0.0
ELECTRIC VEHICLE (EV)	122.0	122.0	122.0	365.9	1.25	152.5	152.5	152.5	457.4
EXISTING(E)	0.0	0.0	0.0	0.0	1.25	0.0	0.0	0.0	0.0
TOTAL DEMAND (KVA)						217.8	213.6	213.2	644.6
TOTAL (A/PH)						786.4	771.0	769.7	775.4

GENERATOR
125KW/156KVA
SEPARATELY DERIVED
DIESEL FUELED
480Y/277V, 3PH, 4W

A1:15,17 (4#10, #10G, 1" C)
COOLANT HTR 1500W, 120V
BATTERY CHARGER 192W, 120V
OIL HTR 150W, 120V
BATTERY HTR 125W, 120V

 JACKET WATER HEATER
AND BATTERY CHARGER





REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
ELECTRICAL
PANEL
SCHEDULES

Page #:

E 0.2

FEED FROM: 112.5 KVA, MDP VOLTAGE: 208/120 A/C: 10000 ENCLOSURE: NEMA1				PANEL: PNL A1 PHASE: 3 BUS AMPACITY: 400A NEUTRAL: 100% GROUND: STD				WIRE: 4 TERMINATION: 400A MCB, FEED-THRU MOUNTING: SURFACE					
CKT NO	DESCRIPTION	LOAD		CKT BREAKER			CKT BREAKER			LOAD		DESCRIPTION	CKT NO
		VA	TYPE	P	A	OPT	A	P	TYPE	VA			
1	EUH-1A	1500	H	2	20		20	1	M	151	EF-3 - BUNKER GEAR 130	2	
3	/	1500	H	/	/		40	2	S	3000	GEAR DRYER - BUNKER GEAR 130	4	
5	EUH-1B	1500	H	2	20		/	/	S	3000	/	6	
7	/	1500	H	/	/		GFI	20	1	R	1980	LOCKER RECPS - BUNKER GEAR 130	8
9	RADIANT HTRS 1RH-1A,1B,1C	500	H	1	20		GFI	20	1	R	2160	LOCKER RECPS - BUNKER GEAR 130	10
11	GEF-1	696	M	1	20		20	1	M	1000	GARAGE DOOR GD-1 - APP BAY 128	12	
13	GEF-2	696	M	1	20		20	1	M	1000	GARAGE DOOR GD-2 - APP BAY 128	14	
15	GEN AUX	467	S	1	20		20	1	M	1000	GARAGE DOOR GD-3 - APP BAY 128	16	
17	GENERATOR COOLANT HTR	1500	H	1	20		20	1	M	1000	GARAGE DOOR GD-4 - APP BAY 128	18	
19	QW/H-1, DCP-1A,DCP-1B	302	H	1	20		GFI	30	1	S	500	CORD REEL RECIP - APP BAY 128	20
21	RECPS - MEZZ 200	1135	M, R	1	20		GFI	20	1	S	500	CORD REEL RECIP - APP BAY 128	22
23	RECPS - ROOF	900	R	1	20		GFI	20	1	S	500	CORD REEL RECIP - APP BAY 128	24
25	WELDING RECIP - WORK RM 129	4000	S	2	50		GFI	20	1	S	500	CORD REEL RECIP - APP BAY 128	26
27	/	4000	S	/	/		GFI	20	1	S	500	CORD REEL RECIP - APP BAY 128	28
29	6-30R RECIP - WORK RM 129	1000	S	2	30			20	1	M	200	CEILING FANS APP BAY 128	30
31	/	1000	S	/	/		25	1	H	1800	BOILER B-1 - MEZZ 200	32	
33	WIREMOLD - WORK RM 129	1080	R	1	20		20	1	M	84	GLYCOL FEEDER GF-1	34	
35	GRINDER RECIP - WORK RM 129	504	M	1	20		20	1	S	100	SNOW MELT CONTROLLER	36	
37	RECPS - WORK RM 129	720	R	1	20		20	1			SPARE	38	
39	RECPS - WORK RM 129	540	R	1	20		20	1			SPARE	40	
41	SPARE			1	20		20	1			SPARE	42	

LOAD SUMMARY											
LOAD	PHASE	KVA									
		L	R	H	M	MLRG	CM	K	S	N	EV
PNL A2	A	0.78	3.06	0	0.06	0.06	0	0	0	0	13.31
/	B	1.77	0.72	0	0	0	0	0	0	1	13.31
/	C	1.31	2.7	0	0	0	0	0	0	1	13.31

LOAD TYPE	CONNECTED (KVA)				DEMAND FACTOR	DEMAND (KVA)			
	A	B	C	TOTAL		A	B	C	TOTAL
LIGHTING (L)	0.8	1.8	1.3	3.9	1.00	0.8	1.8	1.3	3.9
RECEPTACLE (R)	5.8	5.6	3.6	14.9	1.00	3.3	3.3	3.3	10.0
REC (>10000VA) (R)					0.50	1.2	1.1	0.1	2.5
HVAC (H)	5.1	2.0	3.0	10.1	1.00	5.1	2.0	3.0	10.1
LARGEST MOTOR (M)	1.0	1.0	1.0	3.0	1.25	1.3	1.3	1.3	3.8
REMAIN MOTOR (M)	0.9	0.1	2.4	3.4	1.00	0.9	0.1	2.4	3.4
CONTINUOUS MOTOR (CM)	0.0	0.0	0.0	0.0	1.25	0.0	0.0	0.0	0.0
KITCHEN LOADS (K)	0.0	0.0	0.0	0.0	1.00	0.0	0.0	0.0	0.0
SPECIFIC LOADS (S)	6.0	8.6	5.6	20.2	0.95	5.7	8.1	5.3	19.2
NONCOINCIDENTAL (N)	0.0	0.0	0.0	0.0	0.00	0.0	0.0	0.0	0.0
ELECTRIC VEHICLE (EV)	13.3	13.3	13.3	39.9	1.25	16.6	16.6	16.6	49.9
TOTAL DEMAND (KVA)						34.9	34.4	33.4	102.7
SPARE (KVA)						2.6	3.1	4.1	9.8
TOTAL (A/PH)						281.0	286.6	278.2	
SPARE (A/PH)						21.5	25.9	34.3	

NOTES:

FEED FROM: PNL A1 VOLTAGE: 208/120 A/C: 10000 ENCLOSURE: NEMA1							PANEL: PNL A2 PHASE: 3 BUS AMPACITY: 400A NEUTRAL: 100% GROUND: STD							WIRE: 4 TERMINATION: 400A MLO MOUNTING: SURFACE						
CKT NO	DESCRIPTION	LOAD			CKT BREAKER			CKT BREAKER			LOAD			DESCRIPTION	CKT NO					
		VA	TYPE		P	A	OPT	OPT	A	P	TYPE	VA								
1	RECPS - APP BAY 128, BUNKER 130,132	775	M, R	1	20				40	2	EV	3328	FUTURE EV CHARGER	2						
3	RECPS - APP BAY 128	720	R	1	20				/	/	EV	3328	/	4						
5	RECPS - APP BAY 128	720	R	1	20				40	2	EV	3328	FUTURE EV CHARGER	6						
7	RECPS - APP BAY 128	720	R	1	20				/	/	EV	3328	/	8						
9	COINX CONTROLLER - APP BAY 128	100	S	1	20				40	2	EV	3328	FUTURE EV CHARGER	10						
11	CHARGING STATION RECPS - APP BAY 128	1080	R	1	20				/	/	EV	3328	/	12						
13	CHARGING STATION RECPS - APP BAY 128	1620	R	1	20				40	2	EV	3328	FUTURE EV CHARGER	14						
15	SPARE			1	20				/	/	EV	3328	/	16						
17	SPARE			1	20				40	2	EV	3328	FUTURE EV CHARGER	18						
19	SPARE			1	20				/	/	EV	3328	/	20						
21	SPARE			1	20				40	2	EV	3328	FUTURE EV CHARGER	22						
23	EXT RECPS	900	R	1	20				/	/	EV	3328	/	24						
25	LTG - MEZZANINE, STAIRS, STORE 132	501	L	1	20				20	1			SPARE	26						
27	LTG - APP BAY 128	1118	L	1	20				20	1			SPARE	28						
29	LTG - APP BAY 128, STAIRS RED LTS	1314	L	1	20				20	1			SPARE	30						
31	LTG - WORK RM, BUNKER GEAR	280	L	1	20				20	1			SPARE	32						
33	LTG - EXTERIOR BLDG MOUNT	654	L	1	20				20	1			SPARE	34						
35	EXTERIOR BLDG MOUNT SIGNAGE	1000	S	1	20				20	1			SPARE	36						
37	SPARE			1	20				20	1			SPARE	38						
39	SPACE		-	-	-				-	-			SPACE	40						
41	SPACE		-	-	-				-	-			SPACE	42						

LOAD TYPE	CONNECTED (KVA)				DEMAND FACTOR	DEMAND (KVA)			
	A	B	C	TOTAL		A	B	C	TOTAL
LIGHTING (L)	0.8	1.8	1.3	3.9	1.00	0.8	1.8	1.3	3.9
RECEPTACLE (R)	3.1	0.7	2.7	6.5	1.00	3.1	0.7	2.7	6.5
REC (>10000VA) (R)					0.50	0.0	0.0	0.0	0.0
HVAC (H)	0.0	0.0	0.0	0.0	1.00	0.0	0.0	0.0	0.0
LARGEST MOTOR (M)	0.1	0.0	0.0	0.1	1.25	0.1	0.0	0.0	0.1
REMAIN MOTOR (M)	0.0	0.0	0.0	0.0	1.00	0.0	0.0	0.0	0.0
CONTINUOUS MOTOR (CM)	0.0	0.0	0.0	0.0	1.25	0.0	0.0	0.0	0.0
KITCHEN LOADS (K)	0.0	0.0	0.0	0.0	1.00	0.0	0.0	0.0	0.0
SPECIFIC LOADS (S)	0.0	0.1	1.0	1.1	1.00	0.0	0.1	1.0	1.1
NONCOINCIDENTAL (N)	0.0	0.0	0.0	0.0	0.00	0.0	0.0	0.0	0.0
ELECTRIC VEHICLE (EV)	13.3	13.3	13.3	39.9	1.25	16.6	16.6	16.6	49.9
TOTAL DEMAND (KVA)						20.6	19.2	21.7	61.4
SPARE (KVA)						27.4	28.8	26.3	82.6
TOTAL (A/PH)						171.3	160.3	180.5	
SPARE (A/PH)						228.7	239.7	219.5	

NOTES:

FEED FROM: 112.5 KVA, MDP				PANEL: PNL B1				WIRE: 4							
VOLTAGE: 208/120				PHASE: 3				TERMINATION: 400A MCB, FEED-THRU							
A/C: 10000				BUS AMPACITY: 400A				MOUNTING: SURFACE							
ENCLOSURE: NEMA1				NEUTRAL: 100%											
				GROUND: STD											
CKT NO	DESCRIPTION	LOAD			CKT BREAKER			CKT BREAKER			LOAD			DESCRIPTION	CKT NO
		VA	TYPE	P	A	OPT	OPT	A	P	TYPE	VA				
1	FPB-1	2791	H	2	35			20	1	M, L, R	238		TOILET 102	2	
3	/	2791	H	/	/			20	1	R	1080		RACEWAY - DUTY OFFICE 101	4	
5	FPB-2	2791	H	2	35			20	1	R	1080		RECPS - DUTY OFFICE 101	6	
7	/	2791	H	/	/			20	1	R	900		RECPS - DUTY OFFICE 101	8	
9	FPB-3	2791	H	2	35			20	1	S	500		RECIP RADIO SYSTEM - DUTY OFFICE 101	10	
11	/	2791	H	/	/			20	1	K	500		REF RECIP - KITCHEN 106	12	
13	FPB-4	3479	H	2	50			20	1	K	500		REF RECIP - KITCHEN 106	14	
15	/	3479	H	/	/			20	1	K	500		REF RECIP - KITCHEN 106	16	
17	AC-1A	1580	H	2	25		AFCI	20	1	K	1600		MM RECIP - KITCHEN 106	18	
19	/	1580	H	/	/		AFCI	20	1	K	1500		COFFEE MAKER RECIP - KITCHEN 106	20	
21	AC-1B	1580	H	2	25		AFCI/GFI	20	1	K	744		DW RECIP - KITCHEN 106	22	
23	/	1580	H	/	/		AFCI	20	1	R	720		COUNTER RECPS - KITCHEN 106	24	
25	FACP	500	S	1	20		AFCI	20	1	K	972		GD RECIP - KITCHEN 106	26	
27	GAS SOLENOID VALVE, CONTACTOR C1	250	S	1	20		AFCI	20	1	K	744		DW RECIP - KITCHEN 106	28	
29	RACEWAY - OFFICE 103	1080	R	1	20		AFCI	20	1	K	1600		MM RECIP - KITCHEN 106	30	
31	RECPS - OFFICE 103	1080	R	1	20		AFCI	20	1	K	972		GD RECIP - KITCHEN 106	32	
33	RECPS - EMS 127	1280	R	1	20		AFCI/GFI	20	1	K	1800		RANGE - KITCHEN 106	34	
35	RECPS - EXT. 101, 104, 105	900	R	1	20		AFCI	20	1	K	1200		RANGE HOOD - KITCHEN 106	36	
37	SECURITY SYSTEM - OFFICE 101,103	720	R	1	20		AFCI	20	1	R	360		ISLAND RECPS - KITCHEN 106	38	
39	EXT RECPS	900	R	1	20			20	1	S	1380		COPPER RECIP - DUTY OFFICE 101	40	
41	EXIT/ROOF RECPS	900	R	1	20			20	1	L	541		LTG - 100, 101, 103, 104, 127	42	
43	BLOCK HTR RECIP	1500	S	1	20			20	1	L	973		LTG - 105, 106, 107, 108	44	
45	BLOCK HTR RECIP	1500	S	1	20			20	1	L	150		LTG - BLDG EXT	46	
47	BLOCK HTR RECIP	1500	S	1	20			20	1	L	1337		LTG - EXTERIOR	48	
49	BLOCK HTR RECIP	1500	S	1	20			20	1				SPARE	50	
51	SPARE			1	20			20	1				SPARE	52	
53	SPARE			1	20			20	1				SPARE	54	
55	SPACE	-	-	-	-		-	-	-				SPACE	56	
57	SPACE	-	-	-	-		-	-	-				SPACE	58	
59	SPACE	-	-	-	-		-	-	-				SPACE	60	
61	SPACE	-	-	-	-		-	-	-				SPACE	62	
63	SPACE	-	-	-	-		-	-	-				SPACE	64	
65	SPACE	-	-	-	-		-	-	-				SPACE	66	



REVISION NAME		DATE

ISSUE DATE: 2024 0927

Sheet Name:
ELECTRICAL
LIGHTING
SCHEDULES

Page #:

E 0.3

ALLRED & ASSOCIATES

INTERIOR LUMINAIRE SCHEDULE

TYPE	LOCATION	DESCRIPTION	MANUFACTURER	CATALOG #	VOLTS	LAMPING	MOUNTING	WATTS	VA	KEY NOTES
CV	INTERIOR	TROV SLIM. LENGTHS AS REQUIRED, 120-DEGREE OPTICS, 0-10V DIMMING	ECOSENSE	L301-xx-C4-35-80-MULT-120, CBL-4P-LWH-LDR-UNV-10, CBL-4P-LWH-JMP-UNV-1	120V	LED, 3500K 476 LUMENS/FT	COVE	4.5W/FT	4.8VA/FT	
D1	INTERIOR	IVO 6-INCH ROUND SHALLOW RECESSED DOWNLIGHT, MEDIUM WIDE DISTRIBUTION, CONSTANT CURRENT DIMMING TO 1%, NEW CONSTRUCTION HOUSING, OPEN REFLECTOR, CLEAR ANODIZED TRIM, SEMI SPECULAR FINISH, SELF FLANGED, DAMP LOCATION RATED	GOTHAM	IV06S-D-10LM-35K-80CRI-MWD-MIN1-MVOLT-ZT-NCH-P-AR-LSS-F	120V	LED, 3500K 1000 LUMENS, 80CRI	RECESSED	9.2	9.7	
D1E	INTERIOR	IVO 6-INCH ROUND SHALLOW RECESSED DOWNLIGHT, MEDIUM WIDE DISTRIBUTION, CONSTANT CURRENT DIMMING TO 1%, NEW CONSTRUCTION HOUSING, OPEN REFLECTOR, CLEAR ANODIZED TRIM, SEMI SPECULAR FINISH, SELF FLANGED, DAMP LOCATION RATED, INTEGRAL EMERGENCY BATTERY	GOTHAM	IV06S-D-10LM-35K-80CRI-MWD-MIN1-MVOLT-ZT-E6WR-NCH-P-AR-LSS-F	120V	LED, 3500K, 1000 LUMENS, 80CRI	RECESSED	9.2	9.7	
D2	INTERIOR	6-INCH OPEN DOWNLIGHT, CLEAR TRIM, SEMI-SPECULAR FINISH, 0-10V DIMMING TO 10%, WET LOCATION RATED	LITHONIA	LDN6-35/05-LO6-AR-LSS-MVOLT-EZ10-WL	120V	LED, 3500K, 500 LUMENS	RECESSED	5.8	6.1	
D3	INTERIOR	IVO 4-INCH ROUND SHALLOW RECESSED DOWNLIGHT, MEDIUM WIDE DISTRIBUTION, CONSTANT CURRENT DIMMING TO 1%, NEW CONSTRUCTION HOUSING, OPEN REFLECTOR, CLEAR ANODIZED TRIM, SEMI SPECULAR FINISH, SELF FLANGED, DAMP LOCATION RATED	GOTHAM	IV04S-D-10LM-35K-80CRI-MWD-MIN1-MVOLT-ZT-NCH-P-AR-LSS-F	120V	LED, 3500K 1000 LUMENS, 80CRI	RECESSED	9.2	9.7	
D3E	INTERIOR	IVO 4-INCH ROUND SHALLOW RECESSED DOWNLIGHT, MEDIUM WIDE DISTRIBUTION, CONSTANT CURRENT DIMMING TO 1%, NEW CONSTRUCTION HOUSING, OPEN REFLECTOR, CLEAR ANODIZED TRIM, SEMI SPECULAR FINISH, SELF FLANGED, DAMP LOCATION RATED, INTEGRAL EMERGENCY BATTERY	GOTHAM	IV04S-D-10LM-35K-80CRI-MWD-MIN1-MVOLT-ZT-E6WR-NCH-P-AR-LSS-F	120V	LED, 3500K, 1000 LUMENS, 80CRI	RECESSED	9.2	9.7	
F1	INTERIOR BUNKRMS	AIRETOR 52-INCH LED CEILING FAN, BRUSHED NICKEL SILVER	LIGHTOLOGY	MKA925047	120V	LED, 3000K, 837 LUMENS, 16W	SURFACE	30.5	32.1	NOTE 3
F2	INTERIOR	ROBOTO 52-INCH FAN, BRUSHED ALUMINUM HOUSING TITANIUM SILVER BLADES , (1) WALL CONTROL UNIT PER FAN	MODERN FORMS	FR-W1910-52-BA-TT, F-WCBT-WT	120V		CEILING	38	40.0	NOTE 3
L1	INTERIOR DINING	SEEM 4 LED DIRECT/INDIRECT, POP-UP/DOWN LENS, TWO CIRCUIT, 0-10V DIMMING TO 10%, 48" CABLE SUSPENSION, TITANIUM SILVER FINISH, 3-FOOT	FOCAL POINT	FSM4BS-PUPD05-625DN-275UP-35K-2C-UNV-LD1-C48-TS-3FOOT	120V	LED, 3500K 2700 LUMENS	SUSPENDED	25.0	26.3	
L2	INTERIOR DAYROOM	SEEM 4 LED DIRECT/INDIRECT, POP-UP/DOWN LENS, TWO CIRCUIT, 0-10V DIMMING TO 10%, 48" CABLE SUSPENSION, TITANIUM SILVER FINISH, 6-FOOT	FOCAL POINT	FSM4BS-PUPD05-625DN-275UP-35K-2C-UNV-LD1-C48-TS-6FOOT	120V	LED, 3500K 5400 LUMENS	SUSPENDED	49.5	52.1	
L3	INTERIOR FITNESS	SEEM 4 LED DIRECT/INDIRECT, POP-UP/DOWN LENS, TWO CIRCUIT, 0-10V DIMMING TO 10%, 48" CABLE SUSPENSION, TITANIUM SILVER FINISH, 16-FOOT	FOCAL POINT	FSM4BS-PUPD05-275DN-275UP-35K-2C-UNV-LD1-C48-TS-16FOOT	120V	LED, 3500K 8800 LUMENS	SUSPENDED	88	92.6	
L3E	INTERIOR FITNESS	SEEM 4 LED DIRECT/INDIRECT, POP-UP/DOWN LENS, SINGLE CIRCUIT, 0-10V DIMMING TO 10%, 48" CABLE SUSPENSION, TITANIUM FINISH, 16-FOOT, EMERGENCY BATTERY PACK	FOCAL POINT	FSM4BS-PUPD05-275DN-275UP-35K-1C-UNV-LD1-C48-EM-TS-16FOOT	120V	LED, 3500K, 8800 LUMENS	SUSPENDED	88	92.6	
P1	INTERIOR	SQUARE DOT PENDANT, 6-INCH, LOW OUTPUT, THIN TOP GLOW FROSTED CLEAR, CUSTOM COLOR, SINGLE CIRCUIT, TOP SWIVEL STEM MOUNTED, SINGLE GANG, TEXTURED MATTE WHITE CANOPY, HARD CEILING, 0-10V DIMMING	PRUDENTIAL LIGHTING	SDP-6-LED35-LO-TG1-CLER-Yxx-SC-UNV-SSCxx-EBCP1G-TMW-X3-DM01	120V	LED, 3500K, 750 LUMENS	PENDANT	10.2	10.7	
R1	INTERIOR	LED FLAT PANEL, 2X2, 0-10V DIMMING TO 10%,	LITHONIA	EPANL-2X2-3400LM-80CRI-35K-MIN10-ZT-MVOLT-PWS1856LV	120V	LED, 3500K, 3400 LUMENS	RECESSED	30	31.6	
R1E	INTERIOR	LED FLAT PANEL, 2X2, 0-10V DIMMING TO 10%, EMERGENCY BATTERY	LITHONIA	EPANL-2X2-3400LM-80CRI-35K-MIN10-ZT-MVOLT-E1WCP-PWS1856LV	120V	LED, 3500K, 3400 LUMENS	RECESSED	30	31.6	
R2	INTERIOR	LED FLAT PANEL, 2X2, 0-10V DIMMING TO 10%,	LITHONIA	EPANL-2X2-2000LM-80CRI-35K-MIN10-ZT-MVOLT-PWS1856LV	120V	LED, 3500K, 2000 LUMENS	RECESSED	19	20.0	
R2E	INTERIOR	LED FLAT PANEL, 2X2, 0-10V DIMMING TO 10%, EMERGENCY BATTERY	LITHONIA	EPANL-2X2-2000LM-80CRI-35K-MIN10-ZT-MVOLT-PWS1856LV-E10WCP	120V	LED, 3500K, 2000 LUMENS	RECESSED	19	20.0	
R3	INTERIOR LAUNDRY	SEEM6 RECESSED SLOT LED, 6-INCH WIDE, 4-FOOT LONG, FLUSH SATIN LENS, SINGLE CIRCUIT, 0-10V DIMMING TO 10%, MUD-IN TRIMLESS, 6-FOOT FLEX WHIP, MATTE WHITE HOUSING	FOCAL POINT	FSM6L-FL-625LF-35K-1C-UNV-LD1-XF2-FV-WH-4FT	120V	LED, 3500K 2500 LUMENS	RECESSED	31	32.6	
S1	INTERIOR	4-FOOT LED LINEAR STRIP, STANDARD EFFICIENCY, WIDE DIFFUSE LENS, 0-10V DIMMING TO 10%, WHITE FINISH	LITHONIA	CLX-L48-5000LM-SEF-WDL-MVOLT-GZ10-35K-80CRI-VH	120V	LED, 3500K, 5000 LUMENS	SURFACE	35.4	37.3	
S1E	INTERIOR	4-FOOT LED LINEAR STRIP, STANDARD EFFICIENCY, WIDE DIFFUSE LENS, WIDE DISTRIBUTION, 0-10V DIMMING TO 10%, WHITE FINISH, EMERGENCY BATTERY PACK	LITHONIA	CLX-L48-5000LM-SEF-WDL-MVOLT-GZ10-35K-80CRI-PS1050-VH	120V	LED, 3500K, 5000 LUMENS	SURFACE	35.4	37.3	
S2	INTERIOR	8-FOOT LED LINEAR STRIP, STANDARD EFFICIENCY, WIDE DIFFUSE LENS, 0-10V DIMMING TO 10%, WHITE FINISH	LITHONIA	CLX-L96-10000LM-SEF-WDL-MVOLT-GZ10-35K-80CRI-VH	120V	LED, 3500K, 10000 LUMENS	SURFACE	70.8	74.5	
S2E	INTERIOR	8-FOOT LED LINEAR STRIP, STANDARD EFFICIENCY, WIDE DIFFUSE LENS, 0-10V DIMMING TO 10%, WHITE FINISH, EMERGENCY BATTERY PACK	LITHONIA	CLX-L96-10000LM-SEF-WDL-MVOLT-GZ10-35K-80CRI-PS1050-VH	120V	LED, 3500K, 10000 LUMENS	SURFACE	70.8	74.5	
S3	INTERIOR	RED LED LINEAR, EXTRUDED ALUMINUM MOUNTING CHANNEL, 8-FOOT LENGTH, WHITE FINISH, SUSPENSION MOUNTING, END CAPS, 96 WATT 24VDC CLASS 2 POWER SUPPLY, FACTORY MADE LEAD, 0-10V DIMMING	KELVIX	PHRK-WVR-24V-8", FML-2C-6, CH-218-N-8-WH-SP-EC, ULV96	120V/ 24VDC	RED LED, 872 LUMENS, 25.6 WATTS	SUSPENSION	96	101.1	
S4	INTERIOR	8-FOOT LED LINEAR STRIP, STANDARD EFFICIENCY, WIDE DIFFUSE LENS, 0-10V DIMMING TO 10%, WHITE FINISH	LITHONIA	CLX-L96-6000LM-SEF-WDL-MVOLT-GZ10-35K-80CRI-VH	120V	LED, 3500K, 6000 LUMENS	SURFACE	38.2	40.2	
S4E	INTERIOR	8-FOOT LED LINEAR STRIP, STANDARD EFFICIENCY, WIDE DIFFUSE LENS, 0-10V DIMMING TO 10%, WHITE FINISH, EMERGENCY BATTERY PACK	LITHONIA	CLX-L96-6000LM-SEF-WDL-MVOLT-GZ10-35K-80CRI-PS1050-VH	120V	LED, 3500K, 6000 LUMENS	SURFACE	38.2	40.2	
S5	INTERIOR	4-FOOT LED LINEAR STRIP, STANDARD EFFICIENCY, WIDE DIFFUSE LENS, 0-10V DIMMING TO 10%, WHITE FINISH	LITHONIA	CLX-L48-3000LM-SEF-WDL-MVOLT-GZ10-35K-80CRI-VH	120V	LED, 3500K, 3000 LUMENS	SURFACE	20.3	21.4	
S6	INTERIOR	8-FOOT LED LINEAR STRIP, STANDARD EFFICIENCY, WIDE DIFFUSE LENS, 0-10V DIMMING TO 10%, WHITE FINISH	LITHONIA	CLX-L96-8000LM-SEF-WDL-MVOLT-GZ10-35K-80CRI-VH	120V	LED, 3500K, 8000 LUMENS	SURFACE	52.3	55.1	
SL	INTERIOR	LEDme RED STEP LIGHT, BRUSHED NICKEL FINISH	WAC LIGHTING	WL-LED100-RD-BN	120V	RED LED	RECESSED WALL	3.5	3.7	
UC	INTERIOR	UNDERCABINET LED, LENGTHS TBD, ELV DIMMING, BRUSHED ALUMINUM FINISH, REMOTE CLASS 2 TRANSFORMER, END-TO-END CONNECTORS	WAC LIGHTING	LN-LEDxxP-30-AL, EN-24100-120-RB2-T, SL-IF	120V/ 24VDC	LED, 3000K, 275 LUMENS/FT,	UNDER CABINET	60	63.2	
V1	INTERIOR RESTROOM	BRINK BATHROOM SCONCE, 36-INCH, BRUSHED ALUMINUM, ACRYLIC DIFFUSER, ELV DIMMING	WAC LIGHTING	WS-77636-30-AL	120V	LED, 3000K, 2065 LUMENS	WALL	30	31.6	
W1	INTERIOR BUNK RMS	FLIP LED SWING ARM, LEFT SWING, TITANIUM FINISH, FINGERTIP TOUCH DIMMING, HARDWIRED	WAC LIGHTING	BL-1021L-TT	120V	LED, 3000K, 315 LUMENS	WALL	8.5	8.9	
X1	INTERIOR	EXIT SIGN, BATTERY BACKUP, GREEN LETTERS, SINGLE FACE, BRUSHED ALUMINUM, RECESSED CEILING, FIELD INSTALLED ADHESIVE CHEVRON INDICATORS, FLAT TRIM FOR RECESSED CEILING MOUNT	EVENLITE	SOV-EM-G-1M-BA-RC-UC-FT	120V	LED	RECESSED CEILING	3	3.9	
X2	INTERIOR	EXIT SIGN, BATTERY BACKUP, GREEN LETTERS, SINGLE FACE, BRUSHED ALUMINUM, SURFACE WALL, FIELD INSTALLED ADHESIVE CHEVRON INDICATORS, FLAT TRIM FOR RECESSED CEILING MOUNT	EVENLITE	SOV-EM-G-1M-BA-SW-UC-FT	120V	LED	SURFACE WALL	3	3.9	
GENERAL NOTES: 1. SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE PRODUCT BY MANUFACTUR INDICATED IN LUMINAIRE SCHEDULE, OR EQUIVALENT EQUAL BY OTHERS										
KEY NOTES: 1. REFERENCE ARCHITECTURAL PLAN FOR MOUNTING HEIGHTS 2. PROVIDE REMOTE EMERGENCY BALLAST MOUNTED IN ACCESSIBLE LOCATION 3. HANDHELD CONTROLLERS ARE NOT ACCEPTABLE, BLUETOOTH CONTROLLERS ARE NOT ACCEPTABLE										

1 INTERIOR LUMINAIRE SCHEDULE
NO SCALE

2 EXTERIOR LUMINAIRE SCHEDULE
NO SCALE

EXTERIOR LUMINAIRE SCHEDULE										
TYPE	LOCATION	DESCRIPTION	MANUFACTURER	CATALOG #	VOLTS	LAMPING	MOUNTING	WATTS	VA	KEY NOTES
AA	EXTERIOR	CUBE ARCHITECTURAL LED WALL MOUNT, 0-10V DIMMING, AWAY FROM WALL BEAM, BLACK FINISH	WAC LIGHTING	DC-WD0534-F830A-BK	120V	LED, 3000K, (2)1764 LUMENS	SURFACE	34	35.8	NOTE 1
BB	EXTERIOR	4-INCH OPEN DOWNLIGHT, BLACK TRIM, BLACK PAINTED FLANGE, 0-10V DIMMING	LITHONIA	LDN4-30/10-LO4-BR-TRBL-MVOLT-GZ10	120V	LED, 3000K, 1000 LUMENS	RECESSED	10.6	11.2	
BBE	EXTERIOR	4-INCH OPEN DOWNLIGHT, BLACK TRIM, BLACK PAINTED FLANGE, 0-10V DIMMING, EMERGENCY BATTERY PACK	LITHONIA	LDN4-30/10-LO4-BR-TRBL-MVOLT-GZ10-EL	120V	LED, 3000K, 1000 LUMENS	RECESSED	10.6	11.2	
CC	EXTERIOR	6-INCH OPEN DOWNLIGHT, BLACK TRIM, BLACK PAINTED FLANGE, 0-10V DIMMING	LITHONIA	LDN6-30/20-LO6-BR-TRBL-MVOLT-GZ10	120V	LED, 3000K, 2000 LUMENS	RECESSED	22.5	23.7	
CCE	EXTERIOR	6-INCH OPEN DOWNLIGHT, BLACK TRIM, BLACK PAINTED FLANGE, 0-10V DIMMING, EMERGENCY BATTERY PACK	LITHONIA	LDN6-30/20-LO6-BR-TRBL-MVOLT-GZ10-EL	120V	LED, 3000K, 2000 LUMENS	RECESSED	22.5	23.7	
DD	EXTERIOR	LEEDS 1 SMALL SURFACE WEDGE DOWNLIGHT, WET LOCATED RATED, BLACK FINISH, TYPE III	LIGMAN LIGHTING	ULEW-30001-5.5W LED-T3-W30-01-120/277	120V	LED, 3000K, 570 LUMENS	SURFACE	5.5	5.8	NOTE 1
EE	EXTERIOR	LIGHT LINEAR PT 1 SINGLE HEAD BOLLARD, 40-INCH HIGH, TYPE IV BEAM DISTRIBUTION, BLACK RAL 9011 FINISH	LIGMAN	ULI-10021-29W LED-T4-W30-01-120/277V	120V	LED, 3000K, 3169 LUMENS	GRADE	29	30.5	NOTE 2
FF	EXTERIOR	FLAGPOLE LED DOWNLIGHT BY FLAG POLE MANUFACTURER	NA	NA	120V	LED	FLAGPOLE	13	13.7	
GG	EXTERIOR	LIGHT LINEAR PT-X 13 SINGLE HEAD STREETLIGHT, TYPE IV BEAM DISTRIBUTION, BLACK RAL 9011 FINISH	LIGMAN	ULI-21331-105 LED-T4-W30-01-120/277V	120V	LED, 3000K, 14600 LUMENS	15'-0"AFG (13' POLE ON 2' BASE)	105	110.5	
GGR	EXTERIOR POLE LIGHT	LIGHT LINEAR PT-X 13 SINGLE HEAD STREETLIGHT, TYPE IV BEAM DISTRIBUTION, BLACK RAL 9011 FINISH, GFCI BOX	LIGMAN	ULI-21331-105 LED-T4-W30-01-120/277V-GFCI	120V	LED, 3000K, 14600 LUMENS	15'-0"AFG (13' POLE ON 2' BASE)	105	110.5	
F3	EXTERIOR	HYDRA 80-INCH DIA. FAN LIGHT COMBO, MATTE BLACK FINISH, WALL CONTROLLER, 12-INCH DOWNROD, WET LOCATION LISTED	MODERN FORMS	FR-W1805-80L-MB-MB, F-WCBT-WT, XF-12-MB	120V	LED, 3000K, 1013 LUMENS, 23.5W	CEILING	65.5	68.9	
GENERAL NOTES: 1. SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE PRODUCT BY MANUFACTURER INDICATED IN LUMINAIRE SCHEDULE, OR EQUIVALENT EQUAL BY OTHERS										
KEY NOTES: 1. REFERENCE ARCHITECTURAL PLAN FOR MOUNTING HEIGHTS 2. CONSULT MANUFACTURER FOR INSTALLATION DETAILS AND CONCRETE BASE DETAILS/INSTRUCTIONS.										

2

RELAY PANEL SCHEDULE						PANEL #: RP
RELAY #	PANEL #	CIRCUIT #	VOLTAGE	LOAD (VA)	ZONE DESCRIPTION	COMMENTS
1	B1	48	120V	110.5	TYPE GG POLE LIGHT	
2	B1	48	120V	152.5	TYPE EE FIRE FIGHTER PARKING	
3	B1	48	120V	366	TYPE EE PUBLIC/VISITOR PARKING	
4	B1	48	120V	50	TYPE FF POLE LIGHTS	
5	B1	48	120V	332	TYPE GG NORTH STREET LIGHTS	
6	B1	48	120V	331.5	TYPE GG SOUTH STREET LIGHTS	
7					SPARE	
8					SPARE	
GENERAL NOTES: 1. REFERENCE LIGHTING SEQUENCE OF OPERATIONS FOR CONTROL DESCRIPTIONS						
SCHEDULE NOTES: 1 2						

3

LIGHTING RELAY PANEL SCHEDULE
NO SCALE



REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
ELECTRICAL
COMCHECK

COMcheck Software Version COMcheckWeb
Envelope Compliance Certificate

Project Information

Energy Code: 2021 IECC
Project Title: Thornton Fire Station No. 8
Location: Thornton, Colorado
Climate Zone: 5b
Project Type: New Construction

Construction Site: Owner/Agent: Designer/Contractor:

Additional Efficiency Package(s)

Credits: 10.0 Required 15.0 Proposed
Reduced lighting power, 15.0 credit
On-site renewable energy, 0.0 credit

Building Area	Floor Area
1-Fire Station : Nonresidential	10174

Envelope Assemblies

(a) Budget U-factors are used for software baseline calculations ONLY, and are not code requirements.

Envelope TBD: All building area types must be assigned to at least one envelope assembly

Project Title: Thornton Fire Station No. 8 Report date: 08/19/24
Data filename: Page 1 of 12

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixture	D Fixture Watt.	E (C X D)
14-113 (Fire Stations:Sleeping Quarters) LED: W1: Other: LED: UC: Other: LED: F1: Other:	1 2 1	1 10 16	8 21 16	8 21 16
15-114 (Fire Stations:Sleeping Quarters) LED: W1: Other: LED: UC: Other: LED: F1: Other:	1 2 1	1 10 16	8 21 16	8 21 16
16-115 (Fire Stations:Sleeping Quarters) LED: W1: Other: LED: UC: Other: LED: F1: Other:	1 2 1	1 10 16	8 21 16	8 21 16
17-116 (Fire Stations:Sleeping Quarters) LED: W1: Other: LED: UC: Other: LED: F1: Other:	1 2 1	1 10 16	8 21 16	8 21 16
18-117 (Fire Stations:Sleeping Quarters) LED: W1: Other: LED: UC: Other: LED: F1: Other:	1 2 1	1 10 16	8 21 16	8 21 16
19-118 (Fire Stations:Sleeping Quarters) LED: W1: Other: LED: UC: Other: LED: F1: Other:	1 2 1	1 10 16	8 21 16	8 21 16
20-119 (Gymnasium/Fitness Center:Exercise Area) LED: L3: Other:	1	5	88	440
21-120 (Common Space Types:Corridor/Transition <8 ft wide) LED: R2: Other:	1	6	19	114
22-121 (Common Space Types:Corridor/Transition <8 ft wide) LED: D1: Other:	1	1	9	9
23-122 (Common Space Types:Corridor/Transition <8 ft wide) LED: R2: Other:	1	2	19	38
24-123 (Common Space Types:Storage >=50 - <=1000 sq.ft.) LED: R2: Other:	1	1	19	19
25-124 (Common Space Types:Electrical/Mechanical) LED: S5: Other:	1	1	20	20
26-125 (Common Space Types:Restrooms) LED: D1: Other: LED: D2: Other: LED: V1: Other:	1 1 1	2 1 30	9 6 30	18 6 30
27-126 (Common Space Types:Laundry/Washing Area) LED: S1: Other:	1	2	35	71
28-127 (Common Space Types:Storage >=50 - <=1000 sq.ft.) LED: S5: Other:	1	1	20	20
29-128 (Common Space Types:Locker Room) LED: S2 & S2E: Other: LED: S3: Other:	1 12	15 28	71 307	1062 307
30-129 (Common Space Types:Workshop) LED: S6: Other: LED: UC: Other:	1 14	2 10	52 147	105 147
31-130 (Common Space Types:Locker Room) LED: S6: Other:	1	2	52	105
32-131 (Common Space Types:Stairwell)				

Project Title: Thornton Fire Station No. 8 Report date: 08/19/24
Data filename: Page 4 of 12

COMcheck Software Version COMcheckWeb
Interior Lighting Compliance Certificate

Project Information

Energy Code: 2021 IECC
Project Title: Thornton Fire Station No. 8
Project Type: New Construction

Construction Site: Owner/Agent: Designer/Contractor:

Additional Efficiency Package(s)

Credits: 10.0 Required 15.0 Proposed
Reduced lighting power, 15.0 credit
On-site renewable energy, 0.0 credit

Allowed Interior Lighting Power

A Area Category	B Floor Area (ft2)	C Allowed Watts / ft2	D Allowed Watts
1-100 (Common Space Types:Corridor/Transition <8 ft wide)	134	0.71	95
2-101 (Common Space Types:Office - Enclosed)	293	0.74	217
3-102 (Common Space Types:Restrooms)	75	0.63	47
4-103 (Common Space Types:Office - Enclosed)	199	0.74	147
5-104 (Common Space Types:Storage <50 sq.ft.)	38	0.38	14
6-105 (Common Space Types:Dining Area - General)	264	0.43	114
7-106 (Common Space Types:Food Preparation)	504	1.09	549
8-107 (Common Space Types:Corridor/Transition <8 ft wide)	44	0.71	31
9-108 (Common Space Types:Lounge/Breakroom)	548	0.59	323
10-109 (Common Space Types:Laundry/Washing Area)	130	0.53	69
11-110 (Common Space Types:Electrical/Mechanical)	70	0.43	30
12-111 (Common Space Types:Restrooms)	95	0.63	60
13-112 (Common Space Types:Restrooms)	89	0.63	56
14-113 (Fire Stations:Sleeping Quarters)	109	0.23	25
15-114 (Fire Stations:Sleeping Quarters)	109	0.23	25
16-115 (Fire Stations:Sleeping Quarters)	109	0.23	25
17-116 (Fire Stations:Sleeping Quarters)	109	0.23	25
18-117 (Fire Stations:Sleeping Quarters)	109	0.23	25
19-118 (Fire Stations:Sleeping Quarters)	109	0.23	25
20-119 (Gymnasium/Fitness Center:Exercise Area)	897	0.90	807
21-120 (Common Space Types:Corridor/Transition <8 ft wide)	283	0.71	201
22-121 (Common Space Types:Corridor/Transition <8 ft wide)	44	0.71	31
23-122 (Common Space Types:Corridor/Transition <8 ft wide)	99	0.71	70
24-123 (Common Space Types:Storage >=50 - <=1000 sq.ft.)	57	0.38	22
25-124 (Common Space Types:Electrical/Mechanical)	46	0.43	20
26-125 (Common Space Types:Restrooms)	118	0.63	74
27-126 (Common Space Types:Laundry/Washing Area)	170	0.53	90
28-127 (Common Space Types:Storage >=50 - <=1000 sq.ft.)	65	0.38	25
29-128 (Common Space Types:Locker Room)	3439	0.52	1788
30-129 (Common Space Types:Workshop)	280	1.26	353
31-130 (Common Space Types:Locker Room)	305	0.52	159
32-131 (Common Space Types:Stairwell)	365	0.49	179

Project Title: Thornton Fire Station No. 8 Report date: 08/19/24
Data filename: Page 2 of 12

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixture	D Fixture Watt.	E (C X D)
LED: S4 & S4E: Other: LED: S3: Other:	1 1	3 1	38 26	115 26
33-132 (Common Space Types:Electrical/Mechanical) LED: S5: Other:	1	1	20	20
34-200 (Common Space Types:Storage >=50 - <=1000 sq.ft.) LED: S4 & S4E: Other:	1	7	38	267
35-201 (Common Space Types:Storage >=50 - <=1000 sq.ft.) LED: S4 & S4E: Other:	1	1	38	38
36-202 (Common Space Types:Electrical/Mechanical) LED: S5: Other:	1	1	20	20

Total Proposed Watts = 4948

Interior Lighting PASSES: Design 18% better than code

Interior Lighting Compliance

Statement

Compliance Statement: The proposed interior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed interior lighting systems have been designed to meet the 2021 IECC requirements in COMcheck Version COMcheckWeb and to comply with any applicable mandatory requirements listed in the Inspection Checklist.

Name - Title Signature Date

Project Title: Thornton Fire Station No. 8 Report date: 08/19/24
Data filename: Page 5 of 12

A Area Category	B Floor Area (ft2)	C Allowed Watts / ft2	D Allowed Watts
33-132 (Common Space Types:Electrical/Mechanical)	46	0.43	20
34-200 (Common Space Types:Storage >=50 - <=1000 sq.ft.)	681	0.38	259
35-201 (Common Space Types:Storage >=50 - <=1000 sq.ft.)	98	0.38	37
36-202 (Common Space Types:Electrical/Mechanical)	44	0.43	19
Total Allowed Watts =			6057

Proposed Interior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixture	D Fixture Watt.	E (C X D)
1-100 (Common Space Types:Corridor/Transition <8 ft wide) LED: D3 & D3E: Other:	1	4	9	37
2-101 (Common Space Types:Office - Enclosed) LED: R1: Other: LED: UC: Other:	1 3 1	3 21 10	30 10 220	90 220
3-102 (Common Space Types:Restrooms) LED: D1: Other: LED: V1: Other:	1 1	2 1	9 30	18 30
4-103 (Common Space Types:Office - Enclosed) LED: R1: Other: LED: UC: Other:	1 1	4 6	30 10	120 63
5-104 (Common Space Types:Storage <50 sq.ft.) LED: R2: Other:	1	1	19	19
6-105 (Common Space Types:Dining Area - General) LED: L1: Other: LED: D1: Other:	1 3 1	3 1	25 9	75 9
7-106 (Common Space Types:Food Preparation) LED: D1: Other: LED: P1: Other: LED: UC: Other: LED: CV: Other:	1 1 1 1 1	9 5 14 44	9 10 147 4	83 51 147 198
8-107 (Common Space Types:Corridor/Transition <8 ft wide) LED: D1: Other:	1	1	9	9
9-108 (Common Space Types:Lounge/Breakroom) LED: D1: Other: LED: L2: Other:	1 11 3	9 50	9 101 148	101 148
10-109 (Common Space Types:Laundry/Washing Area) LED: R3: Other: LED: UC: Other:	1 1	1 8	31 10	31 84
11-110 (Common Space Types:Electrical/Mechanical) LED: S5: Other:	1	2	20	41
12-111 (Common Space Types:Restrooms) LED: D1: Other: LED: D2: Other: LED: V1: Other:	1 1 1	1 2 1	9 6 30	9 12 30
13-112 (Common Space Types:Restrooms) LED: D1: Other: LED: D2: Other: LED: V1: Other:	1 1 1	1 2 1	9 6 30	9 12 30

Project Title: Thornton Fire Station No. 8 Report date: 08/19/24
Data filename: Page 3 of 12

LIGHTING SEQUENCE OF OPERATIONS													
ROOM #	ROOM NAME	MANUAL ON/OFF	MASTER OVERRIDE ON/OFF	LOCAL OVERRIDE ON/OFF	LOCAL DIMMING	VACANCY MODE (MANUAL ON)	OCCUPANCY MODE (AUTO ON)	SENSOR TIMEOUT PERIOD (MINUTES)	PHOTO CONTROL WITH AUTO DIMMING TARGET	LCP PROGRAMMED		DIMMING VIA LCP PHOTO SENSOR	DESCRIPTION
										TIME OF DAY ON/OFF CONTROL	PHOTO SENSOR ON/OFF CONTROL		
										ON	OFF		
100	ENTRY			X					15 FC	DAWN	DUSK		DUSK TILL 10PM DIM TO 1FC, 10PM TILL DAWN, D3E NIGHTLIGHT ONLY.
101	OFFICE			X		X		10	30 FC				TYPE R1 & UC BALANCED TO ACHIEVE 30FC
102, 111, 112, 125	TOILET			X		X		10					
103	OFFICE			X		X		10	30 FC				TYPE R1 & UC BALANCED TO ACHIEVE 30FC
104, 123, 201	STORAGE			X		X		10					
105	DINING	X	X		X								MASTER ON/OFF
106	KITCHEN	X	X		X								MASTER ON/OFF
107, 121	VEST			X				10	15 FC	DAWN	DUSK		DUSK TILL 10PM DIM TO 1FC, 10PM TILL DAWN VACANCY MODE AT 1FC.
108	DAY ROOM	X	X		X								MASTER ON/OFF
109	LAUNDRY			X	X	X		10					
110	IT	X											
113 THRU 118	BUNK ROOM	X			X								
CIRC B2 44	TYPE K STEP LIGHTS									DUSK	DAWN		
119	FITNESS			X		X		10	30 FC				
120, 122	CORRIDOR			X					15 FC	DAWN	DUSK		DUSK TILL 10PM DIM TO 1FC, 10PM TILL DAWN TURN OFF.
124,132,202	ELEC	X											
126	DECON			X			X	10					
127	EMS			X		X		10					
128	APPARATUS BAY			X		X		10	30 FC				TYPE S2, S2E FIXTURES TYPE S3 FIXTURES (RED NL)
129	WORK RM			X	X	X		10		DUSK	DAWN		
130	BUNKER GEAR			X		X		10					
131, 200	STAIRS/MEZZ			X				10	30 FC				
201	ELEC	X											
EXTERIOR	BLDG SIGN									DUSK	DAWN		CIRCUIT A2 35
EXTERIOR	FRONT ENTRY								5 FC	DUSK	DAWN		TYPE BB & BBE FIXTURES
EXTERIOR	APP BAY ENTRIES								5 FC	DUSK	DAWN		TYPE AA, CC & CCE FIXTURES BALANCED TO ACHIEVE 5 FC
EXTERIOR	CORRIDOR 120 ENTRY								5 FC	DUSK	DAWN		TYPE BB & BBE FIXTURES
EXTERIOR	PATIO	X			X								TYPE BB & BBE FIXTURES
EXTERIOR	RP-1									DUSK	DAWN		
EXTERIOR	RP-2									DUSK	DAWN		
EXTERIOR	RP-3									DUSK	DAWN		
EXTERIOR	RP-4									DUSK	DAWN		
NOTES:													




REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
ELECTRICAL
SITE PLAN

Page #:

E 1.0



1 SITE PLAN
1" = 20'-0"

GENERAL NOTES

- REFERENCE DRAWING E0.0 FOR ADDITIONAL NOTES.
- PROVIDE CONCRETE BASE FOR ALL GROUND MOUNTED LIGHT FIXTURES.
- FOR ALL EXTERIOR RECEPTACLES AT GRADE, PROVIDE WEATHER-RESISTANT THERMOPLASTIC PAD LOCKABLE COVER.
- TO WITHSTAND DE-ICER CHEMICALS. ALL ELECTRICAL EQUIPMENT CONCRETE BASES INCLUDING LIGHT POLES, BOLLARDS, AND PEDESTAL RECEPTACLES SHALL MEET CONCRETE MIX REQUIREMENTS INDICATED PER DETAIL 6, DRAWING S3.4
- ADDITIONAL CONDUIT MAY BE REQUIRED FOR CENTURYLINK CONNECTION. CONTRACTOR SHALL PLAN FOR 100 ADDITIONAL FEED OF 1-1/2" CONDUIT AND PROVIDE LINEAR FEET PRICE FOR DEDUCT/ADD.

WORK NOTES

- FOR FUTURE CHARGEPOINT CT4000 DUAL PORT EV CHARGING STATION, PROVIDE IN GROUND ELECTRICAL PULLBOX WITH CONDUITS INDICATED ROUTED BACK TO PANEL A2. FUTURE #4/#6, #8G CIRCUIT, (2)40A2P CIRCUITS PER CHARGING STATION.
- FOR VEHICLE BLOCK HEATERS, PROVIDE GFI/WP RECEPTACLE MOUNTED ON PEDOC 36" TALL PEDESTAL. INTEGRAL BASE, BLACK FINISH, MODEL 1P36-G-V-B. MOUNT PEDESTAL ON CONCRETE BASE. LOCKABLE COVER.
- CENTURY LINK PULLBOX. COORDINATE EXACT LOCATION WITH SERVICE PROVIDER/OWNER PRIOR TO ROUGH-IN. FOR PULLBOX, PROVIDE 24"x36"x24" WITH LID LABELED "COMMUNICATIONS".
- COMCAST PULLBOX. COORDINATE EXACT LOCATION WITH SERVICE PROVIDER/OWNER PRIOR TO ROUGH-IN. FOR PULLBOX, PROVIDE 24"x36"x24" WITH LID LABELED "COMMUNICATIONS".
- CITY FIBER PULLBOX. COORDINATE EXACT LOCATION WITH SERVICE PROVIDER/OWNER PRIOR TO ROUGH-IN. FOR PULLBOX, PROVIDE 24"x36"x24" WITH LID LABELED "FIBER".
- PULLBOX FOR FUTURE STOP LIGHT. FOR PULLBOX, PROVIDE 24"x36"x24" WITH LID LABELED "TRAFFIC".
- FOR VEHICLE BLOCK HEATER, PROVIDE GFI/WP RECEPTACLE INTEGRAL TO LIGHT POLE. LOCKABLE COVER.
- PULLBOX FOR TELECOM TO PARKS & STREETS BLDG. FOR PULLBOX, PROVIDE 24"x36"x24" WITH LID LABELED "COMMUNICATIONS". CONDUITS SHALL BE EXTENDED BEYOND PULLBOX UNDER PARKS AND STREETS PROJECT.
- FOR FUTURE GATE OPERATOR, PROVIDE IN GROUND ELECTRICAL PULLBOX WITH CONDUITS INDICATED ROUTED BACK TO PANEL B2. FUTURE 2#10, #10G CIRCUIT TO 20A1P.
- FOR FUTURE GATE OPERATOR, PROVIDE IN GROUND ELECTRICAL PULLBOX WITH CONDUITS INDICATED ROUTED BACK TO ACCESS CONTROL PANEL (ACP).
- FOR EACH CAT6A, PROVIDE 75 FEET OF ADDITIONAL COILED IN HANDHOLE FOR FUTURE EXTENSION TO GATE AIPHONE SYSTEM.



REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
**ELECTRICAL
POWER PLAN**

Page #:

E 1.1


WORK NOTES

- FOR ALERT SYSTEM ENDPOINT DISPLAY, PROVIDE RECEPTACLE. COORDINATE EXACT LOCATION AND MOUNTING HEIGHT PRIOR TO ROUGH-IN.
- PROVIDE FLUSH MOUNTED DUAL DUPLEX/USB RECEPTACLE. RECEPTACLES SHALL BE (1) USB TYPE A AND (1) TYPE C PORT.
- FOR WALL MOUNTED FLAT SCREEN PROVIDE DUPLEX RECEPTACLE AT 63" AFF. SEE TELECOM PLANS FOR TELECOM REQUIREMENTS. COORDINATE EXACT LOCATION WITH MOUNTING HARDWARE AND OWNER PRIOR TO ROUGH-IN.
- FOR DRYER, PROVIDE 14-30R RECEPTACLES AND 3#10, #10G CIRCUIT.
- FOR OVERHEAD GARAGE DOORS PROVIDE 30A1P, NON-FUSED DISCONNECT AND 2#12, #12G POWER CIRCUIT INDICATED. PROVIDE WIRE/CONDUIT, INTERCONNECTIONS TO DOOR UP-STOP-DOWN CONTROL STATIONS, AND ADDITIONAL CONTROL DEVICES AS NECESSARY FOR A COMPLETE AND OPERATIONAL SYSTEM. OBSTACLE SENSOR TO ACTIVATE AT 4'-0" AFF. EACH GARAGE DOOR SHALL BE PROVIDED WITH ADDITIONAL UP-STOP-DOWN CONTROL STATION TO BE GROUPED TOGETHER AS INDICATED ON PLANS.
- PROVIDE ADDITIONAL GROUPING OF GARAGE DOOR UP-STOP-DOWN FLUSH MOUNTED CONTROL STATIONS. PROVIDE WIRE/CONDUIT AS NECESSARY FOR FULLY OPERATIONAL SYSTEM.
- FOR CEILING MOUNTED CABLE REEL, PROVIDE CEILING MOUNTED RECEPTACLE. PROVIDE INDUSTRIAL DUTY SPRING TENSION #12AWG WIRE UP TO 35-FOOT WOODHEAD MODEL 9385. PROVIDE FEMALE 5-20R CONNECTOR AT END OR CORD. PROVIDE CORD FROM RECEPTACLE TO CABLE REEL SUFFICIENTLY LONG ENOUGH FOR CABLE REEL TO BE RELOCATED ALONG UNISTRUT AS VEHICLE LENGTHS CHANGE.
- FOR EXTRACTOR, PROVIDE 30A/3P, NONFUSED DISCONNECT AND 3#12, #12G CIRCUIT.
- IN EMS ROOM, PROVIDE QUAD RECEPTACLES FOR CHARGING AUTOP, PRAM, DEFIB, ETC. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- EXHAUST FAN EF-5 SHALL BE POWERED FROM POLYMOVENT CONTROL PANEL.
- PROVIDE RACEWAY SYSTEM, GRAY FINISH, WITH ALTERNATING STANDARD RECEPTACLE, AND DUAL DUPLEX/USB RECEPTACLE MOUNTED 6-INCHES ABOVE COUNTER TO BOTTOM OF RACEWAY. RECEPTACLES SHALL BE SPACED EVERY 12-INCHES. DUAL DUPLEX/USB RECEPTACLE SHALL BE EVERY 3RD DEVICE. DUAL DUPLEX/USB RECEPTACLE SHALL INCLUDE (1) USB TYPE A PORT AND (1) USB TYPE C PORT. RACEWAY SYSTEM SHALL BE WIREMOLD TYPE CABLESMART 40N2 SERIES NONMETALLIC RACEWAY OR EQUAL. NO OUTLETS BEHIND SINK.
- PROVIDE RACEWAY SYSTEM, WHITE FINISH, WITH ALTERNATING STANDARD RECEPTACLE, AND DUAL DUPLEX/USB RECEPTACLE CENTERED BETWEEN COUNTER AND BOTTOM OF WINDOW. RECEPTACLES SHALL BE SPACED EVERY 36-INCHES. DUAL DUPLEX/USB RECEPTACLE SHALL BE EVERY OTHER DEVICE. DUAL DUPLEX/USB RECEPTACLE SHALL INCLUDE (1) USB TYPE A PORT AND (1) USB TYPE C PORT. RACEWAY SYSTEM SHALL BE WIREMOLD TYPE CABLESMART 40N2 SERIES NONMETALLIC RACEWAY OR EQUAL.
- FOR GARBAGE DISPOSAL, PROVIDE COUNTER MOUNTED AIR SWITCH, STAINLESS STEEL FINISH.
- FOR WELDING RECEPTACLE, PROVIDE 6-50R OUTLET AND 2#6, #10G, 3/4" CIRCUIT, MOUNTED AT 46" AFF.
- FOR EXHAUST FAN GEF-2, PROVIDE FUSED COMBINATION MAGNETIC MOTOR STARTER WITH SUMMER-OFF-WINTER SELECTOR SWITCH. FAN SHALL RUN CONTINUOUSLY. IN "WINTER" MODE, FAN SHALL BE CONTROLLED BY CO/NOX CONTROLLER DRY CONTACT CLOSURE. STARTER SHALL OPEN MOTORIZED DAMPER WHEN FAN IS ENERGIZED. PROVIDE CABLE/CONDUIT AS NECESSARY FOR COMPLETE AND OPERATIONAL SYSTEM.
- FOR GEAR DRYER, PROVIDE 60A/2P, NON-FUSED DISCONNECT AND 2#8, #10G CIRCUIT. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- WALL MOUNT SPEED CONTROLLER/TIMER FOR EXHAUST FAN. PROVIDE CABLE/CONDUIT TO EXHAUST FAN.
- PROVIDE 5-FOOT LED STRIP ILLUMINATED DOOR SAFETY LIGHT KITS ON INTERIOR OF EACH GARAGE DOOR ON BOTH SIDES. PROVIDE BRACKETS THAT MOUNT LED'S TO SIDE OF GARAGE DOOR TRACK. PROVIDE ALL ACCESSORIES & WIRE/CONDUIT AS NECESSARY FOR A COMPLETE AND OPERATIONAL SYSTEM. KITS SHALL BE MANUFACTURED BY BRINK ALERT, OR EQUAL.
- FOR DRINKING FOUNTAIN, COORDINATE EXACT MOUNTING LOCATION WITH EQUIPMENT PRIOR TO ROUGH-IN.
- FOR WALL MOUNTED FLAT SCREEN, PROVIDE DUPLEX RECEPTACLE AT 68" AFF. SEE TELECOM PLANS FOR TELECOM REQUIREMENTS. COORDINATE EXACT LOCATION WITH MOUNTING HARDWARE AND OWNER PRIOR TO ROUGH-IN.
- PROVIDE 4-POLE CONTACTOR FOR EMERGENCY SHUT-OFF OF STOVE/OVEN CIRCUITS B1-34 AND GAS SHUT OFF VALVE B1-27. CONTACTOR SHALL BE CONTROLLED BY EMERGENCY STOP PUSH-BUTTON. REFERENCE WORK NOTE NO. 30.
- FOR EXERCISE EQUIPMENT, PROVIDE RECEPTACLE ON DEDICATED CIRCUIT. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- FOR POLYMOVENT CONTROL PANEL, PROVIDE POWER CIRCUIT TO EXHAUST FAN EF-5, 1/2" CONDUITS TO PRESSURE AND TEMP SENSORS. REFERENCE MANUFACTURER SHOP DRAWINGS AND EXACT WIRING REQUIREMENTS. PROVIDE WIRING AS NECESSARY FOR COMPLETE AND OPERATIONAL SYSTEM. REFERENCE POWER ONE-LINE DIAGRAM ON DRAWING E0.1 FOR CIRCUITING INFORMATION.
- FOR AV SYSTEM, PROVIDE QUAD RECEPTACLE IN CABINET BELOW AT 1'-6" AFF.
- PROVIDE POWER CIRCUIT TO KITCHEN HOOD. KITCHEN HOOD SHALL BE INTERLOCKED WITH RANGE SUCH THAT HOOD SHALL TURN ON WHEN RANGE IS ACTIVATED.
- PROVIDE 120V POWER CIRCUIT FOR GAS SHUTOFF SOLENOID VALVE AS SHOWN ON PLUMBING PLANS. CIRCUIT SHALL BE CONTROLLED BY CONTACTOR C1.
- PROVIDE DEDICATED RECEPTACLE FOR KITCHEN RANGE CONTROLLED VIA CONTACTOR C1.
- FOR RADIO CHARGING STATIONS AT EACH SHELVES (TYP OF 5), PROVIDE PLUGMOLD WITH SIMPLEX RECEPTACLES EVERY 6-INCHES OC, WHITE FINISH.
- FOR COFFEE MAKER, PROVIDE GFI/AC RECEPTACLE ON DEDICATED CIRCUIT.
- FOR CONTROL OF CONTACTOR C1, PROVIDE EMERGENCY STOP PUSH-BUTTON, MAINTAIN PUSH-TO-STOP, PULL-TO-START, RED HEAD. PROVIDE LABEL INDICATING "EMERGENCY SHUT-OFF" SEE WORK NOTE NO. 21. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- CONTRACTOR SHALL COMPLETE ONE BUNK ROOM AND AFTER APPROVAL DUPLICATE TO OTHER BUNK ROOMS. CONTRACTOR SHALL COORDINATE ALL DEVICE LOCATIONS WITH OWNER PRIOR TO ROUGH-IN. INDICATOR LIGHTS ON ALL CEILING MOUNTED DEVICES SHALL BE INSTALLED FACING AWAY FROM BED.
- ENGINE GENERATOR ANNUNCIATOR FLUSH MOUNTED. COORDINATE LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- PROVIDE DEDICATED RECEPTACLES FOR TELECOM EQUIPMENT.
- PROVIDE (4) DEDICATED RECEPTACLES FOR FIRST-IN ALERT SYSTEM SERVER RACK UPS'S. REFERENCE "AS" DRAWINGS FOR ADDITIONAL INFORMATION. FIRST-IN ALERT EQUIPMENT MOUNTED IN FLOOR MOUNTED RACK. MOUNT RECEPTACLES TO VERTICAL POST OF RACK.
- FOR BEARCOM RADIO SYSTEM, PROVIDE DEDICATED RECEPTACLE ABOVE COUNTERTOP.
- FOR WALL MOUNTED FLAT SCREEN, PROVIDE DUPLEX RECEPTACLE MOUNTED AT 72" AFF. SEE TELECOM PLANS FOR TELECOM REQUIREMENTS. COORDINATE EXACT LOCATION WITH MOUNTING HARDWARE AND OWNER PRIOR TO ROUGH-IN. REFERENCE AV DRAWINGS FOR ADDITIONAL REQUIREMENTS.
- WALL MOUNT THERMOSTAT. PROVIDE CABLE/CONDUIT TO CONTROLLED UNIT.
- PROVIDE 30A/2P, NON-FUSED DISCONNECT.
- FOR WALL MOUNTED FLAT SCREEN, PROVIDE DUPLEX RECEPTACLE AT 68" AFF. SEE TELECOM PLANS FOR TELECOM REQUIREMENTS. COORDINATE EXACT LOCATION WITH MOUNTING HARDWARE AND OWNER PRIOR TO ROUGH-IN. REFERENCE AV DRAWINGS FOR ADDITIONAL REQUIREMENTS.
- FOR MICROWAVE, PROVIDE GFI RECEPTACLE IN CABINET.
- WALL MOUNTED SPEED CONTROLLER FOR EXHAUST FAN, PROVIDE CABLE/CONDUIT TO EXHAUST FAN.
- PROVIDE CONTINUOUS DEEP UNISTRUT TO ALLOW ADJUSTABLE CORD DROP LOCATIONS.
- PROVIDE 6-30R RECEPTACLE AND 2#10, #10G CIRCUIT MOUNTED AT 46" AFF.
- FOR SECURITY SYSTEM ACCESS CONTROL PANEL (ACP) AND LOCK POWER SUPPLY (LPS) PROVIDE POWER CIRCUIT INDICATED. COORDINATE LOCATION PRIOR TO ROUGH-IN.
- IN IT/ELEC ROOM#110, CONTRACTOR SHALL COORDINATE ALL EQUIPMENT LOCATIONS WITH OWNER PRIOR TO ROUGH-IN.
- FOR AMBULANCE, PROVIDE CEILING MOUNTED CABLE REEL, PROVIDE CEILING MOUNTED 5-30R RECEPTACLE, PROVIDE INDUSTRIAL DUTY SPRING TENSION #10AWG WIRE UP TO 40-FOOT WOODHEAD MODEL 92434. PROVIDE 30A, 125V, 2-POLE, 3 WIRE PIN & SLEEVE RECEPTACLE, MELTRIC MODEL DSN30 SERIES 63-34075 AT END OF CORD. PROVIDE CORD FROM RECEPTACLE TO CABLE REEL SUFFICIENTLY LONG ENOUGH FOR CABLE REEL TO BE RELOCATED ALONG UNISTRUT AS VEHICLE LENGTHS CHANGE. VERIFY PLUG TYPE FOR AMBULANCE WITH OWNER.
- FOR WALL MOUNTED FLAT SCREEN, PROVIDE DUPLEX RECEPTACLE AT 38-INCHES ABOVE CREDENZA. REFERENCE AV DRAWINGS FOR ADDITIONAL REQUIREMENTS.
- FOR HVAC EQUIPMENT ABOVE CEILING, PROVIDE CONVENIENCE RECEPTACLE, PROVIDE CONVENIENCE RECEPTACLE AND SOCKET WITH PULLSTRING. COORDINATE BEST LOCATION WITH EQUIPMENT PRIOR TO ROUGH-IN.
- CO/NOX CONTROLLER AND REMOTE CO/NOX SENSORS. PROVIDE CABLE/CONDUIT FROM CONTROLLER TO REMOTE SENSORS AND EXHAUST FAN GEF-2 MOTOR STARTER AS NECESSARY FOR COMPLETE AND OPERATIONAL SYSTEM.
- REFERENCE LIGHTING FOR ADDITIONAL CONTROLS. DOOR SHALL CLOSE UPON SIGNAL FROM LIGHTING CONTROL SYSTEM WHEN SPACE IS UNOCCUPIED.
- FOR BUNKER POWER RAIL RUN ACROSS TOP OF THE LOCKERS, PROVIDE CONNECTIONS TO POWER CIRCUITS INDICATED. COORDINATE SPECIFIC LOCATION WITH VENDOR PRIOR TO ROUGH-IN.
- FOR FAN POWER BOX, PROVIDE 60A/2P, NON-FUSED DISCONNECT AND 2#8, #10G CIRCUIT.
- RED/GREEN STOP LIGHT STYLE FIXTURE FURNISHED BY GARGE DOOR MANUFACTURER, INTERLOCKED WITH DOOR CONTROLLER. PROVIDE WIRE/CONDUIT AS NECESSARY FOR A COMPLETE AND OPERATIONAL SYSTEM.
- RECEPTACLE FOR BMS SYSTEM. COORDINATE EXACT LOCATION WITH SYSTEM SUPPLIER PRIOR TO ROUGH-IN.
- FOR SECURITY SYSTEM, PROVIDE QUAD RECEPTACLE CENTERED IN LOWER CABINET.
- FOR IRRIGATION CONTROLLER, PROVIDE POWER CIRCUIT INDICATED. COORDINATE EXACT LOCATION PRIOR TO ROUGH-IN.
- MOUNT RECEPTACLE ABOVE FACP FOR AES RADIO. REFERENCE FIRE ALARM SUBMITTAL FOR ADDITIONAL REQUIREMENTS.
- FOR UTILITY XFMR, PROVIDE CONCRETE EQUIPMENT PAD PER UNITED POWER STANDARDS. COORDINATE SPECIFIC OPENING FOR FEEDERS SIZE/LOCATION WITH UTILITY PRIOR TO ROUGH-IN.
- FOR ENGINE GENERATOR, PROVIDE CONCRETE EQUIPMENT HOUSEKEEPING PAD.
- FOR ATS PROVIDE CONCRETE EQUIPMENT HOUSEKEEPING PAD.
- FOR CEILING MOUNTED CABLE REEL, PROVIDE CEILING MOUNTED RECEPTACLE. PROVIDE INDUSTRIAL DUTY SPRING TENSION #12AWG WIRE UP TO 35-FOOT WOODHEAD MODEL 9385. PROVIDE FEMALE 5-20R CONNECTOR AT END OR CORD. PROVIDE CORD FROM RECEPTACLE TO CABLE REEL. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
- FOR FUTURE FIRETRUCK EV CHARGING POWER CABINET,

GENERAL NOTES

- REFERENCE DRAWING E0.0 FOR ADDITIONAL NOTES.
- COORDINATE ALL RECEPTACLE LOCATIONS WITH FURNITURE SYSTEMS.
- ALL 15 AND 20 AMPERE, 120 AND 250 VOLT NON-LOCKING RECEPTACLES IN ROOMS xxxx SHALL BE LISTED TAMPER RESISTANT RECEPTACLES.

1 POWER PLAN 1/8" = 1'-0"



CITY OF THORNTON
FIRE STATION #8
15343 MONACO STREET
THORNTON, COLORADO 80602



REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
ELECTRICAL
LIGHTING PLAN

Page #:


E 1.2

WORK NOTES

- 1 PROVIDE LINE VOLTAGE WALL SWITCH VACANCY SENSOR, DUAL TECHNOLOGY, MANUAL-ON, WHITE FINISH, SENSOR SWITCH MODEL WSXA-PDT-SA-WH, OR EQUAL.
- 2 PROVIDE LINE VOLTGE WALL SWITCH OCCUPANCY SENSOR, DUAL TECHNOLOGY, AUTO ON, 0-10V DIMMING, WHITE FINISH, SENSOR SWITCH MODEL WSXA-PDT-D-WH.
- 3 PROVIDE LINE VOLTAGE WALL SWITCH VACANCY SENSOR, DUAL TECHNOLOGY DETECTION 0-10VDC DIMMING CONTROL, MANUAL-ON, WHITE FINISH, SENSOR SWITCH MODEL WSXA-PDT-D-SA-WH, OR EQUAL.
- 4 NOT USED.
- 5 PROVIDE LOW VOLTAGE CEILING MOUNT SENSOR, DUAL TECHNOOY, SMALL MOTION, 360-DEGREE, NLIGHT MODEL NCM-PDT-9-RJB, OR EQUAL.
- 6 PROVIDE LOW VOLTAGE CEILING MOUNT SENSOR, PASSIVE INFRARED, HIGH BAY, 360-DEGREE, NLIGHT MODEL NCM-6-RJB, OR EQUAL.
- 7 PROVIDE LOW VOLTAGE CEILING MOUNT SENSOR, PHOTOCONTROL WITH AUTO DIMMING, NLIGHT MODEL NCM-ADCX-RJB, OR EQUAL.
- 8 PROVIDE LOW VOLTAGE CEILING MOUNT OCCUPANCY SENSOR DUAL TECHNOLOGY, SMALL MOTION, 360-DEGREE, PHOTOCELL WITH AUTOMATIC DIMMING, NLIGHT MODEL NCM-PDT-9-RJB-ADCX, OR EQUAL.
- 9 PROVIDE LOW VOLTAGE CEILING MOUNT SENSOR, PASSIVE INFARED, HIGH BAY 360-DEGREE, AUTOMATIC DIMMING CONTROL, NLIGHT MODEL NCM-6-RJB-ADCX, OR EQUAL.
- 10 NOT USED.
- 11 PROVIDE POWER RELAY, EXTERNAL FAULT PROTECTION, NLIGHT MODEL NPP16-EFP, OR EQUAL.
- 12 PROVIDE POWER RELAY PACK OCCUPANCY CONTROLLED DIMMING, EXTERNAL FAULT PROTECTION NLIGHT MODEL NPP16-D-EFP, OR EQUAL.
- 13 PROVIDE POWER RELAY, ELECTRONIC LOW VOLTAGE DIMMING, NLIGHT MODEL NSP5-PCD-ELV-120, OR EQUAL.
- 14 PROVIDE PULSE ON/OFF SHADE INTERFACE PACK, NLIGHT MODEL NSHD, OR EQUAL.
- 15 PROVIDE ELECTRONIC LOW VOLTAGE DIMMING SWITCH.
- 16 PROVIDE LOW VOLTAGE PUSH-BUTTON WALLPOD SINGLE CHANNEL, ON/OFF CONTROL, WHITE FINISH NLIGHT MODEL NPODMA-WH.
- 17 PROVIDE LOW VOLTAGE PUSH-BUTTON WALL POD, SINGLE CHANNEL, ON/OFF & RAISE/LOWER DIMMING WITHOUT WIRES, WHITE FINISH, NLIGHT MODEL NPODMA-DX-WH, OR EQUAL.
- 18 PROVIDE LOW VOLTAGE PUSH-BUTTON WALL POD, SINGLE CHANNEL, ON/OFF & RAISE/LOWER DIMMING WITHOUT WIRES, WHITE FINISH, LOW TEMP, NLIGHT MODEL NPODMA-DX-WH-LT, OR EQUAL.
- 19 PROVIDE LOW VOLTAGE PUSH BUTTON WALL POD 2-CHANNEL, ON/OFF CONTROL, WHITE FINISH NLIGHT MODEL NPODMA-2P-WH.
- 20 PROVIDE LOW VOLTAGE PUSH-BUTTON WALLPOD, 2-CHANNEL, ON/OFF & RAISE/LOWER DIMMING WITHOUT WIRES, WHITE FINISH, NLIGHT MODEL NPODMA-2P-DX-WH.
- 21 ROVIDE LOW VOLTAGE PUSH-BUTTON WALLPOD, 4-CHANNEL, ON/OFF & RAISE/LOWER DIMMING WITHOUT WIRES, WHITE FINISH, NLIGHT MODEL NPODMA-4P-DX-WH.
- 22 PROVIDE TOUCHSCREEN NLIGHT MODEL NPOT TOUCH-WH AND 150VA POWER SUPPLY NLIGHT PS-150, OR EQUAL.
- 23 PROVIDE OUTDOOR PHOTOCELL ANALOG PHOTOSENSOR, NLIGHT MODEL ARPA-APS-OL, OR EQUAL.
- 24 PROVIDE LIGHTING CONTROL PANEL, NLIGHT ECLYPSE MODEL NECY-MVOLT-ENC-NW-GFXK, TOUCH-SCREEN INTERFACE MOUNTED SEPARATELY. PROVIDE ALL LOW VOLTAGE WIRING AS NECESSARY FOR A COMPLETE AND OPERATIONAL SYSTEM. PROVIDE ALL PROGRAMMING AS NECESSARY FOR A COMPLETE AND OPERATIONAL SYSTEM.
- 25 PROVIDE LIGHTING RELAY PANEL, 8-RELAYS, AQUITY MODEL ARP-INTENC08-NLT-8FCR-MVOLT-1VB-SC-SM, OR EQUAL.
- 26 PROVIDE TOUCH-SCREEN INTERFACE NLIGHT MODEL NGWY2-GFX AND 150VA POWER SUPPLY NLIGHT PS-150, OR EQUAL.
- 27 PROVIDE 8-PORT, RJ-45, BRIDGE, NLIGHT MODEL NBRG-8-KIT, AND 150VA POWER SUPPLY NLIGHT PS-150, OR EQUAL.
- 28 NOT USED.
- 29 PROVIDE POWER CIRCUIT TO EXTERIOR SIGNAGE. COORDINATE EXACT CONNECTION POINTS WITH MANUFACTURER PRIOR TO ROUGH-IN.
- 30 PROVIDE RECESSED WALL MOUNT FAN CONTROLLER.
- 31 RELAY SHALL PROVIDE SIGNAL TO GARAGE DOOR TO CLOSE WHEN SPACE IS NOT OCCUPIED. COORDINATE CONTACT TYPE (NO/NC) WITH DOOR OPERATOR FOR OPERATIONAL SYSTEM.
- 32 IN BUNKROOMS, 3-WAY SWITCHING SHOWN IS ENTIRELY FOR FIXTURE F1. ONE SET OF 3-WAY SWITCHES WILL ON/OFF CONTROL THE LIGHT, AND OTHER SET OF 3-WAY SWITCHES WILL ON/OFF CONTROL THE FAN.
- 33 CONTRACTOR SHALL COMPLETE ONE BUNK ROOM AND AFTER APPROVAL DUPLICATE TO OTHER BUNK ROOMS. CONTRACTOR SHALL COORDINATE ALL DEVICE LOCATIONS WITH OWNER PRIOR TO ROUGH-IN. INDICATOR LIGHTS ON ALL CEILING MOUNTED DEVICES SHALL BE INSTALLED FACING AWAY FROM BED.

GENERAL NOTES

1. REFERENCE DRAWING E0.0 FOR ADDITIONAL NOTES.




1 LIGHTING PLAN
1/8" = 1'-0"



REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
**ELECTRICAL
TELECOM PLAN**



1 TELECOM PLAN
1/8" = 1'-0"

GENERAL NOTES

1. REFERENCE DRAWING E0.0 FOR ADDITIONAL NOTES.
2. ALL TELEVISIONS AND MONITORS ARE OWNER FURNISHED CONTRACTOR INSTALLED.

WORK NOTES

- (1) FOR WALL MOUNTED FLAT SCREEN, PROVIDE DUAL COAXIAL & DATA OUTLET MOUNTED AT 63" AFF. COORDINATE EXACT LOCATION WITH MOUNTING HARDWARE AND OWNER PRIOR TO ROUGH-IN.
- (2) PROVIDE TELEPHONE DATA OUTLET AT 60" AFF.
- (3) WIRELESS ACCESS POINT (WAP) OWNER FURNISHED CONTRACTOR INSTALLED.
- (4) FOR WALL MOUNTED FLAT SCREEN, PROVIDE DUAL COAXIAL & DAT OUTLET MOUNTED AT 88-3/4" AFF. COORDINATE EXACT LOCATION WITH MOUNTING HARDWARE AND OWNER PRIOR TO ROUGH-IN.
- (5) FOR AV, PROVIDE (1) COAXIAL/(2)DATA OUTLETS IN CABINET BELOW 1'-6" AFF. PROVIDE (1) 1-INCH CONDUIT WITH PULLSTRING TO ABOVE ACCESSIBLE CEILING. COORDINATE MOUNTING HEIGHT WITH FURNITURE SUPPLIER PRIOR TO ROUGH-IN.
- (6) FOR MDF, PROVIDE 3/4" FIRE RETARDANT TREATED PLYWOOD ON WALLS INDICATED. REFERENCE TELECOM ONE-LINE ON DRAWING E2.0 FOR ADDITIONAL REQUIREMENTS.
- (7) ALERT SYSTEM SERVER RACK.
- (8) COMCAST EQUIPMENT LOCATION. COORDINATE EXACT LOCATION WITH OWNER AND VENDOR PRIOR TO ROUGH-IN.
- (9) CONTRACTOR SHALL COMPLETE ONE BUNK ROOM AND AFTER APPROVAL, DUPLICATE TO OTHER BUNK ROOMS. CONTRACTOR SHALL COORDINATE ALL DEVICE LOCATIONS WITH OWNER PRIOR TO ROUGH-IN. INDICATOR LIGHTS ON ALL CEILING MOUNTED DEVICES SHALL BE INSTALLED FACING AWAY FROM BED.
- (10) IN IT RM 110, CONTRACTOR SHALL COORDINATE ALL EQUIPMENT LOCATIONS WITH OWNER PRIOR TO ROUGH-IN.
- (11) FOR BEARCOM RADIO SYSTEM MOUNTED ON COUNTERTOP, PROVIDE RECESSED J-BOX WITH 2-INCH CONDUIT ROUTED TO CABLETRAY. REFERENCE DRAWING E1.5 FOR ANTENNA LOCATION.
- (12) REFERENCE SECURITY DOOR ROUGH-IN DETAILS ON DRAWING E2.0 FOR ADDITIONAL REQUIREMENTS.
- (13) FOR SECURITY SYSTEM ACCESS CONTROL PANEL (ACP) AND LOCK POWER SUPPLY (LPS), PROVIDE 2" EC BETWEEN PANELS. PROVIDE 2" EC FROM ACP TO CABLE TRAY FOR SECURITY CABLING AND ETHERNET CABLE. COORDINATE EXACT LOCATION PRIOR TO ROUGH-IN.
- (14) FOR WALL MOUNTED FLAT SCREEN SECURITY MONITOR, PROVIDE DATA OUTLET MOUNTED AT 63" AFF. COORDINATE EXACT LOCATION PRIOR TO ROUGH-IN.
- (15) PROVIDE 12-INCH WIRE MESH CABLE TRAY ABOVE CEILING FOR DATA CABLING BY OTHERS.
- (16) PROVIDE 6-INCH WIRE MESH CABLE TRAY ABOVE CEILING FOR DATA CABLING BY OTHERS.
- (17) FOR WALL MOUNTED FLAT SCREEN, PROVIDE DUAL COAXIAL & DATA OUTLET MOUNTED AT 72" AFF. COORDINATE EXACT LOCATION WITH MOUNTING HARDWARE AND OWNER PRIOR TO ROUGH-IN.
- (18) FOR WALL MOUNTED FLAT SCREEN, PROVIDE DUAL COAXIAL & DATA OUTLET MOUNTED AT 72" AFF. COORDINATE EXACT LOCATION WITH MOUNTING HARDWARE AND OWNER PRIOR TO ROUGH-IN.
- (19) NOT USED.
- (20) FOR 7-INCH TOUCH PANEL, PROVIDE 2-GANG J-BOX MOUNTED 46" AFF WITH 3/4" TO ABOVE ACCESSIBLE CEILING.
- (21) FOR BLUE TOOTH AUDIO INTERFACE, PROVIDE 2-GANG J-BOX MOUNTED 46" AFF WITH 3/4" TO ABOVE ACCESSIBLE CEILING.
- (22) FOR BLUE TOOTH AUDIO INTERFACE, PROVIDE 2-GANG J-BOX MOUNTED 3" ABOVE CREDENZA WITH 3/4" TO ABOVE ACCESSIBLE CEILING.
- (23) FOR AV RACK IN CREDENZA, PROVIDE 2-GANG J-BOX MOUNTED 18" AFF WITH (2) 1-1/4" TO ABOVE ACCESSIBLE CEILING.
- (24) FOR WALL MOUNTED FLAT SCREEN, PROVIDE 1-GANG J-BOX WITH NOSE PLATE AND MUD RING AT 63" AFF WITH 3/4" TO ABOVE ACCESSIBLE CEILING.
- (25) PROVIDE 2" EC FROM AES TO ABOVE ACCESSIBLE CEILING FOR FUTURE ROOF MOUNTED ANTENNA.
- (26) FOR SECURITY SYSTEM PROVIDE 1-GANG J-BOX AT SECURITY VIDEO EQUIPMENT LOCATION AND 1-GANG J-BOX AT SECURITY MONITOR LOCATION AT 63" AFF WITH 3/4" EC BETWEEN. COORDINATE EXACT LOCATIONS WITH OWNER PRIOR TO ROUGH-IN.
- (27) CCTV SYSTEM EQUIPMENT LOCATED IN LOWER CABINET.
- (28) COORDINATE LOCATIONS OF ALL DEVICES ON THIS WALL SUCH THAT LAYOUT LOOKS BEST IN ACCENT PANEL WALL.
- (29) FOR PTZ CAMERA, PROVIDE 1-GANG JUNCTION BOX 5-INCHES BELOW CUSTOM CEILING WITH 3/4" TO ABOVE ACCESSIBLE CEILING.
- (30) FOR SPEAKER CHANNELS, PROVIDE 1-GANG JUNCTION BOX MOUNTED 96" AFF WITH 3/4" TO ABOVE ACCESSIBLE CEILING.
- (31) FOR CF SPEAKER CHANNEL, PROVIDE 1-GANG JUNCTION BOX MOUNTED 6" ABOVE CABINET, CENTERED ON WALL WITH 3/4" TO ABOVE ACCESSIBLE CEILING.

CITY OF THORNTON
FIRE STATION #8
15343 MONACO STREET
THORNTON, COLORADO 80602



REVISION NAME	DATE

ISSUE DATE: 2024 0927


Sheet Name:
**ELECTRICAL
MEZZANINE
PLANS**

Page #:

E 1.4

GENERAL NOTES


- REFERENCE DRAWING E0.0 FOR ADDITIONAL NOTES.



1 MEZZANINE POWER PLAN
1/8" = 1'-0"

POWER WORK NOTES


- FOR AIR COMPRESSOR, REFERENCE POWER ONE-LINE DIAGRAM ON DRAWING E0.1 FOR DISCONNECT AND CIRCUIT SIZE INFORMATION. COORDINATE WITH ACTUAL COMPRESSOR SUBMITTED PRIOR TO ROUGH-IN.
- FOR TROLLEY HOIST, REFERENCE POWER ONE-LINE DIAGRAM ON DRAWING E0.1 FOR DISCONNECT AND CIRCUIT SIZE INFORMATION.
- PROVIDE 2 TON CAPACITY ELECTRIC CHAIN HOIST WITH TROLLEY, SINGLE SPEED HOIST 14 FT/MIN, SINGLE SPEED TROLLEY, ASME H4 CLASSIFICATION, 25 FT LIFT, CANVAS CHAIN CONTAINER, 2.4HP LIFTING MOTOR, 0.54HP TROLLEY, 480V, 3PH, PUSHBUTTON PENDANT, POWER SUPPLY CABLE WITH CABLE HANGERS, HARRINGTON MODEL (N)ERMO20L-L/S, OR EQUAL.
- FOR PV SYSTEM DATA MANAGER, PROVIDE RECEPTACLE.
- FOR BOILER B-1, PROVIDE 30A1P/NF DISCONNECT AND 2#10,#10G CIRCUIT.
- FOR PUMP P-2, REFERENCE POWER ONE-LINE DIAGRAM ON DRAWING E0.1 FOR DISCONNECT AND CIRCUIT SIZE INFORMATION.
- FOR SNOWMELT CONTROLLER, PROVIDE 120V CIRCUIT TO J-BOX. COORDINATE EXACT LOCATION WITH SYSTEM SUPPLIER PRIOR TO ROUGH-IN.



2 MEZZANINE LIGHTING PLAN
1/8" = 1'-0"

LIGHTING WORK NOTES

- PROVIDE LOW VOLTAGE CEILING MOUNT OCCUPANCY SENSOR, DUAL TECHNOLOGY, SMALL MOTION, 360-DEGREE, PHOTOCELL WITH AUTOMATIC DIMMING, NLIGHT MODEL NCM-PDT-9-RJB-ADCX, OR EQUAL.
- PROVIDE LOW VOLTAGE CEILING MOUNT OCCUPANCY SENSOR, DUAL TECHNOLOGY, SMALL MOTION, 360-DEGREE, NLIGHT MODEL NCM-PDT-9-RJB, OR EQUAL.
- PROVIDE LINE VOLTAGE WALL SWITCH VACANCY SENSOR, DUAL TECHNOLOGY, MANUAL-ON, WHITE FINISH, SENSOR SWITCH MODEL WSXA-PDT-SA-WH, OR EQUAL.
- PROVIDE POWER RELAY PACK OCCUPANCY CONTROLLED DIMMING, EXTERNAL FAULT PROTECTION, NLIGHT MODEL NPP16-D-EFP, OR EQUAL.



3 MEZZANINE SYSTEMS PLAN
1/8" = 1'-0"

CITY OF THORNTON
FIRE STATION #8
15343 MONACO STREET
THORNTON, COLORADO 80602



REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
**ELECTRICAL
ROOF PLAN**

Page #:

E 1.5


GENERAL NOTES

1. REFERENCE DRAWING E0.0 FOR ADDITIONAL NOTES.

WORK NOTES

- (1) FOR SPLIT SYSTEM, PROVIDE WIRE/CONDUIT TO INTERIOR AC UNIT AS RECOMMENDED BY MANUFACTURER, AND AS REQUIRED FOR COMPLETE AND OPERATIONAL SYSTEM. PROVIDE 30A/2P, NON-FUSED, NEMA 3R DISCONNECT AT UNIT.
- (2) REFERENCE POWER ONE-LINE DIAGRAM ON DRAWING E0.1 FOR CIRCUITING INFORMATION.
- (3) NOT USED.
- (4) FOR BEARCOM ANTENNA ON ROOF, PROVIDE WEATHERHEAD WITH 2-INCH CONDUIT ROUTED TO CABLETRAY. COORDINATE EXACT ANTENNA LOCATION WITH VENDOR PRIOR TO ROUGH-IN.
- (5) FOR BEARCOM ANTENNA ON ROOF, PROVIDE WEATHERHEAD WITH 2-INCH CONDUIT ROUTED TO CABLETRAY. COORDINATE EXACT ANTENNA LOCATION WITH VENDOR PRIOR TO ROUGH-IN.
- (6) FOR BDA ANTENNA ON ROOF, PROVIDE WEATHERHEAD WITH 2-INCH CONDUIT ROUTED TO CABLETRAY. COORDINATE EXACT ANTENNA LOCATION WITH VENDOR PRIOR TO ROUGH-IN.
- (7) FOR FUTURE OPTICOM ANTENNA ON ROOF, PROVIDE WEATHERHEAD WITH 2-INCH CONDUIT ROUTED TO CABLETRAY.
- (8) FOR FUTURE AES RADIO ANTENNA ON ROOF, PROVIDE WEATHERHEAD WITH 2-INCH CONDUIT ROUTED TO ABOVE ACCESSIBLE CEILING IN ENTRY 100.
- (9) PROVIDE GFI PROTECTECT 120V POWER CIRCUIT FOR DOWNSPOUT HEAT TRACE AT THIS LOCATION. COORDINATE WITH EXACT REQUIREMENTS OF HEAT TRACE SYSTEM.

DESIGN CRITERIA	
TOTAL ATTACHMENT COUNT (QUANTITY)	4
BASIC WIND SPEED (MPH)	120.0
GROUND SNOW LOAD (PSF)	60.0
SEISMIC (Ss)	0.18
ELEVATION (FT)	5351.0
WIND EXPOSURE	C
RISK CATEGORY	IV
VELOCITY PRESSURE, QZ (PSF)	24.39
PV SYSTEM SUMMARY	
TOTAL SYSTEM SIZE RATING (KW DC)	38.88
TOTAL SYSTEM SIZE RATING (KW AC)	35.0
HELIENE 144 M10 MODULE 540W (QUANTITY)	72
FRONIUS SYMO 17.5-3 480V(QUANTITY)	2
TOTAL NUMBER OF STRINGS (QUANTITY)	6
MODULES PER STRING (QUANTITY)	12
MODULE TILT (DEGREES)	10
MAXIMUM DC VOLTAGE	603
FRONIUS QUATTRO (QUANTITY)	36



1 ROOF PLAN
1/8" = 1'-0"



REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
ELECTRICAL
DETAILS


Page #:

E 2.0


DATA CABLING NOTES:

- FOR TELEPHONE/DATA/CABLING SYSTEM, PROVIDE EMPTY PIPE SYSTEM. CONTRACTOR SHALL COORDINATE WITH SYSTEM PROVIDERS. ALL CONDUITS SHALL HAVE PULL STRINGS.
- FOR CAMERA SYSTEMS, PROVIDE EMPTY PIPE SYSTEM. CONTRACTOR SHALL COORDINATE WITH SYSTEM PROVIDER. ALL CONDUITS SHALL HAVE PULL STRINGS.
- FOR SECURITY SYSTEM, PROVIDE EMPTY PIPE SYSTEM. CONTRACTOR SHALL COORDINATE WITH SYSTEM PROVIDER. ALL CONDUITS SHALL HAVE PULL STRINGS.
- FOR ALERTING SYSTEM, PROVIDE EMPTY PIPE SYSTEM. REFERENCE "FSA" DRAWINGS FOR ADDITIONAL REQUIREMENTS. ALL CONDUITS SHALL HAVE PULL STRINGS.
- FOR AV SYSTEM, PROVIDE EMPTY PIPE SYSTEM. REFERENCE "AV" DRAWINGS FOR ADDITIONAL REQUIREMENTS. ALL CONDUITS SHALL HAVE PULL STRINGS.
- ALL CABLING SHALL BE CONCEALED. WHERE NON-ACCESSIBLE OR EXPOSED, CONDUIT PATHWAYS SHALL BE PROVIDED. CABLING SHALL BE RUN FREE ONLY ABOVE ACCESSIBLE CEILINGS VIA CABLE TRAY OR J-HOOKS.
- DATA CABLING SHALL BE CAT 6A.
- COORDINATE EXACT PEDESTAL AND PULLBOX LOCATIONS SHOWN ON DRAWING E1.0 SITE PLAN WITH SERVICE PROVIDERS PRIOR TO ROUGH-IN.
- AMERICAN DATAPATH IS PREFERRED VENDOR FOR TELECOM CABLING.
- SURVEILLANCE ONE IS PREFERRED VENDOR FOR SECURITY AND ACCESS CONTROL SYSTEMS.
- HIGH COUNTRY AV IS PREFERRED VENDOR FOR AUDIO VISUAL SYSTEM.
- ALL NECESSARY RACEWAYS FOR SYSTEMS SHALL BE PROVIDED BY CONTRACTOR.
- CONTRACTOR SHALL PROVIDE ALL NECESSARY COORDINATION WITH PREFERRED VENDORS TO ENSURE ALL REQUIREMENTS ARE CAPTURED AND THAT ALL SYSTEMS ARE FULLY COMPLETE AND OPERATIONAL.


CONDUIT FILL CHART		
CONDUIT SIZE	CAT 5E CABLE QUANTITY (MAX)	CAT 6A CABLE QUANTITY (MAX)
3/4"	3	3
1"	6	5
1-1/4"	10	9
1-1/2"	14	12
2"	26	21
2-1/2"	41	36
3"	59	55
CABLE QUANTITY BASED ON 40% CONDUIT FILL		



1 DATA CABLING ONE-LINE DIAGRAM
NO SCALE



2 TYPICAL SECURITY DOOR ROUGH-IN (NON-ACCESSIBLE CEILING)
NO SCALE



3 TYPICAL SECURITY DOOR ROUGH-IN (ACCESSIBLE CEILING)
NO SCALE



REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
ELECTRICAL
DETAILS

Page #:


E 2.1

HVC300 power cabinet - Technical specification

Power cabinet	HVC300-25	HVC300-30	HVC300-45	HVC300-40
Product code	CE 6AGC116204 UL - BAA -	6AGC116205 6AGC116219 6AGC116214	6AGC116228 - -	6AGC116200 6AGC116222 6AGC116230
Dispenser compatibility	2 dispensers - Static	2 dispensers - Dynamic	4 dispensers - Static	4 dispensers - Dynamic
Charging mode	Depot charge box single connector	Yes	Depot charge box dual connector	Yes
Parallel charging	Yes	Yes	CCS Control box	Yes
Pantograph-down depot set	Yes	Yes	Pantograph-up depot set	Yes
Distance between power cabinet & dispensers	100 m / 328 ft standard, up to 150 m / 492 ft with long distance package			
Electrical characteristics	DC output current (1)	430 A at 700 V DC, 375 A at 800 V DC	430 A at 700 V DC, 375 A at 800 V DC	430 A at 700 V DC, 375 A at 800 V DC
DC output current per dispenser (3)	215 A at 700 V DC, 188 A at 800 V DC	430A at 700V DC, 375A at 800V DC	105 A at 700 V DC, 90 A at 800 V DC	
DC output power rating (3)	300 kW			
DC output power rating per dispenser	150 kW	max. 300 kW	75 kW	max. 300 kW
DC output voltage	150-940 V			
Input AC power rating - 400 V AC	326 kVA			
Input nominal current - 400 V AC	470 A			
Input AC power rating - 480 V AC	326 kVA			
Input nominal current - 480 V AC	392 A			
Input voltage range	CE: 400 V AC +/- 10% (50 Hz) UL: 480 V AC +/- 10% (60 Hz)			
Power factor (2)	> 0.98			
Efficiency	94-96%			
Standby power (3)	0.13 kW			
Input power cable	AC power cable 3P+PE maximum: 240 mm ² / 500 MCM AWG			
Product characteristics	IP and IK rating	IP-54 and IK-10 (cabinet) / NEMA 3R		
Noise level	62 dB in any direction at 1 m			
Enclosure type	Stainless steel			
Placement	Concrete foundation on soil; Metal frame foundation on a solid floor; Custom foundation on a solid floor			
Operational attitude	Up to 2000 m / 6562 ft			
Operation temperature range (4)	-35°C to +55°C / -31°F to 131°F			
Storage temperature range	+5 to +40°C with relative humidity 5 to 85%			
Humidity limitation	5-95% non-condensing is standard			
Derating	Derating highly depends on the dispenser (cable/pantograph), vehicle inlet, temperature and duration. This can only be given on a system level.			
Dimensions (H x W x D)	2180 x 1170 x 770 mm / 85.83 x 46.06 x 30.32 in			
Weight	890 kg / 1962.11 lb			
Color	RAL 9002			
User interface	Emergency button	Power Cabinet: Can be connected external EMG button. Dispensers: Can be connected external EMG button, Depot Boxes have internal EMG button		
LED	Yes, RGB LED on the power cabinet, 1 per outlet (green: ready to charge / blinking green: preparation phase / blinking blue: charging / blue: charging complete / red: error)			
Service access	Front door			
Vehicle ID recognition	Yes can be used to enable Autocharge			
Communication & Configuration	Communication cabinet - dispensers	CAN2Ethernet		
Connectivity	Internet access via 4G / 3G / Ethernet (R345)			
Communication protocols	OCPP 1.6 J30N			
Charging protocols	DIN 70121, ISO/IEC 15118 series ed 1 with PtC and EIM			
Software update	Over-the-air updates via ABB web portal, OCPP 1.6			
Control and configuration	ABB web portal, on-board service portal, OCPP 1.6			
Certification and standards	Charging standard	IEC 61851-1 ed 3, IEC 61851-21-2 ed 1, IEC 61851-23 ed 1, IEC 61851-24 ed 1, IEC 62196-2, IEC 62196-3, IEC 61000, UL 2902, CSA 22.2		
Electro-Magnetic Compatibility	EMC Class A Conducted and Radiated			
Compliance	CE and UL certification, BAA compliant option for transit			
Warranty	Base warranty 24 months after Site Acceptance Test or 30 months after factory delivery. Warranty extensions available.			
Designed lifespan	ABB chargers are designed for a lifetime of 15 years assuming they receive maintenance according to the maintenance schedule by a trained engineer.			

(1) Maximum output current and output power rating could be limited by the dispenser
(2) Power factor at Output power > 10 kW
(3) HVC300 - 2 x depot charge box + 2 x Control Box / Ambient 25°C, no heater
(4) Measured according to IEC 62196-1, current rating and duration at higher temperatures is highly dependent on the charging interface and vehicle inlet.

4 FUTURE FIRETRUCK EV CHARGING POWER CABINET NO SCALE



RESIDENTIAL SUBDIVISION

Single-phase transformer for residential subdivision installation


NOTES:

- Transformers can be a fire hazard since they contain flammable oil.
- The above dimensions allow access for operation and maintenance.
- Permanent obstruction within or above the hatched working space is prohibited.
- Guard posts are required in traffic area.
- Gate (vented) required if transformer is to be installed within an enclosure, gate must be a minimum of two feet wider than transformer and must include provision for a unit power padlock, contact united power for transformer dimensions and site specific requirements.
-




Working space fire safety clearance

ISSUED	06/07	 Your Touchstone Energy® Cooperative	MINIMUM WORKSPACE ELECTRIC PADMOUNT TRANSFORMERS	1UW
APPROVAL	-			
DATE	BY			
06/07	ER			
05/18	DGO			
REVISIONS				
06/07	ER	New Drawing		
05/18	DGO	Standards Update		




ISSUED	08/05/02	 Your Touchstone Energy® Cooperative	GROUND SLEEVE ASSEMBLY	UM1-7NC UM1-7NF
APPROVAL	-			
DATE	BY			
05/07	ER			
03/08	ER			
REVISIONS				
05/07	ER	Revised Unit Designations		
03/08	ER	Revised Grade Requirement		
08/08	ER	Revised Profile, Add Ballards		
05/18	DGO	Standards Update		

1 UNITED POWER DETAILS NO SCALE



2 POLE LIGHT BASE DETAIL NO SCALE



3 BOLLARD BASE DETAIL NO SCALE

Photovoltaic Cable 2000 V UL 4703

Technical Sheet

Features

Rated and Listed as PV Wire per UL 4703
Also listed as Type USE-2 / RHW-2 per UL 44.
FV-1 Vertical Flame rating per UL 2556
Meet requirements of UL 854 for Type USE-2
Complete Cable is Lead Free and RoHS compliant.

Specifications:

Maximum operating Voltage: 2000 V
Temperature range wet or dry: -40oC ... 90oC

Application:

Technical Sheet

For interconnecting wiring of grounded and ungrounded photovoltaic power systems as described in Wiring Systems, Article 690, and other applicable parts of the National Electrical Code (NEC)/NFPA 70.

Construction:

Single Copper Conductor 19 strands, Cross linked Polyethylene (XLPE Insulation) Manufactured in North America.

1. Copper Compressed Conductor.
2. Cross-Linked Polyethylene Insulation.

Photovoltaic Cable XLPE Insulated 2000 Volts

SIZE AWG mm ²	NO STRANDS	COND. DIAM	INSULATION THICKNESS	OVERALL DIAM	TOTAL WEIGHT LB/100 FT	DC RESISTANCE 250C Ohms per 1000 FT mm ² (AWG) at 25°C	Ohms per 1000 Feet (AWG) at 30°C Temperature R	Single LDR in Air
12	19	0.92	0.075	0.235	45	1.65	2.075	0.045
10	19	0.115	0.075	0.277	60	1.04	1.039	0.033
8	19	0.142	0.085	0.32	90	0.652	0.815	0.038
6	19	0.18	0.085	0.36	123	0.411	0.514	0.038
								75

The above data are approximate and subject to normal manufacturing tolerances. Where required, the compatibility with glands, connectors and accessories should be verified using actual dimensions of the product. Other sizes available upon request.

Impedance: Based on a direct buried/pinned conductor.

Amperes: Based on NEC Table 310.15 (B)(16) for insulated conductors rated up to and including 2000 Volts, based on ambient temperature of 30°C (86°F) for not more than three current carrying conductor in raceways, cable or direct buried conditions.

PROTECTIVE DEVICES	SYMIO ADVANCED 15.0-3 480	SYMIO ADVANCED 20.0-3 480	SYMIO ADVANCED 22.7-3 480	SYMIO ADVANCED 24.0-3 480
DC reverse polarity protection		Yes		
Anti islanding		Yes		
Over temperature protection		Output power derating / Active cooling		
APC		Yes		
Rapid shutdown compliant		Yes		
Ground Fault Protection with Isolation Monitor		Yes		
Integrator				
DC disconnect		Yes		

INTERFACES	SYMIO ADVANCED 15.0-3 480	SYMIO ADVANCED 20.0-3 480	SYMIO ADVANCED 22.7-3 480	SYMIO ADVANCED 24.0-3 480
USB (A socket)		Datalogging and inverter update possible via USB		
2x RS422 (B&S socket)		Fronius Solar Net, interface protocol		
Power Line Communication (PLC)		Yes - SunSpec Rapid Shutdown communication standard		
Wi-Fi/Ethernet/Serial Datalogger and webserver*		Wireless standard 802.11 b/g/n / Fronius Solarweb, SunSpec Modbus TCP, IEC 61850 / SunSpec Modbus RTU		
8 inputs and 4 digital I/Os*		Load management, signaling, multipurpose I/O		

* Available with the Fronius Datamanager 2.0 Card (only one card required for up to 100 inverters)

/ Perfect Welding / Solar Energy / Perfect Charging

THREE BUSINESS UNITS, ONE GOAL: TO SET THE STANDARD THROUGH TECHNOLOGICAL ADVANCEMENT.

What began in 1945 as a one-man operation now sets technological standards in the fields of welding technology, photovoltaics and battery charging. Today, the company has around 5,660 employees worldwide and 1,321 patents for product development show the innovative spirit within the company. Sustainable development means for us to implement environmentally relevant and social aspects equally with economic factors. Our goal has remained constant throughout: to be the innovation leader.

Further information about all Fronius products and our global sales partners and representatives can be found at www.fronius.com



**Rapid
Shutdown**



CERTIFIED



UL

Fronius USA LLC
6797 Fronius Drive
Portage, IN 46368
USA
pw-support-usa@fronius.com
www.fronius.us

Fronius International GmbH
Froniusplatz 1
46000 Wels
Austria
pw-sales@fronius.com
www.fronius.com

2



REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
PV SYSTEM
CUTSHEETS
ADD ALTERATE

Page #:

E 3.1

ALLRED & ASSOCIATES

310771	Attachment	RM10 ATTACHMENT KIT	4	4	18.26	73.04
370030	Mid support kit	MID SUPPORT	32	32	14.89	476.48
310760	RM Roof Pad	RM ROOF PAD	178	178	2.35	418.30
008009P	Grounding Lug	ILSCO LAY IN LUG(BL4DBT)	1	1	7.54	7.54

BASE SYSTEM PRICE	\$10320.76	ACCESSORIES PRICE	\$425.84	TOTAL PRICE	\$10746.6
	\$0.270 PER WATT		\$0.011 PER WATT		\$0.282 PER WATT

This design is to be evaluated to the product appropriate Unirac Code Compliant Installation Manual which references International Building Code 2009, 2012, 2015, 2018 and ASCE 7-05, ASCE 7-10, ASCE 7-16, ASCE-722 and California Building Code 2010, 2016. The installation of products related to this design is subject to requirements in the above mentioned installation manual.

Page 2 of 28



U-BUILDER PROJECT REPORT

PROJECT VERSION 5.4.0
PROJECT VERSION 0.0.0.1

PROJECT TITLE	PROJECT ID	LAST UPDATED
8BF0A89E (copy)	4CE3A7AB	May, 6, 2024
		ORIGINALLY CREATED May, 6, 2024

NAME	Thorton Fire Station No. 8	Designed by alan.ely@elyconsultingengineering.com
ADDRESS	15347 Monaco St	RM10 EVO
		Hellene
CITY, STATE	Brighton, CO	72 - 144HC 530 M10 SL Bifacial
MODULE	Hellene 144HC 530 M10 SL Bifacial	2629 ft²
		38.16 kW

NOTE: Designing on a "blank page" in the U-Builder design tool may not provide accurate wind engineering results because the roof outline is not provided. It is the user's responsibility to verify building dimensions, site criteria, array distance from roof edges. When designing a construction-ready project, it is always recommended to "Design On Map".

NOTE: Installation of the project is intended to happen within the year of project designed in UBuilder. If it's past one year please rerun the design or contact Unirac Engineering Services.

BILL OF MATERIALS

LEGEND: ■ Base System Part ■ Accessory

PART NUMBER	PART TYPE	DESCRIPTION	QUANTITY	SUGGESTED QUANTITY	UNIT PRICE (USD)	TOTAL LIST PRICE (USD)
UserSupplied-Ballast Block	HalfBlock	BALLAST HALF BLOCK	147	147	0.00	0.00
User Supplied	Ballast Block	BALLAST BLOCK	405	405	0.00	0.00
370010	Ballast Bay	RM10 EVO FIELD BAY	153	153	44.76	6848.28
370011	Ballast Bay	RM10 EVO NORTH ROW BAY	13	13	44.76	581.88
370023	Clamp	EVO MOD CLAMP BULK	604	604	2.93	1769.72
370022	RM Hex Bolt	EVO MOD CLAMP SIDE BOLT BULK	604	604	0.64	386.56
310999	Attachment	FLASHLOC RM KIT	4	4	46.20	184.80

Page 2 of 28

DIRECT CURRENT ARRESTOR

SILICON OXIDE ARRESTOR FOR PHOTOVOLTAIC, CATHODIC PROTECTORS, AND OTHER DIRECT CURRENT APPLICATIONS

Conforms to IEEE Std. C62.34 Cert. To CAN/CSA Std. C22.2 No. 8

Collector

LA602DC

DC / AC Inverter

AC Load Center

LA302R

Locknut & Washer furnished

1/2" Nipple

TYPE OF DESIGN

Maximum current

Maximum energy

Maximum number of surges

Response time one millamp test

Response time to clamp 10,000 amps

Response time to clamp 50,000 amps

Leak current at double the rated voltage

Leads

Case Material

Silicon Oxide Varistor

100,000 amps

3,000 joules per pole

Unlimited

5 nanoseconds

10 nanoseconds

25 nanoseconds

none

3 - 18" #12 THHN

PVC

LA602DC for 0-800 Volts DC

LA302DC for 0-500 Volts DC

LA602 for 0-600 Volts AC

LA302R for 0-300 Volts AC

Conduction Characteristics

8 x 20 microsecond wave shape

Discharge Current	5000 Amps	10000 Amps	20000 Amps	40000 Amps	60000 Amps
Clamping Voltage (Line to Neutral)	240 Volts	480 Volts	840 Volts	1300 Volts	2000 Volts

DELTA LIGHTNING ARRESTORS,™ INC.

P. O. BOX 750
BIG SPRING, TX 79721
432-267-1000
www.deltalight.com
deltalight@msn.com

1 DC LIGHTNING ARRESTOR LA-602 (TYP OF 2)
NO SCALE


2 UNIRAC BILL OF MATERIALS
NO SCALE

PLUG CONNECTORS


Female and male cable coupler MC4

Female and male cable coupler as individual part with open crimp contact (including insulating part)

PV-KBT4...



PV-KST4...



Assembly Instructions MA231
www.staubli.com/electrical

Sealing caps page 49
Assembly tools page 54

10 Photocable main cording

5 FEMALE AND MALE CABLE COUPLERS (TYP.)
NO SCALE

DETAILED PARTS DESCRIPTION

QTY

Ballast Block	UserSupplied-HalfBlock	BALLAST HALF BLOCK	147
Ballast Block	UserSupplied	BALLAST BLOCK	405
Ballast Bay	370010	RM10 EVO FIELD BAY	153
Ballast Bay	370011	RM10 EVO NORTH ROW BAY	13
Clamp	370023	EVO MOD CLAMP BULK	604
RM Hex Bolt	370022	EVO MOD CLAMP SIDE BOLT BULK	604
Attachment	310999	FLASHLOC RM KIT	4
Attachment	310771	RM10 ATTACHMENT KIT	4

Page 3 of 28

3 UNIRAC DETAILED PARTS DESCRIPTION
NO SCALE

Mid support kit	370030	MID SUPPORT	32
RM Roof Pad	310760	RM ROOF PAD	178
Grounding Lug	008009P	ILSCO LAY IN LUG(BL4DBT)	1


NOTE: Designing on a "blank page" in the U-Builder design tool may not provide accurate wind engineering results because the roof outline is not provided. It is the user's responsibility to verify building dimensions, site criteria, array distance from roof edges. When designing a construction-ready project, it is always recommended to "Design On Map".

NOTE: Mid support required for (modules larger than 87" and snow load higher than 20 psf) or snow load higher than 60 psf.

Roof Area 1 - Array 1 : Seismic attachments added as risk category is 4.

Page 8 of 28

Roof Area 1 - Array 1 - Ballast Map with Attachment



LEGEND

- Module
- Standard corner bay with CMU block count
- Supplemental bay with CMU block count









NOTE

Blocks above with values greater than 4 require extra ballast bays, except north-most bays which require extra bays for values greater than 6. The proper number of bays are provided in the Bill of Materials. The installer must install these extra bays as near to the indicated location as possible.

Install 2 roof pads to every primary bay.

Page 8 of 28

4 BALLAST MAP
NO SCALE



CITY OF THORNTON
FIRE STATION #8
15343 MONACO STREET
THORNTON, COLORADO 80606

[illegible]

ISSUE DATE: 2024 0927

Sheet Name:
**PV SYSTEM
CUTSHEETS
ADD ALTERNATE**

Page #:

E 3.2



REVISION NAME	DATE


ISSUE DATE: 2024 0927

Sheet Name:
PV SYSTEM
CUTSHEETS
ADD ALTERNATE

Page #:

E 3.3

ASSEMBLY # TABLE	
P/N	DESCRIPTION
310771	RM10 ATTACHMENT KIT



ATTACHMENT PARTS LIST			
ITEM	QTY	PART NUMBER	DESCRIPTION
1	2	M30304	3/8-16 X 3/4 HEX BOLT, SS
2	2	M31184	3/8-16 HEX FLANGE NUT, SS
3	4	M31130	3/8 WASHER, SS
4	2	M30383	3/8-16 STRUT NUT, ZN
5	1	M40600	1 5/8 X 1 5/8 X 24 IN STRUT, GALV




PRODUCT LINE:	RM10 EVO
DRAWING TYPE:	ASSEMBLY
DESCRIPTION:	RM10 ATTACHMENT KIT
REVISION DATE:	12/10/2021

DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL
PRODUCT PROTECTED BY ONE OR MORE US PATENTS
LEGAL NOTICE

EVO-A09
SHEET

- NOTES:
1. ATTACHMENT CAN ACCOMMODATE ROOFING SCREW SIZES #12 - #15. FASTENER SIZE, LENGTH, AND QUANTITY TO BE SELECTED BY STRUCTURAL ENGINEER OF RECORD WHEN DESIGNING FOR THE SPECIFIC PROJECT CONSTRUCTION AND CAPACITY.
2. REFER TO THE UNIRAC INSTALLATION GUIDE FOR PROPER USE OF CHEM LINK M1 AND ONE-PART SEALANTS FOR WATER TIGHT INSTALLATION.



PART # TABLE	
P/N	DESCRIPTION
310999	FLASHLOC RM KIT

ULTIMATE TEST LOAD (WITH 8 ROOF FASTENERS)	
UPLIFT ULTIMATE CAPACITY	6,670 lbs.
SHEAR ULTIMATE CAPACITY	5,760 lbs.




PRODUCT LINE:	RM10 EVO
DRAWING TYPE:	ASSEMBLY DETAIL
DESCRIPTION:	FLASHLOC RM KIT
REVISION DATE:	12/10/2021

DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL
PRODUCT PROTECTED BY ONE OR MORE US PATENTS
LEGAL NOTICE

EVO-A10
SHEET

ASSEMBLY # TABLE	
P/N	DESCRIPTION
370020	RM10 EVO MODULE CLAMP KIT




PRODUCT LINE:	RM10 EVO
DRAWING TYPE:	PARTS
DESCRIPTION:	MODULE CLIP PIN BOLT
REVISION DATE:	12/10/2021

DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL
PRODUCT PROTECTED BY ONE OR MORE US PATENTS
LEGAL NOTICE

EVO-A11
SHEET

PART # TABLE	
P/N	DESCRIPTION
310760	RM10 ROOF PAD



- NOTES:
1. MATERIAL: TPE 70 SHORE A; SANTOPRENE 201-73, ELASTOCON 2870 OR UNISOFT TPE ST-70A BK-2-01.
2. FINISH: BLACK



PRODUCT LINE:	RM10 EVO
DRAWING TYPE:	PART
DESCRIPTION:	RM10 ROOF PAD
REVISION DATE:	12/10/2021

DRAWING NOT TO SCALE ALL DIMENSIONS ARE NOMINAL
PRODUCT PROTECTED BY ONE OR MORE US PATENTS
LEGAL NOTICE

EVO-P01
SHEET

1 UNIRAC RM10 EVO DETAILS
NO SCALE



REVISION NAME	DATE

ISSUE DATE: 2024 0927

Sheet Name:
ELECTRICAL
LABELING
ADD ALTERNATE

Page #:

E 3.4

PV SYSTEM
DISCONNECT

1 LABEL (QUANTITY OF 1)
NO SCALE

WARNING!

ELECTRIC SHOCK HAZARD. DO NOT TOUCH
TERMINALS. TERMINALS ON BOTH THE LINE
AND LOAD SIDE MAY BE ENERGIZED IN THE
OPEN POSITION

2 LABEL (QUANTITY OF 4)
NO SCALE

WARNING!

INVERTER OUTPUT CONNECTION
PHOTOVOLTAIC ELECTRIC POWER SOURCE
EQUIPMENT IS BACKFED

MAX AC FULL CURRENT: 48A
OPERATING AC VOLTAGE: 480V

3 LABEL (QUANTITY OF 3)
NO SCALE

WARNING!

ELECTRIC SHOCK HAZARD
IF A GROUND FAULT IS INDICATED,
NORMALLY GROUNDED CONDUCTORS MAY
BE UNGROUNDED AND ENERGIZED

4 LABEL (QUANTITY OF 2)
NO SCALE

SOLAR PV DC CIRCUIT

NOTE:
PHOTOVOLTAIC CIRCUIT MARKING IS REQUIRED ON ALL DC CIRCUIT
CONDUIT, RACEWAYS, ENCLOSURES, CABLE ASSEMBLIES, AND
JUNCTION BOXES. MARKING SHALL BE PLACED EVERY 10 FEET, AT
TURNS, AND ABOVE AND/OR BELOW PENETRATIONS.

5 LABEL (QUANTITY AS REQUIRED)
NO SCALE

CAUTION: MULTIPLE SOURCES OF POWER
PV SYSTEM DISCONNECT AVAILABLE FOR
ISOLATION FROM UTILITY

6 LABEL (QUANTITY OF 1)
NO SCALE

CAUTION: SOLAR ELECTRIC SYSTEM
CONNECTED

7 LABEL (QUANTITY OF 3)
NO SCALE

INVERTER 1

MAX DC VOLTAGE: 603V

INVERTER 2

MAX DC VOLTAGE: 603V

8 LABEL (QUANTITY OF 1)
NO SCALE

SOLAR AC COMBINER
DO NOT ADD LOADS

9 LABEL (QUANTITY OF 1)
NO SCALE

SOLAR DATA MANAGER

10 LABEL (QUANTITY OF 1)
NO SCALE

PNL ACC


11 LABEL (QUANTITY OF 1)
NO SCALE

RAPID SHUTDOWN
SWITCH FOR
SOLAR PV SYSTEM

12 LABEL (QUANTITY OF 1)
NO SCALE

SOLAR PV SYSTEM EQUIPPED
WITH RAPID SHUTDOWN

TURN RAPID SHUTDOWN
SWITCH TO THE "OFF"
POSITION TO SHUT DOWN
PV SYSTEM AND REDUCE
SHOCK HAZARD IN THE
ARRAY



13 LABEL (QUANTITY OF 1)
NO SCALE