## R2 Reasonable Potential Tool Parameter Report

Compiled on 26 March, 2025

## PR0024163 - 001: Temperature, water deg. centigrade

Evaluated from 2020-03-31 to 2025-01-31

FACILITY INFORMATION:

PRASA HATILLO WTP

STATE ROAD 2, KM 88.9

HATILLO, PR

**SUMMARY STATISTICS:** 

Number of Samples: 59

Min: 23.6 NA

Mean: 25.67 NA

Max: 27.9 NA

WQS - SB: NA NA

WQS - SD: NA NA

RWC: 28.49 NA

## RECEIVING WATER CONCENTRATION CALCULATIONS

## assuming a 95% confidence level and a 95% probability basis

calculations from 1991 Technical Support Document pgs 51-55

Number of samples = n

Maximum effluent concentration = max

Dilution Ratio = DR

Coefficient of Variation (CV) =  $S_n/\mu$  or 0.6 when n < 10

Z-statistic =  $Z_x$ 

Reasonable Potential Multiplier (RPM) =  $\frac{exp(Z_{95} \ln(1 + CV^2)^{0.5} - 0.5 \ln(1 + CV^2))}{exp(Z_x \ln(1 + CV^2)^{0.5} - 0.5 \ln(1 + CV^2))}$ 

Receiving Water Concentration = max \* RPM/Dilution Ratio

n = 59

max=27.9

DR = 1

CV = 0.04

 $Z_{95} = 1.645$ 

 $Z_x = 1.084$ 

$$RPM = \frac{exp(1.645\ln(1+0.04^2)^{0.5}-0.5\ln(1+0.04^2))}{exp(1.084\ln(1+0.04^2)^{0.5}-0.5\ln(1+0.04^2))}$$

= 1.02

RWC = 27.9 \* 1.02/1

= 28.49