

NUCOR

Nucor Steel Decatur, LLC
4301 Iverson Blvd.
Trinity, AL 35673

Phone: 1-866-825-3239
Email: nsd-mtr-inquiries@nucor.com

METALLURGICAL TEST REPORT

Load Number: F190528
Certificate Number: 1155155
Date Printed: 05/04/2026 13:39
Total Wgt: 45,420 lbs

Page: 1 of 2

Customer Name: D-MAC IND INC
Address: 1880 D-MAC DR

ALPHARETTA GA 30004

Customer PO #: 0008363

Order Number: 410400 - 0005
Order Dimensions: 0.0312 in MIN X 58.8750 in MIN, CUT
Product: GALVANIZED COLD ROLL COILED STEEL

Spec: ASTM A653 SS Grade 80 Class 3
Tensile test per ASTM A370; Fig 3 sheet-type 2" gauge length
G165, CT, DRY - No Oil

Spec Rev: 25a

CHEMISTRY ANALYSIS

Coil Num/Wgt	Heat	Slab	C	Mn	P	S	Si	Cu	Sn	Ni	Cr	Mo	Al	N	V	Nb	Ti	B	Ca
5547712.901	NR1338	07	0.05	0.19	0.008	0.001	0.025	0.10	0.002	0.03	0.05	0.01	0.028	0.0051	0.002	0.002	0.000	0.0001	0.0014
22,920 lbs		TUNDISH																	

Test Description	Test Result	Tested Heat / Slab / Gauge(in)	Sample Type	Direction
Yield Strength - lower	97.8 ksi / 674 MPa		ASTM	Long
Tensile Strength	99.8 ksi / 688 MPa		ASTM	Long
Total Elongation (2")	11.4 %		ASTM	Long
Coating Weight Top Average	0.932 oz/ft2 / 284 g/m2			
Coating Weight Bottom Average	0.931 oz/ft2 / 284 g/m2			
Coating Weight Grand Total	1.863 oz/ft2 / 568 g/m2			

WE HEREBY CERTIFY THE ABOVE IS CORRECT AS CONTAINED IN THE RECORDS OF THE CORPORATION.
MATERIAL ABOVE IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE REFERENCED SPECIFICATION/PRODUCT STANDARDS.
MELTED AND ROLLED IN THE USA. MADE IN THE USA. CERTIFICATE ISSUED IN ACCORDANCE WITH EN 10204 3.1.

Matt Silberberg

Matt Silberberg, PLANT METALLURGIST



Metallurgical Certification

Invoice To: D-MAC Industries Incorporated
1880 D-MAC Drive
Alpharetta, GA 30004

Ship To: D-MAC Industries Incorporated
D-MAC Industries INC.
1880 D-MAC Drive
Alpharetta, GA 30004

Date: 5/28/2026
Customer No: 32770
Customer P.O.: 0008429

Mill Order No: 312875-3 **Customer Reference No:** NA **Load No:** 1092371

This product was melted and manufactured in the USA to meet the requirements of: ASTM A653 SS Grade 50 Class 1
PGL-HR Galvanized Cut Edge-G165, CT, Oiled

Coil Number(s): 2031307-1, 2031307-2 **Ordered Size:** Min 0.1020 (In.) X 52.13 (In.) X Coil
Min 2.5908 (mm) X 1324 (mm) X Coil

Nucor Steel Gallatin Laboratories are ISO 17025 Accredited. Certificate available upon request.

CHEMICAL ANALYSIS (Weight %)

Heat No	C	Mn	P	S	Si	Cu	Ni	Cr	Mo
AC0056	0.19	0.48	0.010	0.002	0.02	0.11	0.03	0.05	0.01
	Al	Ca	Nb	V	B	Ti	N	Sn	
	0.029	0.0015	0.000	0.002	0.0001	0.001	0.0080	0.004	

MECHANICAL PROPERTIES

Coil Tested	2031307								
Yield Strength(ksi)	61.3								
Yield Strength(mpa)	423								
Tensile Strength(ksi)	78.7								
Tensile Strength(mpa)	543								
% Elongation	23								
Uniform Elongation	11.8								
N-Value	0.12								
N-Value Range	10-EUE								
Hardness(HRBW)***									
Test Section	Other								
Orientation	Long								
Test Method	ASTM								
Test Date	05/28/2026								

GALVANIZATION - Coating Weight Average (excluded from ISO 17025 accreditation)

Coil ID #	Top oz/ft2	Bottom oz/ft2	Top g/m2	Bottom g/m2	Coil ID #	Top oz/ft2	Bottom oz/ft2	Top g/m2	Bottom g/m2
2031307-1	0.89	0.90	270.87	275.42					
2031307-2	0.86	0.88	261.19	267.66					

The above tests apply to the sample as received.

The above tests were performed in accordance with EN 10204 3.1.

Hot rolled coils manufactured through Nucor Steel Gallatin do not contain welds or weld repairs at the time of shipment (FCA mill).

The above tests were performed in accordance with ASTM standards A370 and E8 (yield strength was determined using the 0.2% offset method and elongation was determined using the at fracture method), or JIS Z2241, ASTM E18, ASTM E415, and ASTM E1019 and are correct as contained in the records of the company.

The decision rule for conformance to the specification or requirements is based on simple acceptance.

This report shall not be reproduced, except in full, without written approval of the undersigned laboratory supervisor or manager.

** This mechanical property has been tested at a subcontractor's laboratory.

*** This test is excluded from ISO 17025 accreditation.

Matt Holt

Matt Holt
Lab Supervisor

matt.holt@nucor.com

The information contained in this report may be confidential information intended only for the use of the individual or entity named above. If the reader of this message is not the intended recipient, you are hereby notified that any dissemination, distribution, or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by telephone and destroy the original message. Thank You.