

# Distance Protection Zone 3 Misoperation During System Wide Cascading Events: The Problem and a Survey of Solutions

A.M. Abdullah<sup>a,\*</sup>, K. Butler-Purphy<sup>b</sup>

<sup>a</sup>*Department of Electrical Power and Machines, Cairo University, Gizah, Egypt, 12613*

<sup>b</sup>*Department of Electrical and Computer Engineering, Texas A&M University, College Station, TX, 77843*

---

## Abstract

Distance relay zone 3 misoperation has been responsible for major blackouts around the world. Zone 3 misoperation generally occurs under system wide cascading events such as the 2003 Northeastern US-Canada blackout or under stressed system conditions such as the 2015 Turkish blackout. This paper explains the problem of zone 3 distance protection misoperation. The paper then proceeds to survey the literature for possible solutions to increase distance relay security to prevent distance protection misoperation. Three categories of solutions were proposed in literature to address the problem of zone 3 distance protection misoperation. The first one is anticipation and prevention of misoperation in the planning stage. The second one is communication assisted protection schemes that use remote measurements to enhance relay security. The last one uses local data to enhance distance relay security.

*Keywords:* Distance protection zone 3, blackouts, cascading events, misoperation, security

---

## 1. Introduction

With the deregulated market structure in the United States and Europe, grid operators are under more pressure to reap more profits of existing infrastructure due to increased competition. The grid is thus increasingly operated near the threshold of stability. Failure of the grid, better known as blackouts, carries catastrophic economic and societal sequences. Large blackouts tend to be due to either extreme natural events such as hurricanes or a series of events called cascading failures [1]. In this paper, we only focus on cascading events. Those events can be any of the following: line tripping, overloading of other lines,

---

\*Corresponding author

Email addresses: [ahmad.abdullah@cu.edu.eg](mailto:ahmad.abdullah@cu.edu.eg) (A.M. Abdullah), [klbutler@tamu.edu](mailto:klbutler@tamu.edu) (K. Butler-Purphy)

malfunctions of protection systems, power oscillations and voltage instability [2]. The reason that is considered in this paper is distance protection misoperation which is a contributing factor in seventy percent of all cascading events [3]. If not discovered and mitigated in an early stage, cascading events generally lead to a complete blackout. With today's society much dependence on electricity as a form of energy, preventing such damage is of high importance.

Cascading failures are defined as "a sequence of dependent failures of individual components that successively weaken the power system" [4]. Since the 2003 US-Canada blackout, cascading events have drawn much attention in the industrial and academic community. Even though the world has witnessed many blackouts prior to the 2003 blackout [1], the dramatic causes and consequences of the 2003 blackout have left industrial and academic community with the burden of exploring this phenomenon in more detail. To understand the severity of the 2003 blackout [5], it is sufficient to say it had caused the loss of 62 GW which caused the lights to turn off for more than 51 million people in the eastern interconnection. Considering the many components and the bits and pieces involved, a domino effect of events evolved slowly (hours) or fast (seconds) according to the region causing a degradation of the integrity of the system leading ultimately to a complete blackout. The main reason of the 2003 blackout was distance relay misoperation. Daunting efforts had to be exerted to gain more knowledge and understanding of the underlying phenomenon.

Relays by design act quickly to remove the fault from the system by disconnecting faulted lines. However, sometimes relays fail to perform such function which is considered a protection system misoperation. Of all protection system misoperations that lead to cascading events, this paper focuses exclusively on distance protection misoperation. A protection system misoperation is defined as "a failure to operate as intended for protection purposes" [6]. Various categories are given for misoperation in [6]. However, in this paper the word misoperation will be used exclusively to mean only one of them, namely, an operation in which a protection system trips a healthy line due to heavy loading when no fault exists. In other words, other causes of distance protection misoperation such as power swing are not considered in this paper. Notable cascading events [2, 7] begin with lines that were tripped due to actual faults. The tripping of those faulty line causes the current flowing in those lines to be redistributed to adjacent lines. Those lines may be overloaded and thus tripped incorrectly - protection misoperation- which may trigger a sequence of cascading events that might ultimately lead to a blackout. It should be noted that regardless of the initial triggering events- whether a fault or not- that cause cascading events, historically those cascading events were triggered under stressful system conditions [5, 8].

As mentioned in [2], one of the effective ways to prevent cascading events is to specify potential undesirable relay operations ahead of time. In this paper, we show that even though distance protection misoperation can be anticipated ahead of time, prevention of this misoperation is not possible with distance protection principle only because the distance protection principle is not able to be selective in some regions of its operation.

The paper is organized as follows: Section (2) provides a sample distance relay that is set according to NERC standards. Once this relay is set according to NERC directives, it will be explained in the same section that the relay may still misoperate under various operating conditions. Anticipation and detection of distance relay misoperation in the planning stage is described Section 3. Section 4 provides an overview of the communication assisted schemes that have been proposed to eliminate the distance protection misoperation. Lastly, Section 5 offers a survey on the methods that were suggested in literature to enhance the distance protection security using local data only.

## 2. The Distance Protection Misoperation Problem

On August 14th of 2003 [5], the US eastern interconnection suffered one of the largest blackouts in the recent US history. Three 345 kV transmission lines sagged into untrimmed trees during the hot summer days. The tripping of those lines caused another 345 kV transmission line to carry substantial system load. The heavy loading of this last line coupled with relatively low system voltage, caused the distance relay to confuse a heavy loading situation for uncleared zone 3 fault as the impedance entered the third zone of protection which in turn resulted in tripping of the heavily loaded line. The tripping of the healthy yet heavily loaded line worsened system conditions leading to a chain of events that ultimately led to system collapse. Also, on March 31st of 2015 [9], the Turkish grid suffered the worst blackout ever recorded since 1999 when an earthquake caused a complete shutdown of the grid. On the contrary to the 1999 earthquake, the 2015 blackout was caused by a impedance protection misoperation that tripped a heavily loaded line on the 400 kV transmission level even though there was no fault on the tripped line or anywhere in the transmission network. As can be seen from the examples in [5, 9] in which distance protection misoperation have been the main cause of the blackouts or in [10] in which distance protection misoperation have been studied in the IEEE 118 bus system, a distance protection misoperation is characterized by a distance protection system seeing a heavy load on a line as a fault. This confusion arises from the fact that the impedance measured by the impedance protection system coincides with that of a fault. The reason for the heavy load can be due to load shifting after a fault as in the 2003 US-Canada blackout [5] or due to lines out of service for maintenance causing one line to carry substantial system power transfer as in the 2015 Turkish blackout [9] or due to any unforeseen reasons.

To illustrate that this confusion is not tied up with certain system conditions but rather inherent insecurity in the distance protection principle, the single line diagram shown in Figure 1 is used to formulate the problem in general terms. It will be shown below that this insecurity always exists and the degraded system conditions only excite it; that is, for some regions in the impedance protection zone the protection system is not able to be selective between a fault and non-fault condition. Without the degraded system conditions, it is highly unlikely that a distance protection misoperates. Even though, degraded system conditions can be anticipated in the planning stage, the system operator will have

nothing in hand to prevent a distance protection misoperation if local function of the distance protection is used alone. It is important to keep in mind that distance protection systems are set locally with the help of the impedance of adjacent lines without any information about the system load until the coordination study phase. In the coordination study phase, the transmission line owner checks all settings against applicable standards. This is explained in detail in [11]. In the following paragraphs, we will set up the relay settings first then discuss what happens in system wide cascading events.

In Figure 1, the distance protection relay that will be studied is the relay at point A of line A-C. Line A-C is connected to three (3) lines, namely C-M, C-N and C-P. The number of lines connected to line A-C will not affect zone 1 or zone 2 settings but will affect zone 3 settings. As will be seen below, tripping in Zone 3 becomes more insecure with more lines connected to line A-C as zone 3 reach becomes larger. To simplify the analysis, all lines are assumed to have the same impedance as well as the short circuit level. However, as will be explained below, this simplification does not affect the generality of the problem formulation. The impedance and the rating of the lines are  $60 \Omega$  and 3000 Amp, respectively and are taken from [12]. The setting of zone 1 is assumed to be 0.85 of the line impedance. Zone 2 setting is assumed to be 1.2 of the line impedance. However, some consideration is needed to set the third zone. The third zone has to be set such that it can protect the longest adjacent line (assumed to be line C-P in this case) and to protect 20% beyond that line to provide backup to the remote circuit breakers. In case of a bolted three phase fault on line C-P and assuming that the short circuit contributions of all buses is given in Figure 1 by  $I_{index}$  where *index* is the bus name (being M, N, A or P), the voltage at distance protection system at A can be written as given in equation (1).




Figure 1: System Configuration for formulating the problem

$$V_A = I_A \times Z_A + Z_P \times (I_M + I_A + I_N) \quad (1)$$

The impedance that is seen by the relay A can then be written as in (2)

$$Z_R = \frac{V_A}{I_A} = Z_A + Z_P \left( 1 + \frac{I_M + I_N}{I_A} \right) \quad (2)$$

Equation (2) will only be applicable to faults on line C-P, if we need to include 20% for the line that is beyond bus P, then the impedance  $Z_P$  in (2)

has be replaced by  $1.2 \times Z_P$ . Using the data in [12] and assuming all lines are identical as well as their short circuit contribution, then the setting of zone 3 will be  $Z_A + 3.6 \times Z_P = 4.6 \times Z_A$ . The three zones are plotted in Figure 2.




Figure 2: Distance protection characteristic for system in Figure 1

After setting up the relay locally, applicable standards and directives need to be applied to the settings for compliance purposes. This step involves running worst case power flow in the summer peak case. The most notable directive is the load encroachment. The load encroachment zone is an area of the protection zone in which the load impedance “encroaches” –intrudes– upon the fault impedance. Load encroachment will obviously cause misoperation and should be removed from the zone of protection [12]. To plot the load encroachment zone according to NERC directives [6, 12, 13], the load zone should include the point which corresponds to 150% line loading and 0.85 per unit voltage. Thus the load encroachment locus of the distance relay at A will consist of two parts. The first part will be an arc of circle of radius given in equation (3) which is given as arc **RIT** in Figure 1. This arc **RIT** corresponds to the least impedance that the relay should not issue a trip command for. The other characteristic load lines will be two lines making an angle of  $\pm 30^\circ$  with the x-axis ( $\pm 30^\circ$  represents the power factor of the line under worst case loading condition)

$$Z_{load} = \frac{V_A}{I_A} = \frac{\frac{345kV}{\sqrt{3}} \times 0.85}{1.5 \times 3000} = 57\Omega \quad (3)$$

The orange hashed area **RLQT** is the load encroachment area. NERC directives [6, 12, 13] states that this load encroachment zone has to be removed from the relay operating zone. It can be seen at once that if the impedance seen by the relay lies within the solid green area **URI** then a relay may confuse this operating point for a fault since the point lies already in zone 3. This confusion arises if the fault resistance is high enough to cause the fault point to lie within the solid green area **URI**. In Figure 2, this fault resistance ranges from  $30\Omega$  to  $90\Omega$ . The fault resistance can be obtained by measuring the distance between the diameter **AB** of zone 3 circle to point **R** and **U** of the green zone. If it is known in advance that the fault resistance calculated cannot be attained along the route of the transmission line, then the risk of misoperation is nonexistence and the green area can be removed from zone 3 without affecting the security or reliability of the distance protection system. However, fault resistance along the route of the transmission line is not known in advance. Also, one should note that solid state and electromechanical relays cannot be programmed, only microprocessor relays can. This really means that older relays will have to comply with NERC standards by disabling zone 3 altogether. It is shown in [14] that disabling zone 3 in some cases will force protection engineers to provide back up protection solutions to remote circuit breakers. This might involve a considerable cost. Additionally, not all countries around the world have standards as strict as NERC, so the solid green area **URI** exist in the zone of protection without regard from the protection engineer. Lastly, even if the relay complies with NERC directives, an impedance can still fall anywhere in zone 3, not only the solid green area **URI**, under stressed system conditions as Phadke and Horowitz pointed out in their paper [14]. This shows clearly the impedance protection is inherently insecure under stressed system conditions.

Attention is now given to the assumptions stated in the beginning. It was assumed that all lines have the same impedance and all of them are contributing equal currents to the fault. It can be seen at once from Figure 2 that this assumption is not restricting the generality of the problem formulation. Because in any case the green area **URI** will exist due to the load profile under stressed conditions. Additionally, the fault contribution of the transmission lines will only affect the diameter **BA** of zone 3 which will only affect point **U**. Point **U** correspond to the max fault resistance. Stated differently, there will always be an overlap between the dynamic rating of the line and zone 3 and the short circuit levels from nearby lines will only affect the size of the overlap (area **URI**) not the overlap itself. Lastly, to derive equations (1) and (2), a three phase fault has been assumed. This is due to the fact that line overload is three phase phenomenon. However, it should not be hard to be able to envision a single line to ground fault causing the same effect if one important line is operated with only one phase due to a line to line fault under heavy loading conditions.

It should be apparent from the description above that the major issue that is faced by traditional impedance protection system is that the steady state impedance corresponding to a heavy load is coincident to the impedance under a fault on a remote line to which the distance protection system provides backup protection. It could be argued that impedance protection should be supervised by other steady state protection principles to enhance its selectivity, i.e., the ability to differentiate between a load and a fault current. However, other protection principles -such as over current protection- that can make the distinction between a load and a fault depend on the anticipated power flow for operation while the problem in hand is different. The confusion that is seen by the distance protection is because the power flow under system wide cascading failures changes considerably from the planned power flow. In other words, the load encroachment zone has to be set for system wide cascading scenarios that are not known in advance, which is close to impossible undertaking. One of the authors [14] states this fact as:

*"The overwhelming thrust of the NERC rules and other instructions regarding the application of zone 3 elements has been to prevent its operation during emergency conditions. Although this is a desirable goal, it should be recognized that even with all the intelligence available to modern computer relays, the problem of distinguishing a fault from a heavy load in a relatively short time and using only the current and voltage signals available to the relay cannot be solved in every single imaginable (and some unimaginable) power system scenarios".*

### **3. Detection and mitigation of zone 3 misoperation in the planning stage**

Most Independent System Operators (ISOs) [15, 16] today use N-1 criterion to judge whether the system is secure after the removal of one line in planning stage. However, given that zone 3 distance protection misoperation is not triggered until two or three lines go out of service [5], the distribution of power flow is hard to be taken into account in the planning stage as it would mean performing N-2 and N-3 contingency analysis which is expensive computationally. Thus, it is increasingly hard to assess protection system capability under the most stressful system conditions. Due to that, the authors in [17, 18] provided an efficient method to study the sensitivity of zone 3 under various operating conditions without the need for performing large number of power flow studies. In [17, 18], the authors define a linearized impedance margin of a distance relay using system voltages, injected power and shunt susceptance. The impedance margin is defined as the distance between the measured impedance locus in the R-X plane to the boundary of the operating characteristic of the relay and is shown in Figure 3. By doing so, the relays that may misoperate can be anticipated ahead of time in an efficient manner in the planning stage using simple formulas. However, it is shown in the paper that if the changes in the voltages or power injections are electrically far away from the relay under study, a situation that always exists in wide area cascading scenarios, the error in the analysis becomes unacceptable especially for long lines.




Figure 3: Impedance margin and impedance locus plot for a distance relay during a wide area cascading scenario

In [19], the authors propose blocking zone 3 of certain distance relays ahead of time based on offline simulations. The authors propose that the system operator perform contingency analysis using credible historical contingencies in planning stage to observe the impedance trajectory at each distance relay in the system. The contingency scenarios to be performed have to include more than one contingency to create an impedance trajectory. The relays that misoperate during each contingency scenario due to the impedance trajectory entering zone 3 when no fault conditions exist should be short listed. Of those relays that are short listed, certain relays are selected such that their zone 3 protection will be disabled. The relays that will be disabled are common to all contingency scenarios and are selected based on a specific criterion explained in the paper. However, the contingency scenarios can be hard to design in the planning stage for modern power systems that have thousands of buses. Additionally, disabling zone 3 effectively disables backup protection for remote circuit breaker which is a situation that should be avoided unless another form of backup is available.

The authors in [20] proposed certain indices that can accurately gauge the severity of system conditions and the likelihood of cascades in real time. An index that is used to monitor distance relays is also proposed. If the indices associated with the distance relays exceed their threshold, then distance protection misoperation is about to occur and the system operator has the option to stop



distance relays from operation. However, in practice only N-1 contingencies are studied and thus the severity index is chosen based on these cases. Nevertheless, if the system enters N-2 or N-3 contingency conditions, tuning of the “severity” threshold will be a difficult task computationally.

Lastly, distance protection co-ordination has been explored in [21, 22]. An SVM for each relay is trained using the impedance trajectory that is seen by the relay during fault conditions. The impedance trajectory is obtained by using a transient stability program. SVM is then trained for various scenarios to distinguish zone 1, zone 2 and zone 3 faults. Training scenarios include cases for different fault types at different distances away from the relay that has the SVM and at different fault resistances. Testing scenarios for SVM include faults that have not used in training. By ensuring that the relays are well co-ordinated under various contingency conditions, unnecessary trip could be avoided. However, the impedance trajectory will depend on the system topology at the time of fault occurrence and this has not been taken into consideration in [21, 22] which could lead to large offline training set.

Due to the fact that distance protection co-ordination requires large amount of offline simulations by performing many contingency conditions, the authors in [23] introduced the idea of “distance of impact” to automate the distance protection co-ordination. However, the authors use the super computer to perform their computations at the first stage. Once the distance of impact of each relay has been calculated, co-ordination of the distance relays becomes straight forward. A shortcoming of the distance co-ordination approach is that even though it can ensure that distance relays never overreach for faults beyond their reach, little research has been performed to study whether the co-ordination can ensure that relays will not misoperate under heavy loading conditions.

**As can be seen above, anticipation detection of distance protection misoperation in the planning stage is a hard task. To be able to fully prevent distance protection misoperation, an N-x, where x is greater than 1, contingency analysis need to be done. Even though this could be done for small benchmark systems, contingency analysis, under uncertain load and generation, is computationally intensive for large system consisting of thousands of buses. Many ISOs may not have access to supercomputers to run such intensive computations.**

#### 4. Communication Assisted Schemes

The 2003 blackouts pointed out the importance of having events along with the time they occurred. Investigators spent much of their time trying to match up the waveforms to reconstruct the sequence of events that led to the black-out. It was then apparent that to facilitate the transfer and comparison of waveforms, all samples need to have a time stamp for this purpose. Phasor Measurement Unit (PMU) or synchrophasor technology was then recommended to address this shortcoming [5]. By the time of 2003 blackout, state estimation was a very mature field, but PMUs opened new areas for the application of state estimation by reducing the time needed to do state estimation due to wide

spread deployment in the transmission network. A PMU measures the positive sequence voltage and current (both the magnitude and angle), which opens new areas for adaptive relaying and wide area control and protection. In typical distance protection schemes, the relay is only applied to a single transmission line. However, in a wide area protection scheme, a complete area (several transmission lines) can be protected using selected PMU devices without the need to apply PMUs to each single bus in the system. By transferring information in between PMUs in the power system, accurate decision regarding the nature of the impedance falling in zone 3 can be made and misoperation can be avoided.

With the introduction of PMUs, several fault detection and locations methods have been proposed. The salient feature of PMU detection schemes [24] is that using the communication links to transfer data between the two ends of the lines, several conclusions can be drawn regarding whether the line is undergoing abnormal conditions. A salient feature of the PMU algorithm is the ability to monitor the status of the line and compute the parameters of the line online in a very accurate way.

Due to the fact that zone 3 of distance relays may not be able differentiate between heavy line load and an actual fault on the system, the authors in [25] proposed that a tool be installed at the control center, also known as Independent System Operator (ISO), to continuously supervise the operation of zone 3 elements. The tool will consist of two modules, a central control unit (CCU) and several regional control units (RCUs). The CCU will be installed in the ISO while the RCUs will be installed at select individual substations. The CCU measures the line outage distribution factors and generation shift factors for the entire power grid and sends all factors to the individual RCUs. RCUs use local measurements at the substation and communicate with one another. The individual RCUs will differentiate between faults and transfer of power flow and supervise distance relays based on the information received from the CCU and other RCUs. Even though this solution might be able to prevent all zone-3 misoperations, it needs considerable cost to construct the communication infrastructure that is needed to transmit the data between the individual substation and the ISO.

The authors in [26] uses synchronized samples from both ends of the line to check whether the transmission line has been tripped successfully or not. The instantaneous power from both line ends are calculated. It is shown in the paper that after fault inception, the instantaneous power at both ends becomes positive. This hold true even under systems with weak infeed. The method is applicable to all systems other than radial systems. However, due to the need to transfer data between both ends, significant cost may be incurred to establish such algorithm across each transmission line in the grid. The approach that has been proposed in [26] has been validated using field data in [27].

In [28], distributed PMUs are used to reach a definitive decision about the existence of the fault in the system using a synchrophasor state estimator (SynSE). The SynSE is used to detect network topology changes as well as determine the fault locations as shown in Figure 4. However, the grid has to be completely observable by PMUs. Thus, siting PMUs has to be done carefully to not create

unobservable islands under stressed system conditions and certain contingency conditions.




Figure 4: Protection logic of the paper in [28]

In [29] synchrophasors are proposed to supervise zone 3 operation. Specific indices are proposed to assert the fault using the currents which result in a very robust zone 3 distance protection system. The algorithm forms a super node from the certain groups of PMUs. By summing the current going into the super node, a decision can be reached whether a disturbance exists or not. If a disturbance is detected, another logic is invoked to determine whether it is a fault for the group of PMUs with the higher deviation. The logic that is invoked after disturbance detection is impedance based. A weighted fault detection index is defined for this purpose. The weights used to define the index depend on the reach of the respective zone 3 distance protection relay. If after disturbance detection, the weighted fault index is exceeded, a fault in zone 3 is declared and the relay is restrained from operation. However, to fully take advantage of the method, strategically located PMUs have to exist in the system which makes the approach highly dependent on the topology and any transmission system upgrades. Additionally, certain contingency conditions can cause some faults not to be detected due to the location of the PMUs.

In [30], agents are used to aid zone 3 relay elements without enforcing a decision. In this scheme, each impedance relay will have the capability to communicate with other agents in the network that protect the same transmission line. If the majority of the agents informs the local distance relay that the impedance in its zone 3 reach is actually due to a fault, then the local distance relay should be energized and a trip command has to be issued. An optimization approach is set up such that the communication delay between the various agents are less than 1 second, which is the time of operation of zone 3. A similar approach has been proposed in [31] where agents are installed everywhere without the optimization approach.

In [32], a limited number of PMUs are used to determine the faulted line as well as the location of the fault. An optimization approach is used to locate a set of PMUs such that the observability is independent of the generator models. A backup protection zone is then constructed using the lines and buses between each PMU such that a line is not included in two regions. The sum of zero and positive sequence currents are used as discriminant for fault detection and location. If the sum is not zero then the area will be flagged as having a fault. Next comes the task of identifying the faulted line. For the area that is flagged as having a fault, a distance quantity will be calculated for each line within the area, i.e., each line will be assumed faulted and a distance quantity will be calculated. If the distance quantity falls between 0 to 1 then the faulted line will be determined. If more than one line is found to be faulted, an estimation of relative residual error is made and the line with the minimum residual error will be selected as the faulted line. It is clear from this description that two faults within any protected zone or cross country faults will be detected as one fault only. And even though one of the two faults may have not been cleared, the algorithm may not be able to detect such situation.

In [33], a backup wide area protection scheme is proposed. Short window DFT is used to extract the phasor information from the three phase voltages and currents. In this scheme, the absolute difference of the bus angles and currents are used to detect the fault. The minimum voltage magnitude establishes the closest bus to the fault and the maximum current angle difference between the buses establishes the faulted lines. However, for the method to work, the minimum voltage threshold has to be established. It is shown in the paper that a voltage threshold less than 0.95 means that there is a fault on a system. This immediately points out that in case of voltage instability conditions, the method can operate erroneously.

In [34], another wide area protection scheme is proposed. The solution consists of two components: a fault element identification (FEI) and a fault area detection (FAD). The FEI is used to identify the faulted element in the zone being protected. After that, the fault isolation is realized by coordination among area circuit breakers. As part of the FEI, the measured voltage and current of one terminal of the protected area are used to estimate the voltages at the other end. If an internal fault occurs within the zone being monitored, then the estimated value will be different from the measured value at that bus causing a fault to be detected. On the other hand, the faulted area is detected through FAD. The substations that are within the faulted area need to send the information to the central control room. Afterwards, the central control room will search the suspected faulty lines and identify actual faulty lines quickly. The use of FAD concept reduces the communication overhead required by the scheme.

The authors in [35] use PMUs, that are in place as part of a wide area protection scheme, to detect the power flow transfer due to the removal of faulted line from service. In [35], the load flow transfer to a line can be calculated using the network topology via the distribution factors. If the measured power flow transfer significantly mismatches the calculated power flow transfer, then a

fault will be declared. Based on that detection, zone 3 is adaptively adjusted to prevent misoperation which eliminate distance protection zone 3 misoperation.

**Even though PMU based schemes and wide-area based schemes can offer attractive solutions to eliminate the problem of distance protection misoperation, these solutions require significant communication infrastructure cost. Additionally, the power grid is a critical infrastructure and the cybersecurity risk may be eminent if the grid is brought online for communications purposes.**

## 5. Modifications to Local Distance Protection

In addition to using PMUs for fault detection and assisting zone 3 tripping, various authors proposed making changes to the way impedance relays operate. In these methods, the authors proposed additional criteria to assist distance protection in order to assert that fault exists within the relay reach using local data.

Local measurements are used in [36] to assist zone-3 tripping. The authors proposed to distinguish three phase faults from system overloads. The DC decaying component and the line load angle are used to determine whether a fault has occurred within the reach of local distance relay. The DC decaying fault component is reconstructed from the measured currents in all three phases. Since the fault is three phase, a DC decaying component must exist in one of the phases. A transient monitoring function will then be defined to be the maximum of all three phases DC decaying components in one cycle. Also, for the three phase to be asserted, the line load angle has to be greater than 50 degrees. Both the monitoring function as well as the line load angle has to be true for a three phase fault to be declared. The drawback of this method is that the fault must have significant decaying DC component which makes it challenging for certain fault incipient angles and transmission line lengths as a significant decaying DC component can only occur when the fault occurs at certain incipient angles and under certain X/R ratios. Additionally, the paper assumes the angle between the current and the voltage at the relay to be more than 50 degrees as a fault indicator. However, it has been pointed out in [14] that under stressed system conditions the angle may indeed exceed that threshold with no fault on the system. Also, if the swing frequency in the system is anticipated to be larger than 5 Hz, threshold selection for transient monitoring becomes a hard task which could mislead the scheme to confuse power system swing for three phase faults. Lastly, the effect of fault resistance has not been studied in the paper. Fault resistance can potentially cause trouble setting the threshold for the transient monitoring function as it affects the DC decaying component.

In [37] the rate of change of voltage is used as a trip restraint to supervise distance protection misoperation. The idea is that fault occurrence or fault clearing causes the voltage seen by the relay to change drastically. The authors propose if the local relay senses that the system voltage is stressed according to the conditions listed in [38], the rate of voltage change ( $\Delta V/\Delta t$ ) will be used

to assert whether a fault has occurred and cleared within zone 3 protection using two thresholds for both fault occurrence and fault clearing. Additionally, the authors proposed to use a thermal loading monitoring function to decide whether the maximum conductor temperature has been reached. The temperature monitoring function will start operation after the fault has been detected. If the temperature monitoring function declares that the line temperature has reached maximum limit, the line will be tripped whether the fault has been cleared or not. However, for the trip command to be secure, large amount of offline simulations need to be carried out to know the worst case rate of change of voltage. The major disadvantage of the method is that under voltage instability, the  $(\Delta V/\Delta t)$  criterion is not exclusive property for faults as pointed in [39] since under voltage instability, a sudden generator tripping could cause the same  $(\Delta V/\Delta t)$ .

Since it is hard to distinguish between evolving pre-blackout event and short circuit conditions using magnitude of voltage, another trip restraint quantity, namely  $(\Delta I/\Delta V)$  has been used along with  $(\Delta V/\Delta t)$  criterion to trip zone 3 securely in [39]. The  $(\Delta I/\Delta V)$  threshold value has also been obtained using offline simulations. The disadvantage of the method in [39] is that neither contingency analysis nor system loading levels have been taken into consideration.

The use of fault generated high frequency components has also been investigated in literature [40]. Such usage can give a more precise answer whether a fault has occurred thus making tripping in zone 3 more secure. In [41], the energy of the first three current levels and the third approximation is used to train a probabilistic classifier. The energy is calculated using certain levels of the discrete wavelet transform of the three phase currents. Using this energy features, a decision is made whether a transient signal is due to a fault or non-fault condition on a line. A simpler online transient classifier has been proposed in [42], where the transient events occurring on the transmission lines nearby any distance relay are identified. Modal transformation is used to transform the phase currents into modal currents. The discrete wavelet transform coefficients of the aerial modes [43] are combined in a certain manner to train a feedforward neural network to classify those transients. However, the major drawbacks of both [41] and [42] is that they cannot be used to tell whether the fault is within the relay protection reach even though they can tell whether a fault has occurred in the network. These papers can only be useful if a method is found to use the transient classification as an entrance point to determining whether the fault is within the protection reach of the relay but this has not been done in literature to the best of our knowledge.

Various adaptive zone 3 settings were also investigated in literature where zone 3 reach is adjusted based on local information. In [44, 45], ANN has been used to predict the correct load blinder under various system conditions. The load blinder is then combined with the zone 3 settings to block any undesirable tripping. The load blinder is only activated under balanced conditions to make sure that the heavy loading is not confused for unbalanced fault conditions. The load blinder is determined based on offline simulations. The simulations take into account the loading level of the power system, fault incipient angle, source

impedance ratio, fault resistance and fault location. The features used to train ANN is the active and reactive power, voltage as well as the rate of change of both the voltages and currents seen at the relay terminal as shown in Figure 5. A simple line connected to another line with a load in between is used to test the method which is a disadvantage of the method. Also, the effect of the system topology wasn't studied. It is also foreseen that the inclusion for contingency analysis in ANN training will require large offline simulations and will make load blinder selection difficult task. Additionally, only three phase fault currents has been used to train the ANN and in case a single line to ground fault occurs and cause the features to be different than the ones used in training, the method is expected to fail because ANN is known to have bad generalization capabilities [46].




Figure 5: Creation of adaptive load blinder in [45]

In [47, 48], the authors propose changing zone 3 reach during emergency conditions to prevent distance protection misoperation if certain system conditions are met. If those system conditions are met, zone 3 protection reach will be shrunk to zone 2 which in turn gives maximum security. During stressed system conditions, the impedance seen by the local relay approaches the original zone 3 border, whether this border is MHO characteristics or polygonal one. The authors propose to define a fourth protection zone, called third zone proximity area (TZPA), as well as a fifth protection zone, called third zone modification area (TZMA), to change zone 3 protection reach based on certain criteria. The TZMA is a region within TZPA but closer to zone 3 protection zone. The authors provided rules on how to set both TZMA and TZPA. Once the impedance enters this TZPA and crosses zone 3 fast enough, the fault will be declared. However, if the impedance enters TZPA and stays within TZPA, the TZMA logic will be put into action. Zone 3 protection will be shrunk to zone 2 if the

impedance crosses TZMA within a minute. This one minute is used to adjust for restorative corrective forces of the grid such as generator excitation controls and transformer load tap changer. In summary, zone 3 protection will only be changed if the impedance crosses TZMA with a certain rate within a specified time delay once it starts changing in TZPA. These ideas are illustrated in Figure 6. Although, the approach is very promising, a fast evolving system instability could mislead the scheme. Additionally, it can be seen that the approach proposed sacrifices dependability for security as evident by shrinking zone 3; if a fault occurs within the original zone 3 protection zone beyond the original zone 2 reach after zone 3 protection zone is shrunk, the approach proposed by the authors will rely heavily on the closest relay and circuit breaker to clear the fault. However, if this relay or circuit breaker fails to clear the fault, the fault will go uncleared worsening the already stressed system conditions. Lastly, the proposed algorithm will fail definitely in case the impedance stays within TZPA, suddenly jumps to original zone 3 due to zone 3 fault before the time delay expires then stays in zone 3 after fault clearing due to line heavy loading conditions.




Figure 6: TZMA and TZPA of the method in [47]



Lastly, the authors in [49] proposed to identify power flow overload based on a newly proposed concept. This concept is based on the phasor relationships in the complex phasor plane. The paper only differentiates between three phase faults and overloads as overloads are three phase balanced phenomenon. Since the paper only aims to distinguish three phase faults from overload, any three phase fault on a transmission line can be analyzed without the need of information from the other end of line. This is due to the fact that the arc voltage is not affected by the infeed fault current making the fault point grounded through the arc resistance. This property is used to derive the criterion to differentiate between three phase faults and overloads based on an impedance criterion that can be adaptively adjusted using the measured phase angle between the voltage and current at the relay location as well as a constant safety factor. However, the method is not applicable when a three phase fault occurs within the distance relay reach during an overload condition. Additionally, it is assumed that all three phase to ground faults involve arc without the consideration of the other situations when three phase downed conductors cause such faults which in turn could cause some of the assumptions used in deriving the impedance criterion to be invalid.

**In summary, the use of rate of change of voltages and currents can prevent the problem of distance protection misoperation in most occasions but does not fully prevent it. Other methods use previous operational experience with distance relays to propose solutions to the problem of distance protection misoperation. However, system conditions and scenarios that were not previously encountered could mislead those proposed solutions. The use of high frequency fault generated transients seems to be a promising area but it is scarcely researched in literature.**

## 6. Conclusion

The problem of distance protection misoperation has been presented. Various approaches to solve the problem have been surveyed and organized into three main categories. The methods in each category have been explained. Additionally, the advantages and disadvantages of each method have been pointed out.

The first category is anticipation of distance protection misoperation in the planning stage. In this category, distance protection misoperation could be anticipated day ahead based on the forecasted load and generation as well as contingency conditions. However, due to the large size of modern day power systems, such anticipation is computationally intensive.

The second category is communication assisted protection schemes. The main idea in this category is that using information from both ends of the line or information from various substations in the network, a blocking command can be issued to the affected distance relay. Nevertheless, these communication assisted protection schemes have not found wide industry acceptance due to

cybersecurity risks as well as the economic cost that is required to build such systems.

The third category is modification of the local distance protection function using local information. The main idea in this family of solutions is that using operational system experience as well as the local data, one can tell with certainty that a distance relay is about to misoperate. By detecting such conditions, a blocking command can be issued to guard the relay against misoperation. Nevertheless, the methods in this last category may fail under system conditions that were not taken into consideration while developing these methods.

The most appropriate method to mitigate zone 3 misoperation is dependent on what is the most important factor for the utility company. For example, one utility company may prefer a communication-assisted scheme using remote measurements to eliminate the possibility for distance protection misoperation while accepting the cybersecurity vulnerabilities that are introduced. Another utility may not be willing to accept the cybersecurity risks or the cost of constructing such scheme and requires a solution using local measurements or minimum remote measurements. The authors think that methods which use local relay data are worthy of research attention as cybersecurity threats are becoming a major concern.

- [1] P. Hines, J. Apt, and S. Talukdar, "Large blackouts in North America: Historical trends and policy implications," *Energy Policy*, vol. 37, no. 12, pp. 5249–5259, 2009.
- [2] K. Yamashita, J. Li, P. Zhang, and C.-C. Liu, "Analysis and control of major blackout events," in *Power Systems Conference and Exposition, 2009. PSCE'09. IEEE/PES. IEEE*, 2009, Conference Proceedings, pp. 1–4.
- [3] J. Chen, J. S. Thorp, and I. Dobson, "Cascading dynamics and mitigation assessment in power system disturbances via a hidden failure model," *International Journal of Electrical Power & Energy Systems*, vol. 27, no. 4, pp. 318–326, 2005.
- [4] R. Baldick, B. Chowdhury, I. Dobson, Z. Dong, B. Gou, D. Hawkins, H. Huang, M. Joung, D. Kirschen, and F. Li, "Initial review of methods for cascading failure analysis in electric power transmission systems IEEE pes cams task force on understanding, prediction, mitigation and restoration of cascading failures," in *Power and Energy Society General Meeting-Conversion and Delivery of Electrical Energy in the 21st Century, 2008 IEEE*. IEEE, 2008, Conference Proceedings, pp. 1–8.
- [5] B. Liscouski and W. Elliot, "Final report on the august 14, 2003 blackout in the united states and canada: Causes and recommendations," *A report to US Department of Energy*, vol. 40, no. 4, 2004.
- [6] NERC, "Standard prc-004-3 - protection system misoperation identification and correction (prc-004-3)," feb 2014, available online at [http://www.nerc.com/pa/Stand/Project%20201005%20Protection%](http://www.nerc.com/pa/Stand/Project%20201005%20Protection%20)

- 20System%20Misoperations%20DL/PRC\_004\_3\_Misoperations\_Draft\_6\_2014\_07\_18\_Clean.pdf.
- [7] D. Novosel, M. M. Begovic, and V. Madani, "Shedding light on blackouts," *Power and Energy Magazine, IEEE*, vol. 2, no. 1, pp. 32–43, 2004.
  - [8] D. N. Kosterev, C. W. Taylor, and W. A. Mittelstadt, "Model validation for the August 10, 1996 Wscc system outage," *Power Systems, IEEE Transactions on*, vol. 14, no. 3, pp. 967–979, 1999.
  - [9] Entoso-E, "Final report on blackout in turkey on 31st march 2015," Entoso-E, Tech. Rep., 2015. [Online]. Available: <http://www.nerc.com/comm/PC/System%20Protection%20and%20Control%20Subcommittee%20SPCS%20DL/Load%20Encroachment%20Final%2012-7-05.pdf>
  - [10] A. Abdullah, A. Esmailian, G. Gurralla, P. Dutta, T. Popovic, and M. Kezunovic, "Test bed for cascading failure scenarios evaluation," in *International Conference on Power Systems Transients*, 2012, Conference Proceedings, pp. 18–20.
  - [11] M. J. Thompson and D. L. Heidfeld, "Transmission line setting calculations-beyond the cookbook," in *Protective Relay Engineers, 2015 68th Annual Conference for.* IEEE, 2015, pp. 850–865.
  - [12] S. Protection and C. T. F. of the NERC Planning Committee, "Increase line loadability by enabling load encroachment functions of digital relays," online, December 2005, available online at <http://www.nerc.com/comm/PC/System%20Protection%20and%20Control%20Subcommittee%20SPCS%20DL/Load%20Encroachment%20Final%2012-7-05.pdf>.
  - [13] —, "Nerc standard prc-023-2," online, December 2005, available online at <http://www.nerc.com>.
  - [14] S. Horowitz and A. Phadke, "Third zone revisited," *Power Delivery, IEEE Transactions on*, vol. 21, no. 1, pp. 23–29, 2006.
  - [15] ERCOT, "Ercot nodal protocols-section 5: Transmission security analysis and reliability unit commitment," online, 2017.
  - [16] CAISO, "California iso planning standards," online, 2015. [Online]. Available: <https://www.caiso.com/Documents/TransmissionPlanningStandards.pdf>
  - [17] S. Li, N. Yorino, and Y. Zoka, "Operation margin analysis of zone 3 impedance relay based on sensitivities to power injection," *IET generation, transmission & distribution*, vol. 1, no. 2, pp. 312–317, 2007.
  - [18] S. Li, N. Yorino, M. Ding, and Y. Zoka, "Sensitivity analysis to operation margin of zone 3 impedance relays with bus power and shunt susceptance," *IEEE Transactions on Power Delivery*, vol. 23, no. 1, pp. 102–108, 2008.

- [19] M. R. Aghamohammadi, S. Hashemi, and A. Hasanzadeh, "A new approach for mitigating blackout risk by blocking minimum critical distance relays," *International Journal of Electrical Power & Energy Systems*, vol. 75, pp. 162–172, 2016.
- [20] H. Song and M. Kezunovic, "A new analysis method for early detection and prevention of cascading events," *Electric Power Systems Research*, vol. 77, no. 8, pp. 1132–1142, 2007.
- [21] B. Ravikumar, D. Thukaram, and H. Khincha, "An approach for distance relay co-ordination using support vector machines," in *TENCON 2008-2008 IEEE Region 10 Conference*. IEEE, 2008, pp. 1–6.
- [22] —, "An approach using support vector machines for distance relay coordination in transmission system," *IEEE Transactions on Power Delivery*, vol. 24, no. 1, pp. 79–88, 2009.
- [23] M. Tasdighi and M. Kezunovic, "Automated review of distance relay settings adequacy after the network topology changes," *IEEE Transactions on Power Delivery*, vol. 31, no. 4, pp. 1873–1881, 2016.
- [24] J. Joe-Air, Y. Jun-Zhe, L. Ying-Hong, L. Chih-Wen, and M. Jih-Chen, "An adaptive pmu based fault detection/location technique for transmission lines. i. theory and algorithms," *IEEE Transactions on Power Delivery*, vol. 15, no. 2, pp. 486–493, 2000.
- [25] S.-I. Lim, C.-C. Liu, S.-J. Lee, M.-S. Choi, and S.-J. Rim, "Blocking of zone 3 relays to prevent cascaded events," *Power Systems, IEEE Transactions on*, vol. 23, no. 2, pp. 747–754, 2008.
- [26] P. Dutta, A. Esmailian, and M. Kezunovic, "Transmission-line fault analysis using synchronized sampling," *IEEE Transactions on Power Delivery*, vol. 29, no. 2, pp. 942–950, 2014.
- [27] A. Esmailian, T. Popovic, and M. Kezunovic, "Transmission line relay misoperation detection based on time-synchronized field data," *Electric Power Systems Research*, vol. 125, pp. 174–183, 2015.
- [28] P. V. Navalkar and S. A. Soman, "Secure remote backup protection of transmission lines using synchrophasors," *IEEE Transactions on Power Delivery*, vol. 26, no. 1, pp. 87–96, 2011.
- [29] P. Kundu and A. K. Pradhan, "Synchrophasor-assisted zone 3 operation," *Power Delivery, IEEE Transactions on*, vol. 29, no. 2, pp. 660–667, 2014.
- [30] S. Garlapati, H. Lin, A. Heier, S. K. Shukla, and J. Thorp, "A hierarchically distributed non-intrusive agent aided distance relaying protection scheme to supervise zone 3," *International Journal of Electrical Power & Energy Systems*, vol. 50, pp. 42–49, 2013.

- [31] M. A. Haj-ahmed and M. S. Illindala, "Intelligent coordinated adaptive distance relaying," *Electric Power Systems Research*, vol. 110, pp. 163–171, 2014.
- [32] M. K. Neyestanaki and A. M. Ranjbar, "An adaptive pmu-based wide area backup protection scheme for power transmission lines," *IEEE Transactions on Smart Grid*, vol. 6, no. 3, pp. 1550–1559, 2015.
- [33] M. Eissa, M. E. Masoud, and M. Elanwar, "A novel back up wide area protection technique for power transmission grids using phasor measurement unit," *Power Delivery, IEEE Transactions on*, vol. 25, no. 1, pp. 270–278, 2010.
- [34] Z. He, Z. Zhang, W. Chen, O. P. Malik, and X. Yin, "Wide-area backup protection algorithm based on fault component voltage distribution," *IEEE Transactions on Power Delivery*, vol. 26, no. 4, pp. 2752–2760, 2011.
- [35] X. Lin, K. Yu, N. Tong, Z. Li, M. S. Khalid, J. Huang, Z. Li, and R. Zhang, "Countermeasures on preventing backup protection mal-operation during load flow transferring," *International Journal of Electrical Power & Energy Systems*, vol. 79, pp. 27–33, 2016.
- [36] P. K. Nayak, A. K. Pradhan, and P. Bajpai, "Secured zone 3 protection during stressed condition," *Power Delivery, IEEE Transactions on*, vol. 30, no. 1, pp. 89–96, 2015.
- [37] M. Jonsson and J. E. Daalder, "An adaptive scheme to prevent undesirable distance protection operation during voltage instability," *Power Delivery, IEEE Transactions on*, vol. 18, no. 4, pp. 1174–1180, 2003.
- [38] K. Vu, M. M. Begovic, D. Novosel, and M. M. Saha, "Use of local measurements to estimate voltage-stability margin," *IEEE Transactions on Power Systems*, vol. 14, no. 3, pp. 1029–1035, 1999.
- [39] M. Sharifzadeh, H. Lesani, and M. Sanaye-Pasand, "A new algorithm to stabilize distance relay operation during voltage-degraded conditions," *Power Delivery, IEEE Transactions on*, vol. 29, no. 4, pp. 1639–1647, 2014.
- [40] S. A. Probert and Y. H. Song, "Detection and classification of high frequency transients using wavelet analysis," in *Power Engineering Society Summer Meeting, 2002 IEEE*, vol. 2, 2002, Conference Proceedings, pp. 801–806 vol.2. [Online]. Available: <http://ieeexplore.ieee.org/ielx5/8076/22355/01043437.pdf?tp=&arnumber=1043437&isnumber=22355>
- [41] N. Perera and A. Rajapakse, "Recognition of fault transients using a probabilistic neural-network classifier," *2011 Ieee Power and Energy Society General Meeting*, 2011. [Online]. Available: <GotoISI>://WOS:000297469600037

- [42] A. Abdullah, "Towards a new paradigm for ultrafast transmission line relaying," in *Power and Energy Conference at Illinois (PECI), 2016 IEEE*. IEEE, 2016, pp. 1–8.
- [43] D. Hedman, "Propagation on overhead transmission lines i-theory of modal analysis," *IEEE Transactions on Power Apparatus and Systems*, vol. 84, no. 3, pp. 200–205, 1965.
- [44] H. K. Zadeh and Z. Li, "Artificial neural network based load blinder for distance protection," in *Power and Energy Society General Meeting-Conversion and Delivery of Electrical Energy in the 21st Century, 2008 IEEE*. IEEE, 2008, pp. 1–6.
- [45] —, "Adaptive load blinder for distance protection," *International Journal of Electrical Power & Energy Systems*, vol. 33, no. 4, pp. 861–867, 2011.
- [46] J. M. Zurada, *Introduction to artificial neural systems*. West St. Paul, 1992, vol. 8.
- [47] V. Nikolaidis, "Emergency zone 3 modification as a local response-driven protection measure against system collapse," *IEEE Transactions on Power Delivery*, vol. PP, no. 99, pp. 1–1, 2016.
- [48] V. Nikolaidis, N. Savvopoulos, A. Safigianni, and C. Vournas, "Adjusting third zone distance protection to avoid voltage collapse," in *Power Systems Computation Conference (PSCC), 2014*. IEEE, 2014, Conference Proceedings, pp. 1–7.
- [49] J. Ma, C. Liu, Y. Zhao, S. Kang, and J. S. Thorp, "An adaptive overload identification method based on complex phasor plane," *IEEE Transactions on Power Delivery*, vol. 31, no. 5, pp. 2250–2259, 2016.