

STANDAR TEGANGAN 20kV 20kV VOLTAGE STANDARD

PARAMETER	TEGANGAN FASE (U_a, U_b, U_c)	TEGANGAN ANTAR FASA (U_{ab}, U_{bc}, U_{ca})	3U0 (TEGANGAN URUTAN NOL)
NORMAL	11.0~12.0kV	19.0~20.5kV	=0.5kV
WASPADA	10.5~11.0kV/ 12.0~12.5kV	18.5~19.0kV/ 20.5~21.0kV	0.5~1.0kV
BAHAYA	<10.5kV <12.0kV	<18.5kV/ 21.0V	>1.0kV

NORMAL: Rentang tegangan fase (U_a, U_b, U_c) adalah 11.0~12.0kV, Tegangan antar fasa (U_{ab}, U_{bc}, U_{ca}) 19.0~20.5kV, dan tegangan urutan nol (3U0) =0.5kV

NORMAL: The phase voltage range (U_a, U_b, U_c) is 11.0~12.0 kV, the line-to-line voltage (U_{ab}, U_{bc}, U_{ca}) is 19.0~20.5 kV, and the zero-sequence voltage (3U0) = 0.5 kV.

WASPADA: Kondisi tegangan mulai menyimpang dari normal, menunjukkan rentang tegangan fase 10.5~11.0kV atau 12.0~12.5kV, tegangan antar fasa 18.5~19.0kV atau 20.5~21.0kV, dan tegangan urutan nol 0.5~1.0kV

CAUTION: The voltage condition is starting to deviate from normal, showing a phase voltage range of 10.5~11.0 kV or 12.0~12.5 kV, a line-to-line voltage of 18.5~19.0 kV or 20.5~21.0 kV, and a zero-sequence voltage of 0.5~1.0 kV.

BAHAYA: Tegangan berada diluar batas aman, dengan tegangan fase <10.5kV atau >12.5kV, tegangan antar fasa <18.5kV atau >21.0kV, dan tegangan urutan nol >1.0kV

DANGER: The voltage is outside the safe limits, with phase voltage <10.5 kV or >12.5 kV, line-to-line voltage <18.5 kV or >21.0 kV, and zero-sequence voltage >1.0 kV.

Jika ada masalah pada kelistrikan, hubungi elektrik
If there is a problem with electricity, contact the electrician

**Peringatan/
Warning!**

Helm safety, sarung tangan isolasi 20 kV, sepatu safety isolasi, kacamata pelindung, baju kerja anti listrik. Multimeter/voltmeter tegangan menengah. Peralatan grounding stick. Alat komunikasi (HT/telepon).

Safety helmet, 20 kV insulating gloves, insulating safety shoes, safety glasses, arc-rated workwear. Medium-voltage multimeter/voltmeter. Grounding stick equipment. Communication devices (HT/radio or telephone).