

TEST REPORT FOR PULL OUT TEST

ACES Client	Fursan Construction Industries	ACES Report No.	RH.MMR26041567.Rev.2
Project Owner	MIASEM / AUTUD-SNB CAPITAL	Date Reported	07-10-26
Project Contractor	ALUFCO (FURSAN FACTORY)	Sample No.	RH.MMS26013066
Project Consultant	ARKITECTONICA CONSULTING	Request No.	RH.MMO26008876
Project No.	169	Client Reference	Receipt No. 46823 dated 21-Sep-2026 dated 21-Sep-2026
Project Name	KEYSTONE-DIRIYAH	WIR/IR No.	N.P

Sample Description	Pull Out Test Anchor Bolt	Sampled By	SULIMAN
Source	N.P.	Epoxy used	Mechanical
Sample Location	Keystone - Diriyah	Grade of Concrete	C-40
Steel Dia.(mm)	16 mm	No. of samples	4 No.'s
Hole Diam./length(mm)	16/90 mm		

Test Method	BS 5080-1:1993	Date Tested	27-09-26
Test Method Var.	Nil	Tested By	SULIMAN
Remarks	Nil	Test Location	Keystone - Diriyah
Reported By	Eng. Conarco RY 1859	Lab. Location	ACES Riyadh

Test Results:

Test No.	Sample Location	Max Applied Force		Steel diameter (mm)	Hole Diameter (mm)	Embedded Length (mm)	Remarks
		Bar	KN				
1	B1	147.0	93.3	16	16	90	No failure
2	B1	147.0	93.3	16	16	90	No failure
3	B4	147.0	93.3	16	16	90	No failure
4	B4	147.0	93.3	16	16	90	No failure

Load(K.N) = Load (Bar) X 0.55 + (12.2)

Notes:

- *The test result(s) and conclusion(s) in this report relate only to the sample(s)/items as received and tested as described herein.
- *This test report may not be reproduced in whole or in part without the written approval of ACES.
- *ACES is responsible for all information provided in the report that resulted from their activities, except for any information provided by the Customer or resulting from activities performed by another entity.
- *In case ACES is not provided with a decision rule from ILAC Guide-G8:09/2019 clause 5.2 Table 1, then the conformity statement, if included in the test reports, will be based on the Simple Acceptance Rule as per ILAC Guide-G8:09/2019 clause 5.2 Table 1.
- *Conformity statement, if provided, is specific only to the tested samples/items as received & their testing results, and does not entail any additional judgment under the responsibility of ACES.

-End of report-

Materials Department
Arab Company for Laboratories and Soil
ACES Riyadh