

COMPLIANCE & SAFETY AUDIT REPORT

Regulatory Environmental & OSHA Facility Standards

Audit ID: AUD-2026-9812

Facility: Apex BioMed Production Lab 4

Lead Inspector: Marcus Vance, CSP, Lead Auditor

Audit Date: 2026-09-18

Compliance Score: 74.5%

Status: ACTION REQUIRED

Remediation Deadline: 2026-10-05

Audit Category	Inspection Standard	Result	Severity
HVAC HEPA Filtration & Air Flow	ISO 14644-1 Cleanroom Cl. 7	FAILED - Differential Pressure Out of Spec	CRITICAL
Emergency Eye Wash & Shower Units	OSHA 1910.151(c) Safety Station	PASSED - Inspected & Tagged	NONE
Hazardous Chemical Secondary Containment	EPA 40 CFR 264.175 Standard	ACTION REQUIRED - Berm Seal Degraded	MODERATE
Electrical Arc Flash Signage	NFPA 70E Electrical Workplace	PASSED - All Panels Verified	NONE

MANDATORY CORRECTIVE ACTION NOTICE:

Facility failed cleanroom environmental containment threshold. Facility management must complete recalibration of primary HVAC differential sensors and repair hazardous chemical containment berms by 2026-10-05.