

23-November-2025

Ref No.: BD-CW-SAMCO-ACE-LET-023

To: ACE Project Management | Moharram Bakhoun

Attention: Eng. Abdelaziz Mohamed (Project Manager)

Project Name: The Big Business District.

Contract/Package: Construction Works.

Subject: Related to waterproofing works

Dear Sir,

According to the previous approval from consultant (PCO) about the following waterproofing materials:

1. Cold Applied Sika Bitucoat Uses For foundation "**SAMCO-PCO-STR-MS-016-R01**" Code "B"
2. SIKA Bitumen Membrane SBS "**SAMCO-PCO-STR-MS-017-R00**" Code "B"
3. SIKA Bitucoat "**SAMCO-PCO-STR-MS-018-R00**" Code "B"
4. Protection Board Membrane (SikaShield PB P15 PE 3 mm) "**SAMCO-PCO-STR-MS-018-R00**" Code "B"

Regarding your instruction based on specs received on 22/10/2025 "**BD-ACE-SAMCO-TRA-0012**" to ensure a 10-year waterproofing warranty, Sika — whose materials were previously approved — has been contacted, and their response is as shown in as follow:

"As per your request, kindly find the below clarification for bituminous membrane warranty as per sika code of practice, the below is for 2 underground basements.

Sika shield P 36 one layer + protection: the maximum warranty Sika Egypt gives for one layer APP is one year only. To get 5 years on the same product we should upgrade to double layer of Sika shield P 36 + protection sheet 3 mm – Sika shield Pb P 12 3 mm.

As suggested on the previously sent mail, we suguest Sika shield E 67, two layers of SBS membrane plus protection - Sika shield Pb P 12 3 mm – to be able to give 10 years warranty."

We kindly request clarification on the insulation materials to be used, in order for us to initiate the approval procedures and proceed with the execution phase.

Attachment:

A snapshot from Sika's official email for your reference

With sincere regards and appreciation,

Eng./ Mohammed Sami Mohammed
Project Director
SAMCO National Construction



Re: the big project basement Waterproofing

Hossam Mahmoud <mahmoud.hossam@eg.sika.com>

Mohamed Elmael@samco-egypt.com; Mohamed Gounaad@samco-egypt.com; asmaa.elhawary@samco-egypt.com

Engr. Refat Elazab Elany; Maria Magdy

Reply

Reply All

Forward

Wed 11 May 2015 14:40

Dear Sirs,

Per your request, kindly find the below clarification for biruminous membrane warranty as per sika code of practice, the below is for 2 underground basemen

shield P 36 one layer + protection : the maximum warranty Sika Egypt gives for one layer APP is one year only. To get 5 years on the same product we should go to double layer of Sika shield P 36 + protection sheet 3 mm – Sika shield Pb P 12 3 mm.

Suggested on the previously sent mail, we suggest Sika shield E 67, two layers of SBS membrane plus protection - Sika shield Pb P 12 3 mm – to be able to give 5 years warranty.

Thank you for understanding

Best Regards

INTERNAL

Hossam Mahmoud

TM waterproofing and roofing manager

Phone: +20 244810580

Mobile: +2 01211200417

Fax: +20 244810459

Email: mahmoud.hossam@eg.sika.com



JOINT TRUST

Egypt for Construction Chemicals S.A.E.

Industrial Zone (A), Section # 10 Blocks 13035 · El Obour City Cairo · Egypt

20150511 14:40

23-November-2025

Ref No.: BD-CW-SAMCO-ACE-LET-023

To: ACE Project Management | Moharram Bakhoum

Attention: Eng. Abdelaziz Mohamed (Project Manager)

Project Name: The Big Business District.

Contract/Package: Construction Works.

Subject: Related to waterproofing works

Dear Sir,

According to the previous approval from consultant (PCO) about the following waterproofing materials:

1. Cold Applied Sika Bitucoat Uses For foundation “**SAMCO-PCO-STR-MS-016-R01**” Code “B”
2. SIKa Bitumen Membrane SBS “**SAMCO-PCO-STR-MS-017-R00**” Code “B”
3. SIKa Bitucoat “**SAMCO-PCO-STR-MS-018-R00**” Code “B”
4. Protection Board Membrane (SikaShield PB P15 PE 3 mm) “**SAMCO-PCO-STR-MS-018-R00**” Code “B”

Regarding your instruction based on specs received on 22/10/2025 “**BD-ACE-SAMCO-TRA-0012**” to ensure a 10-year waterproofing warranty, Sika — whose materials were previously approved — has been contacted, and their response is as shown in as follow:

“As per your request, kindly find the below clarification for bituminous membrane warranty as per sika code of practice, the below is for 2 underground basements.

Sika shield P 36 one layer + protection: the maximum warranty Sika Egypt gives for one layer APP is one year only. To get 5 years on the same product we should upgrade to double layer of Sika shield P 36 + protection sheet 3 mm – Sika shield Pb P 12 3 mm.

As suggested on the previously sent mail, we sugeest Sika shield E 67, two layers of SBS membrane plus protection - Sika shield Pb P 12 3 mm – to be able to give 10 years warranty.”

We kindly request clarification on the insulation materials to be used, in order for us to initiate the approval procedures and proceed with the execution phase.

Attachment:

A snapshot from Sika’s official email for your reference

With sincere regards and appreciation,

Eng./ Mohammed Sami Mohammed
Project Director
SAMCO National Construction

RE: the big project basement Waterproofing



Hossam Mahmoud <mahmoud.hossam@eg.sika.com>

To mohamed.ismael@samco-egypt.com; Mohamed.Goumaa@samco-egypt.com; asmaa.elhawy@samco-egypt.com

Cc Karim Refat; David Hany; Maria Magdy

↩ Reply

↩ Reply All

➔ Forward

...

Wed 11/19/2025 4:40 PM

Dear Sirs,

as per your request , kindly find the below clarification for biruminous membrane warranty as per sika code of practice , the below is for 2 underground basments.

Sika shield P 36 one layer + protection : the maxmium warranty Sika Egypt gives for one layer APP is one year only. To get 5 years on the same product we should upgrade to double layer of Sika shield P 36 + protection sheet 3 mm – Sika shield Pb P 12 3 mm.

As suggested on the previously sent mail , we sugeest Sika shiled E 67 , two layers of SBS membrane plus protection - Sika shield Pb P 12 3 mm – to be able to give 10 years warranty.

Thank you for understanding

Best Regards

INTERNAL



BUILDING TRUST

Hossam Mahmoud

TM waterproofing and roofing manager

Phone: +20 244810580

Mobile: +2 01211200417

Fax: +20 244810459

Email: mahmoud.hossam@eg.sika.com

Sika Egypt for Construction Chemicals S.A.E.

1st Industrial Zone (A), Section # 10 Blocks 13035 · El Obour City Cairo · Egypt

<http://egy.sika.com/>