

ALAMEIN CAMPUS - Generator Test Report

=====

College of Medicine

Generator: GEN-MED-01

Test Date: 2024-03-15

Runtime: 14 hours

Diesel Consumed: 245 L

Result: PASS - All parameters within range

Technician: Eng. Mahmoud Hassan

Notes: Routine scheduled test after power outage event