

Certificate Reference: EMIlombokCroydonJuly17

1 DETAILS OF THE CLIENT

Client: Lombok
Address: 4 Coomber Way, Croydon, CR0 4TQ

2 DETAILS OF THE INSTALLATION ADDRESS

Installation Address: Lombok, 1st Floor office, 4 Coomber Way, Croydon, CR0 4TQ

3 EMERGENCY LIGHTING DEVICE LIST

No.	Location	Type Of Device	Lamp Type	Mode Of Operation	Test Switch No	Test Switch Location
1	Kitchen	LED ceiling mount em c/w battery	LED	Non Maintained	C3	Lombok kitchen DB
2	Rear corridor	LED ceiling mount em c/w battery	LED	Non Maintained	C3	Lombok kitchen DB
3	Hallway	LED ceiling mount em c/w battery	LED	Non Maintained	C3	Lombok kitchen DB
4	Main Office	LED ceiling mount em c/w battery	LED	Non Maintained	C3	Lombok kitchen DB
5	Locker room	LED ceiling mount em c/w battery	LED	Non Maintained	C3	Lombok kitchen DB
6	Hallway	LED ceiling mount em c/w battery	LED	Non Maintained	C3	Lombok kitchen DB
7	Managers Office	LED ceiling mount em c/w battery	LED	Non Maintained	C3	Lombok kitchen DB
8	Above shutter	2W Bulkhead	LED	Maintained	C1	Warehouse C DBH1
9	Warehouse C ground floor	2W Bulkhead	2W LED	Maintained	C1	Warehouse C DBH1
10	Warehouse C ground floor	2W Bulkhead	LED	Maintained	C1	Warehouse C DBH1
11	Warehouse C ground floor	2W Bulkhead	2W LED	Maintained	C1	Warehouse C DBH1
12	Warehouse C ground floor	2W Bulkhead	2W LED	Maintained	C1	Warehouse C DBH1
13	Warehouse C ground floor	2W Bulkhead	2W LED	Maintained	C1	Warehouse C DBH1
14	Warehouse C ground floor	2W Bulkhead	2W LED	Maintained	C1	Warehouse C DBH1
15	Warehouse C ground floor	2W Bulkhead	2W LED	Maintained	C1	Warehouse C DBH1
16	Warehouse C ground floor	2W Bulkhead	2W LED	Maintained	C1	Warehouse C DBH1

4 ADDITIONAL COMMENTS

N/A

5 DETAILS OF THE CONTRACTOR

Trading Title: LondonSparks

Address: Airport House
Purley Way
Croydon

Registration Number (if applicable): 0035258

Telephone Number: 07850557684

Postcode: CR0 0XZ

For the Testing and Inspection of the emergency lights:

Name: John Oconnor Position: Electrician Signature: Date: 30/07/2017

3