

A. DETAILS OF THE CLIENT	
Client:	Owner
Address:	Flat 4 (top) 46 Whitworth Road South Norwood
	Postcode: SE25 6XJ

B. PURPOSE OF THE REPORT	
Purpose for which this report is required:	Letting
Date(s) on which inspection and testing were carried out:	15/07/2017

C. DETAILS OF THE INSTALLATION			
Occupier	Vacant		
Address	Flat 4 (top)		
	46 Whitworth Road South Norwood		
	Postcode: SE25 6XJ		
Estimated age of the electrical installation:	18	years	Evidence of alterations or additions
			<input checked="" type="checkbox"/>
Date of previous inspection:		Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No:	
Records of installation available:	No	Records held by:	

D. EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING	
Extent of the electrical installation covered by this report:	
All areas	
Agreed limitations (including the reasons), if any, on the inspection and testing:	
No removal of panels or boards Insulation test Ph/N - Earth only No test on lighting over 2.4m No EM testing (only power off test- if visible) No Fire/Smoke detection tests No Solar Pv tests	
Agreed with:	
Operational limitations including the reasons (see page No.)	
The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.	

E. SUMMARY OF THE CONDITION OF THE INSTALLATION			
General condition of the installation (in terms of electrical safety):			
Installation is a converted property Supply is a TNS TP&N with all consumer units in the common area System is a small plastic consumer unit with an RCD main switch & mcb's (Mix of manufacture) Cable system is old colour code with new fittings in some rooms. Building works ongoing during testing.			
Summary of the condition of the installation continued on additional pages?	No	Yes	Specify page
Overall assessment of the installation:	SATISFACTORY / UNSATISFACTORY		
An 'Unsatisfactory' assessment indicates that dangerous and/or potentially dangerous conditions have been identified			



DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

Original (To the person ordering the work)

I. NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than

1yr

(Enter interval in terms of years, months or weeks, as appropriate)

provided that any items at F which have been attributed a Classification code C1 (danger present) are remedied immediately and that any items which have been attributed a code C2 (potentially dangerous) or FI (further investigation required without delay) are remedied or investigated respectively as a matter of urgency. Items which have been attributed a Classification code C3 should be improved as soon as practicable (see F).

J. DETAILS OF NICEIC APPROVED CONTRACTOR

Trading Title: londonsparks.com

Address: Airport House
Purley Way
Croydon
Surrey

Telephone number: +447850 557684

Email Address: kevin@londonsparks.com

Enrolment number: D035258

Branch number: (if applicable)

Postcode: CR0 0XZ



K. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

System Type(s)		Number and Type of Live Conductors			Other (please state)	Nature of Supply Parameters			Characteristics of Primary Supply Overcurrent Protective Device(s)				
TN-S	<input checked="" type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>				Nominal Voltage(s): $U_{(1)}$	400	V	$U_0^{(1)}$	230	V	BS(EN)
TN-C-S	N/A	1-phase (2 wire)	N/A	1-phase (3 wire)	N/A	Nominal frequency, $f^{(1)}$	50	Hz	Number of sources	1		Type	2
TT	N/A	2-phase (3 wire)	N/A			Prospective fault current, $I_{pf}^{(2)(3)}$	1.14	kA				Rated current	100 A
		3-phase (3 wire)	N/A	3-phase (4 wire)	<input checked="" type="checkbox"/>	External earth fault loop impedance, $Z_e^{(3)(4)}$	0.20	Ω				Short-circuit capacity	33.5 kA
						<i>Notes:</i> (1) by enquiry (2) by enquiry or by measurement (3) where more than one source, record the higher or highest value (4) by measurement			Confirmation of supply polarity		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

L. PARTICULARS OF INSTALLATION AT THE ORIGIN

Means of Earthing		Details of Installation Earth Electrode (where applicable)	
Distributor's facility:	<input checked="" type="checkbox"/>	Type: (eg rod(s), tape etc)	Location:
Installation earth electrode:	N/A	Electrode resistance, R_A : (Ω)	Method of measurement:

Main Switch or Circuit-Breaker				Earthing conductor		Earthing and protective bonding conductors		Bonding of extraneous-conductive-parts (✓)				
Type: BS(EN)	BS EN 60947-	Voltage rating	230	V	Conductor material	Copper	Conductor material	Copper	Water service	<input checked="" type="checkbox"/>	Gas Service	<input checked="" type="checkbox"/>
No of Poles	2	Rated current, I_n		A	Conductor csa	16	mm ²	Conductor csa	10	mm ²	Oil service	N/A
Primary supply conductors (material)	Copper	RCD operating current, $I_{\Delta n}$ *		mA	Connection/continuity verified	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Connection/continuity verified	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection	N/A
Primary supply conductors (csa)	25	Rated time delay*		ms							Other incoming service(s)	N/A
		RCD operating time (at $I_{\Delta n}$)*		ms							Other (Specify)	

* (applicable only where an RCD is suitable and is used as a main circuit-breaker)

 **APPROVED CONTRACTOR**

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

SCHEDULE OF INSPECTIONS

Item	Description	Outcome *	Location reference
1.0 Condition/adequacy of distributor's/supply intake equipment			
1.1	Service cable	✓	
1.2	Service cut-out/fuse(s)		
1.3	Meter tails - distributor	✓	
1.4	Meter tails - consumer		
1.5	Metering equipment		
1.6	Means of main isolation (where present)		
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		
3.0 Earthing and bonding arrangements			
3.1	Presence and condition of distributor's earthing arrangement	✓	
3.2	Presence and condition of earth electrode connection		
3.3	Confirmation of adequate earthing conductor size	✓	
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	
3.5	Confirmation of adequate main protective bonding conductor sizes		
3.6	Condition and accessibility of main protective bonding conductor connections		
3.7	Provision of earthing and bonding labels at all appropriate locations		

Item	Description	Outcome *	Location reference
4.0 Consumer unit(s)			
4.1	Adequacy of working space or access to consumer unit	✓	
4.2	Security of fixing	✓	
4.3	Condition of enclosure(s) in terms of IP rating	✓	
4.4	Condition of enclosure(s) in terms of fire rating	C3	
4.5	Enclosure not damaged/deteriorated so as to impair safety		
4.6	Presence of linked main switch		
4.7	Operation of main switch (functional check)		
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection		
4.9	Correct identification of circuits and protective devices	✓	
4.10	Presence of RCD test notice at or near consumer unit		
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit		
4.12	Presence of alternative supply warning notice at or near consumer unit		
4.13	Presence of replacement next inspection recommendation label		
4.14	Presence of other required labelling (please specify)		
4.15	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)		
4.16	Single-pole protective devices in the line conductor only		

* All Boxes must be completed
✓ indicates **Acceptable condition**
'LIM' indicates a **limitation**
'W/A' indicates **Not applicable**
Unacceptable condition state **C1** or **C2**
Improvement recommended state **C3**
Further investigation required state **F/I**
(to determine whether danger or potential danger exists)
Outcome
Provide additional comment where appropriate on attached numbered sheets. C1, C2 and C3 coded items to be recorded in section F of the report.

 **APPROVED CONTRACTOR**

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

SCHEDULE OF INSPECTIONS

Item	Description	Outcome *	Location reference
4.17	Protection against mechanical damage where cables enter metallic consumer unit		
4.18	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure		
4.19	RCDs provided for fault protection – includes RCBOs		
4.20	RCDs provided for additional protection – includes RCBOs		
5.0 Final circuits			
5.1	Identification of conductors	✓	
5.2	Cables correctly supported throughout their run	LIM	
5.3	Condition of insulation of live parts		
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)		
5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation		
5.6	Adequacy of protective devices; type and rated current for fault protection	✓	
5.7	Presence and adequacy of circuit protective conductors	✓	
5.8	Co-ordination between conductors and overload protective devices		
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences		
5.10	Concealed cables installed in prescribed zones (see extent and limitations)		

Item	Description	Outcome *	Location reference
5.11	Concealed cables incorporating earthed armour or sheath, or run within earthed wiring containment system, or otherwise protected against mechanical damage from nails, screws and the like where not in prescribed zones or not protected by 30 mA RCD (see extent and limitations)		
5.12	Provision of additional protection by RCD not exceeding 30 mA	✓	
	* used to supply mobile equipment not exceeding 32 A rating for use outdoors		
	* for all socket-outlets not exceeding 20 A rating unless exempt		
	* for cables concealed in walls or partitions		
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects		
5.14	Band II cables segregated/separated from Band I cables	LIM	
5.15	Cables segregated/separated from communications cabling		
5.16	Cables segregated/separated from non-electrical services		
5.17	Termination of cables at enclosures (extent of sampling indicated in Section D of the report)		
	* Connections soundly made and under no undue strain		
	* No basic insulation of a conductor visible outside enclosures		
	* Connections of live conductors adequately enclosed		
	* Adequately connected at point of entry to enclosure (glands,bushes etc.)		

* All Boxes must be completed

✓ indicates Acceptable condition

'LIM' indicates a limitation

'N/A' indicates Not applicable

Unacceptable condition state C1 or C2

Improvement recommended state C3

Further investigation required state F/I
(to determine whether danger or potential danger exists)

Outcome

Provide additional comment where appropriate on attached numbered sheets. C1, C2 and C3 coded items to be recorded in section F of the report.

 **APPROVED CONTRACTOR**

DOMESTIC ELECTRICAL INSTALLATION CONDITION REPORT

SCHEDULE OF INSPECTIONS

Item	Description	Outcome *	Location reference
5.18	Condition of accessories including socket-outlets, switches and joint boxes		
5.19	Suitability of accessories for external influences		
6.0 Isolation and switching (isolation, switching off for mechanical maintenance, emergency switching/stopping and functional switching)			
6.1 In General			
	* presence and condition of appropriate devices	✓	
	* correct operation verified		
6.2 For isolation and switching for mechanical maintenance only			
	* capable of being secured in the OFF position where appropriate		
	* acceptable location – state if local or remote from equipment being controlled where appropriate		
	* clearly identified by position and/or durable marking(s)		
6.3 For isolation only			
	* warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device		
6.4 For emergency switching/stopping only			
	* readily accessible for operation where danger might occur		
7.0 Current-using equipment (Permanently connected)			
7.1	Condition of equipment in terms of IP rating	✓	
7.2	Equipment does not constitute a fire hazard	✓	
7.3	Enclosure not damaged/deteriorated so as to impair safety		
7.4	Suitability for the environment and external influences		
7.5	Security of fixing		

Item	Description	Outcome *	Location reference
7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire List number and location of luminaires inspected. (Separate page)		
7.7 Recessed luminaires (downlighters)			
	* correct type of lamps fitted	✓	
	* installed to minimise build-up of heat by use of 'fire rated' fittings, insulation displacement box or similar	✓	
	* no signs of overheating to surrounding building fabric		
	* no signs of overheating to conductors/terminations		
8.0 Location(s) containing a bath or shower			
8.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA		
8.2	Where used as a protective measure, requirements for SELV or PELV are met		
8.3	Shaver sockets comply with BS EN 61558-2-5 or BS 3535		
8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008		
8.5	Low voltage (e.g. 230 volts) socket outlets sited at least 3 m from zone 1		
8.6	Suitability of equipment for external influences for installed location in terms of IP rating		
8.7	Suitability of equipment for installation in a particular zone		
8.8	Suitability of current-using equipment for a particular position within the location		
9.0 Other special installations or locations - Part 7s			
9.1	List all other special installations or locations present, if any. Record the results of particular inspection applied separately		

* All Boxes must be completed
✓ indicates Acceptable condition
LIM indicates a limitation

'N/A' indicates Not applicable
Unacceptable condition state C1 or C2
Improvement recommended state C3

Further investigation required state F/I
(to determine whether danger or potential danger exists)

Outcome
Provide additional comment where appropriate on attached numbered sheets. C1, C2 and C3 coded items to be recorded in section F of the report.

[illegible]

TEST INSTRUMENTS		Test instruments (serial numbers) used									
Multi-functional	16103359	Insulation resistance		Continuity		Earth electrode resistance		Earth fault current impedance		RCD	

CODES FOR TYPE OF WIRING								
A	B	C	D	E	F	G	H	I (Other - please state)
Thermoplastic insulated	Thermoplastic cables in . . .	Thermoplastic cables in non . . .	Thermoplastic cables in . . .	Thermoplastic cables in non . . .	Thermoplastic SWA cables	Thermosetting SWA cables	Mineral-insulated	