

Certificate Reference: EMPurefoodsCroyJuly2017

1 DETAILS OF THE CLIENT

Client: Purefoods Croydon
Address: 9 Spitfire Way, CR0 4WD

2 DETAILS OF THE INSTALLATION ADDRESS

Installation Address: Purefoods Croydon, 9 Spitfire Way, Hawker Road, Croydon, CR0 4WD

3 EMERGENCY LIGHTING DEVICE LIST

No.	Location	Type Of Device	Lamp Type	Mode Of Operation	Test Switch No	Test Switch Location
1	Corridor near DB3	LED ceiling mount em c/w battery	LED	Non Maintained	1	1st floor high level below DB3
2	Accounts office	LED ceiling mount em c/w battery	LED	Non Maintained	1	1st floor high level below DB3
3	Managers Office	LED ceiling mount em c/w battery	LED	Non Maintained	1	1st floor high level below DB3
4	Main Office	LED ceiling mount em c/w battery	LED	Non Maintained	1	1st floor high level below DB3
5	Corridor near Kitchen	LED ceiling mount em c/w battery	LED	Non Maintained	1	1st floor high level below DB3
6	Mid stairs	Bulk Head Exit	LED	Maintained	1	1st floor high level below DB3
7	Ground floor entrance	Exit Sign Blade	8W Tube	Non Maintained	1	1st floor high level below DB3
8	Ground floor workshop	Twin led flood lights	Twin LED	Non Maintained	2	Ground floor cupboard above DB1
9	Ground floor workshop store	Bulk Head Exit	LED	Maintained	1	Ground floor cupboard above DB1
10	Mezzanine ground floor	Bulk Head Exit	LED	Maintained	2	Ground floor cupboard above DB1
11	Mezzanine middle floor	Bulk Head Exit	LED	Maintained	1	Ground floor cupboard above DB1
12	Mezzanine top floor	Bulk Head Exit	LED	Maintained	2	Ground floor cupboard above DB1
13	Mezzanine top floor front	Bulk Head Exit	LED	Maintained	2	Ground floor cupboard above DB1
14	Mezzanine middle floor back	Bulk Head Exit	LED	Maintained	2	Ground floor cupboard above DB1
15	Mezzanine ground floor back	Bulk Head Exit	LED	Maintained	2	Ground floor cupboard above DB1
16	Mezzanine store above door	Bulk Head Exit	LED	Maintained	2	Ground floor cupboard above DB1

4 ADDITIONAL COMMENTS

Emergency light designed to work with total power loss

5 DETAILS OF THE CONTRACTOR

Trading Title: LondonSparks


Address: Airport House
Purley Way
Croydon

Registration Number (if applicable): 0035258

Telephone Number: 07850557684

Postcode: CR0 0XZ

For the Testing and Inspection of the emergency lights:

Name: Kevin Duffy Position: Qualified Supervisor Signature:  Date: 20/07/2017

3 EMERGENCY LIGHTING DEVICE LIST (CONTINUED)

[illegible]