NICEIC APPROVED CONTRACTOR

Londonsparks.com

This certificate is not valid if the serial number has been defaced or altered **DCN8/0373138**

Contractor's Reference Number

ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House,Houghton Hall Park, Houghton Regis,Dunstable,LU5 5ZX

Original (To the person ordering the work)

TYPE OF INSTALLATION

Domestic Dwelling ✓ | Highway Installation | Leisure Accommodation Vehicle | Modular Dwelling | Transportable Unit

DETAILS OF THE CLIENT/MANUFACTURER

Client and address

Mr & Mrs Burchell
Little Paddock
Rockfield Road
Oxted
RH8 0EL

Postcode: RH8 0EL

ADDRESS OF THE INSTALLATION/LOCATION

Installation address

Little Paddock
Rockfield Road
Oxted
RH8 0EL

Postcode: RH8 0EL

DETAILS OF THE INSTALLATION

Extent of the installation work covered by this certificate

Full re-wire main house
& Garage

The installation is:

New
An addition ✓
An alteration ✓

DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I, being the person(s) responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671, 2008 mmended to 2017 te) except for the departures, if any, detailed as follows:

Details of departures from BS 7671, as amended (Regulations 120.3,133.5)

Cctv & intruder alarm spurs non rcd ccts at customer request

Relevant risk assessment(s) have been attached to this certificate (Regulation 411.3.3 indent (a))

The extent of liability of the signatory is limited to the work described above as the subject of this certificate.
For the **DESIGN** the **CONSTRUCTION** and the **INSPECTION AND TESTING** of the installation.

Signature | Name (CAPITALS) KEVIN DUFFY | Date 01/06/2017

The results of the inspection and testing reviewed by the Qualified Supervisior

Signature | Name (CAPITALS) KEVIN DUFFY | Date 01/06/2017

PARTICULARS OF THE APPROVED CONTRACTOR

Trading Title: londonsparks.com

Address:

Airport
Purley Way
Croydon
Surrey

Telephone No: +447850 557684 Postcode: CR0 0XZ

NICEIC APPROVED CONTRACTOR

NICEIC Enrolment No (Essential information): D035258

Branch No (if applicable):

NEXT INSPECTION

§ *Enter interval in terms of years, months or weeks, as appropriate*

I RECOMMEND that this installation is further inspected and tested after an interval of not more than § 10yrs

COMMENTS ON EXISTING INSTALLATION

Note: Enter 'NONE' or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation

In the case of an alteration or additions see section 633 of BS7671

SCHEDULE OF ADDITIONAL RECORDS*

See attached schedule

** Where the electrical work to which this certificate relates includes the installation of a fire detection/alarm system (or a part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system.*

Please see the 'Notes for Recipients'

NICEIC APPROVED CONTRACTOR

This certificate is not valid if the serial number has been defaced or altered **DCN8/0373138**

ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Original (To the person ordering the work)

SUPPLY CHARACTERISTICS

Tick boxes and enter details, as appropriate

System type(s)

TN-S	✔
TN-C-S	N/A
TT	

Number and type of live conductors

1-phase (2-wire)	✔	1-phase (3-wire)	
3-phase (3-wire)		3-phase (4-wire)	

Other (Please state)

Nature of supply parameters

Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values

Number of sources	1	Nominal voltage(s) $U^{(1)}$	230 V	Nominal frequency, $f^{(1)}$	50 Hz
		U_0 (1)	230 V	External earth fault loop impedance, Z_e (1)	Ω
Single-phase		Prospective fault current, I_{pf} (2)(3)	kA	**3-phase** Prospective fault current, I_{pf} (2)(3)	kA

Characteristics of primary supply overcurrent protective device(s)

BS(EN)	BS 1361 Fu	Short-circuit capacity	33.5 kA
Type	2	Confirmation of supply polarity	
Rated current	100 A		

PARTICULARS OF INSTALLATION AT THE ORIGIN

Tick boxes and enter details, as appropriate

Means of earthing

Distributor's facility	✔
Installation earth electrode	

Details of installation earth electrode (where applicable)

Type (eg rod(s), tape etc)		Location	
Electrode resistance R_A	Ω	Method of measurement	

Protective measure(s) for fault protection

Measured Z_e 0.18 Ω

Maximum demand (Load) Amps

Number of smoke alarms ‡

Earthing conductor

Conductor material	Copper		
Conductor csa	16 mm²	Continuity/ connection verified	✔

Main protective bonding conductors and bonding of extraneous-conductive-parts

Continuity/ connection verified	✔	Conductor material	Copper	Conductor csa	10 mm²
Location (where not obvious)	Basement Stairs				

Water installation pipes	✔	Structural steel	
Oil installation pipes		Other	
Gas installation pipes	✔		

Main Switch/Switch-Fuse/Circuit-Breaker/RCD

Type BS(EN)	BS EN 60947-	Voltage rating	230 V
No of poles	2	Rated current, I_n	A
Supply conductors material	Copper	RCD operating current, $I_{\Delta n}$*	mA
Supply conductors csa	25 mm²	RCD operating time (at $I_{\Delta n}$)*	ms
		Rated time delay*	ms

** applicable only where an RCD is used as a main circuit-breaker*

VEHICLE DETAILS

Type: Touring ☐ Static ☐ Motorhome ☐ Year of manufacture | Model | Registration (motorhome) | VIN

PARTICULARS OF VEHICLE INSTALLATION

☐ **Hook-up connection**

Flexible supply cable

Length m csa mm²

I_z A $(R_1 + R_2)_{cs}$ Ω

$(R_1 + R_2)_{fc}$ Ω

☐ System type: TT

For static (fixed) vehicles

Installation earth electrode details:

Type: *(e.g. rods(s), Tapes(s))* Method of measurement

Electrode resistance, R_A Ω

Location

☐ System type: TN-S

Maximum tolerable upstream earth fault loop impedance, Z_T Ω

Maximum tolerable fault current kA

Maximum demand (Load) per phase provision Amps

Means of earthing

Supply voltage(s) and maximum load/demand

Nominal voltage(s) U_0 U Maximum permitted load Amps

Earthing and protective bonding conductors

Earthing conductor *(for static vehicles*	N/A	Conductor Material		Conductor csa	mm²	Connection/ continuity verified	N/A
Chasis	N/A	Conductor Material		Conductor csa	mm²	Connection/ continuity verified	N/A
Water service	N/A	Conductor Material		Conductor csa	mm²	Connection/ continuity verified	N/A
Gas service	N/A	Conductor Material		Conductor csa	mm²	Connection/ continuity verified	N/A

TRANSPORTABLE UNIT DETAILS

Model name | Description

Maximum tolerable upstream earth fault loop impedance, Z_T Ω | Maximum tolerable fault current kA | Maximum demand (Load) per phase provision Amps

† ***All boxes must be completed.*** *'✔' indicates that an inspection was carried out and that the result was* ***satisfactory.*** *'N/A' indicates that an inspection was* ***not applicable*** *to the particular installation.*

‡ *Where a smoke alarm has been installed, separate certification is required on the appropriate form.*

NICEIC APPROVED CONTRACTOR

This certificate is not valid if the serial number has been defaced or altered **DCN8/0373138**

ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Original (To the person ordering the work)

SCHEDULE OF ITEMS INSPECTED † *See note below*

1.0	**CONDITION/ADEQUACY OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT (the Distributor should be notified of any unsatisfactory equipment)**	
1.1	Service cable	✔
1.2	Service head	✔
1.3	Distributor's earthing arrangement	✔
1.4	Meter tails - Distributor/Consumer	✔
1.5	Metering equipment	✔
1.6	Means of main isolation (where present)	
2.0	**PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY**	
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	
2.3	Presence of alternative/additional supply warning notice(s)	
3.0	**AUTOMATIC DISCONNECTION OF SUPPLY**	
3.1	Presence and adequacy of protective earthing/ bonding arrangements as follows:	
	a) Distributor's earthing arrangement or installation earth electrode arrangement	
	b) Earthing conductor and connections	✔
	c) Main protective bonding conductors and connections	✔
	d) Earthing/bonding labels at all appropriate locations	✔
3.2	Accessibility of:	
	a) Earthing conductor connections	✔
	b) All protective bonding connections	
4.0	**BASIC PROTECTION**	
4.1	Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:	
	a) Insulation of live parts e.g. conductors completely covered with durable insulating materials	✔
	b) Barriers or enclosures e.g. correct IP rating	✔
5.0	**ADDITIONAL PROTECTION**	
5.1	Presence and effectiveness of additional protection methods	
	a) RCD(s) not exceeding 30 mA operating current	✔
	b) Supplementary bonding	
	c) Segregation of safety circuits	
6.0	**OTHER METHODS OF PROTECTION**	
6.1	Basic and fault protection	
	a) SELV	
	b) PELV	
	c) Double insulation/Reinforced insulation	
	d) Electrical separation for one item of equipment	
6.2	Presence of danger notices	
7.0	**SWITCHGEAR/CONSUMER UNIT(S)**	
7.1	Adequacy of working space/accessibility	✔
7.2	Security of fixing	✔
7.3	Adequacy/security of barriers	✔
7.4	Insulation of live parts not damaged during erection	✔
7.5	Enclosures not damaged during installation	✔
7.6	Suitability of enclosures for IP and fire ratings	✔
7.7	Presence and operation of main switch(es), linked, where appropriate to verify disconnection	✔
7.8	Switchgear not damaged/deteriorated such as might impair safety	✔
7.9	Operation of circuit-breakers and RCDs to prove functionality	✔
7.10	Correct identification of circuit protective devices	✔
7.11	RCD(s) provided for fault protection, where specified	✔
7.12	RCD(s) provided for additional protection, where specified	✔
7.13	Confirmation overvoltage protection (SPDs) provided and functional where specified	
7.14	Presence of RCD quarterly test notice at or near the origin	✔
7.15	Presence of diagrams, charts or schedules at or near each Consumer unit(s)	✔
7.16	Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required	
7.17	Presence of next inspection recommendation label	✔
7.18	Presence of other required labelling	✔
7.19	Selection of protective device(s) and base(s); correct type and rating	✔
7.20	Single-pole protective devices in line conductor only	✔
7.21	Protection against mechanical damage where cables enter equipment	✔
7.22	Protection against electromagnetic effects where cables enter ferromagnetic enclosures	
7.23	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	
8.0	**CIRCUITS**	
8.1	Identification of conductors	✔
8.2	Cables adequately supported throughout their length	✔
8.3	Examination of cables for signs of mechanical damage during installation	✔
8.4	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✔
8.5	Adequacy of protective devices: type and rated current for fault protection	✔
8.6	Presence and adequacy of circuit protective conductors	✔
8.7	Coordination between conductors and overload protective devices	✔
8.8	Non-sheathed cables enclosed throughout (e.g. in conduit/trunking)	✔
8.9	Cables installed under floors, above ceilings, in walls/partitions, adequately protected against damage	
	a) Installed in prescribed zones	✔
	b) Incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like	✔
8.10	Provision of additional protection by RCDs having rated residual operating current ($I_{\Delta n}$) not exceeding 30 mA	
	a) For mobile equipment with a current rating not exceeding 32 A for use outdoors	✔
	b) For all socket-outlets of rating 20 A or less, unless exempt	✔
	c) For cables installed in walls/partitions at a depth of less than 50 mm	✔
	d) For cables installed in walls/partitions containing metal parts regardless of depth	✔

† ***All boxes must be completed.*** *'✔' indicates that an inspection was carried out and that the result was* ***satisfactory.*** *'N/A' indicates that an inspection was* ***not applicable*** *to the particular installation.*

‡ *Where a smoke alarm has been installed, separate certification is required on the appropriate form.*

NICEIC APPROVED CONTRACTOR

ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Original (To the person ordering the work)

SCHEDULE OF ITEMS INSPECTED continued

† *See note below*

8.11	Provision of fire barriers, sealing arrangements so as to minimise the spread of fire	✔
8.12	Band II cables segregated/separated from Band I cables	
8.13	Cables segregated/separated from non-electrical services	
8.14	Termination of cables at enclosures	
	a) Connections under no undue strain	
	b) No basic insulation of a conductor visible outside enclosure	
8.15	Circuit accessories not damaged during erection	
8.16	Single-pole devices for switching or protection in the line conductors only	
8.17	Adequacy of connections, including cpcs, within accessories and at fixed and stationary equipment	
8.18	Presence of appropriate devices for isolation and switching correctly located	
	a) Accessible means of switching off for mechanical maintenance	
	b) Correct operation verified (functional check)	
8.19	Cables incorporating earthed armour or sheath or run in an earthed wiring system, or otherwise protected against nails, screws and the like	

9.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)

9.1	Adequacy of working space/accessibility	N/A
9.2	Suitability of equipment in terms of IP and fire ratings	N/A
9.3	Enclosure not damaged/deteriorated during installation so as to impair safety	
9.4	Cable entry holes in ceilings above luminaires, sized or sealed so as to restrict the spread of fire	
9.5	Recessed luminaires (downlighters)	
	a) Correct type of lamps fitted	
	b) Installed to minimise build-up of heat	

10.0 LOCATION(S) CONTAINING A BATH OR SHOWER

10.1	Additional protection by RCD not exceeding 30 mA	
	a) For low voltage circuits serving the location	✔
	b) For low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✔
10.2	Where used as a protective measure, requirements for SELV or PELV are met	
10.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	
10.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	
10.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	
10.6	Suitability of equipment for external influences for installed location in terms of IP rating	
10.7	Suitability of electrical equipment for installation in a particular zone	

11.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

11.1 List all other special installations or locations present, if any. (Record separately where the result of particular inspections apply)

SCHEDULE OF ITEMS INSPECTED PARTICULAR TO A LEISURE ACCOMMODATION VEHICLE OR TRANSPORTABLE UNIT

1.	Cables adequately protected against the effects of vibration	
2.	Presence of protection against mechanical damage where cables enter equipment	
3.	Cables segregated/separated from non-electrical services such as LPG compartment **(see Regulation 721.528.3.4)**	
4.	Accessories/Equipment	
	-Security of fixing, and suitability for the environment and external influences (e.g. IP rating)	
	-Equipment does not constitute a fire hazard	

SCHEDULE OF ITEMS INSPECTED PARTICULAR TO HIGHWAY STREET FURNITURE

1.	The requirements of BS 7671 regarding access to live parts **(see Regulation 714.411.2.201)** have been met.	
2.	Enclosure(s) securely fixed and not damaged/deteriorated so as to impair safety	
3.	Presence of protection against mechanical damage where cables enter equipment	
4.	Provision of RCD of $I_{\Delta n} \leq 30$ mA for additional protection for lighting of bus shelters, telephone kiosks, town plans and the like	
5.	Connection of conductors adequately enclosed	
6.	Accessories/Equipment	
	-Security of fixing, and suitability for the environment and external influences (e.g. IP rating)	
	-Equipment does not constitute a fire hazard	

SCHEDULE OF ITEMS INSPECTED BY:

Signature | Name | Date

† ***All boxes must be completed.*** *'✔' indicates that an inspection was carried out and that the result was* ***satisfactory.*** *'N/A' indicates that an inspection was* ***not applicable*** *to the particular installation.*

‡ *Where a smoke alarm has been installed, separate certification is required on the appropriate form.*

NICEIC APPROVED CONTRACTOR

This certificate is not valid if the serial number has been defaced or altered **DCN8/0373138**

ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Original (To the person ordering the work)

CIRCUIT DETAILS / TEST RESULTS

Circuit number and phase	Circuit designation * To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box	Type of wiring (see code below)	Reference Method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa Live (mm²)	Circuit conductors: csa cpc (mm²)	Max. disconnection time permitted by BS 7671 (s)	Overcurrent protective devices BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	RCD Operating current, $I_{\Delta n}$ (mA)	Maximum Z_s permitted by BS 7671 (Ω)	Circuit impedances (Ω) Ring final circuits only (measured end to end) r_1 (Line)	r_n (Neutral)	r_2 (cpc)	All circuits (At least one column to be completed) $R_1 + R_2$	R_2	Insulation resistance Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)	Polarity (✔)	Maximum measured earth fault loop impedance, Z_s (Ω)	RCD operating times at $I_{\Delta n}$ (ms)	at $5I_{\Delta n}$ (if applicable) (ms)	Test button operation (✔)
1	Garage supply (DB2(	F	101	1	10	10	0.4	60898 MCB	B	32	10		1.37				0.10	N/A	N/A	> 200	> 200	> 200	✔	0.12			
2	S/O (cctv)	A	101	1	2.5	1.5	0.4	60898 MCB	B	16	10		2.73				0.14	N/A	N/A	> 200	> 200	> 200	✔	0.32			
3	Intruder Alarm (spur)	A	101	1	2.5	1.5	0.4	60898 MCB	B	16	10		2.73				0.15	N/A	N/A	> 200	> 200	> 200	✔	0.31			
4	Heating system	A	101	1	2.5	1.5	0.4	60898 MCB	B	16	10		2.73				0.15	N/A	N/A	> 200	> 200	> 200	✔	0.30			
5	Gate	F	101	1	4	4	0.4	61009 RCD/RCBO	B	16	10	30	2.73				Spare	N/A	N/A					Spare			✔
6	Spare	A	101	1	2.5	1.5	5.0	61009 RCD/RCBO	B	16	10	30	2.73					N/A	N/A								
7	Socket outlet (basement dado)	A	101	1	4	4	0.4	61009 RCD/RCBO	B	32	10	30	1.37				0.15	N/A	N/A	> 200	> 200	> 200	✔	0.33	29	29	✔
8	Ring Final (gnd)	A	101	1	2.5	1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.37	0.28	0.29	0.48	0.28	N/A	N/A	> 200	> 200	> 200	✔	0.46	29	29	✔
9	Ring Final (2nd)	A	101	1	2.5	1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.37	0.34	0.36	0.51	0.35	N/A	N/A	> 200	> 200	> 200	✔	0.52	29	29	✔
10	Ring Final (1st)	A	101	1	2.5	1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.37	0.30	0.31	0.52	0.33	N/A	N/A	> 200	> 200	> 200	✔	0.49	29	29	✔
11	Ring Final (Kitchen)	A	101	1	2.5	1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.37	0.25	0.24	0.47	0.26	N/A	N/A	> 200	> 200	> 200	✔	0.44	29	29	✔
12	Ring Final (Under floor heating)	A	101	4	2.5	1.5	0.4	61009 RCD/RCBO	B	32	10	30	1.37	0.37	0.34	0.52	0.35	N/A	N/A	> 200	> 200	> 200	✔	0.51	29	29	✔
13	Spare																	N/A	N/A				✔				
14	Spare																	N/A	N/A				✔				
15	Spare																	N/A	N/A				✔				
16	Spare	A	101	1	1.5	1	0.4	61009 RCD/RCBO	B	32	10	30	1.37					N/A	N/A				✔				
17	Smoke & Heat detectors	A	101	1	1.5	1	0.4	61009 RCD/RCBO	B	32	10	30	1.37				0.51	N/A	N/A	> 200	> 200	> 200	✔	0.69	29	29	✔
18	Lights (1st Master bedroom & upper mez)	A	101	1	1.5	1	0.4	61009 RCD/RCBO	B	32	10	30	1.37				0.72	N/A	N/A	> 200	> 200	> 200	✔	0.90	29	29	✔
19	Lights (1st on-suite, store & mez)	A	101	1	1.5	1	0.4	61009 RCD/RCBO	B	32	10	30	1.37				0.53	N/A	N/A	> 200	> 200	> 200	✔	0.71	29	29	✔
20	Lights (2nd Floor)	A	101	1	1.5	1	0.4	61009 RCD/RCBO	B	32	10	30	1.37				0.60	N/A	N/A	> 200	> 200	> 200	✔	0.78	29	29	✔
21	Lights (Ground)	A	101	1	1.5	1	0.4	61009 RCD/RCBO	B	32	10	30	1.37				0.49	N/A	N/A	> 200	> 200	> 200	✔	0.68	29	29	✔
22	Lights (Kitchen)	A	101	1	1.5	1	0.4	61009 RCD/RCBO	B	32	10	30	1.37				0.48	N/A	N/A	> 200	> 200	> 200	✔	0.65	29	29	✔
23	Cooker	A	101	1	1.5	1	0.4	61009 RCD/RCBO	B	32	10	30	1.37				0.12	N/A	N/A	> 200	> 200	> 200	✔	0.26	29	29	✔

CODES FOR TYPE OF WIRING

A	B	C	D	E	F	G	H	O (Other - please state)
Thermoplastic (PVC) insulated cables (non-sheathed)	Thermoplastic (PVC) insulated & sheathed cable/steel wire armoured	Thermoplastic (PVC) cables in non-metallic conduit	Thermoplastic (PVC) cables in non-metallic trunking	Thermoplastic (PVC) cables in metallic conduit	Thermoplastic (PVC) cables in metallic trunking	Thermosetting (XLPE) SWA cables	Mineral-insulated cables	

Location of consumer unit(s): Basement

Designation of consumer unit(s): DB1

Prospective fault current at consumer unit(s): kA

TEST INSTRUMENTS

Test instrument (serial numbers) used

Multi-function: 16103359

Insulation resistance:

Continuity:

Earth electrode resistance:

Earth fault loop impedance:

RCD:

NICEIC APPROVED CONTRACTOR

This certificate is not valid if the serial number has been defaced or altered **DCN8/0373138**

ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Original (To the person ordering the work)

CIRCUIT DETAILS

TEST RESULTS

Circuit number and phase	Circuit designation * To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box	Type of wiring (see code below)	Reference Method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa Live (mm²)	Circuit conductors: csa cpc (mm²)	Max. disconnection time permitted by BS 7671 (s)	Overcurrent protective devices BS (EN)	Overcurrent protective devices Type	Overcurrent protective devices Rating (A)	Overcurrent protective devices Short-circuit capacity (kA)	RCD Operating current, $I_{\Delta n}$ (mA)	Maximum Z_s permitted by BS 7671 (Ω)	Circuit impedances (Ω) Ring final circuits only (measured end to end) r_1 (Line)	r_n (Neutral)	r_2 (cpc)	All circuits (At least one column to be completed) $R_1 + R_2$	R_2	Insulation resistance Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)	Polarity (✔)	Maximum measured earth fault loop impedance, Z_s (Ω)	RCD operating times at $I_{\Delta n}$ (ms)	at $5I_{\Delta n}$ (if applicable) (ms)	Test button operation (✔)
24	Hob	A	101	1	1.5	1	0.4	61009 RCD/RCBO	B	32	10	30	1.37				0.12	N/A	N/A	> 200	> 200	> 200	✔	0.25	29	29	✔

Location of consumer unit(s): Basement

Designation of consumer unit(s): DB1

Prospective fault current at consumer unit(s): kA

CODES FOR TYPE OF WIRING

A	B	C	D	E	F	G	H	O (Other - please state)
Thermoplastic (PVC) insulated cables (non-sheathed)	Thermoplastic (PVC) insulated and sheathed cables	Thermoplastic (PVC) cables in metallic conduit	Thermoplastic (PVC) cables in non-metallic conduit	Thermoplastic (PVC) cables in metallic trunking	Thermoplastic (PVC) SWA cables	Thermosetting (LSF) SWA cables	Mineral-insulated cables	

TEST INSTRUMENTS

Test instrument (serial numbers) used

Multi-function: 16103359

Insulation resistance:

Continuity:

Earth electrode resistance:

Earth fault loop impedance:

RCD:

NICEIC APPROVED CONTRACTOR

This certificate is not valid if the serial number has been defaced or altered **DCN8/0373138**

ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Original (To the person ordering the work)

CIRCUIT DETAILS / TEST RESULTS

Circuit number and phase	Circuit designation * To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box	Type of wiring (see code below)	Reference Method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa Live (mm²)	Circuit conductors: csa cpc (mm²)	Max. disconnection time permitted by BS 7671 (s)	Overcurrent protective devices BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	RCD Operating current, $I_{\Delta n}$ (mA)	Maximum Z_s permitted by BS 7671 (Ω)	Circuit impedances (Ω) Ring final circuits only (measured end to end) r_1 (Line)	r_n (Neutral)	r_2 (cpc)	All circuits (At least one column to be completed) $R_1 + R_2$	R_2	Insulation resistance Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)	Polarity (✔)	Maximum measured earth fault loop impedance, Z_s (Ω)	RCD operating times at $I_{\Delta n}$ (ms)	at $5I_{\Delta n}$ (if applicable) (ms)	Test button operation (✔)
1	Ring Final (garage/up)	A	A	6	2.5	1.5	0.4	60898 MCB	B	32	6	30	1.37	0.24	0.24	0.39	0.24			> 200	> 200	> 200	✔	0.36	29	19	✔
2	Spare							60898 MCB	B	20	6		2.19												29	19	
3	Lights (hall/wc)	A	A	5	1.5	1	0.4	60898 MCB	B	6	6	30	7.28				0.55			> 200	> 200	> 200	✔	0.67	29	19	✔
4	Lights (external)	A	A	4	1.5	1	0.4	60898 MCB	B	6	6	30	7.28				0.49			> 200	> 200	> 200	✔	0.61	29	19	✔
5	SD	A	A	2	1.5	1	0.4	60898 MCB	B	6	6	30	7.28				0.32			> 200	> 200	> 200	✔	0.44	29	19	✔
6	Ring final (utility area)	A	A	4	2.5	1.5	0.4	60898 MCB	B	32	6	30	1.37	0.25	0.24	0.40	0.25			> 200	> 200	> 200	✔	0.29	29	19	✔
7	Roller shutter spur	A	A	1	2.5	1.5	0.4	60898 MCB	B	20	6	30	2.19				0.22			> 200	> 200	> 200	✔	0.35	29	19	✔
8	Lights (Garage/up)	A	A	11	1.5	1	0.4	60898 MCB	B	6	6	30	7.28				0.47			> 200	> 200	> 200	✔	0.60	29	19	✔
9	Lights (external rear)	A	A	3	1.5	1	0.4	60898 MCB	B	20	6	30	2.19				0.38			> 200	> 200	> 200	✔	0.51	29	19	✔
10	Spare							60898 MCB	B	32	6		1.37												29	19	

CODES FOR TYPE OF WIRING: A Thermoplastic (PVC) insulated/sheathed cable; B Thermoplastic (PVC) insulated cables in metallic conduit; C Thermoplastic (PVC) cables in non-metallic conduit; D Thermoplastic (PVC) cables in non-metallic trunking; E Thermoplastic (PVC) cables in metallic trunking; F Thermoplastic (PVC) SWA cables; G Thermosetting (LSF) SWA cables; H Mineral-insulated cables; O (Other - please state)

Location of consumer unit(s): Garage

Designation of consumer unit(s): DB2

Prospective fault current at consumer unit(s): kA

TEST INSTRUMENTS

Test instrument (serial numbers) used

Multi-function: 16103359

Insulation resistance:

Continuity:

Earth electrode resistance:

Earth fault loop impedance:

RCD: